EAST HELENAWATER MASTER PLAN





Prepared for: City of East Helena, MT - April 2018

Prepared by: **Robert Peccia & Associates**Helena, Montana

www.rpa-hln.com



City of East Helena Water Master Plan

Prepared For: City of East Helena, Montana

April 2018





Prepared by: Robert Peccia & Associates Helena, Montana

TABLE OF CONTENTS

CHAPTER 0	: EXECUTIVE SUMMARY	
0.A. IN	TRODUCTION AND BACKGROUND	0-1
0.B. PF	ROBLEM DEFINITION	0-1
0.C. Al	TERNATIVES CONSIDERED	0-3
0.C.1.	WATER SUPPLY ALTERNATIVES	0-3
0.C.2.	WATER STORAGE ALTERNATIVES	0-3
0.C.3.	DISTRIBUTION ALTERNATIVES	0-3
0.C.4.	MCCLELLAN SOURCE ACCESS	0-4
0.C.5.	TELEMETRY SYSTEM	0-4
O.D. PF	REFERRED ALTERNATIVES	0-4
0.D.1.	WATER SUPPLY ALTERNATIVES TO ADDRESS WYLIE WELL #3 POTENTIAL CONTAMINATION	0-4
0.D.2.		
0.D.3.	WATER STORAGE	0-5
0.D.4.	DISTRIBUTION SYSTEM	0-5
0.D.5.	MCCLELLAN SOURCE ACCESS	0-6
0.D.6.	TELEMETRY SYSTEM	0-6
O.E. PF	ROJECT COSTS AND BUDGET	0-7
CHAPTER 1	: PROJECT PLANNING	
1.A. LC	DCATION	1-1
1.B. EN	NVIRONMENTAL RESOURCES PRESENT	1-1
1.B.1.	LAND RESOURCES	1-1
1.B.2.	SOIL TYPES	1-1
1.B.3.	WATER RESOURCES	1-1
1.B.4.	FLOODPLAINS	1-7
1.B.5.	WETLANDS	1-8
1.B.6.	BIOLOGICAL RESOURCES	1-8
1.B.7.	ENDANGERED SPECIES AND CRITICAL HABITATS	1-8
1.B.8.	HAZARDOUS FACILITIES	1-10
1.B.9.	CULTURAL AND HISTORIC RESOURCES	1-10
1.B.10	. SOCIO-ECONOMIC ENVIRONMENTAL JUSTICE	1-11

	1.C.	POP	ULATION TRENDS	1-11
	1.D.	COM	1MUNITY ENGAGEMENT	1-12
СН	APTE	R 2: I	EXISTING FACILITIES	
	2.A.	LOC	ATION MAP	2-1
	2.B.	HIST	ORY	2-1
	2.C.	CON	DITION OF EXISTING FACILITIES	2-3
	2.C	.1.	WATER SUPPLY	2-3
	2.C	.2.	WATER RIGHTS	2-13
	2.C	.3.	WATER DEMAND	2-15
	2.C	.4.	WATER LOSS	2-19
	2.C	.5.	FIRE PROTECTION	2-20
	2.C	.6.	WATER STORAGE	2-20
	2.C	.7.	WATER TRANSMISSION AND DISTRIBUTION	2-28
	2.C	.8.	WATER MODEL	2-30
	2.C	.9.	WATER METERS	2-36
	2.C	.10.	TELEMETRY SYSTEM	2-37
	2.D.	FINA	NCIAL STATUS OF THE EXISTING FACILITY	2-37
	2.E.	WAT	FER / ENERGY / WASTE AUDITS	2-38
СН	APTE	R 3: 1	NEED FOR PROJECT	
	3.A.	HEA	LTH, SANITATION AND SECURITY	3-1
	3.B.	AGIN	NG INFRASTRUCTURE	3-2
	3.C.	REAS	SONABLE GROWTH	3-2
СН	APTE	R 4: A	ALTERNATIVES CONSIDERED	
	4.A.	WAT	FER SUPPLY ALTERNATIVE 1 – NO-ACTION	4-1
	4.A	.1.	DESCRIPTION	4-1
	4.B.		FER SUPPLY ALTERNATIVE 2 – NEW PRODUCTION WELL AT NORTHEAST	
			NER OF CITY OWNED PROPERTY	
	4.B		DESCRIPTION	
	4.B		DESIGN CRITERIA	
	4.B		MAP	
	4.B		ENVIRONMENTAL IMPACTS	
	4.B		LAND REQUIREMENTS	
	4.B	.6.	WATER RIGHTS	4-4

	4.B.7. POTENTIAL CONSTRUCTION PROBLEMS		4-4
	4.B.8. SUSTAINABILITY CONSIDERATIONS		4-5
	4.B.9.	COST	4-5
4.0		TER SUPPLY ALTERNATIVE 3 – NEW PRODUCTION WELL AT NORTHWEST RNER OF CITY OWNED PROPERTY	4-6
	4.C.1.	DESCRIPTION	4-6
	4.C.2.	DESIGN CRITERIA	4-6
	4.C.3.	MAP	4-6
	4.C.4.	ENVIRONMENTAL IMPACTS	4-8
	4.C.5.	LAND REQUIREMENTS	4-8
	4.C.6.	WATER RIGHTS	4-8
	4.C.7.	POTENTIAL CONSTRUCTION PROBLEMS	4-8
	4.C.8.	SUSTAINABILITY CONSIDERATIONS	4-8
	4.C.9.	COST	4-9
4.		TER SUPPLY ALTERNATIVE 4 – CAISSON PROTECTION AND LEVEL ONITORING IMPROVEMENTS	4-9
	4.D.1.	DESCRIPTION	4-9
	4.D.2.	DESIGN CRITERIA	4-10
	4.D.3.	MAP	4-10
	4.D.4.	ENVIRONMENTAL IMPACTS	4-10
	4.D.5.	LAND REQUIREMENTS	4-10
	4.D.6.	WATER RIGHTS	4-10
	4.D.7.	POTENTIAL CONSTRUCTION PROBLEMS	4-10
	4.D.8.	SUSTAINABILITY CONSIDERATIONS	4-11
	4.D.9.	COST	4-11
4.		TER SUPPLY ALTERNATIVE 5 – CAISSON ACCESS HATCH IMPROVEMENTS D PUMPING MANAGEMENT	4-12
	4.E.1.	DESCRIPTION	4-12
	4.E.2.	DESIGN CRITERIA	4-12
	4.E.3.	MAP	4-12
	4.E.4.	ENVIRONMENTAL IMPACTS	4-13
	4.E.5.	LAND REQUIREMENTS	4-13
	4 F 6	POTENTIAL CONSTRUCTION PROBLEMS	4-13

4.	E.7.	SUSTAINABILITY CONSIDERATIONS	4-13
4.	E.8.	COST	4-14
4.F.	WA	TER STORAGE ALTERNATIVE 1 – NO-ACTION	4-14
4.	F.1.	DESCRIPTION	4-14
4.G.		TER STORAGE ALTERNATIVE 2 – REPLACE MCCLELLAN STORAGE TANKS TH ONE 1,000,000-GALLON PRE-STRESSED CONCRETE STORAGE TANK	4-14
4.	G.1.	DESCRIPTION	4-14
4.	G.2.	DESIGN CRITERIA	4-15
4.	G.3.	MAP	4-15
4.	G.4.	ENVIRONMENTAL IMPACTS	4-15
4.	G.5.	LAND REQUIREMENTS	4-17
4.	G.6.	POTENTIAL CONSTRUCTION PROBLEMS	4-17
4.	G.7.	SUSTAINABILITY CONSIDERATIONS	4-17
4.	G.8.	COST	4-18
4.H.		TER STORAGE ALTERNATIVE 3 – REPLACE MCCLELLAN STORAGE TANKS TH ONE 1,000,000-GALLON GLASS-FUSED-TO-STEEL BOLTED TANK	4-18
4.	H.1.	DESCRIPTION	4-18
4.	H.2.	DESIGN CRITERIA	4-18
4.	H.3.	MAP	4-19
4.	H.4.	ENVIRONMENTAL IMPACTS	4-19
4.	H.5.	LAND REQUIREMENTS	4-21
4.	H.6.	POTENTIAL CONSTRUCTION PROBLEMS	4-21
4.	H.7.	SUSTAINABILITY CONSIDERATIONS	4-21
4.	H.8.	COST	4-21
4.I.	WA	TER DISTRIBUTION ALTERNATIVE 1 – NO-ACTION	4-22
4.	l.1.	DESCRIPTION	4-22
4.J.	WA	TER DISTRIBUTION ALTERNATIVE 2 – MAIN STREET STREAM CROSSING	4-22
4	J.1.	DESCRIPTION	4-22
4	J.2.	DESIGN CRITERIA	4-23
4	J.3.	MAP	4-23
4	J.4.	ENVIRONMENTAL IMPACTS	4-23
4	J.5.	LAND REQUIREMENTS	4-23
1	16	DOTENTIAL CONSTRUCTION DROPLEMS	1 22

4.J.	.7.	SUSTAINABILITY CONSIDERATIONS	4-25
4.J.	.8.	COST	4-25
4.K.	WA	TER DISTRIBUTION ALTERNATIVE 3 – LOOP DISTRIBUTION SYSTEM AT	
	MA	NLOVE	4-26
4.K	. 1.	DESCRIPTION	
4.K	2.	DESIGN CRITERIA	4-26
4.K	ί.3.	MAP	4-26
4.K	.4.	ENVIRONMENTAL IMPACTS	4-26
4.K	ζ.5.	LAND REQUIREMENTS	4-26
4.K	.6.	POTENTIAL CONSTRUCTION PROBLEMS	4-26
4.K	ί.7.	SUSTAINABILITY CONSIDERATIONS	4-28
4.K	.8.	COST	4-28
4.L.		TER DISTRIBUTION ALTERNATIVE 4 – ELIMINATE DEAD-END AT IST STREET A	
4.L		DESCRIPTION	
4.L		DESIGN CRITERIA	
4.L		MAP	
4.L	_	ENVIRONMENTAL IMPACTS	
4.L	5.	4.A.1. LAND REQUIREMENTS	
4.L	.6.	POTENTIAL CONSTRUCTION PROBLEMS	
4.L	.7.	SUSTAINABILITY CONSIDERATIONS	
4.L	.8.	COST	4-31
4.M.	MC	CLELLAN SOURCE ACCESS	4-31
4.N	И.1.	MCCLELLAN SOURCE ACCESS ALTERNATIVE 1 – NO-ACTION	4-31
		MCCLELLAN SOURCE ACCESS ALTERNATIVE 2 – NEW PEDESTRIAN BRIDGE .	
		EMETRY SYSTEM	
		TELEMETRY SYSTEM ALTERNATIVE 1 – NO-ACTION	
4.N		TELEMETRY SYSTEM ALTERNATIVE 2 – UPGRADE SCADA SYSTEM	
		SELECTION OF AN ALTERNATIVE	
		E CYCLE COST ANALYSIS	5-1
	۱.1.	TOTAL CAPITAL COST	
_		INFLATION	
		DDECENT WORTH ANALYSIS	5 <u>2</u>

5.B	. NC	N-MONETARY FACTORS	5-3
5	5.B.1.	SUMMARY AND SELECTION OF THE PREFERRED ALTERNATIVE	5-3
5	5.B.2.	STORAGE TANKS	5-5
5	5.B.3.	DISTRIBUTION SYSTEM	5-7
5	5.B.4.	MCCLELLAN SOURCE ACCESS	5-7
5	5.B.5.	TELEMETRY SYSTEM	5-7
CHAP	TER 6:	PROPOSED RECOMMENDATIONS	
6.A	A. PR	ELIMINARY PROJECT DESIGN	6-1
ϵ	5.A.1.	WATER SUPPLY	6-1
ϵ	5.A.2.	WATER STORAGE	6-2
ϵ	5.A.3.	DISTRIBUTION SYSTEM	6-2
ϵ	5.A.4.	MCCLELLAN SOURCE ACCESS	6-3
ϵ	5.A.5.	TELEMETRY SYSTEM	6-3
6.B	B. PR	OJECT SCHEDULE	6-4
6.0	. PEI	RMIT REQUIREMENTS	6-4
6.0	. SU	STAINABILITY CONSIDERATIONS	6-5
6	5.D.1.	WATER AND ENERGY EFFICIENCY	6-5
ϵ	5.D.2.	GREEN INFRASTRUCTURE	6-5
6	5.D.3.	OTHER	6-5
6.E	. то	TAL PROJECT COST ESTIMATE	6-5
6.F	. AN	NUAL OPERATING BUDGET	6-6
ϵ	5.F.1.	INCOME	6-6
ϵ	5.F.2.	ANNUAL O&M COSTS	6-6
ϵ	5.F.3.	DEBT REPAYMENT	6-6
6	5.F.4.	RESERVES	6-6
CHAP	TER 7:	CONCLUSIONS AND RECOMMENDATIONS	
7.A	A. PR	EFERRED ALTERNATIVE	7-1
7.B	B. FU	NDING OPTIONS AND RECOMMENDATIONS	7-1
7	7.B.1.	FUNDING OBJECTIVES	7-1
7	7.B.2.	PROSPECTIVE FUNDING PROGRAMS	7-1
7	7.B.3.	FUNDING RECOMMENDATIONS	
		RLIC PARTICIPATION	7-7

7.C.4.	FUNDING STRATEGY	7-7
7.C.5.	SECOND PUBLIC MEETING ON DRAFT MASTER PLAN, FUNDING	
	APPLICATIONS, AND ENVIRONMENTAL ASSESSMENT	7-9
7.C.6.	MASTER PLAN ADOPTION, APPLICATION AUTHORIZATION, AND	
	E.A. ADEQUACY	7-9
TABLES		
Table 0.E.1:	Cost Summary for Water System Improvements	0-7
Table 1.B.1:	Summary of Water Quality Data	1-7
Table 1.C.1:	Population Trends for Lewis and Clark County and the City of East Helena	1-12
Table 1.C.2:	Population Projections for Lewis and Clark County and the City of	
	East Helena	1-12
	City of East Helena Water Rights Summary	
Table 2.C.2:	2017 Billed Water Usage	2-17
Table 2.C.3:	2017 Water Production	2-17
Table 2.C.4:	City of East Helena Current and Future Water Demands	2-18
Table 2.C.5:	City of East Helena Source Capacity	2-18
Table 2.C.6:	City of East Helena Water Demand vs. Available Water Rights	2-19
Table 2.C.7:	Estimated Unmetered Water Usage for 2017	2-20
	City of East Helena Storage Tanks	
Table 2.C.9:	Current and Future Storage Requirements for the City of East Helena	2-28
	: Distribution Main Summary	
Table 2.C.11:	: Computer Model Calibration Results for the East Helena Water System	2-31
Table 2.C.12:	: Modeled Available Fire Flows	2-34
Table 2.C.13:	: City of East Helena's Water Rate Structure	2-37
	: City of East Helena's Hookups Per Category	
Table 4.B.1:	Summary of Proposed Design Criteria for Alternative 2	4-2
Table 4.B.2:	Cost Summary for Water Supply Alternative 2 – New Production	
	Well at the Northeast Corner of the City Owned Property	
Table 4.C.1:	Summary of Proposed Design Criteria for Alternative 3	4-6
	Cost Summary for Water Supply Alternative 3 – New Production Well at the	
	Northwest Corner of the City Owned Property	
	Cost Summary for the Radial Well Source Improvements	
	Cost Summary for the Radial Well Source Improvements	
	Design Values for 1,000,000-gallon Pre-Stressed Storage Tank	4-15
	Cost Estimate for Water Storage Alternative 2 – Replace McClellan	
	Storage Tanks with One 1,000,000-Gallon Pre-Stressed Concrete	
	Storage Tank	4-18

Table 4.H.1: Design Values for 1,000,000-gallon Glass-Fused-to-Steel Bolted Tank	. 4-19
Table 4.H.2: Cost Estimate for Water Storage Alternative 3 – Replace McClellan	
Storage Tanks with One 1,000,000-Gallon Glass-Fused-to-Steel Bolted Tank	. 4-22
Table 4.J.1: Cost Summary for Main Street Stream Crossing	
Table 4.K.1: Cost Summary for Water Distribution Alternative 3 – Loop Distribution	
Manlove	. 4-28
Table 4.L.1: Cost Summary for Water Distribution Alternative 4 – Eliminate Dead-End at	
1 st Street and West Groschell	. 4-31
Table 4.M.1: Cost Summary for Infiltration Gallery Access Alternative 2 – New Pedestrian	
Bridge	. 4-34
Table 4.N.1: Cost Summary for Telemetry System Alternative 2 – Update SCADA	
System	. 4-37
Table 5.A.1: Alternative Life Cycle Cost Analysis	
Table 5.B.1: Comparison of Water Supply Alternatives to Address Wylie Well #3	
Potential Contamination	5-4
Table 5.B.2: Comparison of Water Supply Alternatives for McClellan Source	
Table 5.B.3: Comparison of 1,000,000-Gallon Storage Tank Alternatives	
Table 6.B.1: Implementation Schedule for the Recommended Alternatives	
Table 6.E.1: Cost Summary for Water System Improvements	
Table 7.B.1: Funding Scenarios if All Recommended Improvements are Constructed	
in One Phase	7-8
FIGURES	
Figure 1.A.1: Planning Area Map	1-2
Figure 1.B.1: Land Use Map	
Figure 1.B.2: Topographic Map	1-4
Figure 1.B.3: Wetlands	
Figure 2.C.1: Location of the McClellan Source and Land Ownership	2-6
Figure 2.C.2: Contamination Plumes (Hydrometrics Inc., 2014)	. 2-11
Figure 2.C.3: East Valley Controlled Groundwater Area (Hydrometrics, 2014)	. 2-16
Figure 2.C.4: City of East Helena's Fire Hydrant Locations	. 2-21
Figure 2.C.5: Existing McClellan Tanks and Valve Schematic	
Figure 2.C.6: City of East Helena's Existing Distribution System	
Figure 4.B.1: Water Supply Alternative 2 - New Production Well at Northeast Corner	. 2-25
of City Owned Property	. 2-25
	2-25 2-29
Figure 4.C.1: Water Supply Alternative 3 – New Production Well at the Northwest	2-25 2-29
Figure 4.C.1: Water Supply Alternative 3 – New Production Well at the Northwest Corner of City Owned Property	2-25 2-29 4-3
	2-25 2-29 4-3
Corner of City Owned Property	2-25 2-29 4-3 4-7

Figure 4.H.1:	Water Storage Alternative 3 - Replace McClellan Storage	
	Tanks with One 1,000,000-Gallon Glass-Fused-to-Steel Bolted Tank	4-20
Figure 4.J.1:	Water Distribution Alternative 2: Main Street Stream Crossing	4-24
Figure 4.K.1:	Water Distribution Alternative 3: Loop Distribution System at Manlove	4-27
Figure 4.L.1:	Water Distribution Alternative 4: Eliminate Dead-End at 1st Street	
	and West Groschell St	4-30
Figure 4.M.1:	Infiltration Gallery Access Alternative 2: New Pedestrian Bridge	4-33
Figure 4.N.1:	Telemetry System Alternative 2: Upgrade SCADA System	4-36

APPENDICES

APPENDIX A: ENVIRONMENTAL

APPENDIX B: WELL LOGS

APPENDIX C: PRECIPITATION RECORDS

APPENDIX D: SOURCE WATER PROTECTION PLAN

APPENDIX E: 2016 SANITARY SURVEY INSPECTION OF THE CITY OF EAST HELENA (MT0000196)

APPENDIX F: GROUNDWATER CLASSIFICATION CONFIRMATION LETTER FROM DEQ.

APPENDIX G: WATER RIGHTS

APPENDIX H: BILLED MONTHLY USAGE AND WELL PRODUCTION TOTALS FOR 2017

APPENDIX I: CALCULATIONS

APPENDIX J: ISO REPORT FOR EAST HELENA

APPENDIX K: TANK INSPECTIONS

APPENDIX L: CITY OF EAST HELENA'S WATER RATE ORDINANCE

APPENDIX M: COST ESTIMATES

APPENDIX N: PUBLIC PARTICIPATION

APPENDIX O: RESOLUTIONS

CHAPTER 0: EXECUTIVE SUMMARY

0.A. INTRODUCTION AND BACKGROUND

The City of East Helena authorized the preparation of this Master Plan to evaluate the City's existing public water system. The specific objectives of the Master Plan include the following:

- Identify the planning area and physical limits of the existing water systems;
- Determine the Planning Population the Water System needs to support;
- Evaluate the condition of the existing facilities;
- Update a computer model of the water system to be used for evaluation and future planning purposes;
- Identify any deficiencies with supply, storage, and distribution facilities;
- Summarize any health and safety issues associated with system deficiencies;
- Identify and evaluate alternatives for correcting all identified deficiencies;
- Provide cost estimates for all alternatives;
- Identify a set of recommended improvements for implementation through the planning period; and
- Assess the impact on water rates associated with implementation of the recommended improvements.

The City of East Helena's public water system consists of the following:

- Two Water Sources. The McClellan source consists of (2) radial wells near Prickly Pear Creek. The Wylie source consists of (3) vertical wells located north of the City along Wylie Drive. Both sources are chlorinated;
- Three concrete water storage reservoirs (one 250,000-gallon tank, one 350,000-gallon tank and located side by side above the McClellan radial wells, and one 1-million-gallon tank located along Highway 282);
- Two Transmission Mains. The McClellan transmission main delivers water to the City from the McClellan source. The Wylie Drive transmission main delivers water to the City's distribution system and to the Highway 282 Reservoir; and
- Distribution system consisting ranging from 4-inch to 8-inch mains that distribute water to the City customers.

0.B. PROBLEM DEFINITION

Groundwater evaluations in the area have indicated that dissolved arsenic and selenium plumes originating from the ASARCO Smelter have migrated generally northward creating a potential vulnerability for Wylie Well #3. As shown in **Figure 2.C.1** from Hydrometrics, Inc., the selenium plume originating from the ASARCO Smelter is approximately 1,250 feet from the well. The Wylie Well #3 creates a cone of depression when pumping at its rate of 450 gpm in

the unconfined aquifer that could induce groundwater flow from a significant radial distance. Operations at Helena Sand and Gravel's gravel pit near Wylie Well #3 could also create an even greater cone of depression, inducing groundwater flow through the selenium plume, which would contaminate the well. If Wylie Well #3 becomes contaminated the City's water supply well would be unusable without expensive treatment. At the time of this writing, Alternatives to remedy this need (replacement of Wylie Well #3) are being discussed with the Montana Environmental Trust Group.

The McClellan source radial wells have experienced high caisson water levels this Spring (2018). During this event, water from the caissons flowed up through the subfloor hatch and onto the subfloor located 5 feet below the top of the caisson. This water can then flow back through the hatch into the caisson and then be pumped into the City's water system. Water operators and City staff are new in the last several years and are uncertain of past events. Water staining suggests that this has happened in the past, but these events have gone undocumented. Water above the subfloor exposes the City's drinking water source to unsanitary conditions and is a health risk to water customers. The subfloor in the caissons is dry during most times of the year and not sealed to a level to prevent entry from mice, insects, or other small creatures. Additionally, during the summer of 2017, East Helena personnel noted that the north radial well (Radial Well #1) was not able to fill the McClellan tank on its own due to a lack of water (low caisson level). While this event was short lived (approximately 45 days), this is concerning. Historically, each of the two radial wells have been able to fill the tank separately as designed with no previous water shortages noted.

These issues are exacerbated by the poor access to the radial wells. The access consists of a 2-track dirt road that is impassable much of the winter and during run-off events. City personnel must drive or walk through McClellan Creek to access Radial Well #2. These wells are located in a remote area and are not inspected on a regular basis. Improved access for both inspection and maintenance is desirable. Road improvements are needed to safely access the two radial wells.

The existing McClellan storage tanks are severely leaking and deteriorating due to age as describe in **Chapter 2**. These tanks are leaking approximately 44,000 gallons of water a day (16 million gallons annually) which is substantial water loss.

The City's distribution system is split by Prickly Pear Creek that runs northward dividing the City. There are only three places where water mains cross this stream. In 2013, one of the primary crossings was lost on Main Street due to its exposure in the stream. This main was a critical piece of infrastructure in that it provided a crossing to convey water from one side of town to the other. These crossings allow water from the Wylie source to get to the east part of the City and water from the McClellan source to cross to the west. This crossing needs to be reestablished.

Dead-end water mains can lead to low pressure, inadequate fire flow, and stagnant water that allows inorganic sediments to deposit and organic matter to accumulate and organisms to

grow. These organisms can deplete the available oxygen which causing anaerobic conditions and accelerating corrosion. Anaerobic conditions can also cause poor taste and potentially serious odor problems. Dead-end water mains exist on both 1st Street and on Manlove that should be "looped" improve fire flows and to eliminate dead-ends.

The existing telemetry equipment for the City's water system is, at times, not communicating from the radial wells properly to the system at wastewater treatment facility which could be due to a weak signal or problems with the outdated system.

0.C. ALTERNATIVES CONSIDERED

0.C.1. WATER SUPPLY ALTERNATIVES

The water supply alternatives considered in this Master Plan include:

- Alternative 1 No-Action.
- Alternative 2 New Production Well at the Northeast Corner of the City Owned Property to Replace Wylie Well #3.
- Alternative 3 New Production Well at the Northwest Corner of the City Owned Property to Replace Wylie Well #3.
- Alternative 4 Radial Well Source Protection and Level Monitoring Improvements.
- Alternative 5 Caisson Access Hatch Improvements and Pumping Management.

0.C.2. WATER STORAGE ALTERNATIVES

The water storage alternatives considered in this Master Plan include:

- Alternative 1 No-Action.
- Alternative 2 Replace McClellan Storage Tanks with one 1,000,000-Gallon Pre-Stressed Storage Tank.
- Alternative 3 Replace McClellan Storage Tanks with one 1,000,000-Gallon Glass-Fused-To-Steel Bolted Tank.

0.C.3. DISTRIBUTION ALTERNATIVES

The water storage alternatives considered in this Master Plan include:

- Alternative 1 No-Action.
- Alternative 2 Main Street Stream Crossing.
- Alternative 3 Loop Distribution System at Manlove.
- Alternative 4 Eliminate Dead-End at 1st Street and West Groschell.

0.C.4. MCCLELLAN SOURCE ACCESS

- Alternative 1 No-Action.
- Alternative 2 New Pedestrian Bridge.

0.C.5. TELEMETRY SYSTEM

- Alternative 1 No-Action.
- Alternative 2 Upgrade SCADA System.

0.D. PREFERRED ALTERNATIVES

0.D.1. WATER SUPPLY ALTERNATIVES TO ADDRESS WYLIE WELL #3 POTENTIAL CONTAMINATION

The preferred water supply alternative is Alternative 2 – New Production Well at the Northeast Corner of City Owned Property. The City of East Helena is seeking funding from the Montana Environmental Trust Group (METG) for implementation of this alternative. This item is not included in the Funding Strategy and is not included in the total project cost of \$5,562,933 included in Chapter 7. As this item constitutes a major need of the City, it is included in this Chapter.

As part of this alternative Wylie Well #3 would be abandoned and the chlorination system for the Wylie Source would be relocated to Wylie Well #2. A new well would be drilled in the northeast corner of the City's property targeting 450 gpm in the Helena Valley Aquifer to replace Wylie Well #3. A new chlorination system would be installed for this new well. The recommended new well water source alternative includes:

- One new well in the Helena Valley Aquifer, approximately 200' deep;
- New fully grouted well casing;
- 75 HP motor, 8-inch diameter pump, motor controls, VFD with ramp start;
- 480 volt 3-phase power source;
- Well control building (approximately 200 SF), insulated, with CMU walls, concrete floor, heating and venting, and a metal roof;
- Interior building piping, flow meter, recorder, pressure gauges, and blow off;
- Sodium hypochlorite disinfection system;
- Disinfection contact time prior to Montana Avenue;
- Pump testing;
- Emergency generator;
- Secure transfer of well water rights from Wylie Well #3;
- A new building at Wylie Well #2 to accommodate additional space for the Wylie source chlorination system (approximately 200 SF), insulated, with CMU walls, concrete floor, heating and venting, and a metal roof;

- Minor piping changes bringing the piping from Wylie Well #1 into the building for chlorination;
- Interior building piping, flow meter, pressure gauges;
- Sodium hypochlorite disinfection system;
- Demolition of the existing Wylie Well building, piping, and chlorination system;
- · Grout and abandon existing Wylie Well #3; and
- Site reclamation.

0.D.2. WATER SUPPLY ALTERNATIVES FOR MCCLELLAN SOURCE

The preferred water supply alternative is Alternative 4 – Caisson Protection and Level Monitoring Improvements. These improvements include removing the existing subfloor in the caissons and installing a new floor slightly above grade. A small building would be constructed over the top of the caisson to be better protect the water collected therein. The pumps currently utilized at the radial wells are the original pumps (1987 installation) and would be replaced concurrently. These new pumps could be either submersible, as utilized now, or vertical turbine pumps, as used in the Wylie system.

The recommended alternative includes:

- Removal of existing subfloor in the both caissons;
- Construction of building over caisson to better protect the water collected;
- Replacement of existing pumps and motor controls. These would be 20 HP, either vertical turbine or submersible; and
- Installation of level monitoring system in both caissons to be reported continuously to the City's SCADA System.

0.D.3. WATER STORAGE

The preferred storage alternative is Alternative 2 – Replace McClellan Storage Tanks with One 1,000,000-Gallon Pre-Stressed Concrete Storage Tank. This alternative includes the construction of a new 96-foot diameter, 1,000,000-gallon, pre-stressed concrete storage tank with new inlet piping, outlet piping, overflow piping, and valves. The new tank would be constructed north of the McClellan storage tanks on the City's existing property. The property would be re-fenced to include the new tank. The existing McClellan concrete storage tanks will be filled with earth and abandoned-in-place.

0.D.4. DISTRIBUTION SYSTEM

The preferred distribution alternatives include:

- Alternative 2 Main Street Stream Crossing.
- Alternative 3 Loop Distribution System at Manlove.
- Alternative 4 Eliminate Dead-End at 1st Street and West Groschell.

Main Street Stream Crossing

This alternative includes the re-connection of approximately 50 feet of 8-inch PVC water main that is located on Main Street under Prickly Pear Creek that is critical to conveying water from one side of town to the other. This alternative would also include the installation of a 10-inch HDPE casing pipe under Prickly Pear Creek by direction drilling.

Loop Distribution System at Manlove

This alternative includes the addition of approximately 300 feet of 6-inch PVC at below Highway 12 that would connect to Manlove. This would be installed in an 8-inch HDPE casing by directional drill. A bore and jack steel casing would also be required below the railroad tracks. The addition of this loop would eliminate the dead-end main at Manlove and increase the inadequate fire flow for American Chemet.

Eliminate Dead-End at 1st Street and West Groschell

This alternative includes the elimination of the dead-end main at 1st Street and West Groschell Street. This would be accomplished by extending the existing 6-inch main on 1st Street from West Groschell to Gail Street.

0.D.5. MCCLELLAN SOURCE ACCESS

The preferred alternative for the McClellan source access is Alternative 2 – New Pedestrian Bridge. This Alternative includes the construction of a new pedestrian bridge across McClellan Creek between Radial Wells #1 and #2. A new pedestrian bridge would allow City personnel to access Radial Well #2 without having to drive, or walk through, the McClellan Creek for routine maintenance.

Road improvements are needed to safely access the two radial wells. The City of East Helena will be improving the road using maintenance funds and will be working with the adjacent landowner to gain improved access across private property for an emergency or large-scale maintenance event.

0.D.6. TELEMETRY SYSTEM

The preferred alternative for the Telemetry System is Alternative 2 – Upgrade SCADA System. This alternative would replace the existing telemetry system with a new Supervisory Control and Data Acquisition (SCADA) System in order to properly monitor the City's water system pressure, flow, levels, and equipment status. The new system will be able to control all pumps for the water system and monitor operating conditions to ensure it is functioning properly. This system will also alert operators for various emergency situations.

All well facilities, treatment facilities, and storage tanks associated with the City's water system will be retrofitted with the new SCADA telemetry and associated instrumentation and will be connected to the central computer located at the City's wastewater treatment facility.

0.E. PROJECT COSTS AND BUDGET

The total project cost for the water system improvements are summarized in **Table 0.E.1**. The total project cost includes the construction, engineering, administration of grants and loans, and contingency. As stated above, the cost for recommended Alternative 2 to replace existing Wylie Well #3 is not included in the total project cost below. At the time of this writing, the City of East Helena is seeking funding from the Montana Environmental Trust Group (METG) for implementation of this alternative. This item is not included in the Funding Strategy and is not included in the budget included in **Chapter 7**.

Table 0.E.1: Cost Summary for Water System Improvements

Total Project Cost	\$ 5,562,993
Total Annual Operation and Maintenance Cost	\$ 2,280

CHAPTER 1: PROJECT PLANNING

1.A. LOCATION

The City of East Helena is located at the southern end of the Helena Valley in Lewis and Clark County. The City is surrounded by the Elkhorn Mountains to the south, the Big Belt Mountains to the east, with smaller hills and mountains to the north and west.

The planning area for the East Helena water system is the current water service area. This area is included in the City Limits is shown in **Figure 1.A.1**.

1.B. ENVIRONMENTAL RESOURCES PRESENT

1.B.1. LAND RESOURCES

Current land uses include residential and commercial businesses, agricultural lands and open spaces, and industrial facilities. **Figure 1.B.1** shows the land use categories surrounding and include the City of East Helena. The agricultural and rangelands in the planning area are used primarily for grazing and fallow cropping.

Figure 1.B.2 shows the topography of the area. The terrain around the City of East Helena is gently rolling with surface elevations generally decreasing from south to north towards Lake Helena. Surface elevations in the areas range from about 3,800 feet above sea level at locations along Canyon Ferry Road to about 4,100 feet near the Jefferson County line southeast of the City. The topography within the East Helena City Limits is flat.


1.B.2. SOIL TYPES


According to the USDA Natural Resources and Conservation Service Web Soil Survey, there are several types of soil around the East Helena area. Most of these soils found consist of varying types of loam with the typical slopes of occurrence varying anywhere from 0 percent to 5 percent.


Some soils within the planning area are considered farmland of local importance, farmland of statewide importance and prime farmland if irrigated

1.B.3. WATER RESOURCES

Water resources in the area include exploitable groundwater as well as Prickly Pear Creek, Helena Valley Canal, and various other unnamed drainages. Prickly Pear Creek heads in the Elkhorn Mountains south of the City of East Helena and runs north west, eventually emptying into Lake Helena. The Helena Valley Canal runs east in the norther part of the planning area to the Regulating Reservoir. Both are part of the Upper Missouri Water Shed.







1.B.3.1. GROUNDWATER

The principal source of groundwater within the study area is an alluvial aquifer known as the Helena Valley aquifer. The aquifer is comprised of discontinuous and variable alluvium that is continuously saturated from the water table to a depth of at least 500 feet. Typical depths to groundwater of most of East Helena range from 17.5 feet to more than 45 feet below the ground surface. However, groundwater depth is considerably shallower on lands adjoining Prickly Pear Creek.

The City of East Helena utilizes two water sources. The first water source is a set of three wells located north of town along Wylie Drive and is commonly referred to as the "Wylie Source". These wells have been drilled to depths ranging from 90 feet to more than 150 feet and each well typically produces more than 450 gallons per minute. These wells utilize the Helena Valley Aquifer. The second source is a pair of infiltration galleries that draw water from below McClellan Creek. This second source is the referred to as the "McClellan Source".

While alluvial aquifers are an excellent water source, they are susceptible to contaminations because coarse-grained deposits may allow for rapid infiltration of surface contaminants. Groundwater contamination from on-site wastewater disposal systems is an ongoing concern. There is a very high density of septic systems concentrated around the perimeter of East Helena.

An extensive well monitoring program has been implemented by ASARCO at the smelter site and at other East Helena area wells. Well testing has shown that a plume of groundwater contaminated by selenium and arsenic extends beyond the boundaries of the ASARCO smelter site and is found in the shallow and intermediate aquifers underlying a portion of East Helena. This selenium and arsenic contamination is likely due to seepage from contaminated water stored on the ASARCO site into the groundwater and from the former acid plant sediment drying area. Testing has shown that concentrations of arsenic in the groundwater near the former smelter are up to 5,000 times the current EPA drinking water standard of 10 parts per billion.

1.B.3.2. SURFACE WATER

Decades ago, ASARCO moved the creek to the east of the plant footprint and diverted the creek into the "Upper Lake" which was used to cool the hot materials that had gone through the smelting process. From there, surface water from Prickly Pear Creek was either sprayed on the plant site or dumped into the "Lower Lake" which is held back by a 14-foot dam, eventually running back into Prickly Pear Creek.

In 2013, Prickly Pear Creek, which originally ran through the middle of the ASARCO plant site and underneath a large slag pile, was moved away from the ASARCO plant site in a meandering route that would slow down flow and provide for better fish habitat. The creek was also moved to decrease the amount of groundwater flowing though the ASARCO plant site. With the creek flowing though the plant site, this allowed arsenic and selenium to flow off the site and created

underground plumes that are flowing into and around the City. The intent of moving the creek, was to slow down or stop the movement of these plumes.

The Montana Department of Environmental Quality (MDEQ) under the **Montana Water Quality Act** (75-5-701 M.C.A.) establishes water use classifications and related water quality standards for all drainages in the state. The water in Prickly Pear Creek from Lump Gulch to Wylie Drive is classified as "B-1" and from Wylie Drive to Lake Helena is classified as "I". The "B-1" designation means that these waters are suitable for drinking, culinary, and food processing purposes after conventional treatment; bathing, swimming and recreation; growth and propagation of salmonid fishes and associated aquatic life, waterfowl and furbearers; and agricultural and industrial water supply. The "I" designation means the goal of the State of Montana is to have these waters fully support the following uses: drinking, culinary, and food processing purposes after conventional treatment; bathing, swimming and recreation; growth and propagation of fishes and associated aquatic life, waterfowl and furbearers; and agricultural and industrial water supply. The water in the Helena Valley Irrigation Canal has insufficient data to assess the use-support of any applicable beneficial use.

MDEQ also has the responsibility under **Section 401** of the **Clean Water Act** (*33 U.S.C. 1251-1376*) and the **Montana Water Quality Act** (*75-5-101 M.C.A.*) to monitor and assess the quality of Montana surface waters and to identify impaired or threatened stream segments and lakes. The MDEQ sets limits, known as Total Maximum Daily Loads (TMDLs), for each pollutant entering a body of water. TMDLs are established for streams or lakes that fail to meet certain standards for water quality and describe the amount of each pollutant a water body can receive without violating water quality standards. The planning area lies within the Missouri River and Lake Helena TMDL Planning Area.

The MDEQ has identified water bodies (i.e. streams or lakes) that do not fully meet water quality standards and support the appropriate beneficial uses such as recreation, aquatic life, fisheries, water supply, agriculture and industrial use, or that are fully supporting their uses as stipulated in the standards but are threatened. Such streams or lakes are referred to as "water quality limited". Section 303(d) of the Clean Water Act requires States to identify waters where quality is impaired or threatened. The MDEQ prepares and submits a list of these impaired or threatened water to the EPA every two years. Prickly Pear Creek is on MDEQ's list of waters that do not meet State water quality standards for: drinking water and aquatic life from Lump Gulch to Wylie Drive; aquatic life, recreation, drinking water, and agriculture from Wylie Drive to the Helena WWTP; and aquatic life, recreation and drinking water from the Helena WWTP to Lake Helena. Water quality impairments applicable to these areas of Prickly Pear Creek are summarized in **Table 1.B.1**. The Helena Valley Canal is on the Section 303(d) list for 2016 but has not been assessed.

Table 1.B.1: Summary of Water Quality Data

Surface	Montana 303(d) Listed - 2016		
Water	Total Miles	Probably Causes	Probable Sources
Prickly Pear	10.84	Alteration in stream-side or	Highways, roads, bridges,
Creek – Lump		littoral vegetative cover	infrastructure, channelization
Gulch to Wylie		Arsenic	Impacts from abandoned mine
Drive		Cadmium	lands, acid mine drainage,
		Copper	contaminated sediments,
		Lead	industrial point discharge, loss
		Zinc	of riparian habitat, flow
		Physical substrate habitat	alterations from water diversion
		alteration	
		Sedimentation-siltation	
		Temperature, water	
Prickly Pear	6.54	Alteration in stream-side or	Grazing in riparian or shoreline
Creek – Wylie		littoral vegetative covers	zones, impacts from abandoned
Drive to		Ammonia	mines, habitat modifications,
Helena WWTP		Arsenic	irrigated crop production, on-
Prickly Pear	4.15	Cadmium	site treatment systems, acid
Creek –		Copper	mine drainage, contaminated
Helena WWTP		Lead	sediments, industrial point
to Lake Helena		Zinc	source discharge
		Low flow alterations	
		Nitrogen	
		Phosphorus	
		Physical substrate habitat	
		alterations	
		Sedimentations-siltation	
		Water temperature	

1.B.4. FLOODPLAINS

Portions of the planning area are located within the 100-year floodplains associated with Prickly Pear Creek and an unnamed drainage. Map numbers 30049C2327, 30049C2331, 30049C2332, 30049C2333 effective September 19, 2012 identifies the 100-year floodplain and other flood prone areas within and surrounding the City of East Helena. These floodplain maps are located in **Appendix A**.

Any new development in these floodplains must be coordinated with the City of East Helena and Lewis & Clark County's Floodplain Coordinator(s) and a Floodplain Development Permit would be required.

1.B.5. WETLANDS

The Clean Water Act and Executive Order 11990, Protection of Wetlands, establish the Federal Government's authority over activities that occur within wetlands. Federal agencies must ensure their actions minimize the destruction, loss, or degradation of wetlands. It also assures the protection, preservation, and enhancement of the Nation's wetlands to the fullest extent practicable.

According to the National Wetlands Inventory Wetlands Mapper (http://www.fws.gov/wetlands/Data/Mapper.html), various wetlands are located within the planning area. These wetlands include Estuarine and Marine Wetlands, Freshwater Emergent Wetlands, Freshwater Forested/Shrub Wetlands, Freshwater Pond and Riverine and are shown in **Figure 1.B.3**. Some of these wetlands in the planning area have been excavated by humans or are present for only brief periods.

It is not anticipated that any designated wetlands will be impacted as part of the proposed project.

1.B.6. BIOLOGICAL RESOURCES

Common mammals that may be found in and around the project area include: mule deer, white-tailed deer, eastern fox squirrel, mountain cottontail, white-tailed jack rabbit, muskrat, red fox and meadow vole. Commonly observed birds in the area include House Finch, Ring-Billed Gull, Red-winged Blackbird, Tree Swallows, Yellow Warbler, American Crow, American Robin, Canada Goose, Black-Capped Chickadee and the Black-Billed Magpie.


Amphibians and reptiles likely to occur in the planning area include gopher snake, garter snake, painted turtle, western toad, and boreal chorus, and Columbia spotted frogs.

Prickly Pear Creek provides a variety of fish species including brook trout, brown trout, common carp, kokanee, mountain whitefish, rainbow trout, walleye, white sucker and yellow perch.

1.B.7. ENDANGERED SPECIES AND CRITICAL HABITATS

The United States Fish and Wildlife Service lists the following species as endangered, threatened, proposed or candidate species for Lewis and Clark County (April 10, 2018):

- Grizzly Bear (*Ursus arctos horribilis*) Threatened;
- Canada Lynx (Lynx canadensis) Threatened;
- Bull Trout (Salvelinus confluentus) Threatened;
- Red Knot (Calidris canutus rufa) Threatened;
- Wolverine (Gulo gulo luscus) Proposed; and
- Whitebark Pine (*Pinus albicaulis*) Candidate.



The Montana Natural Heritage Program lists 25 animal species and 3 plant species of special concern, 1 animal species of special status and 1 plant species considered a potential species of concern that have been observed within the areas quarter-quarter lat. long. that includes the East Helena project.

1.B.8. HAZARDOUS FACILITIES

A large lead smelter was built on the banks of the Prickly Pear Creek and operated from 1888 to April 2001. ASARCO took ownership of the smelter in 1895 and continued to operate it until its closing. During its operation the smelter produced lead bullion, but also recovered copper, gold, silver, and platinum for refining at other ASARCO facilities. The lead smelting operation deposited lead, arsenic, copper, zinc, cadmium and some 15 other hazardous materials into the soil, surface water, and groundwater in the area.

The ASARCO site was proposed for addition to EPA's Superfund National Priorities List (NPL) in September 1983 and listing became final one year later. The East Helena Superfund site consists of the smelter, all of the City of East Helena, nearby residential subdivisions, numerous rural developments and the surrounding undeveloped and rural agricultural lands.

ASARCO conducted the required remedial actions for the process ponds from 1990 until it was completed in 1996. Under the direction of the EPA and MDEQ, ASARCO has excavated and replaced numerous residential yards the surface material from sections of adjacent alleys, road aprons, public parks, day-care centers, schools, gas stations, parking lots, an irrigation ditch, and a field planned for development. In addition to this clean-up, a long-term monitoring program has been put into effect.

In 1995, the Resource Conservation and Recovery Act (RCRA) Program became responsible for the disposal of process ponds cleanup residues, process ponds, ground and surface water, the slag pile, and former ore storage areas.

1.B.9. CULTURAL AND HISTORIC RESOURCES

The National Register of Historic Places lists 7 National Historic Register properties within Lewis and Clark County (http://www.nationalregisterofhistoricplaces.com/mt/lewis+and+clark/state.html). None of these properties are located within the planning area. No impacts to historic resources or properties are likely to occur from improvements to the water system.

The State Historic Preservation Office (SHPO) was contacted on February 20, 2018 to conduct a cultural resource file search for Township-9-North, Range-2-West, Section 6 and 7 and Township-10-North, Range-3-West, Sections 23, 24, 25, 30, 31 and 36.

Several previously recorded sites are located within the search locales. In addition to these sites, few previously conducted cultural resource inventories have been done. A listing of these sites is located in **Appendix A**. According to SHPO, as long as there will be no disturbance or

alteration to structures over fifty years of age and kept to previously disturbed areas, there is a low likelihood cultural properties will be impacted. Therefore, a cultural resource inventory is not necessary. However, should structures need to be altered or if cultural materials are inadvertently discovered, SHPO must be contacted and the site investigated further.

1.B.10. SOCIO-ECONOMIC ENVIRONMENTAL JUSTICE

Title VI of the U.S. Civil Rights Act of 1964, as amended, **Executive Order 12898** (*Federal Actions to Address Environmental Justice Minority and Low-Income Populations*) and **Order DOT 5610.2** (*Environmental Justice*) require that no minority, or, by extension, low-income person shall be disproportionately adversely impacted by any project receiving federal funds. The project would not adversely affect any social or ethnic groups and it would not isolate or divide existing residential areas. The project would not cause disproportionately high adverse human health or environmental effects on minority and low-income populations and would not have any significant impact on the location, distribution, density or growth rate of the population of East Helena or Lewis and Clark County.

1.C. POPULATION TRENDS

In 1888, the smelter was constructed on the banks of the Prickly Pear Creek, causing a migration of people to the City of East Helena. The smelter was purchased in 1895 by the American Smelting and Refining Company (ASARCO) and originally processed ore mined in places throughout the area. This smelter created an economic base for the East Helena and led to the early attraction of over 1,000 people.

The City of East Helena was officially incorporated in 1927. The first official census was taken in 1930 and placed the population at 1,030. With the exception of 1980 and 1990, the City has seen growth since its incorporation. This slight decrease was likely due to the movement of people from inside the City limits to new housing developments surrounding the city.

Table 1.C.1 summarizes the historical population data for Lewis and Clark County and the City of Helena.

The City of East Helena's Growth Policy determined an annual growth rate for the City of East Helena to be 2.1% annually with a conservative rate of 1.45% annually. For purposes of this Master Plan, an annual growth rate for the City of East Helena is estimated to be 1.45%.

Table 1.C.2 shows the population projections of Lewis and Clark County and the City of East Helena with a projected growth rate of 1.45% over the next 20 years.

Table 1.C.1: Population Trends for Lewis and Clark County and the City of East Helena

Census Year	Population Data		
Celisus real	Lewis and Clark	City of East Helena (1)	
	County ⁽¹⁾		
1960	28,006	1,490	
1970	33,281	1,651	
1980	43,039	1,647	
1990	47,495	1,538	
2000	55,716	1,642	
2010	63,395	1,984	
2017	69,013 ⁽²⁾	2,194 ⁽³⁾	

⁽¹⁾ Source: U.S. Bureau of the Census. Decennial Census of Population (Title Varies per Census), 1890-2010. Compiled June 2013 by the Census & Economic Information Center, MT Department of Commerce (www.ceic.mt.gov).

Table 1.C.2: Population Projections for Lewis and Clark County and the City of East Helena

	Population Data		
Census Year	Lewis and Clark County Population (1)	Lewis and Clark County Population Percent Change	City of East Helena ⁽²⁾
2017	68,385	n/a	2,194
2020	70,208	0.9%	2,291
2025	72,772	3.7%	2,462
2030	74,495	2.4%	2,646
2035	75,419	1.2%	2,846
2037	75,649	0.2%	2,926
(4)	Annual Growth Rate	0.5%	1.45%

⁽¹⁾ eREMI – A Product of Regional Economic Models, Inc. (www.remi.com) – Released April 2013. Compiled by the Census & Economic Information Center, MT Department of Commerce (www.ceic.mt.gov).

1.D. COMMUNITY ENGAGEMENT

The City of East Helena has been actively including the community in the development of this Master Plan and the recommended improvements. The following lists the ways the City has kept the community engaged in the project:

⁽²⁾ eREMI – A Product of Regional Economic Models, Inc. (www.remi.com) – Released April 2013. Compiled by the Census & Economic Information Center, MT Department of Commerce (www.ceic.mt.gov).

⁽³⁾ City of East Helena Growth Policy – Adopted October 7, 2014. Prepared by WWC Engineering.

⁽²⁾ City of East Helena Growth Policy – Adopted October 7, 2014. Prepared by WWC Engineering.

- A website dedicated to the Master Plan was created by City personnel to keep the public informed of the project and provide the public with information on upcoming meetings.
- A public meeting was held on February 27, 2018 to discuss the development of the Master Plan and possible recommendations.
- A newsletter was sent out to all utility users to notify users of the Master Plan and the recommended improvements to the water system as well as to notify the public on the second public meeting scheduled.
- A second public meeting was held on April 5, 2018 to discuss the Preliminary Engineering Report, potential recommendations, any environmental concerns to be included in the environmental assessment, and the funding applications to be submitted.

Copies of the presentation materials that were presented at each public meeting are located in **Appendix N**.

CHAPTER 2: EXISTING FACILITIES

2.A. LOCATION MAP

The City of East Helena is located on the southern border of Lewis and Clark County, approximately 5 miles east of Helena, Montana. **Figure 1.A.1** in **Chapter 1** shows the location of East Helena and the City limits.

2.B. HISTORY

The City of East Helena receives its water from two sources, the McClellan source and the Wylie Drive source. These wells are shown on **Figure 1.A.1** in **Chapter 1**. The McClellan source consists of two radial wells near McClellan Creek southeast of town. Each radial well has two laterals approximately 12 feet beneath the ground surface. Water is collected in these laterals and flows into a caisson that serves as a pumping basin. Water is pumped from these caissons and through a chlorination building before reaching two concrete storage tanks. Each of these radial well pumps have a capacity of 500 gallons-per-minute (gpm).

The Wylie Drive source consists of three vertical groundwater wells north of town along Wylie Drive. Chlorination for the total output of all three wells occurs in the transmission main adjacent to Wylie Well #3 (chlorination equipment is housed in the Wylie Well #3 building). Pumps for Wylie Well #1 and #3 were replaced in 1999. The pump for Wylie Well #2 was replaced in 2014. The design flow for Wylie Well #1 and #2 is approximately 600 gpm. The design flow for Wylie Well #3 is 450 gpm.

Water storage for the City of East Helena is provided by three reservoirs. The location of these storage tanks is shown in **Figure 1.A.1** in **Chapter 1**. All reservoirs in the system are have identical overflow elevations and the City's distribution system operates as one pressure zone.

A 1-million-gallon buried pre-stressed concrete tank was constructed in 1999 southwest of the City along Highway 282. This tank was constructed to replace an at-grade, 312,000-gallon steel tank built in 1964. The original steel tank was located below the location of the new tank southwest of East Helena and was tied to the distribution system by approximately 2,500 feet of 10-inch asbestos cement line and utilized a unique valving system to maintain pressure equal to that provided by the McClellan tanks.

Two side-by-side cast-in-place concrete storage tanks, commonly known as the McClellan Tanks, are located southeast of town above the McClellan Creek radial wells. The older of the two tanks was constructed in 1928 and has a capacity of 250,000 gallons (McClellan Tank #2). The second tank was built in 1948 and holds 300,000 gallons (McClellan Tank #1). The McClellan radial wells pump from their location near McClellan Creek into these two tanks. Hydraulically, these two tanks operate as a single tank due to a direct connection between them. All but the top of these tanks are buried.

The McClellan Tanks have served the City well since their construction. In 2002, the lid on the McClellan Tank #2 was replaced and surface rehabilitation was done on McClellan Tank #1. New hatches and ladders were installed on both tanks as well to conform to Montana Department of Environmental Quality's requirements. The concrete is showing its age however, particularly on the exposed portions of McClellan Tank #1. Also, the piping and valves that connect these tanks, allows filling and isolation, as well as overflow and drainage valves, are not operable and unreliable.

Water from the McClellan tanks flows by gravity to the City through a 10-inch transmission main constructed in 1928. A small 57-foot section of this transmission main was rerouted with 10" PVC in 2013. The transmission main along Wylie Drive that conveys water from the Wylie Wells was replaced in 1999 and consists primarily of 10-inch PVC. Water is pumped south through this transmission main to the City's distribution system and the storage tank along Highway 282.

The City's distribution system is a network of mains ranging in size from 4-inch to 8-inch. In 1999, the City replaced approximately 16,760 feet of water main within the City due to age and condition. In 2012, the City of East Helena disconnected the existing 8" cast-iron water main on Main Street that ran below Prickly Pear Creek due to its exposure in the stream and its condition. This main was a critical piece of infrastructure in that it provided a crossing to convey water from one side of town to the other.

There are 101 fire hydrants of varying types throughout the distribution system. Barrel sizes range from 4-inch to 5½-inch. These hydrants are well spaced with a hydrant on almost every street intersection. Hydrant flow tests were performed by Robert Peccia & Associates in 2015 and were used to calibrate the system-wide water model which is discussed in greater detail in **Section 2.C.8** below.

The City is metered by water meters installed as part of the 1999 Water System Improvements Project. These meters are primarily located in resident basements and readings are radio linked to a mobile City computer which are read monthly to assess charges.

In Accordance with Federal Safe Drinking Water Act requirements, parameters such as coliform bacteria, lead, copper, nitrate, nitrite, volatile organic chemicals, inorganic chemicals, synthetic organic chemicals, and radiological contaminants must be sampled in accordance with schedules specified in the Administrative Rules of Montana. The City of East Helena has had no positive fecal coliform samples and no MCL exceedances were noted for any other constituents monitored within the past five years of sampling. There are currently no outstanding violations.

2.C. CONDITION OF EXISTING FACILITIES

2.C.1. WATER SUPPLY

The City of East Helena receives its water from two different sources, the McClellan source and the Wylie Drive source. The McClellan source consists of two radial wells near McClellan Creek southeast of the City. The Wylie Drive source consists of three vertical groundwater wells north of the City along Wylie Drive. These wells are shown on **Figure 1.A.1** in **Chapter 1**. Well logs for each well are located in **Appendix B**.

2.C.1.1. MCCLELLAN SOURCE

The McClellan source, or infiltration gallery, was constructed in 1987 and consists of two radial wells, caissons, and submersible pumps. Each well has two horizontal laterals approximately 12 feet beneath the ground that extend between 120 and 150 feet. Water infiltrates from the earth and into these collectors which deliver the water by gravity to a caisson from which water is pumped. Submersible pumps located in the caissons pump water to a chlorination building and then into the McClellan tanks. Each of the radial well pumps have a capacity of 500 gpm.

Each individual caisson is fenced and a metal shed sets over the top of each caisson, however, the majority of the area above these laterals is not fenced. During summer months cattle sometimes graze freely in the area which poses a minor threat to this source. The sheds above each caisson are poorly sealed, and do not prevent rodents or other small creatures from entering.



Caisson #2



Caisson Access for Radial Well #2




Chlorination Building for McClellan Source

During the Spring of 2018, East Helena personnel reported high water levels in both caissons #1 and #2. During this event, high water from the caissons flowed up through the subfloor hatch and onto the subfloor (5 feet below ground surface). This water could then flow back through the hatch, into the caisson, and be pumped into the City's water system. This is the only time water above the subfloor has been reported. However, most of the City's operations staff is new in the last several years and the history is unknown. Water staining suggests that this has happened in the past and has gone undocumented. Water above the subfloor exposes the City's drinking water source to unsanitary conditions and poses a health risk to water users. The subfloor in the caissons is dry during most times of the year and not sealed to a level adequate to prevent entry from mice, insects, or other small creatures.

In the summer of 2017, East Helena personnel noted that the north radial well (Radial Well #1) at McClellan Creek was not able to fill the McClellan tank on its own due to a lack of water. While this event was short lived (approximately 45 days), this is concerning. Historically, each of the two radial wells have been able to fill the tank separately as designed with no previous water shortage noted. The lack of water in this well may be indicative of one or more of the following: 1) the well screen could be partially plugged with fines or other debris, 2) McClellan Creek has shifted over time and the groundwater flows are changing 3) there are other unknown factors affecting this well. Precipitation records (located in **Appendix C**) for the area do not show a significant climate change that may lead to a lack of available water. Therefore, this issue should be continuously monitored to determine a likely cause and to determine if this well remains a long-term viable source of the City's water.

The above problems are exacerbated by the poor access to the radial wells. The access consists of a 2-track dirt road that is impassable much of the winter and during run-off events. City personnel must drive or walk through McClellan Creek to access Radial Well #2 as shown in the photos below. This is unsafe for the City's personnel and causes damage to the creek. These wells are located in a remote area and are not inspected on a regular basis. Improved access for both inspection and maintenance is desirable. See **Figure 2.C.1** for the location of the Radial Wells and ownership of land in the area.





Access Between Radial Well #1 and Radial Well #2 (North)



Access Between Radial Well #1 and Radial Well #2 (South)

2.C.1.2. MCLELLAN OWNERSHIP AND EASEMENT SUMMARY

Concurrently and as part of the master planning effort, research was conducted to review and confirm the existence of easements and ownership documents for the McClellan System (Including the radial wells, tanks, and transmission main). This task was completed, and a brief summary is included below as part of this Master Plan. Documents obtained as part of this research were provided to the City of East Helena separately and are not included in this document.

It appears the radial wells are located on City owned property in Jefferson County, in Section 7 of T9N R2W. This property is shown on Certificate of Survey (COS) 139477 filed in Folio F292B. No attempt to locate a deed for this property was made but it is inferred that the transfer deed is located in Book 125 Page 457 (Jefferson County). The description for this document is cryptic and resolution would require a determination on what was owned by the Vollmer Ranch at the time to make sense of the wording in this document and its intent. Further title research could likely determine this ownership, and further clarify this document.

The City owned parcel for the McClellan storage tanks and chlorination building on Mockel Road are deeded to the City in Book 54 Page 571 and retraced on COS 210699 filed in folio 807-B-BR.

The McClellan transmission main runs northwest towards the City. The easement for which is also described in Book 54 Page 571 (Jefferson County). However, a release of that easement was found, which is described in Miscellaneous Book 33 Page 12 (Jefferson County). The meaning described by this document is difficult to explain, as there appears to be no reason to do this with the water main still in service. The release was to a specific person, however, who possibly owned land in Section 8 and may not be affected by the water line. Again, additional title research would clarify this.

The transmission main continues on its assumed path northwest towards East Helena. A retracement was completed in 1987 for "a proposed new easement" shown on COS 146422 filed in folio 326A (Jefferson County). This includes the transmission mains length to where it entered the City at the time in Section 36, T10N R3W.

Of note is document 3250487 recorded in Book M47 Page 8416 (Lewis and Clark County) which is a water line easement agreement between Montana Environmental Trust Group, LLC and the City of East Helena to move the waterline and the easement to a new location in Section 36 and in Section 31 Township 10 North Range 2 West. The language provides an easement defined by the alignment for the new water main as constructed as the center of the easement granted.

At some point, and to fully determine and clarify the City's right for future access to this infrastructure, it may be advisable to complete further title research, as well a retracement survey.

2.C.1.3. WYLIE WELLS

The Wylie Drive source consists of three vertical groundwater wells north of town along Wylie Drive. Chlorination for the total output of all three wells occurs in the transmission main adjacent to Wylie Well #3 (chlorination equipment housed in the Wylie Well #3 building).

Wylie Well #1 was drilled in 1965 to a total depth of 110 feet. The 16-inch steel casing extends to 90 feet and the bottom 20 feet is stainless steel screen. This well has a capacity of 600 gpm.

Wylie Well #2 was drilled in 1965 to a total depth of 92 feet. The 16-inch steel casing extends to the 88 feet with an open bottom. A stainless-steel screen is located at 58 feet to 88 feet. This well has a capacity of 600 gpm.

Wyle Well #3 was drilled in 1987 to a total depth of 153 feet. The 10-inch steel casing extend 2 feet above ground to 71 feet where there is a 10-inch stainless-steel screen is placed between 71 feet to 119 feet with the remaining 34 feet of the is 10-inch steel casing. This well has a capacity of 450 gpm.

Chlorination for the total output of all three wells occurs adjacent to Wylie Well #3 in the transmission main. Chlorine gas is utilized and the injection tap and the chlorine sampling tap are buried downstream of the building which makes access and maintenance difficult. Originally these items were located in a vault across Wylie Drive from the well building. In 2013, during an MDT roadway construction project, the sampling piping and injection piping were lost. This situation had to be remedied quickly and the injection point was relocated at their current location (with no vault).



Chlorination Building at Wylie Well #3

Wylie Well #3 is supported by a portable generator. This generator is shared with one of the City's sewage lift stations. During a power outage, operators would need to bring the generator to the site, make the connection, and operate the manual transfer switch to the generator.

Groundwater evaluations in the area have indicated that dissolved arsenic and selenium plumes originating from the ASARCO Smelter have migrated generally northward creating a potential vulnerability for Wylie Well #3. As shown in **Figure 2.C.2** below from Hydrometrics, Inc., the selenium plume originating from the ASARCO Smelter is approximately 1,250 feet from the well. Wylie Well #3 creates a cone of depression when pumping at its rate of 450 gpm in the unconfined aquifer that could induce groundwater flow from a significant radial distance. Operations at Helena Sand and Gravel's gravel pit near Wylie Well #3 could also create an even greater cone of depression, inducing groundwater flow through the selenium plume, which would contaminate the well. If Wylie Well #3 becomes contaminated, this water supply well would be unusable without expensive treatment.

2.C.1.4. SOURCE WATER DELINEATION AND ASSESSMENT REPORT

A Source Water Delineation and Assessment Report (SWDAR) was prepared in November 2002 by the University of Montana-Helena in cooperation with the Lewis and Clark County Water Quality Protection District for the City of East Helena's Public Water System (PWS). The intent of a SWDAR is intended to develop a source water protection plan for the community's public water supply. The City of East Helena's SWDAR is located in **Appendix D**.

As part of the SWDAR for the City of East Helena's PWS, an inventory of the potential sources of all primary drinking water contaminates, including pathogens, within the control zone and the inventory zones was completed. The significant potential contaminants from the inventory region of the East Helena PWS include:

- Metals and various chemicals;
- Petroleum hydrocarbons;
- Various VOCs; and
- Nitrates and pathogens.

The various sources of these potential contaminants include:

- ASARCO Smelter and American Chemet;
- Active underground storage tanks (5 sites) and Leaking underground storage tank sites (2 active and 7 closed);
- Automotive repairs shops (4 locations);
- Major roads and railroad lines;
- The Yellowstone Pipeline;
- Gravel Pits (2 locations);
- Class V injection wells;




Figure 2.C.2: Contamination Plumes (Hydrometrics Inc., 2014)

- Agricultural and urban land uses;
- Septic systems, sanitary sewer system, wastewater treatment ponds and discharge line;
 and
- Storm water discharge points.

The susceptibility of each well to the potential contaminants listed in the inventory region was assessed as part of the SWDAR. Management actions were recommended based on the susceptibility assessment to help reduce the relative susceptibility of the wells to each potential contaminant source.

Sanitary survey inspections are required by the Administrative Rules of Montana (ARM) under Section 17.38.231 and are completed by the Montana Department of Environmental Quality personnel or representative. The purpose of the survey is to protect public health by ensuring the water system is providing adequate quality and quantity of safe drinking water and is maintaining compliance with all regulations. These surveys are typically completed every 3 years.

The City of East Helena's most recent survey was completed in 2016. See **Appendix E** for the most recent sanitary survey. According to the survey, no significant deficiencies were noted during the inspection. The inspection stated that the City of East Helena proactively identifies potential sources of contamination, source quantity, and quality of the source water supply and that leaks within the distribution system are typically detected and fixed immediately.

2.C.1.5. GROUNDWATER CLASSIFICATION - MCCLELLAN SOURCE

The 1986 Amendments to the Federal Safe Drinking Water Act required that subsurface water collectors, including the McClellan Creek System, be evaluated for their possible direct influence by surface waters. Groundwater under the direct influence of surface water is defined as:

"... any water beneath the surface of the ground that the department determines to have: a) significant occurrences of insects or other macro-organisms, algae, or large-diameter pathogens such as <u>Giardia lamblia</u>; or b) significant and relatively rapid shifts in water characteristics such as turbidity, temperature, conductivity, or pH in close correlation with climatological or surface water conditions."

Surface water is further defined as:

"... all water open to the atmosphere and subject to surface runoff."

In 1992, the Montana Department of Environmental Quality (MDEQ) reviewed several years of data taken at the McClellan Creek system for turbidity. This study included particulate analysis, a review of past particulate examinations, and analyzed the construction of the system. MDEQ determined that East Helena's McClellan Creek system was not under the direct influence of surface water. Therefore, MDEQ classified the system as a *groundwater source* <u>not</u> *directly*

influenced by surface water. A letter confirming this classification is located in **Appendix F.** This classification did not change the current disinfection requirements of the system. Had the system been classified as groundwater under the direct influence of surface water, the City may have needed to provide additional disinfection and/or filter as required under the Surface Water Treatment Rule.

2.C.2. WATER RIGHTS

According to the Montana Department of Natural Resources and Conservation (DNRC), the City of East Helena has 11 municipal water rights of record. These municipal water rights include:

- 4 groundwater statement of claims;
- 2 surface water statement of claims;
- 1 groundwater certificate;
- 3 provisional permits; and
- 1 water reservation.

Table 2.C.1 below summarizes the details of the City of East Helena's water rights including the water right number, type, priority date, source, flow rate and volume. General abstracts for each of the water rights are located in **Appendix G**.

Table 2.C.1: City of East Helena Water Rights Summary

Water Right Number	Туре	Priority Date	Source	Flow Rate	Volume (acre-ft /year)
411 113654 00	Statement of Claim	8/2/1954	Groundwater	100 gpm	162.22
411 113655 00	Statement of Claim	3/22/1965	Groundwater	600 gpm	973.33
411 113656 00	Statement of Claim	4/10/1965	Groundwater	600 gpm	973.33
411 113657 00	Statement of Claim	7/22/1955	Groundwater	100 gpm	162.22
411 113658 00	Statement of Claim	8/1/1866	McClellan Creek	3.13 cfs	2258.44
411 113658 00	Statement of Claim	8/1/1966	McClellan Creek	3.13 cfs	2258.44
411 113659 00	Statement of Claim	4/1/1865	McClellan Creek	1.38 cfs	993.71
411 113659 00	Statement of Claim	4/1/1865	McClellan Creek	1.38 cfs	993.71
411 44698 00	Certificate	5/5/1982	Groundwater	10 gpm	0.7
411 62231 00	Provisional Permit	5/19/1986	Groundwater	450 gpm	160

Water Right Number	Туре	Priority Date	Source	Flow Rate	Volume (acre-ft /year)
411 70576 00	Provisional Permit	12/12/1988	Groundwater	600 gpm	840
411 70577 00	Provisional Permit	12/12/1988	Groundwater	600 gpm	840
411 71895 00	Reservation	7/1/1985	Groundwater	417 gpm	258

The above listed water rights are located in the Missouri River Drainage Basin, specifically the Missouri River above Holter Dam area, and have the same place of use which is the City of East Helena. The total water rights volume for the City of East Helena is 7,363.95 acre-feet. Of this, a total of 4,111.10 acre-feet are groundwater water rights and the water reservation adds another 258 acre-feet. The water reservation has not been put to use and is therefore available for future growth and water needs.

A Water Rights Preliminary Summary and Analysis prepared for the City of East Helena by HydroSolutions, Inc. in 2016 identified some potential issues associated with the City's water rights that were listed on individual water right abstracts. The following are recommendations based on the on the results of this preliminary review:

- Complete due diligence, including an historic use analysis, for each municipal water right, verifying the claimed volume and place of use.
- Identify water rights that may be considered by DNRC as "period of non-use" and evaluate requirements to re-establish use.
- Provide an alternative analysis and recommendation assessment on how best to move forward and prioritize new well development.
- Begin water rights change applications, as needed.
- Investigate instream flow potential to maintain water rights.
- Perfect the City of East Helena water reservation.
- Identify existing wells that may need to be abandoned.
- Coordinate with the City Commissioners and managers to identify other water rights and water resource planning objectives.

It is important that the City of East Helena address these issues regarding water rights before the adjudication process moves forward and a Final Decree is declared.

2.C.2.6. WATER QUALITY / TREATMENT

Water from the McClellan source flows through a chlorination building located adjacent to the storage tanks. Water is chlorinated prior to entering the tanks by use of gas chlorination. Water is drawn from the 6-inch main and boosted by a separate pump. This pump discharges through 1-inch piping fitted with a gas injector used to draw chlorine gas into the water. This solution is pumped back into the 6-inch water main upstream of the tank entry point.

Chlorine gas cylinders (100 lb units) are stored in a separate room within the McClellan chlorination building. A chlorine analyzer continuously monitors the chlorine levels in the water downstream of the injection point and the concentrations are radio linked to the SCADA System. Operators also feed a sequestering agent to assist the City in complying with the Lead and Copper Rule. Corrosivity tests for the McClellan waters indicated enough aggressiveness to suggest a sequestering agent as prudent. This is injected by use of a small positive displacement pump also located in the McClellan chlorination building.

The Wylie Wells (Wylie Well #1, #2, and #3) are vertical groundwater wells north of East Helena located along Wylie Drive. Water from these wells blends together in the transmission main with chlorination for the total throughput occurring adjacent to Wylie Well #3. Chlorine gas is utilized in 100lb cylinders stored in a separate room in the Wylie Well #3 building. Chlorine injection is accomplished by use of a booster pump as described for the McClellan Source. However, the injection tap and the chlorine sampling tap for the analyzer are buried downstream of the building which makes access and maintenance difficult. Originally, these items were located in a vault across Wylie Drive from the well building. In 2013, during an MDT roadway construction project, the sampling piping and injection piping were lost and replaced at their current location (with no vault). Sequestering chemical is not utilized for the Wylie source.

In Accordance with *Federal Safe Drinking Water Act* requirements, parameters such as coliform bacteria, lead, copper, nitrate, nitrite, volatile organic chemicals, inorganic chemicals, synthetic organic chemicals, and radiological contaminants must be sampled in accordance with schedules specified in the Administrative Rules of Montana. The City of East Helena has had no positive fecal coliform samples and no MCL exceedances were noted for any other constituents monitored within the past five years of sampling. There are currently no outstanding violations.

The City of East Helena is located in the East Valley Controlled Groundwater Area for Lewis and Clark County. This area was developed to restrict groundwater usage in areas where observed contaminant concentrations exceed State of Montana Human Health Standards. **Figure 2.C.3** shows the East Valley Groundwater Control Area.

As shown in the figure, Wylie Well #3 is located within the East Valley Controlled Groundwater Area.

2.C.3. WATER DEMAND

The City of East Helena bills 793 accounts using six (6) categories for billing water usage. Monthly totals in 2017 for each usage category are in **Appendix H**. Monthly usage billed for 2017 for the City of East Helena is shown in **Table 2.C.2**.

.




Figure 2.C.3: East Valley Controlled Groundwater Area (Hydrometrics, 2014)

Table 2.C.2: 2017 Billed Water Usage

Month	Billed Usage (gallons)
January	9,158,000
February	4,380,000
March	4,191,000
April	3,829,000
May	8,662,000
June	18,345,000
July	20,179,000
August	22,318,000
September	11,559,000
October	3,950,000
November	3,040,000
December	3,167,000
2017 TOTAL	112,778,000

Annual water production from the Wylie Wells (Wylie Well #1, #2, and #3) and the McClellan source are shown in Table 2.C.3 below. Production records for each well source for 2017 are in Appendix H.

Table 2.C.3: 2017 Water Production

	2017 Water Production (gallons)		
MONTH	Wylie Wells #1, #2, #3	Infiltration Gallery	
January	7,377,000	3,019,300	
February	2,835,000	5,061,900	
March	2,923,000	3,750,500	
April	2,958,000	3,666,100	
May	7,884,000	5,876,900	
June	13,831,000	8,510,400	
July	15,260,000	11,841,400	
August	16,319,000	9,071,100	
September	7,957,000	6,866,100	
October	3,075,000	3,904,600	
November	2,401,000	3,884,400	
December	2,445,000	3,982,000	
2017 TOTAL	85,265,000	69,434,700	
2017 Combined Water Production 154,699,700			

Using the current (2017) annual water produced of 154,699,700 gallons, the average day demand, maximum day demand, and peak hour demand was calculated and shown in **Table 2.C.4**.

Table 2.C.4: City of East Helena Current and Future Water Demands

	Current (2017) Demands	Projected (2037) Demands
Estimated Population (1)	2,194	2,926
Average Day Demand (gpd)	423,835 (294 gpm)	564,718 (392 gpm)
Average Day Demand per capita (gpcd)	193	193
Maximum Day Demand (gpd) (2)	1,059,588 (736 gpm)	1,411,795 (980 gpm)
Peak Hour Demand (gpd) (3)	2,543,010 (1,766 gpm)	3,388,308 (2,353 gpm)

^{(1) 1.45%} annual growth rate as stated in the City of East Helena Growth Policy adopted 2014.

Circular DEQ-1 states "The total developed ground water source capacity for systems utilizing gravity storage or pumped storage, unless otherwise specified by MDEQ, must equal or exceed the design maximum day demand with the largest producing well out of service." **Table 2.C.5** shows the total capacity of the East Helena wells and the source capacity with the largest well out of service.

Table 2.C.5: City of East Helena Source Capacity

Well	Capacity (gpm)
Wylie Well #1	600
Wylie Well #2	600
Wylie Well #3	450
Radial Well #1	500
Radial Well #2	500
Total	2,650
Total with Largest Well Out of Service	2,050

Comparing the maximum day demand for 2017 (1,059,588 gpd) and 2037 (1,411,795 gpd) to the capacity of the City's wells with the largest well out of service (2,952,000 gpd), the City of East Helena has enough source capacity to meet the MDEQ requirement.

Table 2.C.6 below compares the design demands to the current water rights available to the City.

⁽²⁾ Maximum Day Demand is 2.5 times the Average Day Demand per the 2014 *East Helena Water Supply and Distribution System-Hydraulic Computer Model Report* by Robert Peccia & Associates.

⁽³⁾ Peak Hour Demand is 6.0 times the Average Day Demand per the 2014 East Helena Water Supply and Distribution System-Hydraulic Computer Model Report by Robert Peccia & Associates.

Table 2.C.6: City of East Helena Water Demand vs. Available Water Rights

Design Criteria	Current (2017) Demand	Future (2037) Demand	Groundwater Water Rights Available (Including Reservation)
Average Day	423,835 gpd =	565,718 gpd =	4,369.10 acre-ft/year
Demand	474.70 acre-ft/year	633.60 acre-ft/year	4,509.10 dcre-11/ year
Maximum Day	1,059,588 gpd =	1,411,795 gpd =	4,369.10 acre-ft/year
Demand	1,186.74 acre-ft/year	1,581.21 acre-ft/year	4,509.10 acre-11/ year

Table 2.C.6 shows the City of East Helena has enough available groundwater water rights for current and future average day demand and maximum day demand based on future estimates of population through the planning period.

2.C.4. WATER LOSS

For 2017 the City of East Helena's billed water usage was 112,778,000 gallons and the water produced for that same year was 154,699,700 gallons. This suggests a 27% water loss in the system. According to *EPA's Control and Mitigation of Drinking Water Losses in Distribution Systems, 2010,* there currently is no comprehensive national regulatory policy that limits the amount of water loss from a public water supply. While Montana does not set policies and regulations that address water loss, most states set limits that fall between a 10% to 15% water loss as the maximum acceptable value while other States go as high as 25%.

While the City of East Helena bills water customers based on metered usage, there are some areas of the City that are not metered. These areas include the City of East Helena Parks, the City Pool and 7 un-metered irrigation accounts. These irrigation accounts are billed a flat rate of \$20.00 a month for the months of May through October only.

To estimate the actual amount of water loss in the system, the following assumptions were made to approximate the unmetered usage in 2017.

- 26 acres of park area irrigated 1-inch per week for 16 weeks.
- 0.2 acres each for the un-metered irrigated areas irrigated 1-inch per week for 16 weeks.
- 100,000-gallon pool filled 4 times in 1 year.

Using these assumptions, **Table 2.C.7** shows the estimated unmetered water usage for 2017. Detailed calculations for these amounts are located in **Appendix I**.

Table 2.C.7: Estimated Unmetered Water Usage for 2017

Un-metered Area Using City Water	Calculated Usage (gallons)
City Parks	11,251,728
Irrigation Accounts	519,360
City Pool	400,000
Total	12,171,088

Adding 12,171,088 gallons to the amount of water billed for 2017 (112,778,000 gallons) increases the total to 124,949,088 gallons and decreases the system water loss to 19.2%. Additionally (see discussion in Section 2.C.6), leakage testing of the McClellan Tanks in October 2017 suggests the annual leakage from the McClellan Tanks is approximately 16 million gallons annually (43,844 gallons per day). If this leakage was eliminated as well, the system water loss could be reduced to 9%.

2.C.5. FIRE PROTECTION

Fire ratings are issued to cities from the Insurance Services Office (ISO). An ISO report evaluates the fire protection capabilities of a community based on communications, fire department, and the water system. The evaluation of the water system is 40% of the grading. According to the City of East Helena's ISO report dated July 27, 2015, the needed fire flow for the City is 3,500 gpm for 3 hours. A copy of the City's ISO report is located in **Appendix J**.

The City currently has 101 fire hydrants spaced around the City. Fire protection within the City is provided by the East Helena Volunteer Fire Department (EHVFD). **Figure 2.C.4** shows the locations of all the fire hydrants for the City of East Helena.

2.C.6. WATER STORAGE

Water storage for the City of East Helena is provided by three reservoirs. The location of these storage tanks is shown in **Figure 1.A.1** in **Chapter 1**. All reservoirs in the system are have identical overflow elevations and the City's distribution system operates as one pressure zone.

A 1-million-gallon buried pre-stressed concrete tank was constructed in 1999 southwest of the City along Highway 282. Two side-by-side cast-in-place concrete storage tanks, commonly known as the McClellan Tanks, are located southeast of town above the McClellan Creek radial wells. The older of the two tanks was constructed in 1928 (McClellan Tank #2) and the other constructed in 1948 (McClellan Tank #1). Hydraulically, the McClellan Tanks operate as a single tank due to a direct connection between them.

Table 2.C.8 summarizes the City's existing storage tanks. These tanks are inspected every 3 to 4 years. Past inspection reports are included in **Appendix K.**




Table 2.C.8: City of East Helena Storage Tanks

Tank	Material	Year Constructed	Overflow Elevation (feet)	Inside Diameter (feet)	Capacity (gallons)
Hwy 282	Pre-Stressed	1999	4,096	90	1,000,000
	Strand-Wrapped				
	Concrete				
McClellan #1	Cast-In-Place	1948	4,096	50	300,000
	Concrete				
McClellan #2	Cast-In-Place	1928	4,096	40	250,000
	Concrete				
Total Storage Capacity (gallons) 1,550					



McClellan Creek Tanks #1 and #2



Highway 282 Tank

2.C.6.7. HIGHWAY 282 CONCRETE RESERVOIR

This pre-stressed concrete reservoir was constructed in 1999. Radial wall sections were poured and followed by pre-stressing. Pre-stressing was accomplished by wrapping steel strands around the perimeter to a specified tension, putting the concrete sections compression. Seismic base restraint cables anchored into the footing extend into the core wall, providing load transfer during a seismic event. The tank is buried with just the upper most wall portions and lid exposed. This structure has performed well since its construction, requiring little maintenance. Visually, the concrete appears new from the surface.

In March 2018, RPA personnel tested the Highway 282 tank for leakage over a 24-hour period. No leakage was recorded for this tank. Testing information located in **Appendix I**.

2.C.6.8. MCCLELLAN TANKS

The McClellan Tanks are located southeast of town above the McClellan Creek radial wells. The older of the two tanks was constructed in 1928 and has a capacity of 250,000 gallons (McClellan Tank #1). The second tank was built in 1948 and holds 300,000 gallons (McClellan Tank #2). Both are buried cast-in-place structures with the uppermost sections of the wall and lid exposed.


The McClellan Tanks have served the City well since their construction. In 2002, the lid on the McClellan Tank #1 was replaced and surface rehabilitation was done on McClellan Tank #2. New hatches and ladders were installed on both tanks as well to conform to Montana Department of Environmental Quality's requirements. The concrete is showing its age,

however, particularly on the exposed portions of McClellan Tank #2. There is spalling concrete and in places gaps are forming due to the lost concrete large enough to be concerning. If not addressed, these gaps could allow surface water, insects, or rodents to enter the tank.

Additionally, the valves and piping (shown in **Figure 2.C.5**) that connect these tanks have been constructed in piece-meal and do not provide the operators methods for control or isolation. The valves for this piping are located in vaults which are approximately 15 to 17-feet in depth. The manhole steps cast into these vaults for access have all but rusted away. Water system operators are not certain which valves are for what purpose (draining, filling, isolation) and which valves and piping has been abandoned. Operators have attempted in the past to isolate one tank from the other unsuccessfully. Either the wrong valves were turned, or these valves do not function (hold).



Vaults at McClellan Tanks





Vaults at McClellan Tanks

In October 2017, Robert Peccia & Associates (RPA) personnel tested the McClellan tanks for leakage over a 24-hour period (tested together as one unit including the connecting piping). According to the American Concrete Institute (ACI), the allowable leakage rate for an unlined concrete water-containment structure with a side water depth of less than 25 feet is 0.1 percent of the water volume in 24 hours. The allowable leakage rate for each tank would be:

Tank #1 - 250,000 gallons x 0.001 = 250 gallons/24 hours Tank #2 - 300,000 gallons x 0.001 = 300 gallons/24 hours

Water levels were read over a 24-hour period and determined there was a 1.82-foot loss in each of the McClellan tanks. This equates to a loss of 17,110 gallons in Tank #1 and 26,734 gallons lost in Tank #2 for a total of 43,844 gallons of water lost within a 24-hour period (calculations shown in **Appendix I**). This amount is much greater than the allowable leakage rate suggested by ACI.



McClellan Tank #2



McClellan Tank #2

2.C.6.9. STORAGE VOLUME

According to MDEQ Circular DEQ-1, the minimum allowable storage must be equal to the average day demand plus fire flow demand. Any volume less than that must have a Storage Sizing Engineering Analysis completed.

Currently, the City has a total of 1,550,000 gallons of storage available. However, as stated above, the McClellan storage tanks are old and are experiencing a large amount of leakage and should be replaced.

Table 2.C.9 below shows the current storage volume and that predicted during the planning year (2037).

Table 2.C.9: Current and Future Storage Requirements for the City of East Helena

	2017	2037
Average Day	423,835	564,718
Demand (gal)		
Fire Flow	630,000	630,000
Required (gal)	030,000	030,000
Total Storage	1,053,835	1,194,718
Required	1,055,655	1,194,710
Storage Available	1,550,000	1,550,000
Additional Storage Available	496,165	355,282

According to the table above, the City of East Helena has adequate storage available to meet MDEQ Circular DEQ-1 storage requirements.

2.C.7. WATER TRANSMISSION AND DISTRIBUTION

2.C.7.10. TRANSMISSION MAINS


The City of East Helena owns two transmission mains. The McClellan transmission main and the Wylie transmission main.

Water from the McClellan tanks flows by gravity to the City through a 10-inch transmission main constructed in 1928. The pipe material for a majority of this transmission main is unknown. A small 57' section of this transmission main was rerouted with 10-inch PVC in 2013. In October of 2017, RPA and City staff conducted a 24-hour leakage test on the McClellan Transmission Main by closing the valve from the tanks and at the tie in location near the Post Office. Results did not indicate any leakage.

The Wylie transmission main extends north from the City along Wylie Drive to Canyon Ferry Road at the location of Wylie Well #1. This transmission main conveys water from this point south carrying water from all (3) Wylie Wells. This transmission main also extends south of the City along Highway 282 to the location of the 1-million-gallon 282 Reservoir. This transmission main is largely constructed of 10-inch PVC C900.

2.C.7.11. WATER DISTRIBUTION

The City's distribution system is a network of mains ranging in size from 4-inch to 8-inch. **Figure 2.C.6** shows the City of East Helena's existing water distribution network and **Table 2.C.10** summarizes the sizes and estimated lengths of distribution piping. In 1999, the City replaced approximately 16,760 feet of water main within the City due to age and condition.



The \$3.8 million project included new copper services to the property line and curb stop where mains were replaced. However, the City still has several thousand feet of older 4-inch water mains and valves that do not meet MDEQ's current design standards. A majority of these mains date as far back as 1928. MDEQ current design standards state that water mains providing fire protection and serving fire hydrants should be a minimum of 6 inches in diameter.

Table 2.C.10: Distribution Main Summary

Pipe Size/Diameter	Length
(inches)	(feet)
4	4,520
6	40,250
8	24,640
10	20,800
12	7,050
Total	97,260

Update from current City of East Helena water model

The City is split near the middle by Prickly Pear Creek. In 2012, the City of East Helena was forced to disconnect the 8" cast-iron water main on Main Street that ran below Prickly Pear Creek due to its exposure in the stream and its condition. This main was a critical piece of infrastructure and provided one of the few stream crossing locations that allowed water to pass from one side of town to the other.

Dead-end water mains can lead to low pressure, inadequate fire flow, and stagnant water that allows inorganic sediments to deposit and organic matter to accumulate. These accumulations provide locations for biofilm and other organisms to grow. These organisms can deplete available oxygen and in-turn cause anaerobic conditions causing accelerated corrosion. Anaerobic conditions can also cause potentially serious odor problems.

MDEQ Circular DE- 1 recommends minimizing dead-end mains to increase the reliability of the service and reduce head loss in the system. Extending mains to complete a "looped" connection provides more reliable water service and prevents stagnant water in the system.

The City of East Helena has a dead-end main located on 1st Street between Gail Street and Groschell Street. Another dead-end was created on both sides of Prickly Pear Creek on Main Street where the main was disconnected in 2012 due to failure. A dead-end is also located at the end of Manlove. The City reports inadequate fire flows for the American Chemet Building which is located at the end of this 4-inch dead-end main.

2.C.8. WATER MODEL

Water system computer models are an extremely useful tool for analyzing water supply and distribution systems. The City of East Helena's water model includes the water distribution

system, water storage which includes the two (2) McClellan tanks and the Highway 282 tank, and all water wells in the system including Wylie Well #1, #2, #3 and the McClellan Radial Wells.

Model calibration is critical in ensuring that the model accurately represents the actual distribution system. Fire hydrant testing by Robert Peccia & Associates personnel in 2015 were the field measurements used to calibrate the water model. Measurements recorded as part of the hydrant testing included static pressure, hydrant flow, and residual pressure.

Table 2.C.11 below shows the hydrant flows, static pressures and residual pressures for the hydrant flow test performed in 2015, as well as predicted residual pressures from the calibrated model. As the table shows, the calibration for the East Helena model is excellent. Most of the modeled residual pressures are within 10% or less of the measured residual pressures. Note that some hydrants were not included in the model calibration due to issues during the flow testing.

Table 2.C.11: Computer Model Calibration Results for the East Helena Water System

Hydrant		Measured Static	Measured Flow Rate	Residual Pressure (psi)	
Number	Hydrant Location	Pressure (psi)	(gpm)	Measured	Modeled
1	Lewis / Montana	94	900	70	80
4	Dudley / Montana	94	950	74	79
5	Dudley / Grand	90	940	74	77
6	Dudley / Prickly Pear	89	925	74	79
7	Dudley / Kalispell	90	925	78	79
8	King / Helena	86	900	70	78
9	King / Montana	89	940	76	80
10	King / Grand	90	800	80	75
11	King / Prickly Pear	90	920	74	77
12	King / Washington	90	910	74	78
13	Clinton / Helena	88	900	70	77
14	Clinton / Montana	88	925	71	78
15	Clinton / Montana	89	925	72	75
16	Clinton / Washington	88	900	71	77
17	Groschell / Third	86	950	80	80
18	Groschell / Second	88	940	82	77
19	Groschell / First	89	950	78	78
20	Groschell / Cleveland	92	975	80	79
21	Groschell / Morton	90	975	82	84
23	Groschell / Thurman	88	900	70	76
24	Groschell / Montana	88	910	70	76
25	Groschell / Prickly Pear	85	815	70	74
26	Groschell / Kalispell	90	925	72	77

Hydrant	•		Measured Flow Rate	Residual Pressure (psi)	
Number		(gpm)	Measured	Modeled	
28	Riggs / Second	86	940	78	75
29	Riggs / First	84	870	78	79
32	Riggs / Harrison	90	900	68	79
33	Riggs / Thurman	80	950	78	75
34	Riggs / Helena	86	925	70	73
35	Riggs / Montana	86	900	78	75
36	Riggs / Grand	84	825	68	70
37	Riggs / Prickly Pear	84	875	66	72
38	Riggs / Washington	83	900	65	75
39	Main / Fourth	83	940	78	75
40	Main / Third	82	950	76	75
41	Main / Second	83	950	80	77
42	Main / First	82	940	78	78
43	Main / Cleveland	86	900	72	79
44	Main / Morton	82	450	18	82
45	Main / Harrison	89	900	72	77
46	Main Street Park	90	960	80	76
47	Main / Thurman	86	900	70	76
48	Main / Helena	84	925	70	75
49	Main / Montana	84	900	69	76
50	Main / Grand	84	910	70	74
51	Main / Prickly Pear	84	910	70	73
52	Main / Washington	82	900	70	73
53	Main / Kalispell	84	925	70	73
55	Pacific / Cleveland	82	750	62	73
58	Clark / Thurman	87	875	69	74
59	Clark / Helena	90	930	72	69
60	Clark / Montana	83	900	68	74
62	Clark / Prickly Pear	80	850	60	66
63	Clark / Washington	80	875	64	69
64	Bayard / Sixth	75	900	70	62
66	Pacific / Thurman	82	860	60	78
67	Pacific / Helena	84	880	76	70
68	Pacific / Montana	82	850	60	74
70	Porter / Prickly Pear	79	850	61	71
71	Porter / Washington	84	850	62	65
72	Clark / Roselak	82	875	60	64
73	Manlove / Fourth	76	925	74	72

Hydrant		Measured Static	Measured Flow Rate	Residual Pressure (psi)	
Number	Hydrant Location	Pressure (psi)	(gpm)	Measured	Modeled
78	Gail / Fourth	91	800	59	82
79	Gail / Second	89	950	82	81
80	Gail / Cleveland	90	950	80	82
81	Dudley / Washington	91	925	72	79
83	King / Kalispell	91	940	78	78
84	Clinton / Thurman	90	840	60	78
85	Clinton / Prickly Pear	90	900	76	76
86	Clinton / Kalispell	86	910	76	77
87	Clinton / Cul-De-Sac	90	925	74	76
88	Groschell / Oak	90	925	70	76
89	Groschell / North Alley	88	900	70	76
90	Riggs / Kalispell	83	900	69	74
91	Riggs / North Alley	86	900	70	75
92	Riggs / Oak	86	925	71	76
93	Main / North Alley	84	890	68	73
94	Main / Oak	84	900	70	73
95	Clark / Casey	82	875	60	66
97	U.S. 12 / Casey (A&W)	80	850	59	60
98	Lewis / Harrison	95	940	78	72
99	Dudley / Thurman	91	900	68	85
101	King / Harrison	90	910	70	77
102	Manlove / Fifth	75	910	71	64
103	Not located at the time of this testing				

The calibrated model was used to predict available fire flows for all existing hydrant locations included in the model. Fire flows, per MDEQ standards, are modeled under maximum day demand conditions with a minimum system-wide residual pressure of 20 psi. The modeled fire flow results are shown in **Table 2.C.12** below. Predicted fire flows throughout East Helena are excellent, with all but four hydrant locations having a predicted available fire flow of at least 1,500 gpm. Note that the predicted available flows do not take into account the specific hydraulics for each fire hydrant. The results assume that each hydrant is of relatively new construction and in sound condition.

Table 2.C.12: Modeled Available Fire Flows

Hydrant Number	Hydrant Location	Available Fire Flow (gpm)
1	Lewis / Montana	2,050
2	Lewis / Grand	1,780
3	Lewis / Washington	2,100
4	Dudley / Montana	2,120
5	Dudley / Grand	1,910
6	Dudley / Prickly Pear	2,090
7	Dudley / Kalispell	2,100
8	King / Helena	1,990
9	King / Montana	2,140
10	King / Grand	1,910
11	King / Prickly Pear	2,090
12	King / Washington	2,100
13	Clinton / Helena	2,130
14	Clinton / Montana	2,150
15	Clinton / Montana	1,890
16	Clinton / Washington	2,090
17	Groschell / Third	3,220
18	Groschell / Second	2,440
19	Groschell / First	2,460
20	Groschell / Cleveland	2,430
21	Groschell / Morton	2,830
22	Groschell / Harrison	2,010
23	Groschell / Thurman	2,040
24	Groschell / Montana	2,160
25	Groschell / Prickly Pear	1,910
26	Groschell / Kalispell	2,060
27	Riggs / Third	2,710
28	Riggs / Second	2,470
29	Riggs / First	2,920
30	Riggs / Cleveland	2,520
31	Riggs / Morton	2,780
32	Riggs / Harrison	2,310
33	Riggs / Thurman	2,070
34	Riggs / Helena	1,940
35	Riggs / Montana	2,170
36	Riggs / Grand	1,720
37	Riggs / Prickly Pear	1,910
38	Riggs / Washington	2,070

Hydrant Number	Hydrant Location	Available Fire Flow (gpm)
39	Main / Fourth	3,570
40	Main / Third	3,130
41	Main / Second	2,960
42	Main / First	2,910
43	Main / Cleveland	2,240
44	Main / Morton	1,910
45	Main / Harrison	1,680
46	Main Street Park	1,870
47	Main / Thurman	2,000
48	Main / Helena	2,040
49	Main / Montana	2,180
50	Main / Grand	2,070
51	Main / Prickly Pear	2,050
52	Main / Washington	2,050
53	Main / Kalispell	2,010
54	Pacific / First	2,130
55	Pacific / Cleveland	1,780
56	Pacific / Morton	1,690
57	Pacific / Harrison	1,800
58	Clark / Thurman	2,010
59	Clark / Helena	1,760
60	Clark / Montana	2,150
61	Clark / Grand	1,640
62	Clark / Prickly Pear	1,580
63	Clark / Washington	1,710
64	Bayard / Sixth	1,900
65	Bayard / Fifth	2,190
66	Pacific / Thurman	2,010
67	Pacific / Helena	1,760
68	Pacific / Montana	2,100
69	Porter / Grand	1,790
70	Porter / Prickly Pear	2,090
71	Porter / Washington	1,590
72	Clark / Roselak	1,500
73	Manlove / Fourth	3,540
74	Manlove / Third	1,400
75	Manlove / First (Chemet)	480
76	REMOVED IN 2013	NA
77	REMOVED IN 2013	NA

Hydrant Number	Hydrant Location	Available Fire Flow (gpm)
78	Gail / Fourth	3,580
79	Gail / Second	2,820
80	Gail / Cleveland	2,670
81	Dudley / Washington	2,100
82	E. End of Dudley (EVMS)	1,920
83	King / Kalispell	2,090
84	Clinton / Thurman	2,070
85	Clinton / Prickly Pear	2,060
86	Clinton / Kalispell	2,080
87	Clinton / Cul-De-Sac	1,990
88	Groschell / Oak	2,030
89	Groschell / North Alley	2,030
90	Riggs / Kalispell	2,040
91	Riggs / North Alley	1,990
92	Riggs / Oak	2,010
93	Main / North Alley	1,930
94	Main / Oak	1,930
95	Clark / Casey	1,580
96	U.S. 12 / Lane	1,460
97	U.S. 12 / Casey (A&W)	1,410
98	Lewis / Harrison	1,610
99	Dudley / Thurman	1,740
100	King / Harrison (JFK Park)	680
101	King / Harrison	1,880
102	Manlove / Fifth	2,210
103	Manlove / Fifth	2,030

2.C.9. WATER METERS

The City of East Helena installed water meters throughout the City as part of the 1999 Water Improvement Project. This allowed the City to track water usage and bill accordingly. As stated above, there are areas of the City that irrigate or use water that are not metered and therefore are not tracked for usage. These areas include the City of East Helena Parks, the City of East Helena's Pool, and 7 irrigation accounts within the City that are not metered.

Meters are primarily located in resident basements and readings are radio linked to a mobile city computer read monthly to assess charges. The existing meters are aging and replacement meters and parts are being phased out by the manufacturer. The City will need to select a meter type and manufacturer for future installations as additional units fail and understand how these meters interrelate to their current billing software and systems.

2.C.10. TELEMETRY SYSTEM

The existing telemetry equipment was installed in 1999. The system was designed to monitor tank levels, flow meters, chlorine concentrations, and other data. The system operates pumps and maintain tank levels to provide relatively even system pressure. Remote Telemetry Units (RTU's) are installed at each of the Wylie Wells, at each of the McClellan Radial Wells, at the McClellan Tanks, and at the Highway 282 Tank. Each of these RTU's report through radio communications to the Control System Master Computer located at the City's wastewater treatment facility. This computer provides a location for operators to look at system operating data as well as any failure or alarming conditions.

The existing telemetry equipment for the City's water system is, at times, not communicating from the radial wells properly. During these periods no data is received and operators are not certain of the status from the McClellan Radial Wells. These wells are located in a low spot, but communications from this location were reliable until recent years. Technology has improved a great deal since the late 1990's and an improved system may be beneficial and provide more reliable communication.

2.D. FINANCIAL STATUS OF THE EXISTING FACILITY

Operation of the East Helena Water System is funded through the City's water enterprise fund, with revenue generated primarily through water rates charged to users. Water rates are based on metered water consumption and a base rate charge per month according to the nominal size of water meter installed. Table 2.C.13 below shows the City's current water rates.

Nominal Meter Base Rate Varied Rate Size (inch) (gallons used) \$ 1.10 / 1,000 % x ¾ \$ 30.00 \$ 30.00 \$ 1.10 / 1,000 3/4

Table 2.C.13: City of East Helena's Water Rate Structure

1 \$ 53.40 \$ 1.10 / 1,000 \$ 1.10 / 1,000 1½ \$ 120.00 2 \$ 213.30 \$ 1.10 / 1,000 \$ 1.10 / 1,000 3 \$ 480.00 \$853.20 \$ 1.10 / 1,000 4 6 \$ 1,920.00 \$ 1.10 / 1,000 Additional monthly surcharge per \$ 20.00 / month

(May – October)

A copy of the City's water rate ordinance is included in **Appendix L**.

unmetered irrigation hydrant

The City of East Helena has 793 water meter hookups. These hookups are categorized by nominal water meter size for commercial and residential properties. **Table 2.C.14** shows the number of hookups per category.

As an enterprise fund, water revenue must be exclusively used for the municipal water utility. Revenues are used to fund the annual operations and maintenance (O&M) of the water system which includes the supply, storage, distribution system, and treatment operations along with the City administrative and management expenses directly related to the water system. O&M expenses for the City of East Helena's municipal water system are budgeted at \$529,896 for 2018. Of this, \$38,000 is budgeted for energy costs for the water system.

Rate Code	Number
COMM-MTR-0.625"	22
COMM-MTR-0.750"	17
COMM-MTR-1.000"	5
COMM-MTR-2.000"	4
COMM-MTR-3.000"	1
RES-4 UNITS-1.000	1
RES-MTR-0.625"	2
RES-MTR-0.750"	680
RES-MTR-1.000"	53
RES-MTR-1.500"	1
RES-VACATION-0.750"	7
Total	793

Table 2.C.14: City of East Helena's Hookups Per Category

Water revenue is also used to pay any acquired loans or revenue bonds. The City has one SRF loan for the 1999 improvements project for the water system. The SRF Loan is a 30-year loan at an interest rate of 3.00% for \$3,234,000. The outstanding balance for this loan is \$1,539,000 as of February 2018. A reserve account of 125% was required for this loan.

The City of East Helena's Capital Improvements Plan was updated in 2017. The Plan is a budgetary tool that allows the City to plan beyond the immediate need and evaluate the long-term needs for maintaining and improving its public facilities, including its water system. This Plan includes the development of a new public water supply well, land acquisition for additional water storage, a pedestrian bridge across McClellan Creek at the radial wells site, and reconnection of the Main Street water main among other listed improvements.

2.E. WATER / ENERGY / WASTE AUDITS

The purpose of a water audit is to accurately determine the amount of "unaccounted-for" or rather "non-revenue" water in a water distribution system. Non-revenue water is calculated from verified supply and consumption records for at least the past 12 months. Using records

under 12 months will not reflect seasonal climatic and population variations. A water audit is used to provide a way to inventory all water uses in the municipal system and help identify ways to increase water use efficiency.

The City of East Helena has not completed a past water audit on their municipal water system. This document is being used to help identify the City's non-revenue water and identify ways minimize the amount of water that cannot be accounted for.

There has not been an energy audit completed for the City of East Helena's water system.

CHAPTER 3: NEED FOR PROJECT

3.A. HEALTH, SANITATION AND SECURITY

Groundwater evaluations in the area have indicated that dissolved arsenic and selenium plumes originating from the ASARCO Smelter site have migrated generally northward creating a potential vulnerability for Wylie Well #3. As shown in **Figure 2.C.1** in **Chapter 2** from Hydrometrics, Inc., the selenium plume originating from the ASARCO Smelter is approximately 1,250 feet from the well. The Wylie Well #3 creates a cone of depression when pumping at its rate of 450 gpm in the unconfined aquifer that could induce groundwater flow from a significant radial distance. Operations at Helena Sand and Gravel's gravel pit near Wylie Well #3 could also create an even greater cone of depression, inducing groundwater flow through the selenium plume, which would contaminate the well. If Wylie Well #3 becomes contaminated the City's water supply well would be unusable without expensive treatment.

A new production well is needed to replace Wylie Well #3 to maintain consistent service over the long-term in East Helena. The new production well should be located away from any potential contamination from the plumes as well as other possible pollutants and out of the East Valley Groundwater Controlled Area as shown in Figure 2.C.3 in Chapter 2. The proposed location, as well as plans and specifications for the new production well, would need to be approved by MDEQ and must be constructed by a licensed water well contractor in accordance with Title 37, Chapter 43, MCA and ARM Title 36, Chapter 21 along with requirements in Circular DEQ-1, Standards for Water Works. Continued protection for a radius of at least 100 feet around the well from potential sources of contamination must be provided either through deed notice, zoning, easements, leasing, or other means accepted by MDEQ. The existing well would be abandoned and the disinfection system re-located north to Wylie Well #2.

The caissons at both radial wells have experienced high water events that have resulted in water above the subfloor and exposed this water to unsanitary conditions. The subfloor in the caissons is dry during most times of the year and not sealed to a level to prevent entry from mice, insects, or other small creatures. Additionally, operators enter the caisson and stand on this subfloor to perform inspections. Water above the subfloor is a serious risk to the health and safety of the City's water system. Improvements are needed to better protect the water collected in the caissons. These improvements include removing the existing subfloor and installing a new floor slightly above grade. A small building would be constructed over the top of the caisson to be better protect the water collected therein.

Dead-end water mains can lead to low pressure, inadequate fire flow, and stagnant water that will allow inorganic sediments to deposit and organic matter to accumulate which will allow biofilm and other organisms to grow. These organisms can deplete the available oxygen which will in turn cause anaerobic conditions to allow for corrosion issues of the main and potentially serious odor problems. A dead-end water main exists on 1st Street that needs to be extended and another on Manlove that contributes to inadequate fire flows.

In 2012, the City of East Helena disconnected the existing 8" cast iron water main on Main Street that ran below Prickly Pear Creek due to its exposure in the stream and its condition. This main was a critical piece of infrastructure in that it provided a crossing to convey water from one side of town to the other.

The access road to the radial wells is a poor, 2-track dirt road and there is no viable access between Radial Well #1 and Radial Well #2. In order for the City personnel to access Radial Well #2, they must drive or walk through McClellan Creek. This is unsafe for the City's personnel and causes damage to the creek. During the winter months, the road to and between the radial wells is not drivable due to snow conditions. Therefore, the radial wells are not inspected on a regular basis.

Road improvements are needed to safely access the two radial wells. The City of East Helena will be improving the road using maintenance funds and will be working with the adjacent landowner to gain improved access across private property for an emergency or large-scale maintenance event.

3.B. AGING INFRASTRUCTURE

The existing McClellan storage tanks are severely leaking and deteriorating due to age as describe in **Chapter 2**. These tanks are leaking approximately 44,000 gallons of water a day, causing substantial water loss to the City's system. Valves and connecting piping are also unoperable.

The existing telemetry equipment for the City's water system is, at times, not communicating from the radial wells properly to the system at wastewater treatment facility. This could be due to a weak signal or problems with the outdated system. It is recommended that the City install a new and improved telemetry system in order to properly monitor the City's water system pressure, flow, levels, equipment status, etc. The new system should be able to control all pumps for the water system, monitor the system to ensure it is operating properly, and be equipped with alarms for various emergency situations. The installation of a new telemetry system would allow for effective management of the water supply which would save on water as well as the operation and maintenance costs of the system.

3.C. REASONABLE GROWTH

A reasonable expected annual growth rate of 1.45% is used to estimate the 20-year planning period population. The effects of reasonable expected population growth are discussed in **Chapter 2** and presented in **Table 1.C.2** in **Chapter** and **Table 2.C.4** in **Chapter 2**.

The 2017 estimated population that is currently served by City water is 2,194. The planning area projected 2037 population is 2,926.

CHAPTER 4: ALTERNATIVES CONSIDERED

4.A. WATER SUPPLY ALTERNATIVE 1 - NO-ACTION

4.A.1. DESCRIPTION

As stated in **Chapter 2**, the City's Wylie Well #3 is vulnerable to contamination from a selenium plume that originated from the ASARCO smelter. If this well becomes contaminated, the water supply from this well would become unusable. The no-action alternative does nothing to address the issue of potential contamination to this water source and the public health risks associated with its contamination. Therefore, the <u>No-Action Alternative is eliminated from</u> further discussion in this document with regard to addressing concerns at Wylie Well #3.

As stated in **Chapter 2**, the McClellan Source radial wells have experience low flow levels as well as high flow levels. The no-action alternative does nothing to address the potential contamination issue during high flow events and the public health risks associated with the contamination of the City's water source. Also, the no-action alternative does not address the need to study and monitor the possible changing seasonal water levels. Therefore, the <u>No-Action Alternative</u> is eliminated from further discussion in this document with regard to addressing concerns with the McClellan Source.

4.B. WATER SUPPLY ALTERNATIVE 2 — NEW PRODUCTION WELL AT NORTHEAST CORNER OF CITY OWNED PROPERTY

4.B.1. DESCRIPTION

The Helena Valley Aquifer is a consistent water producer in the East Helena area. Depths to the productive zone in the area are likely around 100 feet to 200 feet below ground surface. This alternative includes a new well drilled on the northeast corner of the existing City owned property in the Helena Valley Aquifer. This alternative includes a well pump, a new well house, controls, a chlorine disinfection system, and connecting piping to the distribution system. Chlorine contact time would occur in the piping before the intersection of Plant Road and Montana Avenue. This alternative would provide a new connection point from a water source to the distribution system.

As part of this alternative, Wylie Well #3 would be abandoned and the building demolished. The Agreement between the City and MDT would be terminated and the ROW currently utilized for the well would return to MDT. The chlorination system would be re-located to Wylie Well #2 to better accommodate the flow and operational changes caused by abandonment of Wylie Well #3. This would improve the chlorination system overall as the injection point and sample point for the system are currently buried and cannot be accessed by operators. The existing building at Wylie Well #2 would be modified to include a liquid chlorination system for Wylie Wells #1 and #2. Minor piping changes would be installed to allow metering and chlorination within the building and to prevent some of the problems experienced in the past.

4.B.2. DESIGN CRITERIA

The requirements of the Montana Department of Environmental Quality Circular DEQ-1 would be followed during the design and construction of this alternative.

Table 4.B.1: Summary of Proposed Design Criteria for Alternative 2


System Design Criteria		
Current Population	2,194	
Average Day Demand 2017 (gpd)	423,835 (294 gpm)	
Average Day Demand 2037 (gpd)	564,718 (392 gpm)	
Target Design Year	2037	
2037 Population	2,926	
Maximum Day Demand 2017 (gpd)	1,059,588 (736 gpm)	
Maximum Day Demand 2037 (gpd)	1,411,795 (980 gpm)	
Design Criteria for New Production Well		
Well Target Design Flow	450 gpm	
Estimated Well Depth	Approximately 200 feet	
Well Discharge Diameter	6 inches	
Well Casing	16 inches to 50 feet, 12 inches to 100 feet,	
	and 10 inches to 45 feet	
Well Casing	Steel	
Well Screen	10-inch stainless-steel	
Grouting Requirements	2-inch annulus (minimum) full depth casing	
Chlorination Type	Sodium Hypochlorite with contact time	
Well Pump	8-inch submersible, 75hp	
Well Pump Test Requirements	24 hours	
Design Criteria for Wylie Well #2 Chlorination		
Design Flow	600 to 1,200 gpm	
Chlorination Type	Sodium Hypochlorite with contact time	

4.B.3. MAP

Figure 4.B.1 shows the location of the new well located in the northeast corner of the City's property. The location of Wylie Well #3 (to be abandoned) and Wylie Well #2 (where the chlorine system is to be relocated) are shown in **Figure 1.A.1.**

4.B.4. ENVIRONMENTAL IMPACTS

The proposed well is located outside of the designated East Valley Controlled Groundwater Area designated by the Montana Department of Natural Resources and Conservation (DNRC).



The new well would be located on City owned property where the wastewater treatment facility is also located. However, this is a large parcel of land and a 100-foot control zone would be maintained.

Minor temporary environmental impacts during construction are to be anticipated, however, the construction contract specifications would have requirements to minimize the impacts. The Contractor would be required to obtain all required permits including storm water construction and temporary discharge permits (if required). In general, environmental impacts for this alternative are small.

4.B.5. LAND REQUIREMENTS

The City of East Helena owns the property where the new well would be located. The distribution main would be located within existing utility easements, or City right-of way. The City also owns the property where the new disinfection and pump building will be constructed at Wylie Well #2. Wylie Well #3 is authorized by an occupancy Agreement with MDT. This Agreement would be terminated with the abandonment.

4.B.6. WATER RIGHTS

The location of the new well is in a closed basin, however, the City would be able to transfer the existing water rights from the Wiley Well #3 over to the well proposed for this alternative.

4.B.7. POTENTIAL CONSTRUCTION PROBLEMS

With any well drilling project, there are unknowns and complications are routinely encountered and successfully addressed. The targeted aquifer is relatively shallow and with a shallow drilling depth, some problems become less prevalent. Possible drilling problems include pipe sticking in the hole, lost circulation of drilling fluids, casing alignment problems, pipe failures, borehole collapse, drilling mud contamination, and hole cleaning.

A detailed and well thought out well design would help alleviate problems that may occur with an undersized hole diameter. Construction problems are commonly made part of the Contractors responsibility in the construction specifications. This well depth of about 200 feet is fairly standard in the industry and area, with standard consequential expected risk and associated cost from the Contractor.

Some coordination would be required to maintain water production during the Wylie Well #3 abandonment and to maintain chlorination while the chlorination improvements are constructed at Wylie Well #2.

4.B.8. SUSTAINABILITY CONSIDERATIONS

WATER AND ENERGY EFFICIENCY

Ramp starters on pump would reduce energy consumption. A high-efficiency electrical motor would be utilized. In addition, the City's telemetry system would also help to manage the well pumping requirements efficiently.

GREEN INFRASTRUCTURE

The pump building could be constructed from recyclable materials, regional CMU blocks, and regional wood products. Fly ash used in concrete is another example of recyclable material that can be used and would be specified in the contract documents.

OTHER

The new PVC main would have a life expectancy well over 50 years.

4.B.9. COST

Table 4.B.2 below summarize the cost estimates for this alternative. Detailed cost estimates for this alternative are presented in **Appendix M**. The costs for this alternative are shown separately for construction of the new well, and the abandonment/chlorination relocation. This may be beneficial for project timing and other factors.

Table 4.B.2: Cost Summary for Water Supply Alternative 2 – New Production Well at the Northeast Corner of the City Owned Property

Construction of New Well Cost	\$ 1,345,628
Well Abandonment/Chlorination Relocation Cost	\$ 413,826
Total Project Capital Cost	\$ 1,759,454
Total Annual Operation and Maintenance Cost	\$ 300

Included in this cost estimate are construction contingency of 15%, engineering costs of 18%, and administrative/financial costs of 5%. Also included in the cost estimate is an inflation factor of 3% for the additional time between funding application submittals and actual construction of the project. This inflation is due to the historic volatility of the construction market. A contingency of 15% was used because of the uncertainty associated with the drilling depths of the new well.

4.C. WATER SUPPLY ALTERNATIVE 3 – NEW PRODUCTION WELL AT NORTHWEST CORNER OF CITY OWNED PROPERTY

4.C.1. DESCRIPTION

The Helena Valley Aquifer is a consistent water producer in the East Helena area. Depths to the productive zone in the area are likely around 100 feet to 200 feet below ground surface. This alternative includes a new well drilled on the northwest corner of the existing City owned property in the Helena Valley Aquifer. This alternative includes a well pump, a new well house, and connecting piping to the distribution system. A well at this location would connect to the Wylie transmission main and utilize the existing chlorination system at Wylie Well #3.

4.C.2. DESIGN CRITERIA

The requirements of the Montana Department of Environmental Quality Circular DEQ-1 would be followed during the design and construction of this alternative.

Table 4.C.1: Summary of Proposed Design Criteria for Alternative 3

System Design Criteria	
Current Population	2,194
Average Day Demand 2017 (gpd)	423,835 (294 gpm)
Average Day Demand 2037 (gpd)	564,718 (392 gpm)
Target Design Year	2037
2037 Population	2,926
Maximum Day Demand 2017 (gpd)	1,059,588 (736 gpm)
Maximum Day Demand 2037 (gpd)	1,411,795 (980 gpm)
Design Criteria	
Well Target Design Flow	450 gpm
Estimated Well Depth	Approximately 200 feet
Well Discharge Diameter	6 inches
Well Casing	16 inches to 50 feet, 12 inches to 100 feet,
	and 10 inches to 45 feet
Well Casing	Steel
Well Screen	10-inch stainless-steel
Grouting Requirements	2-inch annulus (minimum) full depth casing
Chlorination	Sodium Hypochlorite with contact time
Well Pump	8-inch submersible, 75hp
Well Pump Test Requirements	24 hours

4.C.3. MAP

Figure 4.C.1 shows the location of the new well located in the northwest corner of the City's property.



4.C.4. ENVIRONMENTAL IMPACTS

This new well would not be located within the East Valley Groundwater Controlled Area for Lewis and Clark County.

The new well would be located on City owned property where the wastewater treatment facility is also located. However, this is a large parcel of land and a 100-foot control zone would be maintained.

Minor temporary environmental impacts during construction are to be anticipated, however, the construction contract specifications would have requirements for the construction contractor to minimize the impacts. The Contractor would be required to obtain all required permits including storm water construction and temporary discharge permits (if required). In general, environmental impacts for this alternative are small.

4.C.5. LAND REQUIREMENTS

The City of East Helena owns the property where the new well would be located. The transmission main would be located in existing utility easements.

4.C.6. WATER RIGHTS

The location of the new well is in a closed basin, however, the City would be able to transfer the existing water rights from the Wiley Well #3 over to the well proposed for this alternative.

4.C.7. POTENTIAL CONSTRUCTION PROBLEMS

With any well drilling project there are unknowns and complications are routinely encountered and successfully addressed. The targeted aquifer is relatively shallow and with a shallow drilling depth, some problems become less prevalent. Possible drilling problems include pipe sticking in the hole, lost circulation of drilling fluids, casing alignment problems, pipe failures, borehole collapse, drilling mud contamination, and hole cleaning.

4.C.8. SUSTAINABILITY CONSIDERATIONS

WATER AND ENERGY EFFICIENCY

Ramp starters on pumps would reduce energy consumption. High-efficiency electrical motors would be specified for the pumps. In addition, the City's telemetry system would also help to manage the well pumping requirements efficiently.

This alternative would save energy by utilizing the current disinfection system.

GREEN INFRASTRUCTURE

The pump building could be constructed from recyclable materials, regional CMU blocks, and regional wood products. Fly ash used in concrete is another example of recyclable material that can be used and would be specified in the contract documents.

OTHER

The new PVC main would have a life expectancy well over 50 years.

4.C.9. COST

Table 4.C.2 below summarizes the cost estimate for this alternative. A detailed cost estimate for this alternative is presented in **Appendix M**.

Table 4.C.2: Cost Summary for Water Supply Alternative 3 – New Production Well at the Northwest Corner of the City Owned Property

Total Project Cost	\$ 1,102,742
Total Annual Operation and Maintenance Cost	\$ 300

Included in this cost estimate are construction contingency of 15%, engineering costs of 20%, and administrative/financial costs of 5%. Also included in the cost estimate is an inflation factor of 3% for the additional time between funding application submittals and actual construction of the project. This inflation is due to the historic volatility of the construction market. A contingency of 15% was used because of the uncertainty associated with the drilling depths of the new well.

4.D. WATER SUPPLY ALTERNATIVE 4 – CAISSON PROTECTION AND LEVEL MONITORING IMPROVEMENTS

4.D.1. DESCRIPTION

The City relies on the McClellan source consisting of two radial wells, caissons, and submersible pumps to supply water to the McClellan tanks and eventually to the City's distribution system. A water shortage in Radial Well #1 (Summer 2017) as well as high water levels constituting a health risk at both Radial Well #1 and Radial Well #2 (Spring 2018) have been noted by City personnel.

This alternative includes measures to improve sanitary conditions and continuously monitor caisson water levels. Improvements would include removing the existing subfloor and installing a new floor slightly above finished grade. A small building would be constructed over the caisson to be better protect the water collected therein. The pumps currently utilized at the radial wells are the original pumps (1987 installation) and would be replaced concurrently with this work. These could be either submersible, as utilized now, or vertical turbine pumps, as used in the Wylie system.

This alternative also includes installation of a transducer to continuously monitor the water level in the caissons to be connected to the City's SCADA system. This will allow City personnel to monitor seasonal water level changes in the wells and better address, manage, and study water levels at this source.

4.D.2. DESIGN CRITERIA

The requirements of the Montana Department of Environmental Quality Circular DEQ-1 would be followed during the design and construction of this alternative.

4.D.3. MAP

Figure 1.A.1 in **Chapter 1** shows the location of the McClellan source radial wells.

4.D.4. ENVIRONMENTAL IMPACTS

Minor temporary environmental impacts during construction are to be anticipated, however, the construction contract specifications would have requirements for the construction contractor to minimize the impacts. The Contractor would be required to obtain all required permits including storm water construction and temporary discharge permits (if required). In general, environmental impacts for this alternative are small.

4.D.5. LAND REQUIREMENTS

The City owns the land where the radial wells are located. Well improvements will be conducted within the City's property boundaries.

4.D.6. WATER RIGHTS

The City owns water rights for the existing radial wells. This alternative will not affect current water rights and will not require additional water rights to be obtained.

4.D.7. POTENTIAL CONSTRUCTION PROBLEMS

Problems that could arise during construction include:

- Working in a confined space.
- Failure of other radial well during construction.

The contractor would be responsible for keeping the community supplied with water. At least one of the radial wells will need to remain in service while the other radial well improvements are underway.

There are no other construction problems anticipated for this alternative. However, construction projects can generate unforeseen difficulties that cannot be predicted prior to construction. Construction problems that may arise in the field would be promptly addressed and remedied.

4.D.8. SUSTAINABILITY CONSIDERATIONS

WATER AND ENERGY EFFICIENCY

Ramp starters on pumps would reduce energy consumption. Current motor starting is "across the line". High-efficiency electrical motors would be specified for the pumps. In addition, the City's telemetry system would also help to manage the well pumping requirements efficiently.

GREEN INFRASTRUCTURE

The pump building could be constructed from recyclable materials and regional wood products. Fly ash used in concrete is another example of recyclable material that can be used and would be specified in the contract documents.

OTHER

The vertical submersible pump will have a life expectancy of 20 years.

4.D.9. COST

Table 4.D.1 below summarizes the cost estimate for this alternative. A detailed cost estimate for this alternative is presented in **Appendix M**. This estimate assumes that improvements for the Telemetry System (**Section 4.M.**) are being constructed/implemented and allow transducer water level information to be incorporated into the City's SCADA System.

Table 4.D.1: Cost Summary for the Radial Well Source Improvements

Total Project Cost	\$ 649,178
Total Annual Operation and Maintenance Cost	\$0

Included in this cost estimate are construction contingency of 15%, engineering costs of 20%, and administrative/financial costs of 5%. Also included in the cost estimate is an inflation factor of 3% for the additional time between funding application submittals and actual construction of the project. This inflation is due to the historic volatility of the construction market. A contingency of 15% is due to some uncertainty at the time the cost estimate was completed.

4.E. WATER SUPPLY ALTERNATIVE 5 – CAISSON ACCESS HATCH IMPROVEMENTS AND PUMPING MANAGEMENT

4.E.1. DESCRIPTION

The City relies on the McClellan source consisting of two radial wells, caissons, and submersible pumps to supply water to the McClellan tanks and eventually the City's distribution system. A water shortage in Radial Well #1 (Summer 2017) as well as high water levels constituting a health risk at both Radial Well #1 and Radial Well #2 (Spring 2018) have been noted by City personnel.

To improve sanitary conditions, improvements include installing better hatches that provide a better seal at the top of the caisson and at the subfloor. The upper hatch would prevent entry from mice, insects, or other small creatures. The subfloor hatch would better exclude mud and other debris brought in during inspections and other times the upper hatch may be open. The pumps currently utilized at the radial wells are the original pumps (1987 installation) and would be replaced concurrently with submersible turbine pumps.

This alternative also includes installation of a transducer to continuously monitor the water level in the caissons to be connected to the City's SCADA system. This will allow for City personnel to monitor seasonal water level changes in the wells and better address, manage, and study water levels in this area.

This Alternative includes management of the caisson levels and assumes the improvements for the Telemetry System (Section 4.M.) are being constructed/implemented and allow caisson water level information to be incorporated into the City's SCADA System. The hatches included in this alternative could not be relied upon to prevent water from flowing up through the hatch onto the subfloor. Alarms would be configured to alert operators before water reaches the subfloor. It is estimated (but not known for all events) that the water level in the caisson could be lowered and maintained below the subfloor by continuous pumping. The highwater alarms would trigger continuous pumping. During these events, this may require the Wylie system be temporarily shut off (all water during this period being supplied by the radial wells). These events also might dictate that some water be lost and overflow from the McClellan Tank.

4.E.2. DESIGN CRITERIA

The requirements of the Montana Department of Environmental Quality Circular DEQ-1 would be followed during the design and construction of this alternative.

4.E.3. MAP

Figure 1.A.1 in Chapter 1 shows the location of the McClellan source radial wells.

4.E.4. ENVIRONMENTAL IMPACTS

Minor temporary environmental impacts during construction are to be anticipated, however, the construction contract specifications would have requirements for the construction contractor to minimize the impacts. The Contractor would be required to obtain all required permits including storm water construction and temporary discharge permits (if required). In general, environmental impacts for this alternative are small.

4.E.5. LAND REQUIREMENTS

The City owns the land where the radial wells are located. Well improvements will be conducted within the City's property boundaries.

4.E.5.1. WATER RIGHTS

The City owns water rights for the existing radial wells. This alternative will not affect current water rights and will not require additional water rights to be obtained.

4.E.6. POTENTIAL CONSTRUCTION PROBLEMS

Problems that could arise during construction include:

- Working in a confined space.
- Failure of other radial well during construction.

The contractor would be responsible for keeping the community supplied with water. At least one of the radial wells will need to remain in service while the other radial well improvements are underway.

There are no other construction problems anticipated for this alternative. However, construction projects can generate unforeseen difficulties that cannot be predicted prior to construction. Construction problems that may arise in the field would be promptly addressed and remedied.

4.E.7. SUSTAINABILITY CONSIDERATIONS

WATER AND ENERGY EFFICIENCY

Ramp starters on pumps would reduce energy consumption. Current motor starting is "across the line". High efficiency electrical motors would be specified for the pumps. In addition, the City's telemetry system would also help to manage the well pumping requirements efficiently.

GREEN INFRASTRUCTURE

There are no green infrastructure considerations with this alternative.

OTHER

The submersible turbine pump will have a life expectancy of 20 years.

4.E.8. COST

Table 4.E.1 below summarizes the cost estimate for this alternative. A detailed cost estimate for this alternative is presented in **Appendix M**. This estimate assumes that improvements for the Telemetry System (**Section 4.M.**) are being constructed/implemented and allow water level transducer level information to be incorporated into the City's SCADA System.

Table 4.E.1: Cost Summary for the Radial Well Source Improvements

Total Project Cost	\$ 216,598
Total Annual Operation and Maintenance Cost	\$0

Included in this cost estimate are construction contingency of 15%, engineering costs of 20%, and administrative/financial costs of 5%. Also included in the cost estimate is an inflation factor of 3% for the additional time between funding application submittals and actual construction of the project. This inflation is due to the historic volatility of the construction market. A contingency of 15% is due to some uncertainty at the time the cost estimate was completed.

4.F. WATER STORAGE ALTERNATIVE 1 – NO-ACTION

4.F.1. DESCRIPTION

As stated in **Chapter 2**, the two McClellan storage tanks are leaking and deteriorating. The existing piping and valves for these structures are not operable. This no-action alternative would not address these issues. Therefore, the <u>No-Action Alternative</u> is eliminated from <u>further discussion in this document</u>

4.G. WATER STORAGE ALTERNATIVE 2 – REPLACE MCCLELLAN STORAGE TANKS WITH ONE 1,000,000-GALLON PRE-STRESSED CONCRETE STORAGE TANK

4.G.1. DESCRIPTION

This alternative includes the construction of a new 96-foot diameter, 1,000,000-gallon, prestressed concrete storage tank with new inlet, outlet, and overflow piping and valves. The new tank would be constructed north of the McClellan storage tanks on the City's existing property. The property would need to be re-fenced to include the new tank. The existing McClellan concrete storage tanks would be filled with earth and abandoned-in-place.

4.G.2. DESIGN CRITERIA

The requirements of the Montana Department of Environmental Quality Circular DEQ-1 would be followed during the design and construction of this alternative.

The tank structure has a standard spread footing, 6-inch membrane floor slab, wall footing, concrete roof, biaxially compressed pre-stressed tank walls, and shotcrete exterior. A shallow foundation is assumed for cost estimating purposes. Also, included are typical tank appurtenances such as a vent, 4 feet x 8 feet hatch, 6-inch roof sleeves, additional hatches, and handrails, etc.

The tank would be built with the same overflow elevation as the existing tanks to maintain equal pressure within the distribution system. New telemetry and controls would be installed to ensure the tank remains full and that pumps are turned off and on as needed.

There should not be any additional O&M requirements. This alternative should decrease O&M because of the decrease leakage. The new tank would require periodic cleaning (3-5 years) as is required with the existing tanks.

Additional design values for this alternative is shown in **Table 4.G.1** below.

ItemDesign ValueTank Floor and WallsPre-Stressed ConcreteTank RoofConcreteTank Volume1,000,000 gallonsTank Diameter96 ftTank Height18.5 ft

Table 4.G.1: Design Values for 1,000,000-gallon Pre-Stressed Storage Tank

4.G.3. MAP


Figure 4.G.1 shows the new 1,000,000-gallon pre-stressed concrete storage tank location.

4,096 ft

4.G.4. ENVIRONMENTAL IMPACTS

Overflow Elevation

There are very few environmental considerations associated with this alternative. The primary environmental impact during construction for this alternative is the surface disturbance and restoration around the tank site. The negative environmental considerations associated with this alternative would primarily be in the short-term, resulting from the construction activities required. However, these impacts would only be temporary, and the construction sites would be returned to existing or improved conditions.



The contractor must obtain any permits required for discharge of water during construction. The contractor is also required to provide dust control during construction excavation to minimize impacts on air quality.

4.G.5. LAND REQUIREMENTS

The City of East Helena owns the land at the site of the existing McClellan tanks where the new tank is to be constructed. A construction easement from the adjacent land owner may be required.

The City's property is not currently fenced in its entirety. In order to abandon-in-place the existing tanks and construct a new tank on the City's property, the fencing for the property would need to be extended or re-fenced.

4.G.6. POTENTIAL CONSTRUCTION PROBLEMS

Problems that could arise during construction include:

- Working in a confined space.
- Failure of another concrete water tank during construction.

The contractor would be responsible for keeping the community supplied with water. At least one of the McClellan tanks may need to remain in service while the new tank is built. The new tank would be brought on-line after successful completion of all required testing and inspection.

There are no other construction problems anticipated for this alternative. However, construction projects can generate unforeseen difficulties that cannot be predicted prior to construction. Construction problems that may arise in the field would be promptly addressed and remedied.

4.G.7. SUSTAINABILITY CONSIDERATIONS

WATER AND ENERGY EFFICIENCY

Installation of a new tank to replace the existing concrete tanks would conserve water and energy wasted due to the leakage at the tanks. Currently water is being pumped and lost at a rate of approximately 44,000 gallons per day (16 million gallons annually).

GREEN INFRASTRUCTURE

To the extent possible, recyclable materials like fly ash can be used in the construction of the tank in products like the concrete.

OTHER

The new concrete tank is expected to last at least 70 years or more.

4.G.8. COST

Table 4.G.2 below summarizes the cost estimate for this alternative. A detailed cost estimate for this alternative is presented in **Appendix M**. There would be no additional annual O&M costs to maintain a new 1,000,000-gallon pre-stressed concrete tank since it would be replacing the existing two McClellan tanks that are already being maintained by the City. In fact, the O&M cost would decrease with the replacement of two aging and leaking tanks to one new tank.

Table 4.G.2: Cost Estimate for Water Storage Alternative 2 – Replace McClellan Storage Tanks with One 1,000,000-Gallon Pre-Stressed Concrete Storage Tank

Total Project Cost	\$ 3,383,014
Total Annual Operation and Maintenance Cost	\$0

Included in this cost estimate are construction contingency of 15%, engineering costs of 18%, and administrative/financial costs of 5%. Also included in the cost estimate is an inflation factor of 3% for the additional time between funding application submittals and actual construction of the project. This inflation is due to the historic volatility of the construction market. A contingency of 15% is due to some uncertainty at the time the cost estimate was completed.

4.H. WATER STORAGE ALTERNATIVE 3 – REPLACE MCCLELLAN STORAGE TANKS WITH ONE 1,000,000-GALLON GLASS-FUSED-TO-STEEL BOLTED TANK

4.H.1. DESCRIPTION

This alternative includes the construction of a new 96-foot diameter, 1,000,000-gallon buried round glass-fused-to-steel steel tank with new inlet, outlet, and overflow piping and valves. The new tank would be constructed north of the McClellan storage tanks on the City's existing property. The property would need to be re-fenced to include the new tank. The existing McClellan concrete storage tanks would be filled and abandoned-in-place. Glass-fuse-to-steel tanks cannot be buried and therefore, would require excavation and possibly a retaining wall around the tank.

4.H.2. DESIGN CRITERIA

The requirements of the Montana Department of Environmental Quality Circular DEQ-1 would be followed during the design and construction of this alternative.

This type of tank is constructed using a multi-step process to create the glass-fused-to-steel technology system. Fabricated sheets of steel are grit blasted to a uniform, near white surface. A sprayable slurry of borosilicate, minerals, water, and clays mixed together are fused to the steel sheets to produce the glossy glass finish. The molten glass reacts with the profiled steel surface to form an inert, inorganic chemical and mechanical bond. Floors and walls are all glass-fused-to-steel. Each glass-fused-to-steel panel is bolted and sealed into place. Roofs can

be glass-fused-to-steel or aluminum geodesic domes. Both are free span and do not require columns to support the weight.

The tank never needs painting and would not corrode or rust. The tank would not rely on any coating as a part of the water tightness. New sealant should be applied to the tank interior and exterior every 20 years.

The new tank would be with the same overflow elevation as the existing tanks to maintain the same pressure within the distribution system. New telemetry and controls would be installed to ensure the tank remains full and that pumps are turned off and on as needed.

This alternative should not require any more time of the operator than the existing tanks currently do. O&M requirements should increase slightly initially because sealant on the inside and outside of the tank would need to be re-applied every 20 years.

Additional design values for this alternative is shown in **Table 4.H.1** below.

Table 4.H.1: Design Values for 1,000,000-gallon Glass-Fused-to-Steel Bolted Tank

Item	Design Value
Tank Floor and Walls	Glass-Fusted-to-Steel
Tank Roof	Glass-Fused-to-Steel or Aluminum Geodesic Dome
Tank Volume	1,000,000 gallons
Tank Diameter	96 feet
Tank Height	18.5 feet
Overflow Elevation	4,096 feet


4.H.3. MAP

Figure 4.H.1 shows the new glass-fused-to-steel bolted tank location.

4.H.4. ENVIRONMENTAL IMPACTS

There are very few environmental considerations associated with this alternative. The primary environmental impact during construction for this alternative is the surface disturbance and restoration around the tank site. The negative environmental considerations associated with this alternative would primarily be in the short-term, resulting from the construction activities required. However, these impacts would only be temporary, and the construction sites would be returned to existing or improved conditions.

The contractor must obtain any permits required for discharge of water during construction. The contractor is also required to provide dust control during construction to minimize impacts on air quality.



Water Storage Alternative 3 - Replace McClellan Storage Tanks with One 1,000,000-Gallon Glass-Fused-To-Steel Bolted Storage Tank

Robert Peccia & Associates

4.H.5. LAND REQUIREMENTS

The new tank would be located on property owned by the City. Adjacent land would be disturbed due to the excavation required. A construction easement from the adjacent land owner is required. Retaining walls could allow adjacent lands to be returned to their original condition.

The City's property is not currently fenced in its entirety. In order to abandon-in-place the existing tanks and construct a new tank on the City's property, the fencing for the property would need to be extended or re-fenced.

4.H.6. POTENTIAL CONSTRUCTION PROBLEMS

Problems that could arise during construction include:

- Working in a confined space.
- Failure of another concrete water tank during construction.

The contractor would be responsible for keeping the community supplied with water. At least one of the McClellan tanks may need to remain in service while the new tank is built. The new tank would be brought on line after successful completion of all required testing and inspection.

There are no other construction problems anticipated for this alternative. However, construction projects can generate unforeseen difficulties that cannot be predicted prior to construction. Construction problems that may arise in the field would be promptly addressed and remedied.

4.H.7. SUSTAINABILITY CONSIDERATIONS

WATER AND ENERGY EFFICIENCY

Installation of a new tank to replace the existing concrete tanks would conserve water and energy wasted due to the leakage at the tanks. Currently, water is being pumped and lost at a rate of approximately 44,000 gallons per day.

GREEN INFRASTRUCTURE

To the extent possible, recyclable materials like fly ash can be used in the construction of the tank in products like the concrete.

4.H.8. COST

Table 4.H.1 below summarizes the cost estimate for this alternative. A detailed cost estimate for this alternative is presented in **Appendix M**. There would be a slight annual O&M cost to maintain a new 1,000,000-gallon glass-fused-to-steel tank. Resealing every 20 years is required for the glass-fused-steel tanks and is included in the cost estimate.

Table 4.H.2: Cost Estimate for Water Storage Alternative 3 – Replace McClellan Storage Tanks with One 1,000,000-Gallon Glass-Fused-to-Steel Bolted Tank

Total Project Cost	\$ 4,336,105
Total Annual Operation and Maintenance Cost	\$ 3,000

Included in this cost estimate are construction contingency of 15%, engineering costs of 18%, and administrative/financial costs of 5%. Also included in the cost estimate is an inflation factor of 3% for the additional time between funding application submittals and actual construction of the project. This inflation is due to the historic volatility of the construction market. A contingency of 15% is due to some uncertainty at the time the cost estimate was completed.

4.I. WATER DISTRIBUTION ALTERNATIVE 1 – NO-ACTION

4.I.1. DESCRIPTION

The no-action alternative for the distribution system improvements was <u>eliminated from consideration</u> because it does not address the issues within the water distribution system. The remaining distribution system alternatives were not compared as they address different issues including: reconnection of the Main Street stream crossing is critical to conveying water from one side of the City to the other; looping of the distribution system at Manlove to address a dead-end main and inadequate fire flow; and looping of the distribution system at 1st Street to eliminates a dead-end main.

4.J. WATER DISTRIBUTION ALTERNATIVE 2 – MAIN STREET STREAM CROSSING

4.J.1. DESCRIPTION

The City's distribution system is divided by Prickly Pear Creek which flows through the center of the City. This alternative reconnects the water main on Main Street that ran below Prickly Pear Creek due to its exposure in the stream and its condition. This main was a critical piece of infrastructure in that it provided a crossing to convey water from one side of town to the other. There are only 3 places where mains cross the stream. Those crossings allow Wylie water to get to the east side of the City and McClellan water to the west side. If one of these sources is lost or out of service, the stream crossing at Main Street is critical to maintaining reliable service.

Dead-end water mains can lead to low pressure, inadequate fire flow, and stagnant water that allow inorganic sediments to deposit, organic matter to accumulate, and allow biofilm and other organisms to grow. These organisms can deplete the available oxygen which in turn causes anaerobic conditions. Anaerobic conditions cause corrosion issues in mains and potentially serious odor problems.

4.J.2. DESIGN CRITERIA

The requirements of the Montana Department of Environmental Quality Circular DEQ-1 would be followed during the design and construction of this alternative.

This alternative involves installing a new 8-inch PVC water main to reconnect the main under Prickly Pear Creek on Main Street by directional drilling. A 10-inch HDPE casing pipe is assumed.

4.J.3. MAP

Figure 4.J.1 shows the location of the Main Street Stream Crossing improvements.

4.J.4. ENVIRONMENTAL IMPACTS

The creek crossing at Prickly Pear would need to be directional drilled in order to minimize impacts to the open stream. The piping would have adequate cover to prevent exposure.

The negative environmental considerations associated with this alternative would primarily be in the short-term, resulting from the construction activities required such as noise and dust. However, these impacts would only be temporary, and the construction sites would be returned to existing or improved conditions. The contractor would be required to implement noise and dust control measures.


4.J.5. LAND REQUIREMENTS

The main reconnection would not require an additional easement or land as it would be placed in the right-of-way near the location of the old main. Main Street is under jurisdiction of Montana Department of Transportation (MDT) and would require a Utility Occupancy Permit from the MDT.

A Joint Application for Proposed Work in Montana's Streams, Wetlands, Floodplains, and Other Water Bodies would need to be submitted to obtain a SPA 124 permit from Montana Fish, Wildlife and Parks and a 404 permit from the Army Corps of Engineers as well as a Floodplain Development Permit from the City of East Helena's Floodplain Administrator.

4.J.6. POTENTIAL CONSTRUCTION PROBLEMS

There are very few construction problems associated with this alternative. Isolation of sections of the existing system may present a small problem during construction. Portions of the distribution system may need to be shut down temporarily to facilitate the installation of new mains, valves, and services. The Contractor would be responsible for coordinating these shutdowns with both the operator and the consumers that would be impacted and provide temporary water for long disruptions in service. This roadway is under the jurisdiction of the



Planning And Design For Future Generations

Robert Peccia & Associates
CVIL ENGINEERING | TRANSPORTATION | SURVEYING | LANDSCAPE ARCHITECTURE
Helena, M.T. Kalispell, M.T. Fort Collins, CO

Figure 4.J.1.
Water Distribution Alternative 2:
Main Street Stream Crossing

Montana Department of Transportation (MDT) and construction would need to be coordinated with MDT.

There are no other construction problems anticipated for this alternative. However, construction projects can generate unforeseen difficulties that cannot be predicted prior to construction. Construction problems that may arise in the field would be promptly addressed and remedied.

4.J.7. SUSTAINABILITY CONSIDERATIONS

WATER AND ENERGY EFFICIENCY

Looping the distribution system and eliminating dead-ends would increase the efficiency of the water distribution system.

GREEN INFRASTRUCTURE

There are no green infrastructure considerations with this alternative.

OTHER

PVC has a life expectancy of well over 70 years.

4.J.8. COST

Table 4.J.1 below summarizes the cost estimate for this alternative. A detailed cost estimate for this alternative is presented in **Appendix M**.

Table 4.J.1: Cost Summary for Main Street Stream Crossing

Total Project Cost	\$ 214,833
Total Annual Operation and Maintenance Cost	\$ 660

Included in this cost estimate are construction contingency of 15%, engineering costs of 18%, and administrative/financial costs of 5%. Also included in the cost estimate is an inflation factor of 3% for the additional time between funding application submittals and actual construction of the project. This inflation is due to the historic volatility of the construction market. A contingency of 15% is due to some uncertainty at the time the cost estimate was completed.

4.K. WATER DISTRIBUTION ALTERNATIVE 3 – LOOP DISTRIBUTION SYSTEM AT MANLOVE

4.K.1. DESCRIPTION

The 4-inch water main on Manlove dead-ends at the American Chemet Complex. The City reports inadequate fire flows at this location. DEQ requires a 6-inch minimum diameter for water mains.

Dead-end water mains can lead to low pressure, inadequate fire flow, and stagnant water that allow inorganic sediments to deposit, organic matter to accumulate, and allow biofilm and other organisms to grow. These organisms can deplete the available oxygen which in turn causes anaerobic conditions. Anaerobic conditions cause corrosion issues in mains and potentially serious odor problems.

4.K.2. DESIGN CRITERIA

The requirements of the Montana Department of Environmental Quality Circular DEQ-1 would be followed during the design and construction of this alternative.

4.K.3. MAP

Figure 4.K.1 shows the location of the Manlove looping alternative.

4.K.4. ENVIRONMENTAL IMPACTS


There are very few environmental considerations associated with this alternative. The negative environmental considerations associated with this alternative would primarily be in the short-term, resulting from the construction activities required such as noise and dust. However, these impacts would only be temporary, and the construction sites would be returned to existing or improved conditions. The contractor would be required to implement noise and dust control measures.

4.K.5. LAND REQUIREMENTS

This new main would not require additional easements or land but would, however, require a Utility Occupancy Permit from the Montana Department of Transportation and a utility permit with Montana Rail Link.

4.K.6. POTENTIAL CONSTRUCTION PROBLEMS

There are very few construction problems associated with this alternative. Isolation of sections of the existing water system may present a small problem during construction. Portions of the distribution system may need to be shut down temporarily to facilitate the installation of new mains, valves, and services. The Contractor would be responsible for coordinating these



0 250 500

Planning And Design For Future Generations

Robert Peccia & Associates

OVIL ENGINEERING | TRANSFORTATION | SURVEYING | LAUNGAPE ARCHITECTURE

Figure 4.K.1.
Water Distribution Alternative 3:
Loop Distribution System at Manlove

shutdowns with both the operator and the consumers that would be impacted and provide temporary water for long disruptions in service. The project would require consultation with Montana Rail Link as well as the Montana Department of Transportation.

There are no other construction problems anticipated for this alternative. However, construction projects can generate unforeseen difficulties that cannot be predicted prior to construction. Construction problems that may arise in the field would be promptly addressed and remedied.

4.K.7. SUSTAINABILITY CONSIDERATIONS

WATER AND ENERGY EFFICIENCY

Looping the distribution system and eliminating dead-ends would increase the efficiency of the water distribution system.

GREEN INFRASTRUCTURE

There are no green infrastructure considerations with this alternative.

OTHER

PVC has a life expectancy of well over 50 years.

4.K.8. COST

Table 4.K.1 below summarizes the cost estimate for this alternative. A detailed cost estimate for this alternative is presented in **Appendix M**.

Table 4.K.1: Cost Summary for Water Distribution Alternative 3 – Loop Distribution Manlove

Total Project Cost	\$ 589,380
Total Annual Operation and Maintenance Cost	\$ 660

Included in this cost estimate are construction contingency of 15%, engineering costs of 20%, and administrative/financial costs of 5%. Also included in the cost estimate is an inflation factor of 3% for the additional time between funding application submittals and actual construction of the project. This inflation is due to the historic volatility of the construction market. A contingency of 15% is due to some uncertainty at the time the cost estimate was completed.

4.L. WATER DISTRIBUTION ALTERNATIVE 4 – ELIMINATE DEAD-END AT IST STREET AND WEST GROSCHELL STREET

4.L.1. DESCRIPTION

The City of East Helena a dead-end main located on 1st Street between Gail Street and West Groschell Street.

Dead-end water mains can lead to low pressure, inadequate fire flow, and stagnant water that allow inorganic sediments to deposit, organic matter to accumulate, and allow biofilm and other organisms to grow. These organisms can deplete the available oxygen which in turn causes anaerobic conditions. Anaerobic conditions cause corrosion issues in mains and potentially serious odor problems.

4.L.2. DESIGN CRITERIA

The requirements of the Montana Department of Environmental Quality Circular DEQ-1 would be followed during the design and construction of this alternative.

4.L.3. MAP

Figure 4.L.1 shows the location of this alternative.

4.L.4. ENVIRONMENTAL IMPACTS


There are very few environmental considerations associated with this alternative. The negative environmental considerations associated with this alternative would primarily be in the short-term, resulting from the construction activities required such as noise and dust. However, these impacts would only be temporary, and the construction sites would be returned to existing or improved conditions. The contractor would be required to implement noise and dust control measures.

4.L.5. LAND REQUIREMENTS

The new main would be located in City right-of-way and would not require additional land or easements.

4.L.6. POTENTIAL CONSTRUCTION PROBLEMS

There are very few construction problems associated with this alternative. Isolation of sections of the existing water system may present a small problem during construction. Portions of the distribution system may need to be shut down temporarily to facilitate the installation of new mains, valves, hydrants, and services. The Contractor would be responsible for coordinating these shutdowns with both the operator and the consumers that would be impacted and provide temporary water for long disruptions in service.



0 250 500

Robert Peccia & Associates

Figure 4.L.1.

Water Distribution Alternative 4:
Eliminate Dead End at 1st Street and West Groschell St

There are no other construction problems anticipated for this alternative. However, construction projects can generate unforeseen difficulties that cannot be predicted prior to construction. Construction problems that may arise in the field would be promptly addressed and remedied.

4.L.7. SUSTAINABILITY CONSIDERATIONS

WATER AND ENERGY EFFICIENCY

Looping the distribution system and eliminating dead-ends would increase the efficiency of the water distribution system.

GREEN INFRASTRUCTURE

There are no green infrastructure considerations with this alternative.

OTHER

New PVC mains have a life expectancy well over 50 years.

4.L.8. COST

Table 4.L.1 below summarizes the cost estimate for this alternative. A detailed cost estimate for this alternative is presented in **Appendix M**.

Table 4.L.1: Cost Summary for Water Distribution Alternative 4 – Eliminate Dead-End at 1st Street and West Groschell

Total Project Cost	\$ 144,887
Total Annual Operation and Maintenance Cost	\$ 660

Included in this cost estimate are construction contingency of 15%, engineering costs of 20%, and administrative/financial costs of 5%. Also included in the cost estimate is an inflation factor of 3% for the additional time between funding application submittals and actual construction of the project. This inflation is due to the historic volatility of the construction market. A contingency of 15% is due to some uncertainty at the time the cost estimate was completed.

4.M. MCCLELLAN SOURCE ACCESS

4.M.1. MCCLELLAN SOURCE ACCESS ALTERNATIVE 1 - NO-ACTION

4.M.1.1. DESCRIPTION

In order for the City personnel to access Radial Well #2, they must drive or walk through McClellan Creek. This is unsafe for the City's personnel and causes damage to the creek. The no-action alternative would not allow the City personnel to safely access Radial Well #2 during routine maintenance procedures without damage to the creek. For this reason, the No-Action Alternative is eliminated from further discussion.

4.M.2. MCCLELLAN SOURCE ACCESS ALTERNATIVE 2 – NEW PEDESTRIAN BRIDGE

4.M.2.1. DESCRIPTION

This Alternative includes the construction of a new pedestrian bridge across McClellan Creek between Radial Wells #1 and #2. This would allow City personnel to access Radial Well #2 without having to drive through, or walk through, the Creek during routine maintenance.

The road to access the McClellan source is a poor 2-tract dirt road. The City has elected to use maintenance funds to improve the road and would work together with the adjacent landowner for temporary access to Radial Well #2 in case of emergency or large-scale maintenance event. No costs for these items are included in the project budget.

4.M.2.2. DESIGN CRITERIA

The new bridge would be used for pedestrian traffic only. Access to the bridge would be locked and only available to City personnel.

4.M.2.3. MAP

Figure 4.M.1 shows the location of the radial wells and the proposed pedestrian bridge.

4.M.2.4. ENVIRONMENTAL IMPACTS

A pedestrian bridge across McClellan Creek would allow the City personnel to cross McClellan Creek without causing damage to the creek and is therefore, a benefit to the environment surrounding the Radial Wells. During summer months, operators currently drive vehicles through the stream causing damage to the stream bank, increase turbidity, and cause riparian damage.


4.M.2.5. LAND REQUIREMENTS

The new pedestrian bridge would be installed on City owned property.

A Joint Application for Proposed Work in Montana's Streams, Wetlands, Floodplains, and Other Water Bodies would need to be submitted to obtain a SPA 124 permit from Montana Fish, Wildlife and Parks and a 404 permit from the Army Corps of Engineers as well as a Floodplain Development Permit from Jefferson County's Floodplain Administrator. The permitting process may be difficult for this alternative.

4.M.2.6. POTENTIAL CONSTRUCTION PROBLEMS

Access to the construction site may be slightly difficult do to the condition of the road to the McClellan source.



There are no other construction problems anticipated for this alternative. However, construction projects can generate unforeseen difficulties that cannot be predicted prior to construction. Construction problems that may arise in the field would be promptly addressed and remedied.

4.M.2.7. SUSTAINABILITY CONSIDERATIONS

WATER AND ENERGY EFFICIENCY

The radial wells are located in a remote area and are not inspected on a regular basis. Improving the access to the site would allow City personnel to routinely inspect and maintain the well which would allow the system to run more efficiently.

GREEN INFRASTRUCTURE

Portions of the pedestrian bridge may be constructed with recyclable materials if possible.

4.M.2.8. COST

Table 4.M.1 below summarizes the cost estimate for this alternative. A detailed cost estimate for this alternative is presented in **Appendix M**.

Table 4.M.1: Cost Summary for Infiltration Gallery Access Alternative 2 – New Pedestrian Bridge

Total Project Cost	\$ 107,607
Total Annual Operation and Maintenance Cost	\$ 0

Included in this cost estimate are construction contingency of 15%, engineering costs of 18%, and administrative/financial costs of 5%. Also included in the cost estimate is an inflation factor of 3% for the additional time between funding application submittals and actual construction of the project. This inflation is due to the historic volatility of the construction market. A contingency of 15% is due to some uncertainty at the time the cost estimate was completed.

4.N. TELEMETRY SYSTEM

4.N.3. TELEMETRY SYSTEM ALTERNATIVE 1 - NO-ACTION

4.N.3.1. DESCRIPTION

The City of East Helena relies on the telemetry system to monitor and control the pumps for the water system and to monitor the water levels of each storage tank in the system. Currently, the existing telemetry system is not communicating properly from the radial wells either due to a weak signal or an outdated system. If the existing telemetry system is not upgraded, the City would not be able to monitor their water system properly. For this reason, the No-Action Alternative is eliminated from further discussion.

4.N.4. TELEMETRY SYSTEM ALTERNATIVE 2 – UPGRADE SCADA SYSTEM

4.N.4.1. DESCRIPTION

As stated above, the City relies on the telemetry system to monitor and control the water system pumps and to monitor the water levels of each storage tank in the system. This alternative includes the installation of a new and improved Supervisory Control and Data Acquisition (SCADA) system in order to properly monitor the City's water system pressure, flow, levels, equipment status, etc. The new system should be able to control all pumps for the water system, monitor the system to ensure it is operating properly, and be equipped with alarms for various emergency situations. This equipment would also collect and archive the operational data of the system.

All well facilities, treatment facilities, and storage tanks associated with the City's water system would be retrofitted with the new SCADA telemetry and associated instrumentation and would be connected to the central computer located at the City's wastewater treatment facility.

4.N.4.2. DESIGN CRITERIA


The control telemetry system would be a SCADA (Supervisory Control And Data Acquisition) system used to monitor equipment status; monitor operating parameters; alert operators of alarm conditions and failures; and track trends and changes. The system would include a remote unit at the following locations:

- Each Wylie well;
- Each caisson (assuming improvements as proposed in this document are completed);
- New well building as proposed;
- McClellan tank/chlorination building; and
- Existing 1-million-gallon tank (Highway 282).

A supervisory computer control station would be located at the wastewater treatment facility. Each remote unit would include a Programmable Logic Controller (PLC) and radio with the capability of communicating with the supervisory computer control station. Hardwired inputs (information/status from equipment) and outputs (used to start/stop equipment) would be connected to each remote unit. The supervisory computer would be used to monitor and record operating conditions. The supervisory computer would also be used by City staff to make changes to operating parameters.

4.N.4.3. MAP

The new supervisory computer station and equipment would be located in the footprint of the existing wastewater treatment facility. Remote units located at each well and tank would report to the supervisory computer at the wastewater treatment plant. **Figure 4.N.1** shows the location of the supervisory computer at the wastewater treatment plant facility and each remote unit.



Master Plan - 2018






Figure 4.N.1.
Telemetry System Alternative 2:
Upgrade SCADA System

4.N.4.4. ENVIRONMENTAL IMPACTS

There would be no environmental impacts associated with this alternative.

4.N.4.5. LAND REQUIREMENTS

The new SCADA system would replace the existing system that is currently located in the City's new wastewater treatment plant building. Therefore, no new land requirements would be necessary.

4.N.4.6. POTENTIAL CONSTRUCTION PROBLEMS

There are no other construction problems anticipated for this alternative. However, construction projects can generate unforeseen difficulties that cannot be predicted prior to construction. There is a potential for issues during testing and start-up of the new system.

4.N.4.7. SUSTAINABILITY CONSIDERATIONS

WATER AND ENERGY EFFICIENCY

The installation of new SCADA system would allow for effective management of the water supply which would save on water as well as the operation and maintenance costs of the system.

GREEN INFRASTRUCTURE

There is no green infrastructure associated with this alternative.

OTHER

The installation of new SCADA system would simplify the operations of the water system by allowing the City to have a central location where the water system can be controlled, operated, and monitored with a high degree of efficiency. The new system would allow the operators of the water system correct issues and provide reliable, efficient service.

4.N.4.8. COST

Table 4.N.1 below summarizes the cost estimate for this alternative. A detailed cost estimate for this alternative is presented in **Appendix M**.

Table 4.N.1: Cost Summary for Telemetry System Alternative 2 – Update SCADA System

Total Project Cost	\$ 474,094
Total Annual Operation and Maintenance Cost	\$0

Included in this cost estimate are construction contingency of 15%, engineering costs of 18%, and administrative/financial costs of 5%. Also included in the cost estimate is an inflation factor of 3% for the additional time between funding application submittals and actual construction of the project. This inflation is due to the historic volatility of the construction market. A contingency of 15% is due to some uncertainty at the time the cost estimate was completed.

CHAPTER 5: SELECTION OF AN ALTERNATIVE

In this chapter, the alternatives selected as potentially feasible and cost-effective through the alternatives discussion in **Chapter 4** are compared in further detail. This chapter focuses on the alternative analysis for the East Helena Water System. Please refer to **Chapter 4** for a more detailed discussion of the alternatives presented in this chapter.

5.A. LIFE CYCLE COST ANALYSIS

Table 5.A.1 below shows the life cycle cost analysis for the Alternatives detailed in **Chapter 4**.

Water Supply operation and maintenance (O&M) costs will increase as system demands increase when discussing pumps. Wylie Well #3 will be abandoned and a new well pump of similar horsepower will be installed. Likewise, there is no proposed increase in horsepower for the replacement of the existing pumps within the caissons at the McClellan Source. The cost of pumping will increase proportionally with growth every year and result in an estimated increase of approximately \$20,000 per year for the planning year (2037) based on a 1.45% growth rate. Demands are currently met, and the unit cost for power is generally equal for well pumps discussed in these alternatives. The increase in power cost will be incremental due to growth itself and not a change in the equipment or the effort required to maintain improvements. The O&M costs in this document exclude the incremental cost associated with growth, and focus on any change in the system (such as an addition in length in buried piping).

New chlorine systems are recommended for both the new well and at Wylie Well #2 (relocate from abandonment of Wylie Well #3). This will result in one additional chlorine system for operators to monitor and maintain. However, the chlorine system at existing Wylie Well #3 (to be abandoned) has been quite problematic for operators over the past five years because of the configuration. With new equipment, and the proposed change from gas chlorine to liquid chlorine, the net change in operator effort should be similar (maybe less) that that put forth today. Therefore, no increase for maintenance has been included for this additional chlorine system.

There would be no additional annual O&M costs to maintain a new 1,000,000-gallon prestressed concrete tank since this alternative replaces the existing two McClellan tanks already maintained by the City. In fact, the O&M cost may decrease with the replacement of two aging tanks to one new tank. There would be a slight annual O&M cost to maintain a new 1,000,000gallon glass-fused-to-steel tank. Resealing the tank every 20 years is required for the glassfused-steel tanks and is included in the cost estimate.

5.A.1. TOTAL CAPITAL COST

Refer to **Appendix M** for detailed cost estimates for each alternative. Included in these estimates are a construction contingency cost of 15%, engineering costs of 18%, and

administrative/financial costs of 5%. A contingency of 15% is due to some uncertainty at the time the cost estimate was completed.

5.A.2. INFLATION

An inflation factor of 3% annually was included in the cost estimate due to the historic volatility of the construction market and the time between funding application submittals and the actual construction of the project. The 3% is based on the current March issue of the Engineering News Record (ENR) Magazine's reporting of the annual inflation rate for construction costs. The current rate is 2.7% but is on a steadily increasing trend since January 2018. Therefore, an inflation rate of 3% per year was used for the cost estimates. Construction is expected to occur in 2020, therefore, a 3% inflation rate over 2 years was used.

5.A.3. PRESENT WORTH ANALYSIS

A present worth analysis has been completed for each of the alternatives and is shown in the detailed cost estimates in **Appendix M**. The present worth analysis includes the capital cost, annual O&M cost for each alternative, and a 20-year salvage value. The result is the amount that would have to be invested (in 2020 dollars) at an interest rate of 3.2% to pay for the capital cost and the annual O&M costs, less the salvage value in 20 years.

Table 5.A.1: Alternative Life Cycle Cost Analysis

Alternative	Total Project Cost	O&M	Salvage Value (est.)	Total Net Present Worth (3.2% for 20 years)
One New Well on East Side of City Property; Abandon Wylie Well#3, Chlorine Relocation	\$1,759,454	\$300	\$313,900	\$1,596,651
One New Well on the West Side of City Property	\$1,102,742	\$300	\$189,400	\$1,006,248
Caisson Protection and Level Monitoring Improvements	\$649,178	\$0	\$79,440	\$606,868
Caisson Access Hatch Improvements	\$216,598	\$0	\$0	\$216,598

	T		T	
and Pumping				
Management				
1,000,000-Gallon	\$3,383,014	\$0	\$969,657	\$2,866,569
Pre-Stressed				
Concrete Storage				
Tank				
1,000,000-Gallon	\$4,336,105	\$3,000	\$710,133	\$4,001,702
Glass-Fused-to-				
Steel Storage				
Tank				
Main Street	\$214,833	\$660	\$49,950	\$197,869
Stream Crossing				
Loop Main at	\$589,380	\$660	\$180,540	\$502,863
Manlove				
1 st Street Loop	\$144,887	\$660	\$14,700	\$146,698
McClellan Source	\$107,607	\$0	\$14,000	\$100,151
Access				
Telemetry	\$474,094	\$0	\$0	\$474,094
System				

5.B. NON-MONETARY FACTORS

5.B.1. SUMMARY AND SELECTION OF THE PREFERRED ALTERNATIVE

5.B.1.1. WATER SUPPLY

Table 5.B.1 below ranks each water supply alternative in several categories. Each alternative is ranked from 1 through 5 in each of the categories, with ranking of 1 being the lowest ranking and a 5 being the highest ranking. The ranking is then multiplied by the weight assigned to each criterion by a value between 1 and 3, with 3 having the highest weight and hence, the most importance. The highest score possible for any category would be 15. The ranking table includes both monetary and non-monetary criteria to provide an overall ranking of the alternatives.

The No-Action water supply alternative was eliminated in the screening process. The No-Action alternative does nothing to address the issue of potential contamination to Wylie Well #3 or the McClellan source water level fluctuations. The public health risks associated with not addressing this issue are not responsible.

As shown in **Table 5.B.1**, the two water supply alternatives that address the potential for contamination of Wylie Well #3 scored extremely close. Alternative 2, installation of one new well on the east side of the City's property, scores more favorably in health and safety because it will allow the City to have a separate disinfected water source that could work independently if the Wylie Wells and/or the McClellan sources were not operating for any reason. This would allow two sources to provide water to the City during most circumstances and allow one source

to be off for maintenance or inspection without jeopardizing supply volume. Alternative 3, installation one new well on the west side of the City's property, does have slightly less annual O&M than Alternative 2 since it does not require the additional disinfection system. At the time of this writing, the City of East Helena is pursing funding for Alternative 2 through the Montana Environmental Trust Group (METG). Therefore, this Alternative is not included in the Project Costs outlined in Chapter 7, as the timing and methods for implementation are unknown.

Table 5.B.1: Comparison of Water Supply Alternatives to Address Wylie Well #3

Potential Contamination

Criteria	Criteria Weight		ve 2 – One New ast Side of City		ive 3 – One New West Side of City
Technical Feasibility	2	5	10	5	10
Longevity/Reliability	1	5	5	4	4
Water Quality	2	5	10	5	10
Regulatory Compliance	2	5	10	5	10
Constructability	1	5	5	5	5
Environmental Impacts	1	5	5	5	5
Financial Feasibility	3	5	15	5	15
Operation and Maintenance	2	4	8	5	10
Public Health and Safety	3	5	15	4	12
Land Impact/Availability	1	5	5	5	5
Total			88		86

As shown in **Table 5.B.2**, the alternatives that address the McClellan source, Alternative 4 scored higher than Alternative 5. Alternative 4 more directly addresses the health risks associated with water above the subfloor of the caissons. There if very little history on how much water needs to be pumped to keep the caisson water level below the subfloor. A pumping rate of 500 gpm may or may not be adequate in all circumstances. Alternative 5 would not guarantee that sanitary requirements would be met. Operators stand on this subfloor

currently to perform inspections and maintenance. It would be difficult to ensure that contamination is not brought onto this subfloor through these efforts, and that sanitary conditions would be maintained at the subfloor surface. Also, Alternative 5 could result in water being pumped and wasted as overflow, which is a waste of energy and the water resource. Alternative 4 more directly addresses these concerns by removing the subfloor, which would allow water to rise to any level in the caisson, and modifications would be made so that inspection and maintenance would be performed from the surface rather than require operators to enter the caisson. Alternative 4 includes the construction of buildings and although this is an increased cost, the source water would be better protected from contamination.

Table 5.B.2: Comparison of Water Supply Alternatives for McClellan Source

Criteria	Criteria Weight		_	Access Ir	ve 5 – Caisson nprovements and Management
Technical Feasibility	2	5	10	3	6
Longevity/Reliability	1	5	5	3	3
Water Quality	2	5	10	3	6
Regulatory Compliance	2	5	10	3	6
Constructability	1	5	5	5	5
Environmental Impacts	1	5	5	5	5
Financial Feasibility	3	4	12	5	15
Operation and Maintenance	2	5	10	3	6
Public Health and Safety	3	4	12	3	9
Land Impact/Availability	1	5	5	5	5
Total			84		66

5.B.2. STORAGE TANKS

The No-Action option was disqualified during alternative discussions since it does not address the leakage and deterioration of the existing McClellan storage tanks.

Table 5.B.3 below ranks each water storage alternative in several categories. Each alternative is ranked from 1 through 5 in each of the categories, with ranking of 1 being the lowest ranking and a 5 being the highest ranking. The ranking is then multiplied by the weight assigned to each criterion by a value between 1 and 3, with 3 having the highest weight and hence, the most importance. The highest score possible for any category would be 15. The ranking table includes both monetary and non-monetary criteria to provide an overall ranking of the alternatives.

Table 5.B.3: Comparison of 1,000,000-Gallon Storage Tank Alternatives

Criteria	Criteria Weight	Gallon F	tive 2 – 1,000,000 Pre-Stressed e Storage Tank	Gallon (tive 3 – 1,000,000- Glass-Fused-to- orage Tank
Technical Feasibility	2	5	10	4	8
Longevity/Reliability	1	5	5	3	3
Water Quality	2	5	10	5	10
Regulatory Compliance	2	5	10	5	10
Constructability	1	5	5	3	3
Environmental Impacts	1	5	5	5	5
Financial Feasibility	3	5	15	4	12
Operation and Maintenance	2	5	10	5	10
Public Health and Safety	3	5	15	5	15
Land Impact/Availability	1	5	5	4	4
Total			90		80

Of the two storage tank alternatives, Alternative 3, construction of a glass-fused-to-steel storage tank, scored the lowest due to the amount of excavation that would be required around the tank to maintain the required elevation and utilize the City's current property. This complication adds considerable expense to the construction of the tank. Also, concrete tanks are known to last over 70 years and, though a reliable technology, the glass-fused tank is a relative new technology by comparison.

5.B.3. DISTRIBUTION SYSTEM

The No-Action alternative for the distribution system improvements was eliminated from consideration because it does not address the issues with the water distribution system. The remaining distribution system alternatives were not compared as they address different issues. Alternative 2, reconnection of the Main Street stream crossing, is critical to conveying water from one side of the City to the other and maintain adequate pressure. Alternative 3, loop distribution system at Manlove, addresses the area within the City where the fire flow is extremely inadequate and Alternative 4, loop the distribution system at 1st Street, eliminates a dead-end which can cause pressure issues as well as water quality issues.

5.B.4. MCCLELLAN SOURCE ACCESS

The No-Action alternative for access to the McClellan source access improvements was not compared to the installation of a pedestrian bridge because it does not address the issue the City personnel has in accessing Radial Well #2. Currently, they must walk or drive through Prickly Pear Creek which is difficult during winter months and causes damage to Prickly Pear Creek. The City of East Helena plans to improve the road conditions by allocating funds from their annual operation and maintenance budget.

5.B.5. TELEMETRY SYSTEM

The No-Action alternative for the City's telemetry system improvements was not compared to the installation of a new Supervisory Control and Data Acquisition (SCADA) system because it does not address the issue the City has with its current telemetry system. The existing system is not communicating properly from the radial wells either due to a weak signal or an outdated system and, therefore, the City is unable to monitor the water system properly.

CHAPTER 6: PROPOSED RECOMMENDATIONS

6.A. PRELIMINARY PROJECT DESIGN

6.A.1. WATER SUPPLY

6.A.1.1. WYLIE SOURCE

The preferred water supply alternative for addressing those issues associated with potential contamination of Wylie Well #3, is Alternative 2 – New Production Well at the Northeast Corner of City Owned Property. **The City of East Helena is seeking funding from the Montana Environmental Trust Group (METG) for implementation of this alternative**. This item is not included in the Funding Strategy and is not included in the total project cost of \$5,562,993 included in **Chapter 7**.

This alternative includes a new well drilled in the northeast corner of the City's property targeting 450 gpm in the Helena Valley Aquifer to replace Wylie Well #3. The well will be equipped with a new well pump, a new well house with controls and a chlorine disinfection system, and connecting piping to the distribution system. As part of this alternative, Wylie Well #3 will be grouted and abandoned, the structure demolished, and the Agreement that authorizes the City to utilize the right-of-way with the Montana Department of Transportation (MDT) would be terminated. Improvement to the structure at Wylie Well #2 would be completed, as well as piping improvements to allow chlorination of the Wylie Source at this location. This alternative includes the following items:

- One new well in the Helena Valley Aquifer, approximately 200' deep;
- Fully grouted well casing;
- 75 HP motor, 8-inch diameter pump, motor controls, VFD with ramp start;
- 480 volt 3-phase power source;
- Well control building (approximately 200 SF), insulated, with CMU walls, concrete floor, heating and venting, and a metal roof;
- Interior building piping, flow meter, recorder, pressure gauges, and blow off;
- Sodium hypochlorite disinfection system;
- Disinfection contact time prior to Montana Avenue;
- · Pump testing;
- Site reclamation and gravel access;
- Emergency generator;
- Secure transfer of well water rights from Wylie Well #3;
- Abandon and grout Wylie Well #3;
- A new building at Wylie Well #2 to accommodate additional space for the Wylie source chlorination system (approximately 200 SF), insulated, with CMU walls, concrete floor, heating and venting, and a metal roof;
- Minor piping changes bringing the piping from Wylie Well #1 into the building for chlorination;

- Interior building piping, flow meter, pressure gauges; and
- Sodium hypochlorite disinfection system.

6.A.1.2. MCCLELLAN SOURCE

The preferred water supply alternative is Alternative 4 – Caisson Protection and Level Monitoring Improvements. These improvements include removing the existing subfloor in the caissons and installing a new floor slightly above grade. A small building would be constructed over the top of the caisson to be better protect the water collected therein. The pumps currently utilized at the radial wells are the original pumps (1987 installation) and would be replaced concurrently. These new pumps could be either submersible as utilized now or vertical turbine pumps as used in the Wylie system. The recommended alternative includes:

- Removal of existing subfloor in the both caissons;
- Construction of building over caisson to better protect the water collected;
- Replacement of existing pumps and motor controls. These would be 20 HP, either vertical turbine or submersible; and
- Installation of level monitoring system in both caissons to report continuously to the City's SCADA System.

6.A.2. WATER STORAGE

The preferred storage alternative is Alternative 2 – Replace McClellan Storage Tanks with One 1,000,000-Gallon Pre-Stressed Concrete Storage Tank. This alternative includes the construction of a new 96-foot diameter, 1,000,000-gallon, pre-stressed concrete storage tank with new inlet, outlet, and overflow piping and valves. The new tank would be constructed north of the McClellan storage tanks on the City's existing property. The property would be referced to include the new tank. The existing McClellan concrete storage tanks will be filled with dirt and abandoned-in-place.

6.A.3. DISTRIBUTION SYSTEM

The preferred distribution alternatives include:

- Alternative 2 Main Street Stream Crossing.
- Alternative 3 Loop Distribution System at Manlove.
- Alternative 4 Eliminate Dead-End at 1st Street and West Groschell.

6.A.3.1. MAIN STREET STREAM CROSSING

This alternative includes the re-connection of approximately 50 feet of 8-inch PVC water main that is located on Main Street under Prickly Pear Creek that is critical to conveying water from one side of town to the other. This alternative would also include the installation of a 10-inch HDPE casing pipe under Prickly Pear Creek by direction drilling.

6.A.3.2. LOOP DISTRIBUTION SYSTEM AT MANLOVE

This alternative includes the addition of approximately 300 feet of 6-inch PVC at Manlove that would loop the water distribution system by bore and jack method under the railroad tracks and directional drilling of 8-inch HDPE casing under Highway 12. The addition of this loop would eliminate the dead-end main at Manlove and increase the inadequate fire flows for the building.

6.A.3.3. ELIMINATE DEAD-END AT 1ST STREET AND WEST GROSCHELL

This alternative includes the elimination of the dead-end main at 1st Street and West Groschell by extending the existing 6-inch main on 1st Street from West Groschell to Gail Street. This alternative would also include a new fire hydrant, valves, and pavement removal and replacement.

6.A.4. MCCLELLAN SOURCE ACCESS

The preferred alternative for the McClellan source access is Alternative 2 – New Pedestrian Bridge. This Alternative includes the construction of a new pedestrian bridge across McClellan Creek between Radial Wells #1 and #2. A new pedestrian bridge would allow City personnel to access Radial Well #2 without having to drive, or walk through, the McClellan Creek during routine maintenance.

The road to access the McClellan source is a poor 2-tract dirt road. The City will use maintenance funds to improve the road and will work together with the adjacent landowner on access to Radial Well #2 by vehicle.

6.A.5. TELEMETRY SYSTEM

The preferred alternative for the Telemetry System is Alternative 2 – Upgrade SCADA System. This alternative would replace the existing telemetry system with a new Supervisory Control and Data Acquisition (SCADA) System in order to properly monitor the City's water system pressure, flow, levels, equipment status, etc. The new system will be able to control all pumps for the water system, monitor the system to ensure it is operating properly, and be equipped with alarms for various emergency situations.

All well facilities, treatment facilities, and storage tanks associated with the City's water system will be retrofitted with the new SCADA telemetry and associated instrumentation and will be connected to the central computer located at the City's wastewater treatment facility.

6.B. PROJECT SCHEDULE

See **Table 6.B.1** below for the proposed project improvements schedule.

Table 6.B.1: Implementation Schedule for the Recommended Alternatives

TASK		20	18			20	19			20	20			20	21	
IASK	1st	2nd	3rd	4th	1st	2nd	3rd	4th	1st	2nd	3rd	4th	1st	2nd	3rd	4th
Adopt Water System PER	Х															
Apply for TSEP and RRGL	Х															
Grant Award						Х										
PROJECT STARTUP																
Preliminary Design							Х									
Final Design							Х	Х	Х							
MDEQ Plan Review and Approval									Х							
PROJECT BIDDING AND AWARD OF I	MPRO	VEMEN	ITS													
Public Bid Advertisement										х						
Open Bids and Examine Proposals										х						
Request Contractor Debarment																
Review										х						
Select Contractor and Award Bid										х						
PROJECT CONSTRUCTION OF IMPRO	VEME	NTS														
Conduct Pre-Construction Meeting										х						
Issue Contractor Notice to Proceed										х						
Submit Compliance Documents										х						
Begin Construction										х						
Monitor Engineer & Contractor										х	Х	Х				
Submit Drawdowns and Progress																
Reports										х	Х	Х				
Hold Construction Progress																
Meetings										х	Х	Х				
Final Inspection												Х				
PROJECT CLOSE OUT OF IMPROVEM	ENTS															
Submit Final Drawdown													Х			
Project Completion Report													Х			
Submit Condition Certification													Х			
Submit Final Certification													Х			
Local Government Audit														Х		
Warranty Inspection																Х

6.C. PERMIT REQUIREMENTS

The following permits will be required for the East Helena Water System Improvements.

- DEQ certified checklist and plans approval. The improvements will specifically comply with Circular DEQ-1.
- Licensed water well Contractor.
- Temporary discharge permit for pump test waters.
- DNRC transfer of Water Rights.
 - Other related DNRC requirements for construction include Well Abandonment Forms; Aquifer Test Data Forms; and Well Log Report Forms.
- Joint Application for Proposed Work in Montana's Streams, Wetlands, Floodplains, and Other Water Bodies.
- Stormwater Permit submitted by the Contractor.

- Floodplain Permits for work in floodplain.
- Application for Pipeline submitted to Montana Rail Link.
- Utility Occupancy Permit submitted to the Montana Department of Transportation.

6.D. SUSTAINABILITY CONSIDERATIONS

6.D.1. WATER AND ENERGY EFFICIENCY

All new buildings will be well insulated to minimize heating and cooling costs.

Ramp starters on the pumps will reduce energy consumption. High-efficiency electrical motors will be specified for the pumps. In addition, the City's telemetry system will also help to manage the well pumping requirements efficiently.

Installation of a new tank to replace the existing concrete tanks will conserve water and energy wasted due to the leakage at the tanks. Currently, water is being pumped and lost at this location (approximately 44,000 gallons per day).

Looping the distribution system and eliminating dead-ends will increase the efficiency of the water distribution system.

6.D.2. GREEN INFRASTRUCTURE

Buildings could be constructed from recyclable materials, regional CMU blocks, and regional wood products.

To the extent possible, recyclable materials like fly ash can also be used in the construction of the new pump building and concrete storage tank.

6.D.3. OTHER

A new concrete tank should last for 70 years or more and new PVC mains have a life expectancy well over 50 years.

6.E. TOTAL PROJECT COST ESTIMATE

The total project cost for the water system improvements are summarized in **Table 6.E.1**. This total excludes recommended Water Supply Alternative 2 – New Production Well at the Northeast Corner of City Owned Property for replacement of Wylie Well #3. The City of East Helena is seeking funding from the Montana Environmental Trust Group (METG) for implementation of this alternative. The total project cost includes the construction, engineering, administration of grants and loans, and contingency. Detailed cost estimates are located in **Appendix M**.

Table 6.E.1: Cost Summary for Water System Improvements

Total Project Cost	\$ 5,562,993
Total Annual Operation and Maintenance Cost	\$ 2,280

6.F. ANNUAL OPERATING BUDGET

6.F.1. INCOME

The City of East Helena operates its water utility on approximately \$420,000 in rate revenues. This fully and adequately funds the including an annual payment of \$152,376 on a \$1.54 million in current water enterprise fund debt.

6.F.2. ANNUAL O&M COSTS

For FY2018, the water enterprise fund expenditure budget includes \$312,396 budgeted for operations and maintenance of the system.

6.F.3. DEBT REPAYMENT

The current water system debt repayment includes an annual payment of \$107,000 on a \$3,234,000 30-year DNRC/SRF loan with an interest rate of 3.00% for \$3,234,000. The current loan also requires 10% excess coverage.

6.F.4. RESERVES

Any surplus of annual rate revenue beyond the fiscal year expenditures is contributed to the water enterprise fund reserves for equipment repair and replacement.

CHAPTER 7: CONCLUSIONS AND RECOMMENDATIONS

7.A. PREFERRED ALTERNATIVE

As discussed in **Chapter 6**, the preferred alternatives for the East Helena Water System Improvements are listed below. While this constitutes a critical need of the City, separate funding for this project is being pursued.

- Water Supply Alternative 2 New Production Well at the Northeast Corner of the City Owned Property - \$1,759,454. While this constitutes a critical need for the City, separate funding is being pursued, and this item is excluded from the Total Project Cost below.
- Water Supply Alternative 4 Caisson Protection and Level Monitoring Improvements -\$649,178.
- Water Storage Alternative 2 Replace the McClellan Storage Tanks with One (1) 1,000,000-Gallon Pre-Stressed Concrete Storage Tank \$3,383,014.
- Water Distribution Alternative 2 Main Street Stream Crossing \$214,833.
- Water Distribution Alternative 3 Loop Distribution System at Manlove \$589,380.
- Water Distribution Alternative 4 Eliminate Dead-End at 1st Street and West Groschell -\$144,887.
- McClellan Source Access Alternative 2 New Pedestrian Bridge \$107,607.
- Telemetry System Alternative 2 Upgrade SCADA System \$474,094.

The **TOTAL PROJECT COST**, to be carried forward and incorporated into the funding strategy, is **\$5,562,993**.

7.B. FUNDING OPTIONS AND RECOMMENDATIONS

7.B.1. FUNDING OBJECTIVES

A well-founded funding strategy will be pivotal for implementation of the proposed water improvements. The final funding strategy will require further dialogue with the City and prospective funding agencies. The funding strategy presented in this document focuses on the best viable approach for the City.

7.B.2. PROSPECTIVE FUNDING PROGRAMS

Public facilities assistance programs are typically restricted to specific project types. This is partly due to the specific focus (and legislative mandate) of the respective programs and also to the enterprise fund origin of local monies typically used to match assistance dollars. Programs that have potential application for the East Helena Water Improvements include the following:

Natural Resource Damage Program

Decades of mining and mineral processing operations at the ASARCO Smelter south of East Helena has released substantial quantities of hazardous material including heavy metals such as lead and zinc, as well as selenium and arsenic, into the soils and groundwater. The State of Montana filed a natural resource damage lawsuit against ASARCO and a settlement was reached in 1999, 2005, and 2008. In addition to the lawsuit against ASRCO, the State completed a settlement for the East Helena site. With this settlement, \$100 million was put in a custodial trust to clean up and restore the former smelter site and other lands in the East Helena area.

The Natural Resource Damage Program within the Montana Department of Justice administers an annual restoration grants process. A restoration project must include the restoration of injured resources that will restore, rehabilitate, replace, or require the equivalent of the injured natural resources and/or the services lost as a result of damage caused by the ASARCO Smelter activities. Approved grant projects are intended to improve water, fish and wildlife resources, public drinking water supplies, and natural resource-based recreational opportunities such as hiking, hunting, fishing, and wildlife watching.

The City of East Helena is eligible for project funding assistance from the NRD Program under the "Final Restoration Plan" and has submitted a Technical Memorandum to the Program for projects that are eligible for grant funding. The memorandum addresses City-wide projects that may be eligible for funding assistance including the proposed project for the City's municipal drinking water system.

While it seems likely that some funding from the NRD Program seems probable, there has been no decision in this regard, or indication of the amount.

Drinking Water State Revolving Fund Program (DWSRF)

This loan program is administered by the Montana Department of Environmental Quality (MDEQ) for public water system improvements. Prior to initiating the formal loan process, projects must be listed on the program's Project Priority Listing (PPL). The PPL ranks priority projects on a "first come, first served" basis. Loans are made for a 20-year term at a current interest rate of 2.50 percent.

There is no cap on SRF loan amounts and the application cycle is open, subject to availability of funds. SRF loans must be secured by issuance of a bond, which water user rate or tax-based revenues are pledged to repay. Excess coverage of 10% is required from user rates established to repay the bond unless property tax revenues are pledged. A reserve equal to one-half annual payment must be borrowed or locally provided at the time loan funds are advanced. There are currently no loan fees for SRF assistance. Cities and counties are eligible for DWSRF loans.

Montana Treasure State Endowment Program (TSEP)

The Treasure State Endowment Program (TSEP) is a state grant program authorized by the Montana Legislature, and funded by coal severance tax interest earnings. It is designed to assist cities, towns, counties, consolidated governments, tribal governments, and county or multicounty water, sewer or solid waste districts. Eligible projects include drinking water systems, wastewater systems, sanitary or storm sewers, solid waste disposal and separation facilities, and bridges. The award cycle is biannual, with applications due in even-numbered years. Applications are subject to legislative approval, with awards typically announced the summer following legislative sessions. Applications are competitive, and typically about half of the applicants are successful. TSEP applications are due in June of 2018 for this funding cycle.

Administered by the Montana Department of Commerce (MDOC), funding availability varies each biennium and is derived from the interest on the state coal tax trust. TSEP grant awards are limited to 50 percent of project cost, and grants are provided up to \$750,000 per recipient.

Criteria for TSEP grant awards include urgent threats to health and safety, regulatory compliance, economic development, and financial need. Funding may be used for qualifying project administration expense, engineering, and construction. A minimum of one public meeting or hearing is required before submitting a TSEP application.

TSEP grants are typically leveraged with other grant and loan sources, and an MDOC "target (user) rate" analysis is considered in evaluation of applicants for water and sewer projects. Target rate is a statewide average for user rates for water and sewer systems – currently 1.4 percent of median household income for water, 0.9 percent for sewer, and 2.3 percent combined. This threshold must normally be surpassed for a project to be ranked competitively with the TSEP program.

Applicant's user rates based on the projected monthly rates with TSEP assistance must be at least 150% of the communities MDOC "target rate" after project completion to be eligible for \$750,000 in grant funds. If the user rates are projected to be between 125% and 150%, applicants are eligible to apply for no more than \$625,000 and if the user rates are less than 125%, the maximum grant amount is limited to \$500,000.

Tentative target rate analysis indicates that the City of East Helena should meet the eligibility criterion for TSEP grant consideration. Based on TSEP requirements, the City's user rates upon completion of the proposed project after TSEP assistance is over 123% of the "target rate" and therefore is eligible to apply for \$500,000 in assistance.

Community Development Block Grant (CDBG) Public Facilities

Also administered by the MDOC, the Community Development Block Grant (CDBG) program is federally funded by the U.S. Department of Housing and Urban Development. Qualifying projects in the "public facilities" category include water, wastewater, and solid waste improvements.

Application cycles are annual, due in June of 2018 for this funding cycle unless funds remain, then the cycle will remain open until all funds are exhausted, with approximately \$2.5 million available yearly. Applications are ranked competitively, with typically one-third of applicants being successful in a given cycle. Utility projects compete with other institutional projects such as hospitals, rest homes, and educational facilities within the "public facilities" category. Eligible CDBG applicants include municipalities and counties.

The CDBG program can award up to a maximum of \$450,000 per project, but grants are limited to \$20,000 per benefitted "Low-and-Moderate-Income" (LMI) household. CDBG grants require 25% local match of CDBG funds unless granted a waiver. Grants are competitive, and the presence of potential health threats helps a community's ranking. A minimum threshold of 51% percent LMI households must be directly benefitted by the project, as determined from census data or a local Income Survey. An even higher LMI percentage garners additional ranking points. The CDBG program also utilizes Target Rate analysis, requiring applicants for to exceed that threshold to be eligible for consideration.

An optional CDBG technique known as "targeting" is also available. Targeting requires that project financing be paid through assessments rather than user rates (see Creation of Special Districts discussion, following). In targeting, CDBG funds are used to pay all assessments for construction cost for only those qualifying LMI residents in an area. Households exceeding LMI criteria and businesses would receive no subsidy. Annual water system O&M costs would still be paid through water rates (i.e., Water Enterprise Fund), which both LMI and non-LMI users would pay.

The targeting technique applies CDBG funds directly to only LMI households, and consequently achieves "100 percent LMI benefit." Targeting would likely require formation of an SID, and property assessments or hook-up fees could be paid directly with CDBG funds for LMI residents. Creation of an improvement district and application of the targeting approach would require assistance from a qualified legal counsel, as well as further consultation with MDOC prior to grant application. Eligibility for households under a targeting approach would require that interested residents come forward, and provide copies of their federal tax return for verification. If the assessments for interested eligible households exceed CDBG grant funds (i.e., \$450,000), the City would still be obligated to pay all such assessments even if additional local funds were required. Execution of individual assistance contracts with each eligible homeowner, renter, or landlord is also required. This process plus the legal services for SID creation entail additional costs.

Application to the CDBG Public Facilities grant program was considered but eliminated. According to the MDOC's Montana Community Target Rate Calculator, the City of East Helena has a 39.34% low-and-moderate household income (2015 Estimate). This does not exceed the 51% threshold for CDBG eligibility.

DNRC Renewable Resource Grant and Loan (RRGL) Program

The Renewable Resource Grant and Loan Program (RRGL) is administered by the Montana Department of Natural Resources and Conservation (DNRC), and is funded through interest accrued on the State Resource Indemnity Trust Fund.

RRGL grants are limited to \$125,000. Loan amounts are not limited and are issued for 20 years. Eligible projects must "promote conservation of the water resource," although proposals involving fish/wildlife benefits, flood prevention, or mitigation of threats to water resources are also eligible. Any governmental entity is eligible to apply.

Applications are competitive, and funding is available on a biannual basis, subject to legislative approval. Applications are typically due in May of even-numbered years. Unique to the RRGL program is that local match is not mandatory for Construction Project grants but a match is required for Project Planning Grants. Grants or loans can be obtained for capital construction, including engineering and administration.

An application by the City for \$125,000 to use towards this project is feasible, subject to competitive ranking and award. The next application deadline for RRGL grant applications is May 15, 2018.

USDA Rural Development (RD) Water and Environmental Loan and Grant Program

The USDA through its Rural Development (RD) program offers funding packages for qualifying public water, wastewater, and solid waste projects. This program typically combines grant and loan offerings to municipalities, counties, tribes, and districts. Grant eligibility and loan rates are summarized as follows, but remain discretionary with the agency and subject to change. RD uses an alternate income index known as "Non-Metropolitan Median Household Income," and grant shares shown are typically the maximums allowed and can be substantially less. RD funding thresholds are currently as follows:

- Loan funds only for MHIs above \$47,757 (loans at market interest rate currently 3.875%)
- Grant share up to 45% for MHIs between \$38,205 and \$47,757 (loans share at 3.125%)
- Grant share up to 75% for MHIs below \$38,205 and documented health or sanitation problems (loans share at 2.375%)

Grant share percentages are calculated based on an RD funding package after deducting other grants (rather than the overall project cost), and are discretionary with the agency. Predicted user rates also heavily influence RD's final determination of grant share, based on achieving comparability with user rates in other similar systems.

Grant/loan funds are typically released at the end of construction so interim financing is required with RD assistance and is available through the SRF or INTERCAP programs. Applications are considered on an open cycle, and can be submitted at any time. Applications are not competitive, but are subject to agency approval and availability of funds. RD requires

water metering as a condition of funding either water or sewer projects, except where individual private wells are used.

RD typically provides loans for up to a 40-year term and requires 10% excess coverage in rate revenues. RD allows a loan reserve (typically one annual payment) to be accumulated from excess coverage revenues over the first few years of the loan. RD also requires a Short-Lived Assets (SLA) set aside in projected rates to fund replacement of system mechanical components.

Montana Board of Investments INTERCAP Loan Program

The Montana Board of Investments offers up to 15-year loans to communities, counties, and districts. These INTERCAP loans are not limited to water and sewer improvements, and may be used for other capital needs such as vehicles, road paving, building improvements, as well as interim financing. Applications are not competitive but are subject to availability of funds.

Loans up to \$5 million can be issued with staff or INTERCAP Loan Committee approval; larger amounts require Board of Investments approval. Current interest rates are variable at 3.15% and change February 16 of each year. The average rate over the last 10 years is 1.885%. INTERCAP loans are often used for "interim financing" for infrastructure improvements to allow project initiation, prior to loan or grant funds availability from other sources. Applications for INTERCAP loans are on an open cycle.

INTERCAP borrowing does not fit well with the water improvements since repayment within 15 years would cause undue rate escalation. Longer term borrowing is more appropriate for these improvements.

Funding Application Procedures and Supporting Plans

With the exception of the INTERCAP program, the preceding programs require submission of the Montana Uniform Application for Public Facilities Projects, in some cases with supplemental information required by individual funding agencies. A current Preliminary Engineering Report is also required.

Particularly for the MDOC funding programs, a local Needs Assessment Survey (or County Growth Policy) needs to indicate the proposed project as a high local priority.

Applications to the TSEP, CDBG, or DNRC grant programs will require public meeting(s) and/or hearing, once a full PER is available and funding applications are being prepared. Requirements are specific to each program, and the respective agencies should be consulted for exact stipulations on type and number of meetings or hearings, as well as advertising requirements.

7.B.3. FUNDING RECOMMENDATIONS

The financial strategy recommended for the East Helena Water Improvements include pursuing TSEP and RRGL grants and borrowing through the DWSRF program. Loan reserves will be

required and will be included in the overall loan amount. The City is also pursuing funds from the NRD program. While it seems likely that some funding from the NRD Program seems probable, as stated above, there has been no decision in this regard, or indication of the amount. A significant amount (\$4.23 million) is shown from the NRD in the funding strategy. This decision was based on a rate increase of approximately \$5.00 per month per user, which provides a city-wide combined rate between 123% and 128% of the Department of Commerce Target Rate (depending on success in obtaining other funding sources). Some adjustments to the funding strategy and project timing may be needed to keep rates at levels affordable to East Helena's citizens. Wastewater treatment requirements, particularly the requirement to remove some metals from wastewater effluent have caused the wastewater rates to escalate in the recent years (2012) to \$66.40 per user. Project timing adjustments may include applying for funding during multiple grant cycles.

Table 7.B.1 compares the estimated post-project city-wide water rates with only DWSRF funding versus a combination of grant funding through NRD, TSEP, and RRGL.

A TSEP grant would require a 50% match and cannot exceed \$500,000 unless post-project user rates are over 125% of the Target Rate. The City would repay its local share with system-wide rate revenues through the City's Water Enterprise Fund.

7.C. PUBLIC PARTICIPATION

Public participation for the proposed project was a key element in the development of this PER and subsequent funding applications. In addition to regular City Council meetings open to the public, two formal public meetings were held regarding the proposed project. These meeting were used to solicit citizen input on the water improvement project, any environmental concerns associated with the project, and information on the funding applications to be submitted. Documentation on the public meetings including meeting presentation materials, copy of the meeting advertisements, attendee sign-in sheets, and meeting minutes are located in **Appendix N**.

7.C.4. FIRST PUBLIC MEETING ON NEEDS, P.E.R., PROCESS AND FUNDING STRATEGY

The first public meeting was held on February 27, 2018. The meeting was advertised twice in City's local newspaper, the Independent Record, in order to give citizens adequate notice and was posted at City Hall and on the Master Plan web page developed by the City. The meeting was intended to update the public on the proposed project, discuss possible alternatives, and inform citizens of possible funding options available for the project.

Table 7.B.1: Funding Scenarios if <u>All</u> Recommended Improvements are Constructed in One Phase

			SRF Loan,	SRF Loan,
			NRD and	NRD, RRGL
Item	SRF Loan Only	SRF Loan and NRD	RRGL	and TSEP
Estimated Total Project Cost:	\$5,562,993	\$5,562,993	\$5,562,993	\$5,562,993
NRD Grant		\$4,225,000	\$4,225,000	\$4,225,000
RRGL Grant			\$125,000	\$125,000
TSEP Grant				\$500,000
Subtotal Non-grant Share:	\$5,562,993	\$1,337,993	\$1,212,993	\$712,993
Bond Reserve (1/2 annual Pmt., assumed borrowed)	\$230,803	\$44,119	\$39,997	\$23,510
Total Loan Amount:	\$5,793,796	\$1,382,112	\$1,252,990	\$736,503
Assumed Loan Term (year)	20	20	20	20
Interest Rate	2.500%	2.500%	2.500%	2.500%
Annual Debt Service	\$461,606	\$88,238	\$79,994	\$47,020
plus Excess Coverage (110%)	\$46,161	\$8,824	666′2\$	\$4,702
Total Annual Debt Service:	\$507,767	\$90,062	\$87,994	\$51,722
Estimated System O&M Cost	\$2,280	\$2,280	\$2,280	\$2,280
Total Annual Water Cost (projected):	\$510,047	\$99,342	\$90,274	\$54,002
Avg. Monthly Cost per Water Connection	\$48.19	\$9.39	\$8.53	\$5.10
Total Connections	882	882	882	882
Existing Water Rate	\$33.85	\$33.85	\$33.85	\$33.85
Total Rate (Existing + Project)	\$82.04	\$43.24	\$42.38	\$38.95
Existing Sewer Rate	\$66.40	\$66.40	\$66.40	\$66.40
Current Combined Water and Sewer Rate	\$100.25	\$100.25	\$100.25	\$100.25
Projected Combined Water and Sewer Rate	\$148.44	\$109.64	\$108.78	\$105.35
DOC Targe Rate	\$85.92	\$85.92	\$85.92	\$85.92
Percent Target Rate	173%	128%	127%	123%

7.C.5. SECOND PUBLIC MEETING ON DRAFT MASTER PLAN, FUNDING APPLICATIONS, AND ENVIRONMENTAL ASSESSMENT

The second public meeting was held on April 5, 2018. The meeting was advertised in the Independent Record in order to give citizens adequate notice and was posted at City Hall and posted on the Master Plan web page. The meeting was intended to update the public on the proposed project, resulting user rates with different funding scenarios, and any possible environmental concerns.

7.C.6. MASTER PLAN ADOPTION, APPLICATION AUTHORIZATION, AND E.A. ADEQUACY

The City Council passed Resolution No. 503 adopting this Master Plan and the recommended water system improvements, Resolution No. 505 authorizing submission of the TSEP and RRGL grant applications in May 2018 and June 2018, and based on advertisement for public comments and a review of the Environmental Assessment (EA) for the proposed water system improvements, the City further determined that the EA was adequate and further environmental analysis was not necessary, as reflected in Resolution No. 504. Copies of these Resolutions are located in **Appendix O**.

APPENDIX A – ENVIRONMENTAL

This map is for use in administering the National Flood Insurance Program. It does not necessarily identify all areas subject to flooding, particularly from local drainage sources of small size. The community map repository should be consulted for possible updated or additional flood hazard information.

to obtain more detailed information in areas where Base Flood Elevations (BFEs To obtain move detailed information in areas where Base Flagod Elevations (BFEs) and/or floodways have been determined, users are encourage that the Flood Profiles and Floodway Data and/or Summary of Stillwater Elevations tables contained within the Flood Insurance Study (FIS) Report of that accompanies this FIRM. Users should be ware that BFEs shown on the FIRM profiles the Flood Well-vision to the theory of the Flood Still was should be within the Flood Still with the Flood Still was only and should not be used as the sole source flood elevation information. Accordingly, the flood elevation information Accordingly the flood elevation information and the sole source flood elevation information of the Flood the FIRM for purposes of construction and/or floodplain management

Coastal Base Flood Elevations shown on this map apply only landward of 0.0' North American Vertical Datum of 1988 (NAVD 88). Users of this FIRM should be aware that coastal flood elevations are also provided in the Summary of Stillwater Elevations table in the Flood Insurance Study Report for this jurisdiction. Elevations shown in the Summary of Stillwater Elevations table should be used for construction and/or floodplain management purposes when they are higher than the elevations shown on this FIRM.

Boundaries of the **floodways** were computed at cross sections and interpolated between cross sections. The floodways were based on hydraulic considerations with regard to requirements of the National Flood Insurance Program. Floodway widths and other pertinent floodway data are provided in the Flood Insurance Study Report

The projection used in the preparation of this map was Montana State Plane The projection used in the preparation of this map was Montana State Plane 2 Cane (FIPS 2 one 2500). The horizontal datum was NAB 38, GRS 1980 spheroid. Differences in datum, spheroid, projection or UTM zones used in the production of FIRMs for adjacent jurisdictions may result in slight positional differences in map features across jurisdiction boundaries. These differences do no affect the accuracy of this FIRMs.

Flood elevations on this map are referenced to the North American Vertical Datum of 1988. These flood elevations must be compared to structure and ground elevations referenced to the same verifical datum. For information regarding conversion between the National Geodetic Vertical Datum of 1929 and the North American Vertical Datum of 1984, visit the National Geodetic Survey website at https://www.ngs.noaa.gov, or contact the National Geodetic Survey at the following address:

NGS Information Services NOAA, N/NGS12 National Geodetic Survey SSMC-3, #9202 1315 East-West Highway Silver Spring, Maryland 20910-3282 (301) 713-3242

To obtain current elevation, description, and/or location information for bench marks shown on this map, please contact the Information Services Branch of the Nationa Geodetic Survey at (301) 713-3242, or visit its website at http://www.ngs.ngaa.gov/.

Base map information shown on this FIRM was derived from NAIP Orthophotogra-produced with a one meter ground resolution from photography dated 2005.

This map reflects more detailed and up-to-date stream channel configurations than those shown on the previous FIRM for this jurisdiction. The floodplains and floodways that were transferred from the previous FIRM may have been adjusted to conform to these new stream channel configurations. As a result, the Flood Profiles and Floodway Data tables for multiple streams in the Flood Insurance Study Report (which contains authoritative hydraulic data) may reflect stream channel distances that differ from what is shown on this map.

porate limits shown on this map are based on the best data available at the tim corporate limits shown on this map are based on the best data available at the time of publication. Because changes due to annexations or de-annexations may have courred after this map was published, map users should contact appropriate community officials to verify current corporate limit locations.


Please refer to the separately printed Map Index for an overview map of the county showing the layout of map panels; community map repository addresses; and a Listing of Communities table containing National Flood insurance Program dates for each community as well as a listing of the panels on which each community

For information on available products associated with this FIRM visit the Map Service Center (MSC) website at http://msc.fema.gov.. Available products may include previously issued Letters of Map Change, a Flood Insurance Study Report, and/or digital versions of this map. Many of these products can be ordered or obtained directly from the MSC website.

If you have questions about this map, how to order products, or the National Flood Insurance Program in general, please call the FEMA Map Information exchange (FMIX) at 1-87F-FEMA-MAP (1-87F-338-2627) or visit the FEMA website at https://www.fema.gov/business/infig

Flooding Source

Example: To convert Blackfoot River elevations to NAVD 88, 3.7 feet were added to the NGVD 29 elevations.



LEGEND

SPECIAL FLOOD HAZARD AREAS (SFHAs) SUBJECT TO INUNDATION BY THE 19% ANNIAL CHANCE FLOOD

The 1% annual knone flood (100-year flood), also known as the base flood, is the flood that he a 1% chance of being equaled or exceeded in any given year. The Special Flood Hazard Area is the area subject to flooding by the 1% annual charce flood. Areas of Special Flood Hazard include Zones A, AE, AH, AO, AR, A99, V, and VE. The Base Flood Bevation is the water-surface elevation of the 1% annual charce flood.

ZONE A No Base Flood Elevations determined. ZONE AE Base Flood Elevations determined.

Flood depths of 1 to 3 feet (usually areas of ponding); Base Flood Elevations ZONE AH

ZONE AO Flood depths of 1 to 3 feet (usually sheet flow on sloping terrain); average depths determined. For areas of alluvial fan flooding, velocities also determin

Special Plood Hazard Areas formerly protected from the 1% annual chance flood by a flood control system that was subsequently desertified. Zone All indicates that fee former flood control system is being restored to provide protection from the 1% annual chance or greater flood.

Area to be protected from 11% annual chance flood by a Federal flood protection system under construction; no Base Flood Blevitions determined.

ZONE A99

ZONE V Coastal flood zone with velocity hazard (wave action); no Base Flood Elevat

ZONE VE Coastal flood zone with velocity hazard (wave action); Base Flood Elevations

7/// FLOODWAY AREAS IN ZONE AE

The floodway is the channel of a stream plus any adjacent floodplain areas that must be kept free or encroachment so that the 1% annual chance flood can be carried without substantial increases in flood neights.

OTHER FLOOD AREAS

Areas of 0.2% annual chance flood; areas of 1% annual chance flood with average depths of less than 1 foot or with drainage areas less than 1 square mile: and areas protected by levees from 1% annual chance flood. ZONE X

OTHER AREAS ZONE X

Areas determined to be outside the 0.2% annual chance floodplain

7777 COASTAL BARRIER RESOURCES SYSTEM (CBRS) AREAS

OTHERWISE PROTECTED AREAS (OPAs)

CBRS areas and OPAs are normally located within or adjacent to Special Flood Hazard Areas

0.2% Annual Chance Floodplain Boundary

Zone D boundary

..... CBRS and OPA boundary

Boundary dividing Special Flood Hazard Area Zones and boundary dividing Special Flood Hazard Areas of different Base Flood Bevatio flood depths, or flood velocities.

~~ 512~~ Base Flood Elevation line and value: elevation in feet*

(EL 987) Base Flood Elevation value where uniform within zone; elevation in feet*

Referenced to the North American Vertical Datum of 1988

(A)- Cross section line ②------3

45" 02" 08", 93" 02" 12"

89^{000} N

• M1.5

DX5510 X

Geographic coordinates referenced to the North Am 1983 (NAD 83) Western Hemisphere

1000-meter ticks: Moritana State Plane Zone (FIPS Zone 2500), Lambert Conformal Conic projection 1000-meter Universal Transverse Mercator grid values, zone 11

Bench mark (see explanation in Notes to Users section of this FIRM panel)

EFFECTIVE DATE(S) OF REVISION(S) TO THIS PANEL

For community map revision history prior to countywide mapping, refer to the Co Map History table located in the Flood Insurance Study report for this jurisdiction

To determine if flood insurance is available in this community, contact your into or call the National Flood insurance Program at 1-800-638-9620.



MAP SCALE 1" = 500"

FIRM

PANEL 2327E

FLOOD INSURANCE RATE MAP LEWIS AND CLARK COUNTY, MONTANA

PANEL 2327 OF 2450 (SEE MAP INDEX FOR FIRM PANEL LAYOUT)

CONTAINS:

 COMMUNITY
 NUMBER
 PANEL
 SUFFIX

 HILLENA CITY OF
 300040
 2327
 E

 LEFWIS & CLARK COUNTY, 100036
 2327
 E

 LININCORPORATED AREPORTATED AREA TO THE PROPERTY AND AREA TO THE PROPERTY AND

Notice to User: The Map Number shown below should be used when placing map orders; the Community Number shown above should be



MAP NUMBER 30049C2327E EFFECTIVE DATE SEPTEMBER 19, 2012

This map is for use in administering the National Flood Insurance Program. It does not necessarily identify all areas subject to flooding, particularly from local drainage sources of small size. The community map repository should be consulted for

to obtain more detailed information in areas where Base Flood Elevations (BFEs To obtain move detailed information in areas where Base Flagod Elevations (BFEs) and/or floodways have been determined, users are encourage that the Flood Profiles and Floodway Data and/or Summary of Stillwater Elevations tables contained within the Flood Insurance Study (FIS) Report of that accompanies this FIRM. Users should be ware that BFEs shown on the FIRM profiles the Flood Well-vision to the theory of the Flood Still was should be within the Flood Still with the Flood Still was only and should not be used as the sole source flood elevation information. Accordingly, the flood elevation information Accordingly the flood elevation information and the sole source flood elevation information of the Flood he FIRM for purposes of construction and/or floodplain management

Coastal Base Flood Elevations shown on this map apply only landward of 0.0' North American Vertical Datum of 1988 (NAVD 88). Users of this FIRM should be aware that coastal flood elevations are also provided in the Summary of Stillwater Elevations table in the Flood Insurance Study Report for this jurisdiction. Elevations shown in the Summary of Stillwater Elevations table should be used for construction and/or floodplain management purposes when they are higher than the elevations shown on this FIRM.

Boundaries of the **floodways** were computed at cross sections and interpolal between cross sections. The floodways were based on hydraulic considerations w regard to requirements of the National Flood Insurance Program. Floodway wid and other pertinent floodway data are provided in the Flood Insurance Study Repo

The projection used in the preparation of this map was Montana State Plane Zone (FIPS zone 2500). The horizontal datum was NAD 83, GRS 1980 spheroid. Differences in datum, spheroid, projection or UTM zones used in the production of FIRMs for adjacent jurisdictions may result in slight positional differences in map features across jurisdiction boundaries. These differences do no affect the accuracy of this FIRM.

Flood elevations on this map are referenced to the North American Vertical Datum of Flood elevations on time impa are reterenced to the North American Vertical Datum of 1988. These flood elevations must be compared to structure and ground elevations referenced to the same vertical datum. For information regarding conversion between the National Geodetic Vertical Datum of 1929 and the North American Vertical Datum of 1939, visit the National Geodetic Survey website at https://www.rogs.norae.gov/ or contact the National Geodetic Survey at the following

NGS Information Services NOAA, NNGS12 National Geodetic Survey SSMC-3, #9202 1315 East-West Highway Silver Spring, Maryland 20910-3282 (301) 713-3242

To obtain current elevation, description, and/or location information for bench marks shown on this map, please contact the Information Services Branch of the Nationa Geodetic Survey at (301) 713- 3242, or visit its website at http://www.ngs.noaa.gov/.

Base map information shown on this FIRM was derived from NAIP Orthophotogra produced with a one meter ground resolution from photography dated 2005

This map reflects more detailed and up-to-date stream channel configurations than those shown on the previous FIRM for this jurisdiction. The floodplains and floodways that were transferred from the previous FIRM may have been adjusted to conform to these new stream channel configurations. As a result, the Flood Profiles and Floodway Data tables for multiple streams in the Flood Insurance Study Report (which contains authoritative hydraulic data) may reflect stream channel distances that differ from what is shown on this map.

orporate limits shown on this map are based on the best data available at the time in publication. Because changes due to annexations or de-annexations may have courred after this map was published, map users should contact appropriate immunity officials to verify current corporate limit locations.


Please refer to the separately printed Map Index for an overview map of the county showing the layout of map panels; community map repository addresses; and a Listing of Communities table containing National Flood Insurance Program dates for each community as well as a listing of the panels on which each community

For information on available products associated with this FIRM visit the Map Service Center (MSC) website at http://msc.fema.gov.. Available products may include previously issued Letters of Map Change, a Flood Insurance Study Report, and/or digital versions of this map. Many of these products can be ordered or obtained directly from the MSC website.

If you have questions about this map, how to order products, or the National Flood Insurance Program in general, please call the FEMA Map Information exchange (FRMX) at 1-87F-FEMA-MAP (1-87F-336-2627) or visit the FEMA website at https://www.fema.gov/business/info

Vertical Datum Offset (ft) Flooding Source

Example: To convert Blackfoot River elevations to NAVD 88, 3.7 feet were added to the NGVD 29 elevations.



LEGEND

SPECIAL FLOOD HAZARD AREAS (SFHAs) SUBJECT TO INUNDATION BY THE 19% ANNIAL CHANCE FLOOD

The 1% annual knone flood (100-year flood), also known as the base flood, is the flood that he a 1% chance of being equaled or exceeded in any given year. The Special Flood Hazard Area is the area subject to flooding by the 1% annual charce flood. Areas of Special Flood Hazard include Zones A, AE, AH, AO, AR, A99, V, and VE. The Base Flood Bevation is the water-surface elevation of the 1% annual charce flood.

ZONE A No Base Flood Elevations determined. ZONE AE Base Flood Elevations determined.

ZONE AO

Flood depths of 1 to 3 feet (usually areas of ponding); Base Flood Elevations ZONE AH

Flood depths of 1 to 3 feet (usually sheet flow on sloping terrain); average depths determined. For areas of alluvial fan flooding, velocities also determin

ZONE A99 ZONE V Coastal flood zone with velocity hazard (wave action); no Base Flood Eleva

ZONE VE Coastal flood zone with velocity hazard (wave action); Base Flood Elevations determined.

7/// FLOODWAY AREAS IN ZONE AE

The floodway is the channel of a stream plus any adjacent floodplain areas that must be kept free or encroachment so that the 1% annual chance flood can be carried without substantial increases in flood neights.

OTHER FLOOD AREAS

Areas of 0.2% annual chance flood; areas of 1% annual chance flood with average depths of less than 1 foot or with drainage areas less than 1 square mile: and areas protected by levees from 1% annual chance flood. ZONE X

OTHER AREAS ZONE X

Areas determined to be outside the 0.2% annual chance floodplai

7777 COASTAL BARRIER RESOURCES SYSTEM (CBRS) AREAS

OTHERWISE PROTECTED AREAS (OPAs)

CBRS areas and OPAs are normally located within or adjacent to Special Flood Hazard Areas

0.2% Annual Chance Floodplain Boundary

Zone D boundary

..... CBRS and OPA boundary

Boundary dividing Special Flood Hazard Area Zones and boundary dividing Special Flood Hazard Areas of different Base Flood Bevalut flood depths, or flood velocities.

~~ 513~~ Base Flood Elevation line and value: elevation in feet*

(EL 987) Base Flood Elevation value where uniform within zone; elevation in feet*

Referenced to the North American Vertical Datum of 1988 (A)-Cross section line

②------3 45" 02' 08", 93" 02" 12"

89^{000} N

• M1.5

Geographic coordinates referenced to the North Am 1983 (NAD 83) Western Hemisphere

1000-meter ticks: Moritana State Plane Zone (FIPS Zone 2500), Lambert Conformal Conic projection 1000-meter Universal Transverse Mercator grid values, zone 11

Bench mark (see explanation in Notes to Users section of this FIRM panel) DX5510 X

EFFECTIVE DATE(S) OF REVISION(S) TO THIS PANEL

For community map revision history prior to countywide mapping, refer to the Co Map History table located in the Flood Insurance Study report for this jurisdiction



MAP SCALE 1" = 500"

(0)(0)(0)

FIRM

FLOOD INSURANCE RATE MAP LEWIS AND CLARK COUNTY, MONTANA

PANEL 2331E

PANEL 2331 OF 2450

(SEE MAP INDEX FOR FIRM PANEL LAYOUT)

CONTAINS:

 COMMUNITY
 NUMBER
 PANEL
 SUFFIX

 EAST HELENA CITY OF
 300036
 2331
 E

 LEWIS & CLARK COUNTY
 300036
 2331
 E

 UNINCORPORATE DARGER
 200036
 2331
 E

Notice to User: The Map Number shown below should be used when placing map orders; the Community Number shown above should be



MAP NUMBER 30049C2331E EFFECTIVE DATE **SEPTEMBER 19, 2012**

This map is for use in administering the National Flood Insurance Program. It does not necessarily identify all areas subject to flooding, particularly from local drainage sources of small size. The community map repository should be consulted for possible updated or additional flood hazard information.

To obtain more detailed information in areas where Base Flood Elevations (BFEs To obtain more detailed information in areas where Beacouraged Everything (BFEs) and/or floodways have been determined, users are encouraged to the Hospital Profiles and Floodway Data and/or Summary of Stillwater Elevations tables contained within the Flood insurance Study (FIS) Report of that accompanies this FIRM. Users should be ware that BFEs shown on the FIRM represent rounded whole-floot elevations. These BFEs are interested for flood elevation information. Accordingly, and of the used as the sole source of flood elevation information. Accordingly, the flood elevation that presented in the FIS Report should be utilized in conjunction with

Coastal Base Flood Elevations shown on this map apply only landward of 0.0' North American Vertical Datum of 1988 (NAVD 88). Users of this FIRM should be aware that coastal flood elevations are also provided in the Summary of Stillwater Elevations table in the Flood Insurance Study Report for this jurisdiction. Elevations shown in the Summary of Stillwater Elevations table should be used for construction and/or floodplain management purposes when they are higher than the elevations shown on this FIRM.

Boundaries of the **floodways** were computed at cross sections and interpolate between cross sections. The floodways were based on hydraulic considerations witt regard to requirements of the National Flood Insurance Program. Floodway width: and other pertinent floodway data are provided in the Flood Insurance Study Report

The projection used in the preparation of this map was Montana State Plane Zone (FIPS zone 2500). The horizontal datum was NAD 83, GRS 1980 spheroid. Differences in datum, spheroid, projection or UTM zones used in the production of FIRMs for adjacent jurisdictions may result in slight positional differences in map features across jurisdiction boundaries. These differences do no affect the accuracy of this FIRM.

Flood elevations on this map are referenced to the North American Vertical Datum of 1988. These flood elevations must be compared to structure and ground elevations referenced to the same verifical datum. For information regarding conversion between the National Geodetic Vertical Datum of 1929 and the North American Vertical Datum of 1989, visit the National Geodetic Survey website at https://dx.www.ngs.noaa.gov, or contact the National Geodetic Survey at the following address:

NGS Information Services NOAA, N/NGS12 National Geodetic Survey SSMC-3, #9202 1315 East-West Highway Silver Spring, Maryland 20910-3282 (301) 713-3242

To obtain current elevation, description, and/or location information for bench marks shown on this map, please contact the Information Services Branch of the National Geodetic Survey at (301) 713-3242, or visit its website at http://www.ngs.ngas.gov.

Base map information shown on this FIRM was derived from NAIP Orthophotogra produced with a one meter ground resolution from photography dated 2005

This map reflects more detailed and up-to-date stream channel configurations than those shown on the previous FIRM for this jurisdiction. The floodylains and floodways that were transferred from the previous FIRM may have been adjusted to conform to these new stream channel configurations. As a result, the Flood Profiles and Floodway Data tables for multiple streams in the Flood Insurance Study Report (which contains authoritative hydrautic data) may reflect stream channel distances that differ from what is shown on this map.

corporate limits shown on this map are based on the best data available at the time of publication. Because changes due to annexations or de-annexations may have courred after this map was published, map users should contact appropriate community officials to verify current corporate limit locations.

Please refer to the separately printed Map Index for an overview map of the county showing the layout of map panels; community map repository addresses; and a Listing of Communities table containing National Flood Insurance Program dates for each community as well as a listing of the panels on which each community

For information on available products associated with this FIRM visit the Map Service Center (MSC) website at http://msc.fema.gov, Available products may include previously issued Letters of Map Change, a Flood Insurance Study Report, and/or digital versions of this map. Many of these products can be ordered or obtained directly from the MSC website.

If you have questions about this map, how to order products, or the National Flood Insurance Program in general, please call the FEMA Map Information exchange (FMIX) at 1-877-FEMA-MAP (1-877-336-2627) or visit the FEMA website at https://www.fema.gov/business/info

Vertical Datum Offset (ft) Flooding Source

Example: To convert Blackfoot River elevations to NAVD 88, 3.7 feet were added to the NGVD 29 elevations.



LEGEND

SPECIAL FLOOD HAZARD AREAS (SFHAs) SUBJECT TO INUNDATION BY THE 19% ANNIAL CHANCE FLOOD

The 1% annual knonce flood (100-year-flood), also known as the base flood is the flood that he a 1% chance of being equaled or exceeded in any given year. The Special Flood Hazard Area is the area subject to flooding by the 1% annual chance flood. Areas of Special Flood Hazard include Zones A, AE, AH, AO, AR, A99, V, and VE. The Base Flood Elevation is the water-surface developed or the 1% annual chance floor.

ZONE A No Base Flood Elevations determined. ZONE AE Base Flood Elevations determined.

Flood depths of 1 to 3 feet (usually areas of ponding); Base Flood Elevations ZONE AH

ZONE AO Flood depths of 1 to 3 feet (usually sheet flow on sloping terrain); average depths determined. For areas of alluvial fan flooding, velocities also determine

Special Plood Hazard Areas formerly protected from the 1% annual chance flood by a flood control system that was subsequently described. Zone AR incidates that the former flood control system is being restored to provide protection from the 1% annual chance or greater flood.

Area to be protected from 1% annual chance flood by a Federal flood protection system under construction, no Base Flood Evalutions determined.

ZONE A99

Coastal flood zone with velocity hazard (wave action); no Base Flood Elevat ZONE V

Coastal flood zone with velocity hazard (wave action); Base Flood Elevations determined. ZONE VE

9/// FLOODWAY AREAS IN ZONE AE

The floodway is the channel of a stream plus any adjacent floodplain areas that must be kept free or encroachment so that the 1% annual chance flood can, be carried without substantial increases in flood heights.

OTHER FLOOD AREAS

Areas of 0.2% annual chance flood; areas of 1% annual chance flood with average depths of less than 1 foot or with drainage areas less than 1 square mile: and areas protected by levees from 1% annual chance flood. ZONE X

OTHER AREAS ZONE X

Areas determined to be outside the 0.2% annual chance floodplain Areas in which flood hazards are undetermined, but possible.

COASTAL BARRIER RESOURCES SYSTEM (CBRS) AREAS

OTHERWISE PROTECTED AREAS (OPAs)

CBRS areas and OPAs are normally located within or adjacent to Special Flood Hazard Areas

0.2% Annual Change Floodplain Boundary

___ Zone D boundary CBRS and OPA boundary

Boundary dividing Special Flood Hazard Area Zones and boundary dividing Special Flood Hazard Areas of different Base Flood Bevation flood depths, or flood velocities.

~~ 513~~ Base Flood Elevation line and value: elevation in feet*

(EL 987) Base Flood Elevation value where uniform within zone; elevation in foot*

Referenced to the North American Vertical Datum of 1988 Cross section line

@-----

(A)-

#89³⁰⁰ N

• M1.5

45° 02' 08°, 93° 02' 12" Geographic coordinates referenced to the North American Datum of 1983 (NAD 83) Western Hemisphere

1000-meter ticks: Montana State Plane Zone (FIPS Zone 2500), Lambert Conformal Conic projection 1000-meter Universal Transverse Mercator grid values, zone 11

Bench mark (see explanation in Notes to Users section of this FIRM panel) DX5510 X

EFFECTIVE DATE(S) OF REVISION(S) TO THIS PANEL

For community map revision history prior to countywide mapping, refer to the C Map History table located in the Flood Insurance Study report for this jurisdictio



MAP SCALE 1" = 500"

WALLONAL

FIRM

FLOOD INSURANCE RATE MAP LEWIS AND CLARK COUNTY, MONTANA

PANEL 2332E

PANEL 2332 OF 2450

(SEE MAP INDEX FOR FIRM PANEL LAYOUT)

CONTAINS:

 COMMUNITY
 NUMBER
 PANEL
 SUFFIX

 EAST HELENA CITY OF
 300039
 2332
 E

 LITHUS & CLARK COUNTY
 300036
 2332
 E

 UNINCORPORATE DARGE PRATE DARGE PRATE DARGE PRATE DARGE PRATE DARGE PRATE PRAT

Notice to User: The Map Number shown below should be used when placing map orders; the Community Number shown above should be



MAP NUMBER 30049C2332E EFFECTIVE DATE **SEPTEMBER 19, 2012**

This map is for use in administering the National Flood Insurance Program. It does not necessarily identify all areas subject to flooding, particularly from local drainage sources of small size. The community map repository should be consulted for possible updated or additional flood hazard information.

to obtain more detailed information in areas where Base Flood Elevations (BFEs To obtain move detailed information in areas where Base Flagod Elevations (BFEs) and/or floodways have been determined, users are encourage that the Flood Profiles and Floodway Data and/or Summary of Stillwater Elevations tables contained within the Flood Insurance Study (FIS) Report of that accompanies this FIRM. Users should be ware that BFEs shown on the FIRM profiles the Flood Well-vision to the theory of the Flood Still was should be within the Flood Still with the Flood Still was only and should not be used as the sole source flood elevation information. Accordingly, the flood elevation information Accordingly the flood elevation information and the sole source flood elevation information of the Flood he FIRM for purposes of construction and/or floodplain management

Coastal Base Flood Elevations shown on this map apply only landward of 0.0' North American Vertical Datum of 1988 (NAVD 89). Users of this FIRM should be aware that coastal flood elevations are also provided in the Summary of Stillwater Elevations table in the Flood Insurance Study Report for this jurisdiction. Elevations shown in the Summary of Stillwater Elevations table should be used for construction and/or flood/gain management purposes when they are higher than the elevations shown on this FIRM.

Boundaries of the **floodways** were computed at cross sections and interpolate between cross sections. The floodways were based on hydraulic considerations with regard to requirements of the National Flood Insurance Program. Floodway width and other pertinent floodway data are provided in the Flood Insurance Study Repor

The projection used in the preparation of this map was Montana State Plane The projection used in the preparation of this map was Montana State Plane 2 Cane (FIPS 2 one 2500). The horizontal datum was NAB 38, GRS 1980 spheroid. Differences in datum, spheroid, projection or UTM zones used in the production of FIRMs for adjacent jurisdictions may result in slight positional differences in map features across jurisdiction boundaries. These differences do no affect the accuracy of this FIRMs.

NGS Information Services NOAA, N/NGS12 National Geodetic Survey SSMC-3, #9202 1315 East-West Highway Silver Spring, Maryland 20910-3282 (301) 713-3242

To obtain current elevation, description, and/or location information for bench marks shown on this map, please contact the Information Services Branch of the Nationa Geodetic Survey at (301) 713-3242, or visit its website at http://www.ngs.ngaa.gov/.

Base map information shown on this FIRM was derived from NAIP Orthophotogra-produced with a one meter ground resolution from photography dated 2005.

This map reflects more detailed and up-to-date stream channel configurations than those shown on the previous FIRM for this jurisdiction. The floodplains and floodways that were transferred from the previous FIRM may have been adjusted to conform to these new stream channel configurations. As a result, the Flood Profiles and Floodway Data tables for multiple streams in the Flood Insurance Study Report (which contains authoritative hydraulic data) may reflect stream channel distances that differ from what is shown on this map.


Corporate limits shown on this map are based on the best data available at the tim corporate limits shown on this map are based on the best data available at the time of publication. Because changes due to annexations or de-annexations may have courred after this map was published, map users should contact appropriate community officials to verify current corporate limit locations.

Please refer to the separately printed Map Index for an overview map of the county showing the layout of map panels; community map repository addresses; and a Listing of Communities table containing National Flood Insurance Program dates for each community as well as a listing of the panels on which each community

For information on available products associated with this FIRM visit the Map Service Center (MSC) website at http://msc.fema.gov.. Available products may include previously issued Letters of Map Change, a Flood Insurance Study Report, and/or digital versions of this map. Many of these products can be ordered or obtained directly from the MSC website.

If you have questions about this map, how to order products, or the National Flood Insurance Program in general, please call the FEMA Map Information exchange (FMIX) at 1-87F-FEMA-MAP (1-87F-338-2627) or visit the FEMA website at https://www.fema.gov/business/infig

Vertical Datum Offset (ft) Flooding Source Example: To convert Blackfoot River elevations to NAVD 88, 3.7 feet were added to the NGVD 29 elevations.



LEGEND

SPECIAL FLOOD HAZARD AREAS (SFHAs) SUBJECT TO INUNDATION BY THE 19% ANNIAL CHANCE FLOOD

The 1% annual knone flood (100-year flood), also known as the base flood, is the flood that he a 1% chance of being equaled or exceeded in any given year. The Special Flood Hazard Area is the area subject to flooding by the 1% annual charce flood. Areas of Special Flood Hazard include Zones A, AE, AH, AO, AR, A99, V, and VE. The Base Flood Bevation is the water-surface elevation of the 1% annual charce flood.

ZONE A No Base Flood Flevations determined.

ZONE AE Base Flood Elevations determined. ZONE AH Flood depths of 1 to 3 feet (usually areas of ponding); Base Flood Elevations

ZONE AO Flood depths of 1 to 3 feet (usually sheet flow on sloping terrain); average depths determined. For areas of alluvial fan flooding, velocities also determin

Special Plood Hazard Areas formerly protected from the 1% annual chance flood by a flood control system that was subsequently desertified. Zone All indicates that fee former flood control system is being restored to provide protection from the 1% annual chance or greater flood.

Area to be protected from 11% annual chance flood by a Federal flood protection system under construction; no Base Flood Blevitions determined.

ZONE A99

ZONE V Coastal flood zone with velocity hazard (wave action); no Base Flood Elevat

ZONE VE

Coastal flood zone with velocity hazard (wave action); Base Flood Elevations

7/// FLOODWAY AREAS IN ZONE AE

The floodway is the channel of a stream plus any adjacent floodplain areas that must be kept free or encroachment so that the 1% annual chance flood can be carried without substantial increases in flood heights.

OTHER FLOOD AREAS

Areas of 0.2% annual chance flood; areas of 1% annual chance flood with average depths of less than 1 foot or with drainage areas less than 1 square mile: and areas protected by levees from 1% annual chance flood. ZONE X

OTHER AREAS ZONE X

Areas determined to be outside the 0.2% annual chance floodplain

7777 COASTAL BARRIER RESOURCES SYSTEM (CBRS) AREAS

OTHERWISE PROTECTED AREAS (OPAs)

CBRS areas and OPAs are normally located within or adjacent to Special Flood Hazard Areas

0.2% Annual Chance Floodplain Boundary

___ Zone D boundary

CBRS and OPA boundary

Boundary dividing Special Flood Hazard Area Zones and boundary dividing Special Flood Hazard Areas of different Base Flood Bevatio flood depths, or flood velocities. Base Flood Elevation line and value: elevation in feet*

~~ 512~~ (EL 987) Base Flood Elevation value where uniform within zone; elevation in

Referenced to the North American Vertical Datum of 1988

(A)- Cross section line ②------3 45" 02" 08", 93" 02" 12"

89^{000} N

• M1.5

Geographic coordinates referenced to the North An 1983 (NAD 83) Western Hemisphere 1000-meter ticks: Moritana State Plane Zone (FIPS Zone 2500), Lambert Conformal Conic projection 1000-meter Universal Transverse Mercator grid values, zone 11

Bench mark (see explanation in Notes to Users section of this FIRM panel) DX5510 X

EFFECTIVE DATE(S) OF REVISION(S) TO THIS PANEL

To determine if flood insurance is available in this community, contact your insi or call the National Flood insurance Program at 1-800-638-6620.



MAP SCALE 1" = 500"

FIRM

FLOOD INSURANCE RATE MAP LEWIS AND CLARK COUNTY, MONTANA AND INCORPORATED AREAS

PANEL 2333E

PANEL 2333 OF 2450

(SEE MAP INDEX FOR FIRM PANEL LAYOUT)

CONTAINS:

COMMUNITY NUMBER
EAST HELENA, CITY OF 300039
HELENA, CITY OF 300040
LEWIS & CLARK COUNTY, 300038
UNINCORPORATED AREAS PANEL 2333 2333 2333

Notice to User: The Map Number shown below should be used when placing map orders; the Community Number shown above should be



MAP NUMBER 30049C2333E EFFECTIVE DATE SEPTEMBER 19, 2012



HELENA, MT KALISPELL, MT BOZEMAN, MT FORT COLLINS, CO

ROBERT PECCIA & ASSOCIATES

February 20, 2018

Bonnie Lovelace, Regulatory Affairs Manager Department of Environmental Quality Director's Office P.O. Box 200901 Helena, MT 59620-0901

Subject: East Helena Water Master Plan

East Helena, Montana

Dear Ms. Lovelace:

Our firm was retained by the City of East Helena to complete the *East Helena Water Master Plan*. As part of our work for the City, we are compiling information for an environmental checklist to be included with the document and funding applications for this project. Guidelines for the funding applications require us to advise appropriate agencies of the scope of the project and request their comments.

The City of East Helena currently receives its municipal water from two sources. One source is an alluvial infiltration gallery consisting of two radial wells near McClellan Creek southeast of the City and the other source is three municipal wells along Wylie Drive (Wylie Wells #1, #2, and #3) northwest of the City. A figure showing the locations of the City's wells is included.

Groundwater evaluations in the area have indicated that dissolved arsenic and selenium plumes originating from the ASARCO Smelter have migrated generally northward creating a potential vulnerability for Wylie Well #3. The selenium plume originating from the ASARCO Smelter is approximately 1,250 feet from the well. Wylie Well #3 creates a cone of depression when pumping at its rate of 500+ gpm in the unconfined aquifer that could induce groundwater flow from a significant radial distance. Operations at Helena Sand and Gravel's gravel pit near Wylie Well #3 could also act to induce groundwater flow from the selenium plume, which would contaminate the well. If Wylie Well #3 becomes contaminated the City's water supply well would be unusable without expensive treatment. Therefore, the proposed project includes a new production well that is needed to maintain consistent service over the long-term in East Helena. A figure showing the new potential well location is included.

Water storage for the City of East Helena is provided by three reservoirs (location shown in figure included). A 1-million-gallon buried pre-stressed concrete tank was constructed in 1999 to hold water from the Wylie Wells. Two side-by-side cast-in-place concrete storage tanks are located southeast of town near the McClellan Creek radial wells and provide the remining storage for the City. The older of the two McClellan tanks was constructed in 1928 and has a capacity of 250,000 gallons. The second tank was built in 1948 and holds 300,000

Helena

3147 Saddle Drive P.O. Box 5653 Helena, MT 59601 Tele: 406.447.5000 Fax: 406.447.5036

www.rpa-hln.com

gallons. Hydraulically, these two tanks operate as a single tank due to a direct connection between them.

Recent testing of the tanks near the McClellan Creek radial wells have shown significant leakage and are in need of replacement. Therefore, the proposed project also includes the replacement of these two cast-in-place concrete storage tanks with one large tank.

The proposed project will also include some distribution system work to eliminate dead-ends that can lead to low pressure, inadequate fire flow, and stagnant water that can cause water quality issues for the system. The most urgent improvement to the distribution system is to the 8" water main along Main Street between 1st Street and Grand Avenue that was installed in 1928 and is located under Prickly Pear Creek. Recently, failures have caused this connection to be lost. This connection is critical to conveying water from one side of town to the other.

To satisfy our requirements, we would like you to identify any additional environmental permitting requirements or other issues of interest to your agency we should consider in the development of this project. Any other statements you may have on this project will help us determine the need for further coordination and for more detailed evaluation for the potential project impacts. If we do not receive a reply, we will assume that your agency has no comments to offer about this project.

If you have any questions, please contact Brad Koenig, P.E. or me at 406-447-5000 or tbodlovic@rpa-hln.com

Sincerely,

ROBERT PECCIA & ASSOCIATES

Trisha Bodlovic, Project Designer

Enclosures



HELENA, MT KALISPELL, MT BOZEMAN, MT FORT COLLINS, CO

ROBERT PECCIA & ASSOCIATES

February 20, 2018

Jodi Bush
Field Supervisor
U.S. Fish and Wildlife Services
Ecological Services
Montana Field Office
585 Shepard Way, Suite 1
Helena, MT 59601

Subject: East Helena Water Master Plan

East Helena, Montana

Dear Ms. Bush:

Our firm was retained by the City of East Helena to complete the *East Helena Water Master Plan*. As part of our work for the City, we are compiling information for an environmental checklist to be included with the document and funding applications for this project. Guidelines for the funding applications require us to advise appropriate agencies of the scope of the project and request their comments.

The City of East Helena currently receives its municipal water from two sources. One source is an alluvial infiltration gallery consisting of two radial wells near McClellan Creek southeast of the City and the other source is three municipal wells along Wylie Drive (Wylie Wells #1, #2, and #3) northwest of the City. A figure showing the locations of the City's wells is included.

Groundwater evaluations in the area have indicated that dissolved arsenic and selenium plumes originating from the ASARCO Smelter have migrated generally northward creating a potential vulnerability for Wylie Well #3. The selenium plume originating from the ASARCO Smelter is approximately 1,250 feet from the well. Wylie Well #3 creates a cone of depression when pumping at its rate of 500+ gpm in the unconfined aquifer that could induce groundwater flow from a significant radial distance. Operations at Helena Sand and Gravel's gravel pit near Wylie Well #3 could also act to induce groundwater flow from the selenium plume, which would contaminate the well. If Wylie Well #3 becomes contaminated the City's water supply well would be unusable without expensive treatment. Therefore, the proposed project includes a new production well that is needed to maintain consistent service over the long-term in East Helena. A figure showing the new potential well location is included.

Water storage for the City of East Helena is provided by three reservoirs (location shown in figure included). A 1-million-gallon buried pre-stressed concrete tank was constructed in 1999 to hold water from the Wylie Wells. Two side-by-side cast-in-place concrete storage tanks are located southeast of town near the McClellan Creek radial wells and provide the

Helena

3147 Saddle Drive P.O. Box 5653 Helena, MT 59601 Tele: 406.447.5000 Fax: 406.447.5036

www.rpa-hln.com

remining storage for the City. The older of the two McClellan tanks was constructed in 1928 and has a capacity of 250,000 gallons. The second tank was built in 1948 and holds 300,000 gallons. Hydraulically, these two tanks operate as a single tank due to a direct connection between them.

Recent testing of the tanks near the McClellan Creek radial wells have shown significant leakage and are in need of replacement. Therefore, the proposed project also includes the replacement of these two cast-in-place concrete storage tanks with one large tank.

The proposed project will also include some distribution system work to eliminate dead-ends that can lead to low pressure, inadequate fire flow, and stagnant water that can cause water quality issues for the system. The most urgent improvement to the distribution system is to the 8" water main along Main Street between 1st Street and Grand Avenue that was installed in 1928 and is located under Prickly Pear Creek. Recently, failures have caused this connection to be lost. This connection is critical to conveying water from one side of town to the other.

To satisfy our requirements, we would like you to identify any federally-listed threatened or endangered species or critical habitat for such species that occur or may occur in the Kalispell area. Any other statements you may have on this project will help us determine the need for further coordination and for more detailed evaluation for the potential project impacts. If we do not receive a reply, we will assume that your agency has no comments to offer about this project.

If you have any questions, please contact Brad Koenig, P.E. or me at 406-447-5000 or tbodlovic@rpa-hln.com

Sincerely,

ROBERT PECCIA & ASSOCIATES

Trisha Bodlovic, Project Designer

Enclosures



HELENA, MT KALISPELL, MT BOZEMAN, MT FORT COLLINS, CO

ROBERT PECCIA & ASSOCIATES

February 20, 2018

Todd Tillinger, P.E. Montana Program Manager U.S. Army Corps of Engineers 10 West 15th Street, Suite 2200 Helena, MT 59626

Subject: East Helena Water Master Plan

East Helena, Montana

Dear Mr. Tillinger:

Our firm was retained by the City of East Helena to complete the *East Helena Water Master Plan*. As part of our work for the City, we are compiling information for an environmental checklist to be included with the document and funding applications for this project. Guidelines for the funding applications require us to advise appropriate agencies of the scope of the project and request their comments.

The City of East Helena currently receives its municipal water from two sources. One source is an alluvial infiltration gallery consisting of two radial wells near McClellan Creek southeast of the City and the other source is three municipal wells along Wylie Drive (Wylie Wells #1, #2, and #3) northwest of the City. A figure showing the locations of the City's wells is included.

Groundwater evaluations in the area have indicated that dissolved arsenic and selenium plumes originating from the ASARCO Smelter have migrated generally northward creating a potential vulnerability for Wylie Well #3. The selenium plume originating from the ASARCO Smelter is approximately 1,250 feet from the well. Wylie Well #3 creates a cone of depression when pumping at its rate of 500+ gpm in the unconfined aquifer that could induce groundwater flow from a significant radial distance. Operations at Helena Sand and Gravel's gravel pit near Wylie Well #3 could also act to induce groundwater flow from the selenium plume, which would contaminate the well. If Wylie Well #3 becomes contaminated the City's water supply well would be unusable without expensive treatment. Therefore, the proposed project includes a new production well that is needed to maintain consistent service over the long-term in East Helena. A figure showing the new potential well location is included.

Water storage for the City of East Helena is provided by three reservoirs (location shown in figure included). A 1-million-gallon buried pre-stressed concrete tank was constructed in 1999 to hold water from the Wylie Wells. Two side-by-side cast-in-place concrete storage tanks are located southeast of town near the McClellan Creek radial wells and provide the remining storage for the City. The older of the two McClellan tanks was constructed in 1928 and has a capacity of 250,000 gallons. The second tank was built in 1948 and holds 300,000

Helena 3147 Saddle Drive P.O. Box 5653

Helena, MT 59601 Tele: 406.447.5000 Fax: 406.447.5036

www.rpa-hln.com

gallons. Hydraulically, these two tanks operate as a single tank due to a direct connection between them.

Recent testing of the tanks near the McClellan Creek radial wells have shown significant leakage and are in need of replacement. Therefore, the proposed project also includes the replacement of these two cast-in-place concrete storage tanks with one large tank.

The proposed project will also include some distribution system work to eliminate dead-ends that can lead to low pressure, inadequate fire flow, and stagnant water that can cause water quality issues for the system. The most urgent improvement to the distribution system is to the 8" water main along Main Street between 1st Street and Grand Avenue that was installed in 1928 and is located under Prickly Pear Creek. Recently, failures have caused this connection to be lost. This connection is critical to conveying water from one side of town to the other.

To satisfy our requirements, we would like you to identify any additional environmental permitting requirements or other issues of interest to your agency we should consider in the development of this project. Any other statements you may have on this project will help us determine the need for further coordination and for more detailed evaluation for the potential project impacts. If we do not receive a reply, we will assume that your agency has no comments to offer about this project.

If you have any questions, please contact Brad Koenig, P.E. or me at 406-447-5000 or tbodlovic@rpa-hln.com

Sincerely,

ROBERT PECCIA & ASSOCIATES

Trisha Bodlovic, Project Designer

Enclosures



HELENA, MT KALISPELL, MT BOZEMAN, MT FORT COLLINS, CO

ROBERT PECCIA & ASSOCIATES

February 20, 2018

Marc Pitman, P.E., C.F.M. Regional Engineer Montana Department of Natural Resources and Conservation Kalispell Regional Office 655 Timberwolf Parkway, Suite 4 Kalispell, MT 59901-1215

Subject: East Helena Water Master Plan

East Helena, Montana

Dear Mr. Pitman:

Our firm was retained by the City of East Helena to complete the East Helena Water Master Plan. As part of our work for the City, we are compiling information for an environmental checklist to be included with the document and funding applications for this project. Guidelines for the funding applications require us to advise appropriate agencies of the scope of the project and request their comments.

The City of East Helena currently receives its municipal water from two sources. One source is an alluvial infiltration gallery consisting of two radial wells near McClellan Creek southeast of the City and the other source is three municipal wells along Wylie Drive (Wylie Wells #1, #2, and #3) northwest of the City. A figure showing the locations of the City's wells is included.

Groundwater evaluations in the area have indicated that dissolved arsenic and selenium plumes originating from the ASARCO Smelter have migrated generally northward creating a potential vulnerability for Wylie Well #3. The selenium plume originating from the ASARCO Smelter is approximately 1,250 feet from the well. Wylie Well #3 creates a cone of depression when pumping at its rate of 500+ gpm in the unconfined aquifer that could induce groundwater flow from a significant radial distance. Operations at Helena Sand and Gravel's gravel pit near Wylie Well #3 could also act to induce groundwater flow from the selenium plume, which would contaminate the well. If Wylie Well #3 becomes contaminated the City's water supply well would be unusable without expensive treatment. Therefore, the proposed project includes a new production well that is needed to maintain consistent service over the long-term in East Helena. A figure showing the new potential well location is included.

Water storage for the City of East Helena is provided by three reservoirs (location shown in figure included). A 1-million-gallon buried pre-stressed concrete tank was constructed in 1999 to hold water from the Wylie Wells. Two side-by-side cast-in-place concrete storage tanks are located southeast of town near the McClellan Creek radial wells and provide the remining storage for the City. The older of the two McClellan tanks was constructed in 1928

Helena

3147 Saddle Drive P.O. Box 5653 Helena, MT 59601 Tele: 406.447.5000 Fax: 406.447.5036

www.rpa-hln.com

and has a capacity of 250,000 gallons. The second tank was built in 1948 and holds 300,000 gallons. Hydraulically, these two tanks operate as a single tank due to a direct connection between them.

Recent testing of the tanks near the McClellan Creek radial wells have shown significant leakage and are in need of replacement. Therefore, the proposed project also includes the replacement of these two cast-in-place concrete storage tanks with one large tank.

The proposed project will also include some distribution system work to eliminate dead-ends that can lead to low pressure, inadequate fire flow, and stagnant water that can cause water quality issues for the system. The most urgent improvement to the distribution system is to the 8" water main along Main Street between 1st Street and Grand Avenue that was installed in 1928 and is located under Prickly Pear Creek. Recently, failures have caused this connection to be lost. This connection is critical to conveying water from one side of town to the other.

To satisfy our requirements, we would like you to identify any additional environmental permitting requirements or other issues of interest to your agency we should consider in the development of this project. Any other statements you may have on this project will help us determine the need for further coordination and for more detailed evaluation for the potential project impacts. A similar request has also been sent to Lindsay Morgan, Lewis and Clark County Floodplain Administrator, and we are working closely with Scott St. Claire, City of East Helena's Floodplain Administrator. If we do not receive a reply, we will assume that your agency has no comments to offer about this project.

If you have any questions, please contact Brad Koenig, P.E. or me at 406-447-5000 or tbodlovic@rpa-hln.com

Sincerely,

ROBERT PECCIA & ASSOCIATES

Trisha Bodlovic, Project Designer



HELENA, MT KALISPELL, MT BOZEMAN, MT FORT COLLINS, CO

ROBERT PECCIA & ASSOCIATES

February 20, 2018

Damon Murdo, Cultural Records Manager State Historic Preservation Office Montana Historical Society P.O. Box 201802 Helena, MT 59620-1202

Subject: East Helena Water Master Plan

East Helena, Montana

Dear Mr. Murdo:

Our firm was retained by the City of East Helena to complete the *East Helena Water Master Plan*. As part of our work for the City, we are compiling information for an environmental checklist to be included with the document and funding applications for this project. Guidelines for the funding applications require us to advise appropriate agencies of the scope of the project and request their comments.

The City of East Helena currently receives its municipal water from two sources. One source is an alluvial infiltration gallery consisting of two radial wells near McClellan Creek southeast of the City and the other source is three municipal wells along Wylie Drive (Wylie Wells #1, #2, and #3) northwest of the City. A figure showing the locations of the City's wells is included.

Groundwater evaluations in the area have indicated that dissolved arsenic and selenium plumes originating from the ASARCO Smelter have migrated generally northward creating a potential vulnerability for Wylie Well #3. The selenium plume originating from the ASARCO Smelter is approximately 1,250 feet from the well. Wylie Well #3 creates a cone of depression when pumping at its rate of 500+ gpm in the unconfined aquifer that could induce groundwater flow from a significant radial distance. Operations at Helena Sand and Gravel's gravel pit near Wylie Well #3 could also act to induce groundwater flow from the selenium plume, which would contaminate the well. If Wylie Well #3 becomes contaminated the City's water supply well would be unusable without expensive treatment. Therefore, the proposed project includes a new production well that is needed to maintain consistent service over the long-term in East Helena. A figure showing the new potential well location is included.

Water storage for the City of East Helena is provided by three reservoirs (location shown in figure included). A 1-million-gallon buried pre-stressed concrete tank was constructed in 1999 to hold water from the Wylie Wells. Two side-by-side cast-in-place concrete storage tanks are located southeast of town near the McClellan Creek radial wells and provide the remining storage for the City. The older of the two McClellan tanks was constructed in 1928 and has a capacity of 250,000 gallons. The second tank was built in 1948 and holds 300,000

Helena 3147 Saddle Drive P.O. Box 5653 Helena, MT 59601 Tele: 406 447 5000

Tele: 406.447.5000 Fax: 406.447.5036

gallons. Hydraulically, these two tanks operate as a single tank due to a direct connection between them.

Recent testing of the tanks near the McClellan Creek radial wells have shown significant leakage and are in need of replacement. Therefore, the proposed project also includes the replacement of these two cast-in-place concrete storage tanks with one large tank.

The proposed project will also include some distribution system work to eliminate dead-ends that can lead to low pressure, inadequate fire flow, and stagnant water that can cause water quality issues for the system. The most urgent improvement to the distribution system is to the 8" water main along Main Street between 1st Street and Grand Avenue that was installed in 1928 and is located under Prickly Pear Creek. Recently, failures have caused this connection to be lost. This connection is critical to conveying water from one side of town to the other.

In an effort to help us identify any historical or archaeological resources that may be affected by the proposed project, we would like to request a cultural resource file search for the following areas:

T-9-N, R-2-W, Section 6 and 7 T-10-N, R-3-W, Sections 23, 24, 25, 30, 31 and 36

Any other statements you may have on this project will help us determine the need for further coordination and for more detailed evaluation for the potential project impacts. If we do not receive a reply, we will assume that your agency has no comments to offer about this project.

If you have any questions, please contact Brad Koenig, P.E. or me at 406-447-5000 or tbodlovic@rpa-hln.com

Sincerely,

ROBERT PECCIA & ASSOCIATES

Trisha Bodlovic, Project Designer



HELENA, MT KALISPELL, MT BOZEMAN, MT FORT COLLINS, CO

ROBERT PECCIA & ASSOCIATES

February 20, 2018

Mark Deleray Regional Supervisor Montana Department of Fish, Wildlife & Parks Region 3 1400 South 19th Bozeman, MT 59718

Subject: East Helena Water Master Plan

East Helena, Montana

Dear Mr. Deleray:

Our firm was retained by the City of East Helena to complete the *East Helena Water Master Plan*. As part of our work for the City, we are compiling information for an environmental checklist to be included with the document and funding applications for this project. Guidelines for the funding applications require us to advise appropriate agencies of the scope of the project and request their comments.

The City of East Helena currently receives its municipal water from two sources. One source is an alluvial infiltration gallery consisting of two radial wells near McClellan Creek southeast of the City and the other source is three municipal wells along Wylie Drive (Wylie Wells #1, #2, and #3) northwest of the City. A figure showing the locations of the City's wells is included.

Groundwater evaluations in the area have indicated that dissolved arsenic and selenium plumes originating from the ASARCO Smelter have migrated generally northward creating a potential vulnerability for Wylie Well #3. The selenium plume originating from the ASARCO Smelter is approximately 1,250 feet from the well. Wylie Well #3 creates a cone of depression when pumping at its rate of 500+ gpm in the unconfined aquifer that could induce groundwater flow from a significant radial distance. Operations at Helena Sand and Gravel's gravel pit near Wylie Well #3 could also act to induce groundwater flow from the selenium plume, which would contaminate the well. If Wylie Well #3 becomes contaminated the City's water supply well would be unusable without expensive treatment. Therefore, the proposed project includes a new production well that is needed to maintain consistent service over the long-term in East Helena. A figure showing the new potential well location is included.

Water storage for the City of East Helena is provided by three reservoirs (location shown in figure included). A 1-million-gallon buried pre-stressed concrete tank was constructed in 1999 to hold water from the Wylie Wells. Two side-by-side cast-in-place concrete storage tanks are located southeast of town near the McClellan Creek radial wells and provide the remining storage for the City. The older of the two McClellan tanks was constructed in 1928

Helena

3147 Saddle Drive P.O. Box 5653 Helena, MT 59601 Tele: 406.447.5000 Fax: 406.447.5036

and has a capacity of 250,000 gallons. The second tank was built in 1948 and holds 300,000 gallons. Hydraulically, these two tanks operate as a single tank due to a direct connection between them.

Recent testing of the tanks near the McClellan Creek radial wells have shown significant leakage and are in need of replacement. Therefore, the proposed project also includes the replacement of these two cast-in-place concrete storage tanks with one large tank.

The proposed project will also include some distribution system work to eliminate dead-ends that can lead to low pressure, inadequate fire flow, and stagnant water that can cause water quality issues for the system. The most urgent improvement to the distribution system is to the 8" water main along Main Street between 1st Street and Grand Avenue that was installed in 1928 and is located under Prickly Pear Creek. Recently, failures have caused this connection to be lost. This connection is critical to conveying water from one side of town to the other.

To satisfy our requirements, we would like you to identify any wildlife or fisheries concerns or other issues important to your agency we should consider in the development of this project. Any other statements you may have on this project will help us determine the need for further coordination and for more detailed evaluation for the potential project impacts. If we do not receive a reply, we will assume that your agency has no comments to offer about this project.

If you have any questions, please contact Brad Koenig, P.E. or me at 406-447-5000 or tbodlovic@rpa-hln.com

Sincerely,

ROBERT PECCIA & ASSOCIATES

Trisha Bodlovic, Project Designer



HELENA, MT

KALISPELL, MT

BOZEMAN, MT

FORT COLLINS, CO

ROBERT PECCIA & ASSOCIATES

February 20, 2018

Lindsay Morgan Lewis & Clark County Floodplain Administrator 221 Breckenridge Ave Helena, MT 59601-4230

Subject: East Helena Water Master Plan

East Helena, Montana

Dear Ms. Morgan:

Our firm was retained by the City of East Helena to complete the *East Helena Water Master Plan*. As part of our work for the City, we are compiling information for an environmental checklist to be included with the document and funding applications for this project. Guidelines for the funding applications require us to advise appropriate agencies of the scope of the project and request their comments.

The City of East Helena currently receives its municipal water from two sources. One source is an alluvial infiltration gallery consisting of two radial wells near McClellan Creek southeast of the City and the other source is three municipal wells along Wylie Drive (Wylie Wells #1, #2, and #3) northwest of the City. A figure showing the locations of the City's wells is included.

Groundwater evaluations in the area have indicated that dissolved arsenic and selenium plumes originating from the ASARCO Smelter have migrated generally northward creating a potential vulnerability for Wylie Well #3. The selenium plume originating from the ASARCO Smelter is approximately 1,250 feet from the well. Wylie Well #3 creates a cone of depression when pumping at its rate of 500+ gpm in the unconfined aquifer that could induce groundwater flow from a significant radial distance. Operations at Helena Sand and Gravel's gravel pit near Wylie Well #3 could also act to induce groundwater flow from the selenium plume, which would contaminate the well. If Wylie Well #3 becomes contaminated the City's water supply well would be unusable without expensive treatment. Therefore, the proposed project includes a new production well that is needed to maintain consistent service over the long-term in East Helena. A figure showing the new potential well location is included.

Water storage for the City of East Helena is provided by three reservoirs (location shown in figure included). A 1-million-gallon buried pre-stressed concrete tank was constructed in 1999 to hold water from the Wylie Wells. Two side-by-side cast-in-place concrete storage tanks are located southeast of town near the McClellan Creek radial wells and provide the remining storage for the City. The older of the two McClellan tanks was constructed in 1928 and has a capacity of 250,000 gallons. The second tank was built in 1948 and holds 300,000

Helena 3147 Saddle Drive P.O. Box 5653 Helena, MT 59601 Tele: 406.447.5000 Fax: 406.447.5036

gallons. Hydraulically, these two tanks operate as a single tank due to a direct connection between them.

Recent testing of the tanks near the McClellan Creek radial wells have shown significant leakage and are in need of replacement. Therefore, the proposed project also includes the replacement of these two cast-in-place concrete storage tanks with one large tank.

The proposed project will also include some distribution system work to eliminate dead-ends that can lead to low pressure, inadequate fire flow, and stagnant water that can cause water quality issues for the system. The most urgent improvement to the distribution system is to the 8" water main along Main Street between 1st Street and Grand Avenue that was installed in 1928 and is located under Prickly Pear Creek. Recently, failures have caused this connection to be lost. This connection is critical to conveying water from one side of town to the other.

To satisfy our requirements, we would like you to identify any additional environmental permitting requirements or other issues of interest to your agency we should consider in the development of this project. Any other statements you may have on this project will help us determine the need for further coordination and for more detailed evaluation for the potential project impacts. A similar request has also been sent to Marc Pitman, Regional Engineer, Montana Department of Natural Resources and Conservation and we are working closely with Scott St. Claire, City of East Helena's Floodplain Administrator. If we do not receive a reply, we will assume that your agency has no comments to offer about this project.

If you have any questions, please contact Brad Koenig, P.E. or me at 406-447-5000 or tbodlovic@rpa-hln.com

Sincerely,

ROBERT PECCIA & ASSOCIATES

Trisha Bodlovic, Project Designer



HELENA, MIT KALISPELL, MT BOZEMAN, MT FORT COLLINS, CO

ROBERT PECCIA & ASSOCIATES

February 20, 2018

Jonathan George **District Conservationist USDA Natural Resources Conservation Services** Helena Field Office 790 Colleen Street Helena, MT 59601-9713

Subject: East Helena Water Master Plan

East Helena, Montana

Dear Mr. George:

Our firm was retained by the City of East Helena to complete the East Helena Water Master Plan. As part of our work for the City, we are compiling information for an environmental checklist to be included with the document and funding applications for this project. Guidelines for the funding applications require us to advise appropriate agencies of the scope of the project and request their comments.

The City of East Helena currently receives its municipal water from two sources. One source is an alluvial infiltration gallery consisting of two radial wells near McClellan Creek southeast of the City and the other source is three municipal wells along Wylie Drive (Wylie Wells #1, #2, and #3) northwest of the City. A figure showing the locations of the City's wells is included.

Groundwater evaluations in the area have indicated that dissolved arsenic and selenium plumes originating from the ASARCO Smelter have migrated generally northward creating a potential vulnerability for Wylie Well #3. The selenium plume originating from the ASARCO Smelter is approximately 1,250 feet from the well. Wylie Well #3 creates a cone of depression when pumping at its rate of 500+ gpm in the unconfined aquifer that could induce groundwater flow from a significant radial distance. Operations at Helena Sand and Gravel's gravel pit near Wylie Well #3 could also act to induce groundwater flow from the selenium plume, which would contaminate the well. If Wylie Well #3 becomes contaminated the City's water supply well would be unusable without expensive treatment. Therefore, the proposed project includes a new production well that is needed to maintain consistent service over the long-term in East Helena. A figure showing the new potential well location is included.

Water storage for the City of East Helena is provided by three reservoirs (location shown in figure included). A 1-million-gallon buried pre-stressed concrete tank was constructed in 1999 to hold water from the Wylie Wells. Two side-by-side cast-in-place concrete storage tanks are located southeast of town near the McClellan Creek radial wells and provide the remining storage for the City. The older of the two McClellan tanks was constructed in 1928

Helena 3147 Saddle Drive P.O. Box 5653 Helena, MT 59601

Tele: 406.447.5000 Fax: 406.447.5036

and has a capacity of 250,000 gallons. The second tank was built in 1948 and holds 300,000 gallons. Hydraulically, these two tanks operate as a single tank due to a direct connection between them.

Recent testing of the tanks near the McClellan Creek radial wells have shown significant leakage and are in need of replacement. Therefore, the proposed project also includes the replacement of these two cast-in-place concrete storage tanks with one large tank.

The proposed project will also include some distribution system work to eliminate dead-ends that can lead to low pressure, inadequate fire flow, and stagnant water that can cause water quality issues for the system. The most urgent improvement to the distribution system is to the 8" water main along Main Street between 1st Street and Grand Avenue that was installed in 1928 and is located under Prickly Pear Creek. Recently, failures have caused this connection to be lost. This connection is critical to conveying water from one side of town to the other.

To satisfy our requirements, we would like you to identify any additional environmental permitting requirements or other issues of interest to your agency we should consider in the development of this project. Any other statements you may have on this project will help us determine the need for further coordination and for more detailed evaluation for the potential project impacts. If we do not receive a reply, we will assume that your agency has no comments to offer about this project.

If you have any questions, please contact Brad Koenig, P.E. or me at 406-447-5000 or tbodlovic@rpa-hln.com

Sincerely,

ROBERT PECCIA & ASSOCIATES

Trisha Bodlovic, Project Designer



HELENA, MT KALISPELL, MT BOZEMAN, MT FORT COLLINS, CO

ROBERT PECCIA & ASSOCIATES

February 20, 2018

Brianna Whitaker Montana Department of Transportation Program & Policy Analysis Bureau P.O. Box 201001 Helena, MT 59620-1001

Subject: East Helena Water Master Plan

East Helena, Montana

Dear Ms. Whitaker:

Our firm was retained by the City of East Helena to complete the *East Helena Water Master Plan*. As part of our work for the City, we are compiling information for an environmental checklist to be included with the document and funding applications for this project. Guidelines for the funding applications require us to advise appropriate agencies of the scope of the project and request their comments.

The City of East Helena currently receives its municipal water from two sources. One source is an alluvial infiltration gallery consisting of two radial wells near McClellan Creek southeast of the City and the other source is three municipal wells along Wylie Drive (Wylie Wells #1, #2, and #3) northwest of the City. A figure showing the locations of the City's wells is included.

Groundwater evaluations in the area have indicated that dissolved arsenic and selenium plumes originating from the ASARCO Smelter have migrated generally northward creating a potential vulnerability for Wylie Well #3. The selenium plume originating from the ASARCO Smelter is approximately 1,250 feet from the well. Wylie Well #3 creates a cone of depression when pumping at its rate of 500+ gpm in the unconfined aquifer that could induce groundwater flow from a significant radial distance. Operations at Helena Sand and Gravel's gravel pit near Wylie Well #3 could also act to induce groundwater flow from the selenium plume, which would contaminate the well. If Wylie Well #3 becomes contaminated the City's water supply well would be unusable without expensive treatment. Therefore, the proposed project includes a new production well that is needed to maintain consistent service over the long-term in East Helena. A figure showing the new potential well location is included.

Water storage for the City of East Helena is provided by three reservoirs (location shown in figure included). A 1-million-gallon buried pre-stressed concrete tank was constructed in 1999 to hold water from the Wylie Wells. Two side-by-side cast-in-place concrete storage tanks are located southeast of town near the McClellan Creek radial wells and provide the remining storage for the City. The older of the two McClellan tanks was constructed in 1928 and has a capacity of 250,000 gallons. The second tank was built in 1948 and holds 300,000

Helena 3147 Saddle Drive P.O. Box 5653

Helena, MT 59601 Tele: 406.447.5000 Fax: 406.447.5036

gallons. Hydraulically, these two tanks operate as a single tank due to a direct connection between them.

Recent testing of the tanks near the McClellan Creek radial wells have shown significant leakage and are in need of replacement. Therefore, the proposed project also includes the replacement of these two cast-in-place concrete storage tanks with one large tank.

The proposed project will also include some distribution system work to eliminate dead-ends that can lead to low pressure, inadequate fire flow, and stagnant water that can cause water quality issues for the system. The most urgent improvement to the distribution system is to the 8" water main along Main Street between 1st Street and Grand Avenue that was installed in 1928 and is located under Prickly Pear Creek. Recently, failures have caused this connection to be lost. This connection is critical to conveying water from one side of town to the other.

We would like you to identify any additional environmental permitting requirements or other issues of interest to your agency we should consider in the development of this project. Any other statements you may have on this project will help us determine the need for further coordination and for more detailed evaluation for the potential project impacts. If we do not receive a reply, we will assume that your agency has no comments to offer about this project.

If you have any questions, please contact Brad Koenig, P.E. or me at 406-447-5000 or tbodlovic@rpa-hln.com

Sincerely,

ROBERT PECCIA & ASSOCIATES

Trisha Bodlovic, Project Designer



HELENA, MT KALISPELL, MT BOZEMAN, MT FORT COLLINS, CO

ROBERT PECCIA & ASSOCIATES

March 1, 2018

Megan Bullock Jefferson County Floodplain Administrator Box H Boulder, MT 59632

Subject: East Helena Water Master Plan

East Helena, Montana

Dear Ms. Bullock:

Our firm was retained by the City of East Helena to complete the *East Helena Water Master Plan*. As part of our work for the City, we are compiling information for an environmental checklist to be included with the document and funding applications for this project. Guidelines for the funding applications require us to advise appropriate agencies of the scope of the project and request their comments.

The City of East Helena currently receives its municipal water from two sources. One source is an alluvial infiltration gallery consisting of two radial wells near McClellan Creek southeast of the City and the other source is three municipal wells along Wylie Drive (Wylie Wells #1, #2, and #3) northwest of the City. A figure showing the locations of the City's wells is included.

Groundwater evaluations in the area have indicated that dissolved arsenic and selenium plumes originating from the ASARCO Smelter have migrated generally northward creating a potential vulnerability for Wylie Well #3. The selenium plume originating from the ASARCO Smelter is approximately 1,250 feet from the well. Wylie Well #3 creates a cone of depression when pumping at its rate of 500+ gpm in the unconfined aquifer that could induce groundwater flow from a significant radial distance. Operations at Helena Sand and Gravel's gravel pit near Wylie Well #3 could also act to induce groundwater flow from the selenium plume, which would contaminate the well. If Wylie Well #3 becomes contaminated the City's water supply well would be unusable without expensive treatment. Therefore, the proposed project includes a new production well that is needed to maintain consistent service over the long-term in East Helena. A figure showing the new potential well location is included.

Water storage for the City of East Helena is provided by three reservoirs (location shown in figure included). A 1-million-gallon buried pre-stressed concrete tank was constructed in 1999 to hold water from the Wylie Wells. Two side-by-side cast-in-place concrete storage tanks are located southeast of town near the McClellan Creek radial wells and provide the remining storage for the City. The older of the two McClellan tanks was constructed in 1928 and has a capacity of 250,000 gallons. The second tank was built in 1948 and holds 300,000

Helena

3147 Saddle Drive P.O. Box 5653 Helena, MT 59601 Tele: 406.447.5000 Fax: 406.447.5036

gallons. Hydraulically, these two tanks operate as a single tank due to a direct connection between them.

Recent testing of the tanks near the McClellan Creek radial wells have shown significant leakage and are in need of replacement. Therefore, the proposed project also includes the replacement of these two cast-in-place concrete storage tanks with one large tank.

The proposed project will also include some distribution system work to eliminate dead-ends that can lead to low pressure, inadequate fire flow, and stagnant water that can cause water quality issues for the system. The most urgent improvement to the distribution system is to the 8" water main along Main Street between 1st Street and Grand Avenue that was installed in 1928 and is located under Prickly Pear Creek. Recently, failures have caused this connection to be lost. This connection is critical to conveying water from one side of town to the other.


To satisfy our requirements, we would like you to identify any additional environmental permitting requirements or other issues of interest to your agency we should consider in the development of this project. Any other statements you may have on this project will help us determine the need for further coordination and for more detailed evaluation for the potential project impacts. A similar request has also been sent to Marc Pitman, Regional Engineer, Montana Department of Natural Resources and Conservation, Lindsay Morgan, Lewis & Clark County Floodplain Administrator and we are working closely with Scott St. Claire, City of East Helena's Floodplain Administrator. If we do not receive a reply, we will assume that your agency has no comments to offer about this project.

If you have any questions, please contact Brad Koenig, P.E. or me at 406-447-5000 or tbodlovic@rpa-hln.com

Sincerely,

ROBERT PECCIA & ASSOCIATES

Trisha Bodlovic, Project Designer





From: <u>Murdo, Damon</u>
To: <u>Trisha Bodlovic</u>

Subject: EAST HELENA WATER MASTER PLAN, EAST HELENA

Date: Friday, February 23, 2018 11:21:27 AM

Attachments: CRABS.xlsx

CRIS.xlsx 2018022219.pdf



February 23, 2018

Trisha Bodlovic RP&A PO Box 5653 Helena MT 59604

RE: EAST HELENA WATER MASTER PLAN, EAST HELENA. SHPO Project #: 2018022219

Dear Trisha:

I have conducted a cultural resource file search for the above-cited project located in Sections 6, 7, T9N R2W, Sections 30, 31, T10N R2W, and Sections 23, 24, 25, 36, T10N R3W. According to our records there have been a few previously recorded sites within the designated search locale. In addition to the sites there have been a few previously conducted cultural resource inventories done in the area. I've attached a list of these sites and reports. If you would like any further information regarding these sites or reports you may contact me at the number listed below.

It is SHPO's position that any structure over fifty years of age is considered historic and is potentially eligible for listing on the National Register of Historic Places. If any structures are to be altered and are over fifty years old we would recommend that they be recorded and a determination of their eligibility be made.

In areas that have had previous ground disturbance we feel that there is a low likelihood cultural properties will be impacted and the need for a cultural resource inventory is unwarranted. However, if there is to be new ground disturbance, in previously undisturbed areas, we would recommend that a cultural resource inventory be conducted in order to determine whether or not sites exist and if they will be impacted.

If you have any further questions or comments you may contact me at (406) 444-7767 or by e-mail at dmurdo@mt.gov. I have attached an invoice for the file search. Thank you for consulting with us.

Sincerely,

Damon Murdo Cultural Records Manager

Last Name SCHWAB	First Name DAVID C.	Report Date 9/1/1995	Title LACASE SUBDIVISION WATER WELL	Report LC 6 17958	TRS Township:10 N Range:2 W
DEAVER	SHERRI	10/15/1990	MISSOURI-MADISON HYDROELECTRIC PROJECT REPORT ON INTENSIVE PEDESTRIAN SURVEY FOR CULTURAL RESOURCES AND RECOMMENDATIONS FOR TESTING	ZZ 6 11930	Section: 30 Township:10 N Range:2 W Section: 31
SPATH	CARL	9/15/2008	EAST HELENA SMELTER, HISTORIC RECORDATION, PHASE I, LEWIS AND CLARK COUNTY	LC 6 30706	Township:10 N Range:2 W Section: 31
AXLINE	JON	4/26/2010	ASARCO RESIDENCES ASSOCIATED WITH THE EAST HELENA SMELTER (24LC2036)	LC 6 32000	Township:10 N Range:2 W Section: 31
PETERSON	LYNN M.	2/1/2012	FILE AND LITERATURE REVIEW: MT5 EAST HELENA, 805 EAST CLARK STREET, EAST HELENA, LEWIS AND CLARK COUNTY, MONTANA 10N 2W, SEC.31	LC 6 33492	Township:10 N Range:2 W Section: 31
BROWNELL	JOAN, ET AL.	7/1/1994	HELENA CITY GATE/EAST HELENA GAS LINE	LC 6 16161	Township:10 N Range:3 W Section: 23
TRAVIS	LAURI L.	7/1/1997	A CULTURAL RESOURCE INVENTORY FOR THE HELENA AIRPORT EXPANSION, LEWIS AND CLARK COUNTY, MONTANA	LC 6 19489	Township:10 N Range:3 W Section: 23
ROSSILLON	MITZI	10/9/2001	A CULTURAL RESOURCE INVENTORY OF CANYON FERRY ROAD HIGIHWAY PROJECT STPS 430-1(5)1 IN LEWIS AND CLARK COUNTY MONTANA	LC 4 24429	Township:10 N Range:3 W Section: 23
AXLINE	JON	11/29/2004	CULTURAL RESOURCE SURVEY OF THE WYLIE DRIVE - NORTH OF EAST HELENA IN LEWIS AND CLARK COUNTY, MONTANA	LC 4 27579	Township:10 N Range:3 W Section: 23
BROWNELL	JOAN, ET AL.	7/1/1994	HELENA CITY GATE/EAST HELENA GAS LINE	LC 6 16161	Township:10 N Range:3 W Section: 24
ROSSILLON	MITZI	10/9/2001	A CULTURAL RESOURCE INVENTORY OF CANYON FERRY ROAD HIGIHWAY PROJECT STPS 430-1(5)1 IN LEWIS AND CLARK COUNTY MONTANA	LC 4 24429	Township:10 N Range:3 W Section: 24
AXLINE	JON	11/29/2004	CULTURAL RESOURCE SURVEY OF THE WYLIE DRIVE - NORTH OF EAST HELENA IN LEWIS AND CLARK COUNTY, MONTANA	LC 4 27579	Township:10 N Range:3 W Section: 24
AXLINE	JON A.	3/1/2000	INVENTORY AND ASSESSMENT: REINFORCED CONCRETE T-BEAM BRIDGES	ZZ 4 24227	Township:10 N Range:3 W Section: 25
AXLINE	JON	11/29/2004	CULTURAL RESOURCE SURVEY OF THE WYLIE DRIVE - NORTH OF EAST HELENA IN LEWIS AND CLARK COUNTY, MONTANA	LC 4 27579	Township:10 N Range:3 W Section: 25
AXLINE	JON	4/26/2010	ASARCO RESIDENCES ASSOCIATED WITH THE EAST HELENA SMELTER (24LC2036)	LC 6 32000	Township:10 N Range:3 W Section: 25
AXLINE	JON	7/1/2010	REPORT ON RANCHING AND FARMING IN THE PRICKLY PEAR VALLEY, 1864-1883 LEWIS AND CLARK COUNTY, MONTANA. (RE FEATURE 5 AT THE MERRITT-DARTMAN FARMSTEAD (24LC2177)	LC 6 36632	Township:10 N Range:3 W Section: 25
SPATH	CARL	9/15/2008	EAST HELENA SMELTER, HISTORIC RECORDATION, PHASE I, LEWIS AND CLARK COUNTY	LC 6 30706	Township:10 N Range:3 W Section: 36
AXLINE	JON	4/26/2010	ASARCO RESIDENCES ASSOCIATED WITH THE EAST HELENA SMELTER (24LC2036)	LC 6 32000	Township:10 N Range:3 W Section: 36

HERBORT	DALE P.	9/1/1988	MONTANA CITY ARCHAEOLOGICAL STUDY: ENVIRONMENTAL ANALYSIS AND PREHISTORIC SETTLEMENT (AND) MONTANA CITY ARCHAEOLOGICAL STUDY: PHASE II MODEL TESTING AND CULTURAL CHRONOLOGY	JF 6 4263	Township:9 N Range:2 W Section: 6
MOHLER	EDWIN A., ET AL.	10/9/1984	A CULTURAL RESOURCE SURVEY OF THE MCCLELLAN CREEK QUARRY	JF 5 4238	Township:9 N Range:2 W Section: 7
MUNDAY	FREDERICK C.	6/1/1978	ARCHAEOLOGY INVESTIGATIONS NEAR MONTANA CITY, MONTANA	JF 5 4234	Township:9 N Range:2 W Section: 7
BRAMMER	MAUCK	1/29/1978	MONTANA CITY, THE GHOST TOWN OF A GHOST TOWN- A HISTORY OF MONTANA(PRICKLY PEAR) CITY AND VICINITY FOR OVER TEN MILLENIA	JF 6 29997	Township:9 N Range:2 W Section: 7

C:+o #	T	Dag	Ç.,	00	Cita Tura 1	Site Time 2	Time Devied	0	ND Status
Site # 24LC1139	Twp 10N	Rng 2W	Sec 31	Qs comb	Site Type 1 Historic Railroad	Site Type 2	Time Period Historic More Than One Decade	Owner Other	NR Status Eligible
24LC2176	10N	2W	31	SW	Historic Homestead/Farmstead		Historic More Than One Decade	No Data	Ineligible
24LC2178	10N	2W	31	NW	Historic Residence		Historic More Than One Decade	Private	Ineligible
24LC2179	10N	2W	31	NW	Historic Residence		Historic More Than One Decade	Private	Ineligible
24LC2180	10N	2W	31	NW	Historic Residence		Historic More Than One Decade	Private	Ineligible
24LC2181	10N	2W	31	NW	Historic Residence		Historic More Than One Decade	Private	Ineligible
24LC1062	10N	3W	23	comb	Historic Irrigation System		1950-1959	Combination	Ineligible
24LC1312	10N	3W	23	SW	Historic Homestead/Farmstead		Historic Period	State Owned	Ineligible
24LC1314	10N	3W	23	Comb	Historic Irrigation System		Historic Period	State Owned	Ineligible
24LC1691	10N	3W	23	SW	Historic Irrigation System		Historic More Than One Decade	Private	Unresolved
24LC1692	10N	3W	23	Comb	Historic Irrigation System		Historic More Than One Decade	Private	Unresolved
24LC1693	10N	3W	23	Comb	Historic Irrigation System		Historic More Than One Decade	Private	Unresolved
24LC1062	10N	3W	24	comb	Historic Irrigation System		1950-1959	Combination	Ineligible
24LC1688	10N	3W	24	NW	Historic Residence		Historic More Than One Decade	Private	Ineligible
24LC1693	10N	3W	24	Comb	Historic Irrigation System		Historic More Than One Decade	Private	Unresolved
24LC1694	10N	3W	24	Comb	Historic Irrigation System		Historic More Than One Decade	Private	Unresolved
24LC1695	10N	3W	24	comb	Historic Irrigation System		Historic More Than One Decade	Private	Unresolved
24LC0504	10N	3W	25	SE	Historic Vehicular/Foot Bridge		Historic More Than One Decade	MDOT	Undetermined*
24LC0877	10N	3W	25	SE	Historic Religion	Historic Church	1890-1899	Private	DOE
24LC1139	10N	3W	25	comb	Historic Railroad		Historic More Than One Decade	Other	Eligible
24LC1292	10N	3W	25	SW	Historic Railroad		1910-1919	Private	Eligible
24LC1693	10N	3W	25	Comb	Historic Irrigation System		Historic More Than One Decade	Private	Unresolved
24LC2177	10N	3W	25	NE	Historic Homestead/Farmstead		Historic More Than One Decade	National Park	Unresolved
24LC2184	10N	3W	25	SE	Historic Political/Government		Historic More Than One Decade	Other	Eligible
24LC0542	10N	3W	25	SE	Historic Railroad Building/Structure		Historic Period	Private	Undetermined*
24LC0856	10N	3W	36	SE	Tipi Ring	Rock Cairn(s)	No Indication of Time	Private	Undetermined*
24LC1139	10N	3W	36	NE	Historic Railroad		Historic More Than One Decade	Other	Eligible
24LC1292	10N	3W	36	Comb	Historic Railroad		1910-1919	Private	Eligible
24LC1765	10N	3W	36		Mammal Fossil		Tertiary	No Data	Undetermined*
24LC2036	10N	3W	36	NE	Historic Smelter		Historic More Than One Decade	Private	Eligible
24LC2175	10N	3W	36	NE	Historic Residence		Historic More Than One Decade	Private	Eligible
24LC2174	10N	3W	36	NE	Historic Residence		Historic More Than One Decade	Private	Ineligible
24JF0814	9N	2W	6	NW	Historic Stock Raising	Historic Cattle Camp	1880-1889	Private	NR Listed
24JF0878	9N	2W	6	NW	Lithic Material Concentration	·	Prehistoric More Than One Period	Private	Undetermined*
24JF0951	9N	2W	6	SW	Historic Railroad		1860-1869	No Data	Eligible
24JF1353	9N	2W	6	Comb	Historic Outbuildings		Historic More Than One Decade	BLM and Other	Undetermined*

24JF0222	9N	2W	7	SW	Lithic Material Concentration		No Indication of	Corps of Engineer	:Undetermined*
							Time		
24JF0223	9N	2W	7	SW	Surface Stone Quarry		No Indication of	Private	Undetermined*
							Time		
24JF0224	9N	2W	7	SE	Lithic Material Concentration		No Indication of	State Owned	Undetermined*
							Time		
24JF0225	9N	2W	7	SE	Lithic Material Concentration		No Indication of	Private	Undetermined*
							Time		
24JF0824	9N	2W	7	SE	Lithic Material Concentration	Firehearths or Roasting Pits, FCR	No Indication of	Private	Unresolved
							Time		
24JF0951	9N	2W	7	Comb	Historic Railroad		1860-1869	No Data	Eligible
24JF1048	9N	2W	7	NW	Tipi Ring	Lithic Material Concentration	No Indication of	Private	Undetermined*
							Time		
24JF1049	9N	2W	7	Comb	Tipi Ring		No Indication of	Private	Undetermined*
							Time		
24JF1353	9N	2W	7	Comb	Historic Outbuildings		Historic More Than	BLM and Other	Undetermined*
							One Decade		

From: Rouse, David
To: Trisha Bodlovic

Subject: INFO: East Helena Water Master Plan-Threatened and Endangered Species

Date: Tuesday, February 27, 2018 3:40:39 PM

Good Afternoon Ms. Bodlovic

I am writing in response to your letter dated February 20, 2018 requesting information on federally-listed species and designated critical habitat at or near your project location. Updated species lists can now be obtained by visiting the U.S. Fish and Wildlife Service online Information for Planning and Consultation (IPaC) website at https://ecos.fws.gov/ipac/. Based on the user-defined project location and area, an updated species list will be generated for you.

The Service appreciates your efforts to incorporate fish and wildlife resource concerns into your project planning. If you have further questions related to this issue, please do not hesitate to contact David Rouse at david_rouse@fws.gov or (406) 449-5225 ext. 211.

Sincerely,

David Rouse

David Rouse

U.S. Fish and Wildlife Service Environmental Contaminants Specialist 585 Shephard Way, Suite 1 Helena, MT 59601 Phone 406.449.5225 Ext. 211 david_rouse@fws.gov From: <u>Pitman, Marc</u>
To: <u>Trisha Bodlovic</u>

Cc: Gartland, Bryan; Sears, Traci; ehpchop8@gmail.com; Olsen, Kathy

Subject: East Helena Water Master Plan

Date: Thursday, March 15, 2018 9:52:23 AM

Attachments: <u>image002.png</u>

Trisha.

The purpose of this email is to respond to your letter dated February 20, 2018, requesting comments to the subject project.

Regarding Floodplain Development Permits: A floodplain development permit is required for any work in or under a mapped floodplain. The 8" water main crossing under the mapped Zone AE special Flood Hazard Area of Prickly Pear Creek along Main street between Morton Avenue and Harrison Road will required a permit. The City of East Helena administers floodplain development permitting for this location. The local Floodplain Administrator for East Helena, Scott St. Claire, ph. (406)227-5321, email ehpchop8@gmail.com. Please contact Scott for floodplain development permit application requirements for this project.

Regarding the new well and water rights: Please contact the DNRC Water Resource Division Helena Regional Office to go over any water right requirements for the new well. You can contact the Helena Regional Manager, Bryan Gartland by phone at (406)444-5783 or by email at BGARTLAND@mt.gov.

Please call or email me if you have any questions.

Marc



Marc Pitman, PE CFM Regional Engineer, Kalispell DNRC Water Resources Division 655 Timberwolf Parkway, Suite 4 Phone (406) 752-2713 Fax: (406) 752-2843

Email: mpitman@mt.gov



DEPARTMENT OF THE ARMY

CORPS OF ENGINEERS, OMAHA DISTRICT HELENA REGULATORY OFFICE 10 WEST 15TH STREET, SUITE 2200 HELENA MT 59626

March 8, 2018

Regulatory Branch Montana State Program Corps No. NWO-2010-00541-MTH

Subject: East Helena Water Master Plan

East Helena, Montana

Robert Peccia & Associates Attn: Trisha Bodlovic PO Box 5653 Helena, Montana 59601

Dear Ms. Bodlovic:

We have reviewed your letter regarding the proposed East Helena Water Master Plan. The project site is located in Lewis and Clark County, Montana.

The mission of the U.S. Corps of Engineers (Corps) Regulatory Program is to protect the Nation's aquatic resources while allowing reasonable development through fair, flexible and balanced permit decisions. In particular, under Section 404 of the Clean Water Act, we work to protect the biological, physical, and chemical integrity of the Nation's aquatic resources. Projects are evaluated on a case-by-case basis to determine the potential benefits and detriments that may occur as a result of the proposal. In all cases an applicant must avoid and minimize impacts to aquatic resources to the greatest extent practicable.

Under the authority of Section 404 of the Clean Water Act, Department of the Army (DA) permits are required for the discharge of fill material into waters of the United States (WOUS). WOUS include the area below the ordinary high water mark of stream channels and lakes or ponds connected to the tributary system, and wetlands adjacent to these waters. Isolated waters and wetlands, as well as man-made channels, may be WOUS in certain circumstances, which must be determined on a case-by-case basis.

The information provided does not indicate if the site has been assessed for the presence of aquatic resources that may be regulated by Section 404 of the Clean Water Act. In order to evaluate whether a DA permit is necessary for any part of the project an assessment will be required. The Corps will review any proposed work within waters to determine if permits are required.

If fill is proposed within jurisdictional waters, for this project, the project area should be evaluated for the presence of wetlands or waters of the U.S. If wetlands are identified within the project area, they must be delineated in accordance with the Corps' 1987 Wetland Delineation Manual and appropriate Regional Supplement.

Note that this letter is not an authorization to proceed with any work affecting jurisdictional waters. No fill may be placed temporarily or permanently in waters of the U.S. without a DA permit. Any other applicable Federal, tribal or local permits must be obtained as required.

Please note that deviations from the reviewed plans and specifications of your project could require authorization from this office. Please contact me at (406) 441-1363 and reference Corps File Number **NWO-2010-00541-MTH** if you have questions concerning this determination.

Sincerely,

COLE.ROBERT.H.1 Digitally signed by COLEROBERT.H.1266139710 DN: cut/S, o=U.S. Government, out=Dol., out=PKI, out=U.S. Government, out=Dol., out=V.S. Government,

Robert H. Cole Regulatory Project Manager From: <u>Lindsay Morgan</u>
To: <u>Trisha Bodlovic</u>

Subject: East Helena Water Master Plan - Comments Re: Floodplain from Lewis and Clark County

Date: Friday, March 16, 2018 4:06:55 PM

Trisha,

As per our phone conversation on February 28, 2018, none of the sites where you are proposing work in Lewis and Clark County are located within the floodway or 100-year floodplain. However, should any changes (such as the possible relocation of the chlorination building and its associated piping) be made to Well No. 2, which is located within the floodway and/or 100-year floodplain, a floodplain development permit will be needed prior to any disturbance to this area. With regard to the sites where you are proposing work in Jefferson County, you will want to talk with their County floodplain administrator about the proposal.

Please feel free to contact me with any questions.

Lindsay

Lindsay A. Morgan Planner II Lewis and Clark County 1 (406) 447-8376



Trisha Bodlovic
Project Designer
Robert Peccia & Associates

April 5, 2018

RE: East Helena Water Master Plan

East Helena, Montana

Dear Ms. Bodlovic:

Thank you for the information and request for comments regarding the above referenced proposed project. Since the Department of Environmental Quality (DEQ) will be reviewing environmental documents, the engineering report, plans, specifications for the proposed project and issuing an approval to construct the new facilities, those reviews will serve as DEQ's comments.

The reviews will be performed by either the Public Water Supply Program or, if DEQ funding is also proposed, the Water Pollution Control State Revolving Fund Program (SRF). Both programs are in DEQ's Engineering Bureau. Please keep in mind that other DEQ permits associated with construction of the project may be required and if there is an associated discharge permit, the Water Protection Bureau will have input for your project upon submittal for review.

If you decide to use SRF and have questions please contact Paul LaVigne, Section Supervisor, at (406) 444-5321 or plantouse SRF and have questions please contact Rachel Clark, Section Supervisor, Public Water Supply Engineering, at (406) 444-6722 or relark@mt.gov.

I'm attaching a fact sheet for water protection that will assist you in determining if you meet thresholds for permitting should the project change. If after looking at the fact sheet you determine that your project may require further consultation you can reach the Water Protection Bureau staff at (406) 444-3080.

Sincerely

Lindsay Ford

Director's Office Support Coordinator

(406) 444-5270

REF# 2018-041

UNIFORM ENVIRONMENTAL CHECKLIST

As the engineer that prepared the preliminary engineering report, I Brad Koenig, P.E.

(print name of engineer)

have reviewed the information presented in this checklist and believe that it accurately identifies the environmental resources in the area and the potential impacts that the project could have on those resources. In addition, the required state and federal agencies were provided with the required information about the project and requested to provide comments on the proposed public facility project. Their comments have been incorporated into and attached to the Preliminary Engineering Report.

Engineer's Signature:

BHI

___ Date: 4-30-18

Key Letter: N – No Impact B – Potentially Beneficial A – Potentially Adverse P – Approval/Permits Required M – Mitigation Required

PHYSICAL ENVIRONMENT

Key N, P 1. Soil Suitability, Topographic and/or Geologic Constraints (e.g., soil slump, steep slopes, subsidence, seismic activity)

Comments and Source of Information:

Comment. No topographic, or geological conditions are likely to affect the recommended East Helena water system improvements.

The East Helena water improvements are located within the Administrative Boundary of the East Helena Superfund Area. Regulations governing soils displacement and disposal in the East Helena Superfund in Lewis and Clark County, Montana must be followed. These regulations are necessary to prevent lead and arsenic contamination of uncontaminated areas, prevent recontamination of remediated areas, and prevent potential health risks to humans.

Permit. According to the Regulations, all persons engaging in soil displacement in excess of one cubic yard within the Administrative Boundary of the East Helena Superfund Area must obtain a permit from the Lead Education and Abatement Program (LEAP) of the Lewis and Clark City-County Health Department.



Key Letter: N – No Impact **B** – Potentially Beneficial **A** – Potentially Adverse **P** – Approval/Permits Required **M** – Mitigation Required

<u>K</u>	ey	
N,	М,	Р

2. Hazardous Facilities (e.g., power lines, EPA hazardous waste sites, acceptable distance from explosive and flammable hazards including chemical/petrochemical storage tanks, underground fuel storage tanks, and related facilities such as natural gas storage facilities & propane storage tanks)

Comments and Source of Information:

Comment. The City of East Helena, the old smelter site, nearby residential subdivisions, numerous rural developments, and the surrounding undeveloped and rural agricultural lands are all part of the East Helena Superfund Site. This site was proposed for addition to the EPA's Superfund National Priorities List (NPL) in September 1983 and the listing became final one year later.

Under the direction of the EPA and MDEQ, ASARCO has excavated and replaced numerous residential yards, the surface material from sections of adjacent alleys, road aprons, public parks, day-care centers, schools, gas stations, parking lots, an irrigation ditch and a field planned for development. In addition to this clean-up, a long-term monitoring program has been put into effect.

In 1995, the Resource Conservation and Recovery Act (RCRA) Program, became responsible for the disposal of process ponds cleanup residue, process ponds, ground and surface water, the slag pile and former ore storage areas.

Mitigation. The recommended water system improvements will result in limited disturbance of soils. It is possible that contaminated soils may exist in some areas of the recommended improvements. If this contamination exists, it is likely that the top 12-inches of soil will be removed and disposed of off-site in an area approved for such waste.

The City of East Helena has and will continue to coordinate its plans for water infrastructure improvements with the Montana Department of Environmental Quality and the Environmental Protection Agency to identify areas where soil contamination may exist and the requirements pertaining to its removal and disposal.

Permit. As stated above, all persons engaging in soil displacement in excess of one cubic yard within the Administrative Boundary of the East Helena Superfund Area must obtain a permit from the Lead Education and Abatement Program (LEAP) of the Lewis and Clark City-County Health Department.

Key N, M	3.	Effects of Project on Surrounding Air Quality or Any Kind of Effects of Existing Air Quality on Project (e.g., dust, odors, emissions)
		Comments and Source of Information:
		Comment. The recommended improvements are located within the East Helena sulfur dioxide and lead Nonattainment Area.
		Impacts. The recommended improvements would not create any new violations of the Federal air quality standards, increase the frequency or severity of existing violations of the standards, or delay attainment of the standards in the East Helena area.
		The recommended East Helena water system improvements may result in temporary decrease in air quality in construction zones. This impact will be short-term and generally confined to the area where construction equipment is operating.
		Mitigation. The application of water or chemicals to control dust in areas subject to heavy vehicle traffic can be included, if deemed necessary, during the construction of the proposed project. Newly disturbed areas would be promptly reseeded or restored when construction activities are completed.
<u>Key</u> B	4.	Groundwater Resources & Aquifers (e.g., quantity, quality, distribution, depth to groundwater, sole source aquifers)
		Comments and Source of Information:
		Comment. The City of East Helena utilizes two groundwater sources. The first source is a set of three wells located north of the City known as the "Wylie source". These wells have been drilled to depths ranging from 90 feet to more than 150 feet and each well produces at least 450 gallons per minute or more. These wells utilize the Helena Valley aquifer comprised of discontinuous and variable alluvium that is continuously saturated from the water table to a depth of at least 500 feet. The second source is a pair of infiltration galleries that draw water from below McClellan Creek known as the "McClellan source".
		An extensive well monitoring has shown that a plume of groundwater contaminated by selenium and arsenic extends beyond the boundaries of the ASARCO smelter site and is found in the shallow and intermediate aquifers underlying a portion of East Helena. The East Valley Groundwater Controlled Area has been established in the area to prevent the drilling of new wells that may expose the public to specific contaminants in the groundwater as well as prevent groundwater withdrawal that may alter or induce contaminant migration.
		Impacts. The location of the new well would allow the City to still utilize the Helena Valley Aquifer. The new production well should be located away from any potential contamination from the plumes as well as other possible pollutants and out of the East Valley Groundwater Controlled Area. The recommended improvements to the City of East Helena's water system would also ensure the City can meet all needed design requirements.

Key Letter: N – No Impact B – Potentially Beneficial A – Potentially Adverse P – Approval/Permits Required M – Mitigation Required

<u>Key</u> N, P, M 5. Surface Water/Water Quality, Quantity & Distribution (e.g., streams, lakes, storm runoff, irrigation systems, canals)

Comments and Source of Information:

Comment. The surface water resources in the East Helena area include Prickly Pear Creek and its tributaries. Prickly Pear Creek originates in the Elkhorn Mountains several miles south of the City and flows in a northwesterly direction through the City. Prickly Pear discharges into Lake Helena which is located north of the City.

Impacts. The recommended East Helena water system improvements will not affect the quantity or distribution of surface waters in the project area. Construction activities will temporarily disturb soil and could increase the potential for erosion and transport of sediments to surface waters.

Permitting:

Section 404 Permit. A Section 404 permit is required by the Department of the Army Corps of Engineers for the discharge of fill material into waters of the United States. Waters of the United States include the area below the ordinary high-water mark of stream channels and lakes or ponds connected to the tributary system and wetlands of adjacent waters. The Department of the Army (DA) Corps of Engineers was advised of the recommended improvements in correspondence dated February 20, 2018. There has been no response as of this writing.

Stream Protection Act (124 SPA) Permit. If project-related activities affect the beds and banks of the streams, a 124 SPA permit will be required from the Montana Department of Fish, Wildlife & Parks (MFWP). The MFWP was advised of the recommended alternative in correspondence dated February 20, 2018. According to the response dated March 8, 2018, the site would need to be assessed for the presence of aquatic resources that may be regulated by Section 404 of the Clean Water Act.

Storm Water Discharge Permit. If construction disturbs more than 1 acre, a General Discharge Permit for Storm Water Associated with Construction Activity under the Montana Pollution Discharge Elimination System (MPDES) must be obtained. As a requirement of the Storm Water Discharge Permit, a Notice of Intent (NOI) form including a storm water erosion control plan specifying the measures that would be employed during construction to control erosion and sediment transport by storm runoff must be prepared and submitted to the Montana Department of Environmental Quality.

Mitigation: Employing erosion control measures is especially important in areas adjacent to surface waters where construction activities could encounter wetlands or riparian areas. Measures to control runoff and erosion from disturbed areas will be required of the Contractor to minimize potential water quality impacts during construction.

Key N, P	6.	Floodplains & Floodplain Management (Identify any floodplains within one mile of the boundary of the project.)
		Comments and Source of Information:
		Comment. Flood Insurance Rate Mapping (FIRM) for Lewis and Clark County and Incorporated Areas map #30049C2327E and map #30049C2331E, effective September 19, 2012 and for Jefferson County map #3001540050B effective June 17, 1986 shows portions of the recommended improvements to the East Helena water system are located within special flood hazard areas.
		The Montana Department of Natural Resources and Conservation (DNRC) Regional Engineering Marc Pitman was advised of the recommended improvements on February 20, 2018. A response received March 15, 2018 stated that any work in or under a mapped floodplain, including the Main Street stream crossing recommendation, would require a Floodplain Development Permit. Mr. Pitman also recommended contacting Helena DNRC Regional Manager Bryan Gartland regarding water rights during the development of the new well.
		Lewis and Clark County's Floodplain Administrator Lindsay Morgan was contacted on February 20, 2018 regarding the recommended alternatives. A response received March 16, 2018 stated the potential for a Floodplain Development Permit if the chlorination building at Wylie Well #3 was moved to Wylie Well #2.
		Jefferson County's Floodplain Administrator Megan Bullock were advised of this proposed project in correspondence dated March 1, 2018. A response has not been received as of this writing.
		The City of East Helena's Floodplain Administrator is working closely with consultants on the development of the recommended alternatives.
		Impacts. The proposed work is located within areas that have been previously disturbed. The proposed construction will not adversely affect the natural values and functions of the floodplain in this area.
		Permit. If the recommended improvements to the water system are located within the 100-year floodplain, floodplain development permits will be required.
<u>Key</u> N	7.	Wetlands Protection (Identify any wetlands within one mile of the boundary of the project.)
		Comments and Source of Information:
		Comment. According to the National Wetlands Inventory Wetlands Mapper, various wetlands including Estuarine and Marine Wetlands, Freshwater Emergent Wetlands, Freshwater Forested/Shrub Wetlands, Freshwater Pond and Riverine are located within 1 mile of the recommended water improvements. It is not anticipated that any designated wetlands will be impacted as part of the recommended water system improvements.

Key N	8.	Agricultural Lands, Production, & Farmland Protection (e.g., grazing, forestry, cropland, prime or unique agricultural lands) (Identify any prime or important farm ground or forest lands within one mile of the boundary of the project.) Comments and Source of Information: Comment. The recommended East Helena water system improvements are located in areas that are considered prime, unique, or important farmland. The USDA Natural Resources Conservation Service (NRCS) was advised of this project by letter dated February 20, 2018. No response has been made as of this writing. Impacts. The recommended improvements are located on land already irreversibly converted and land committed to water storage which are exempt from the Farmland Protection Policy Act (FPPA).
N, M	9.	Vegetation & Wildlife Species & Habitats, Including Fish (e.g., terrestrial, avian and aquatic life and habitats) Comments and Source of Information: Comment. Typical wildlife species in the East Helena planning area include: mule deer, white-tailed deer, eastern fox squirrel, mountain cottontail, white-tailed jack rabbit, muskrat, red fox and meadow vole, and numerous nesting and migrant bird species. Surface waters associated channels, tributaries, wetlands and adjoining uplands provide important wildlife habitats in the project area. Various wildlife species depend on these habitats which are intermixed with urban development, rural homes, and agricultural uses. Impacts. The recommended improvements would not cause any long-term adverse impacts to wildlife and their habitat since work is confined within previously disturbed areas. Short-term impacts on small mammals and bird species may occur during construction. Temporary displacement due to noise or construction activities could affect such species. The Montana Department of Fish, Wildlife and Parks (FWP) was contacted on February 20, 2018 regarding potential impacts on wildlife and fishery resources. No reply has been received as of this writing. Mitigation Required. The Contractor will be required to implement erosion control measures to minimize the potential for erosion and sedimentation impacts on nearby surface waters and fisheries. Additionally, surface areas disturbed by construction will be promptly revegetated.

<u>Key</u> N, M	10.	Unique, Endangered, Fragile, or Limited Environmental Resources, Including Endangered Species (e.g., plants, fish, sage grouse, or other wildlife)
		Comments and Source of Information:
		Comment. The following paragraphs discuss unique, endangered, fragile, or limited environmental resources in the project area:
		Threatened or Endangered Wildlife - The U.S. Fish and Wildlife Service (USFWS) was contacted on February 20, 2018 regarding the presence of threatened or endangered species in the proposed East Helena planning area. Correspondence from the USFWS dated February 27, 2018 suggested using the Department's online Information for Planning and Consultation (IPaC) website for updated information on the planning area. According to IPaC, there are 3 threatened or endangered species (the Canada Lynx, the Grizzly Bear, and the North American Wolverine) that may occur in the planning area as well as migratory birds. There is no designated critical habitat in the planning area.
		 Threatened or Endangered Plants - There are three federally-listed threatened plant species in Montana: Water Howellia, Spalding's Catchfly, and Ute Ladies'-tress. The USFWS does not list any of these species within the planning area.
		Species of Special Interest or Concern - The Montana Natural Heritage Program lists 25 animal species and 3 plant species of special concern, 1 animal species of special status and 1 plant species considered a potential species of concern that have been observed within the areas quarter-quarter lat. long. that includes the East Helena project.
		 Sage Grouse - According to the Montana Sage Grouse Habitat Conservation Map, the recommended improvements to the East Helena water system are not located in sage grouse habitat designated as core, general, connectivity habitats or BLM priority areas. Therefore, no further coordination regarding sage grouse is required.
		Impacts. Based on the nature, scope, and location of the recommended improvements, no adverse impacts to unique, endangered, fragile, or limited environmental resources are expected.
		Mitigation. If active eagle nests are present within 0.5 mile of the project during construction, t seasonal restrictions and construction / development distance buffers specified in the 2010 Montana Bald Eagle Management Guidelines: An Addendum to Montana Bald Eagle Management Plan (1994) should be followed in order to avoid/minimize the risk for eagle take.
<u>Key</u>	11.	Unique Natural Features (e.g., geologic features)
<u> </u>		Comments and Source of Information:
		Comment. There are no known unique natural features that are anticipated to be impacted in the East Helena area as a result of the recommended alternatives.

Key N	12.	Access to, and Quality of, Recreational & Wilderness Activities, Public Lands and Waterways (including Federally Designated Wild & Scenic Rivers), and Public Open Space Comments and Source of Information: Comment. The recommended East Helena water system improvements would have no effect on the access to or the quality of recreational and wilderness activities, public lands and waterways, and public open space.
HUMAN POP	ULAT	ION
<u>Key</u> N	1.	Visual Quality – Coherence, Diversity, Compatibility of Use and Scale, Aesthetics
		Comments and Source of Information:
		Comment. The recommended East Helena water system improvements would have no long-term adverse effects on the visual quality of the area. A new storage tank would be constructed below ground with only the top 2' visible just as the existing tanks are constructed. Land surfaces would be temporarily disturbed during construction but returned to pre-project conditions after construction.
<u>Key</u>	2.	Nuisances (e.g., glare, fumes)
<u>N</u>		Comments and Source of Information:
		Comment. There are no anticipated nuisances associated with the recommended alternatives.
Key N	3.	Noise suitable separation between noise sensitive activities (such as residential areas) and major noise sources (aircraft, highways & railroads)
		Comments and Source of Information:
		Comment. Temporary increases in noise would be expected during the construction of the recommended East Helena water system improvements. Such impacts would be localized to the area of construction and short-term in nature.

Key	4.	Historic Properties, Cultural, and Archaeological Resources
N, M	4.	Comments and Source of Information: Comment. The Montana State Historic Preservation Office (SHPO) was contacted on February 20, 2018 for information about previous cultural resource surveys completed and for a listing of previously recorded historical and archaeological sites in the East Helena water planning area. Impacts. In correspondence dated February 23, 2018, SHPO stated that any structure over fifty years of age is considered historic and is potentially eligible for listing on the National Register of Historic Places. SHPO also stated that they feel there is low likelihood cultural properties will be impacted in areas that have had previous ground disturbance and the need for a cultural resource inventory is unwarranted at this time. Mitigation. If any structures are to be altered and are over fifty years old SHPO recommends that they be recorded and a determination of their eligibility be made. If there is to be new ground disturbance in previously undisturbed areas, SHPO also recommends that a cultural resource inventory be conducted in order to determine whether or not sites exist and if they will be impacted.
Key N, B	5.	Changes in Demographic (population) Characteristics (e.g., quantity, distribution, density) Comments and Source of Information: Comment. The recommended East Helena water system improvements will not have a major impact on the location, distribution, density or growth rate of the area's population. The recommended improvements would not adversely affect any social or ethnic groups and will not isolate or divide existing residential areas. Impact. According to the City of East Helena's 2014 Growth Policy, the City will see a 1.45% growth rate over the next 20 years. Improvements to the municipal water system will ensure the City can meet future water demands.
Key N	6.	Environmental Justice – (Does the project avoid placing lower income households in areas where environmental degradation has occurred, such as adjacent to brownfield sites?) Comments and Source of Information: Comment. The recommended East Helena water system improvements will not place lower income households in areas where environmental degradation has occurred.
Key N	7.	General Housing Conditions - Quality, Quantity, Affordability Comments and Source of Information: Comment. The recommended East Helena water system improvements would have little effect on the quality, quantity, or affordability of housing in East Helena or surrounding portions of Lewis and Clark County.

Key	8.	Displacement or Relocation of Businesses or Residents
<u>N</u>		Comments and Source of Information:
		Comment. The recommended East Helena water system improvements would not displace or relocate any businesses or residents in the area.
Key	9.	Public Health and Safety
<u>B</u>		Comments and Source of Information:
		Comment. Groundwater evaluations in the area have indicated that dissolved arsenic and selenium plumes originating from the ASARCO Smelter site have migrated generally northward creating a potential vulnerability for Wylie Well #3. The selenium plume originating from the ASARCO Smelter is approximately 1,250 feet from the well. Also, dead-ends in the distribution system can lead to low pressure, inadequate fire flow, and stagnant water. Stagnation can cause water quality issues for the system and a potential health risk.
		Impacts. A new production well will ensure the City's municipal water will not be contaminated by the nearby selenium plume and elimination of the dead-end mains in the distribution system will help prevent low pressure, inadequate fire flow, and stagnant water.
Key	10.	Lead Based Paint and/or Asbestos
<u>N</u>		Comments and Source of Information:
		Comment. The handling of any lead based paint and/or asbestos is not anticipated as part of the recommended improvements.
Key_	11.	Local Employment & Income Patterns - Quantity and Distribution of Employment, Economic Impact
<u>B</u>		Comments and Source of Information:
		Comment. Construction of the recommended East Helena water system improvements would temporarily create jobs and the need for local goods and services resulting in short-term economic benefits to the City of East Helena and Lewis and Clark County. Completion of this project will not cause any long-term changes in the local economy.
Key	12.	Local & State Tax Base & Revenues
<u>B</u>		Comments and Source of Information:
		Comments. The recommended East Helena water system improvements will benefit the City of East Helena overtime by expanding the tax base through new residential and commercial development.

Key	13.	Educational Facilities - Schools, Colleges, Universities
<u> N</u>		Comments and Source of Information:
		Comment. The recommended East Helena water system improvements would not adversely affect any education facility in the area.
<u>Key</u> B	14.	Commercial and Industrial Facilities - Production & Activity, Growth or Decline
		Comments and Source of Information:
		Comment. The recommended water main improvements to loop the Manlove water main will provide the American Chemet building with significantly higher fire flows. Currently, fire flows in the area do not meet the needed fire flow.
Key	15.	Health Care – Medical Services
<u> </u>		Comments and Source of Information:
		Comment. The recommended East Helena water system improvements will not affect existing health care or medical services nor create the demand for additional medical services.
Key	16.	Social Services – Governmental Services (e.g., demand on)
<u> </u>		Comments and Source of Information:
		Comment. The recommended improvements will not affect the demand for social or governmental services.
<u>Key</u>	17.	Social Structures & Mores (Standards of Social Conduct/Social Conventions)
<u> </u>		Comments and Source of Information:
		Comment. The recommended East Helena water system improvements will not affect social structures or community mores.
Key B	18.	Land Use Compatibility (e.g., growth, land use change, development activity, adjacent land uses and potential conflicts)
		Comments and Source of Information:
		Comment. No major changes in land use within the East Helena planning area are expected. The recommended improvements will allow the City of East Helena to better accommodate new residential and commercial development to the community. Any new development within the community will be subject to existing land use plans and land use controls.

<u>Key</u>	19.	Energy Resources - Consumption and Conservation
<u> </u>		Comments and Source of Information:
		Comment. There will be no long-lasting adverse impact on the energy supply of the areas. Energy use would increase for a short time during the construction of the recommended East Helena water system improvements due to the need for construction equipment.
Key N	20.	Solid Waste Management
		Comments and Source of Information:
		Comment. The recommended water system improvements would not affect the generation and management of solid waste within the community.
<u>Key</u>	21.	Wastewater Treatment - Sewage System
<u> </u>		Comments and Source of Information:
		Comment. The recommended City of East Helena water system improvements would not affect the community's wastewater system.
<u>Key</u>	22.	Storm Water – Surface Drainage
<u> </u>		Comments and Source of Information:
		Comment. The recommended water system improvements project would have no long-term effects on storm water and surface drainage.
<u>Key</u>	23.	Community Water Supply
<u>B</u>		Comments and Source of Information:
		Comment. The recommended East Helena water system improvements will provide a great benefit to the community's water supply. Several significant threats to the public health and safety will be reduced and/or eliminated by the improvements to the municipal water system including a new production well, a new storage reservoir, elimination of dead-ends in the system including the re-connection of the Main Street main and looping of the distribution system to provide adequate fire flow, as well as the installation of a bridge over McClellan Creek to access the infiltration gallery.
<u>Key</u>	24.	Public Safety – Police
<u> </u>		Comments and Source of Information:
		Comment. The recommended East Helena water system improvements would not affect public safety or increase the need for additional law enforcement.

<u>Key</u>	25.	Fire Protection – Hazards
<u>B</u>		Comments and Source of Information:
		Comments. Increasing the storage capacity and looping the water system will increase the available fire flow for the City.
<u>Key</u>	26.	Emergency Medical Services
<u> </u>		Comments and Source of Information:
		Comment. The recommended East Helena water system improvements would not increase the need for emergency medical services.
<u>Key</u>	27.	Parks, Playgrounds, & Open Space
<u> </u>		Comments and Source of Information:
		Comment. No public parks, playgrounds, or open space would be adversely affected by the recommended East Helena water system improvements.
Key	28.	Cultural Facilities, Cultural Uniqueness & Diversity
<u> </u>		Comments and Source of Information:
		Comment. The recommended water system improvements would not affect cultural facilities or the cultural uniqueness and diversity of East Helena or Lewis and Clark County.
Key N, P	29.	Transportation Networks and Traffic Flow Conflicts (e.g., rail; auto including local traffic; airport runway clear zones - avoidance of incompatible land use in airport runway clear zones)
		Comments and Source of Information:
		Comment. The Montana Department of Transportation (MDT) is responsible for maintenance on Main Street. MDT was contacted on February 20, 2018 regarding the recommended water system improvements. There has been no response as of this writing.
		Construction of the recommended improvements may cause temporary disturbances to vehicle traffic on local streets and roads in area. However, traffic control plans will be implemented to ensure that alternate routes within the community are available and that work areas are marked to ensure that local traffic is safely accommodated during construction. A traffic control plan for the Main Street stream crossing will be submitted to and approved by MDT prior to the start of construction.
		A contractor's agreement with MDT will also be required. This agreement between MDT and the construction contractor will allow additional oversite and penalties if work is not constructed properly and in a timely manner.

		Permits. MDT will require an encroachment permit for work located in MDT right-of-way. The permit must include this environmental checklist and all supporting documentation.
Key B	30.	Consistency with Local Ordinances, Resolutions, or Plans (e.g., conformance with local comprehensive plans, zoning, or capital improvement plans)
		Comments and Source of Information:
		Comment. According to the Capital Improvements Plan for the City of East Helena, April 2017, the recommended water system improvements are consistent with the City of East Helena's long-term plans for its water system. The recommended East Helena water system improvements project not conflict with any other local ordinances, resolutions, or plans.
Key N	31.	Is There a Regulatory Action on Private Property Rights as a Result of this Project? (consider options that reduce, minimize, or eliminate the regulation of private property rights.)
		Comments and Source of Information:
		Comment. The recommended East Helena water system improvements will not involve any regulatory actions that would affect private property rights.

APPENDIX B – WELL LOGS

Wyhe Well#1

MONTANA WELL LOG REPORT

This well log reports the activities of a licensed Montana well driller. serves as the official record of work done within the borehole and casing, and describes the amount of water encountered. This report is compiled electronically from the contents of the Ground Water Information Center (GWIC) database for this site. Acquiring water rights is the well owner's responsibility and is NOT accomplished by the filing of this report.

Other Options

Return to menu Plot this site in State Library Digital Atlas Plot this site in Google Maps View scanned well log (10/23/2006 1:34:47 PM)

Site Name: EAST HELENA CITY OF

GWIC Id: 61839

DNRC Water Right: W113655-00

Section 1: Well Owner(s)

1) EAST HELENA CITY OF (MAIL) 2970 CANYON FERRY RD

EAST HELENA MT 59635 [03/22/1965]

Section 2: Location

Township Section **Quarter Sections** 10N 03W SE1/4 SE1/4 SE1/4 County Geocode

LEWIS AND CLARK

Latitude Longitude Geomethod Datum 46.6177 -111.9371 MAP NAD27

3796

Addition **Block** Lot

Section 3: Proposed Use of Water

PUBLIC WATER SUPPLY (1)

Section 4: Type of Work

Drilling Method: CAISSON DRILLED

Status: NEW WELL

Section 5: Well Completion Date

Date well completed: Monday, March 22, 1965

Section 6: Well Construction Details

Borehole dimensions From To Diameter 0 110 56

Casing

From	То	Diameter	Wall Thickness	Pressure Rating	Joint	Туре
0	30	48				STEEL
0	90	16				STEEL

Completion (Perf/Screen)

From	То		 Size of Openings	Description
90	110	16		SS LOUVER SCREEN

Annular Space (Seal/Grout/Packer)

			Cont.
From	То	Description	Fed?
0	0	CEMENT	

Section 7: Well Test Data

Total Depth: 110 Static Water Level: 34 Water Temperature:

Pump Test *

Depth pump set for test _ feet.

600 gpm pump rate with _ feet of drawdown after 12 hours

of pumping.

Time of recovery _ hours. Recovery water level _ feet. Pumping water level 54 feet.

* During the well test the discharge rate shall be as uniform Ground Surface Altitude Ground Surface Method Datum Date as possible. This rate may or may not be the sustainable yield of the well. Sustainable yield does not include the reservoir of the well casing.

Section 8: Remarks

Section 9: Well Log Geologic Source

110ALVM - ALLUVIUM (QUATERNARY)

TOAL	-VIVI - /	ALLUVIUM (QUATERNARY)
From	То	Description
0	37	ROCKS SAND & BOULDERS
37	46	ROCK SAND BOULDERS W/ CLAY STREAKS
46	51	HARDPAN & ROCK
51	110	ROCK SAND BOULDERS W/ STREAKS OF CLAY
-		

Driller Certification

All work performed and reported in this well log is in compliance with the Montana well construction standards. This report is true to the best of my knowledge.

Company: LAYNE-MINNESOTA

License No: WWC-76

Date 3/22/1965 Completed:

Wylie Well #2

MONTANA WELL LOG REPORT

This well log reports the activities of a licensed Montana well driller. serves as the official record of work done within the borehole and casing, and describes the amount of water encountered. This report is compiled electronically from the contents of the Ground Water Information Center (GWIC) database for this site. Acquiring water rights is the well owner's responsibility and is NOT accomplished by the filing of this report.

Other Options

Return to menu Plot this site in State Library Digital Atlas Plot this site in Google Maps View scanned well log (10/31/2006 9:12:03 AM)

Site Name: EAST HELENA CITY OF

GWIC Id: 62116

DNRC Water Right: W113656-00

Section 1: Well Owner(s)

1) EAST HELENA CITY OF (MAIL)

2995 WYLIE DR

EAST HELENA MT 59635 [04/10/1965]

Section 2: Location

Township Section **Quarter Sections** 10N 03W 24 SE1/4 NW1/4 NW1/4 County Geocode

LEWIS AND CLARK

Latitude Longitude Geomethod Datum 46.6128 -111.9345 MAP NAD27

Ground Surface Altitude Ground Surface Method Datum Date

3807

Addition Block Lot

* During the well test the discharge rate shall be as uniform as possible. This rate may or may not be the sustainable yield of the well. Sustainable yield does not include the reservoir of the well casing.

600 gpm pump rate with _ feet of drawdown after 12 hours

Section 3: Proposed Use of Water

PUBLIC WATER SUPPLY (1)

Section 4: Type of Work

Drilling Method: CAISSON Status: NEW WELL

Section 5: Well Completion Date

Date well completed: Saturday, April 10, 1965

Section 6: Well Construction Details

Borehole dimensions From To Diameter 0 92 56

Casing

From	То	Diameter	Wall Thickness	Pressure Rating	Joint	Туре
0	30	48				STEEL
0	88	16				STEEL

Completion (Perf/Screen)

From	То		Size of Openings	Description
58	88	0		OPEN BOTTOM
58	88	16		SS LOUVER SCREEN

Annular Space (Seal/Grout/Packer)

			Cont.
From	То	Description	Fed?
0	0	CEMENT	

Section 8: Remarks

Section 7: Well Test Data

Depth pump set for test _ feet.

Time of recovery _ hours.

Recovery water level _ feet.

Pumping water level 54 feet.

Total Depth: 92 Static Water Level: 39 Water Temperature:

Pump Test*

of pumping.

Section 9: Well Log **Geologic Source**

110ALVM - ALLUVIUM (QUATERNARY)

From	То	Description
0	38	TOPSOIL ROCK BOULDERS AND SANDY CLAY
38	45	ROCK BOULDERS SAND WITH STREAKS OF CLAY
45	69	ROCK CLAY SAND AND HARDPAN
69	92	ROCK SAND STREAKS OF CLAY
-		

Driller Certification

All work performed and reported in this well log is in compliance with the Montana well construction standards. This report is true to the best of my knowledge.

Company: LAYNE-MINNESOTA

License No: WWC-76

Date 4/10/1965

Wylie Well #3

MONTANA WELL LOG REPORT

This well log reports the activities of a licensed Montana well driller. serves as the official record of work done within the borehole and casing, and describes the amount of water encountered. This report is compiled electronically from the contents of the Ground Water Information Center (GWIC) database for this site. Acquiring water rights is the well owner's responsibility and is NOT accomplished by the filing of this report.

Other Options

Return to menu Plot this site in State Library Digital Atlas Plot this site in Google Maps View scanned well log (10/31/2006 11:50:01 AM)

Site Name: CITY OF EAST HELENA

GWIC Id: 62125

DNRC Water Right: P062231-00

Section 1: Well Owner(s)

1) CITY OF EAST HELENA (MAIL)

2700 WYLIE DR

EAST HELENA MT 59635 [10/16/1987]

Range

03W

County

Section 2: Location

Township 10N

Section 24

Quarter Sections SW1/4 NW1/4 SW1/4

Geocode

LEWIS AND CLARK

Latitude 46.60591

Longitude -111.93585 Geomethod MAP

Datum NAD83

Ground Surface Altitude Ground Surface Method Datum Date

Section 7: Well Test Data

Total Depth: 153 Static Water Level: 35 Water Temperature:

Pump Test *

Depth pump set for test _ feet.

550 gpm pump rate with _ feet of drawdown after 24 hours

of pumping.

Time of recovery _ hours. Recovery water level feet. Pumping water level 80 feet.

* During the well test the discharge rate shall be as uniform as possible. This rate may or may not be the sustainable yield of the well. Sustainable yield does not include the reservoir of the well casing.

Addition

Block

Lot

Section 8: Remarks

Section 9: Well Log **Geologic Source**

120SDMS - SEDIMENTS (TERTIARY)

From	То	Description
0	20	SILTY LOAM WITH GRAVELS
20	35	GRAVELY CLAYS
35	54	FINE, SANDY CLAY
54	58	MED. GRAVELS
58	71	CLAY AND GRAVELS
71	74	COARSE GRAVELS
74	80	CLEAN GRAVELS
80	84	SILTY GRAVELS
84	88	COARSE GRAVELS
88	99	SILTY GRAVELS
99	107	COARSE TO FINE GRAVELS
107	119	FINE TO COARSE, SILTY CLAYBOUND AND GRAVELS
119	153	SOFT SILTSTONE

Section 3: Proposed Use of Water

PUBLIC WATER SUPPLY (1)

Section 4: Type of Work

Drilling Method: FORWARD ROTARY

Status: NEW WELL

Section 5: Well Completion Date

Date well completed: Friday, October 16, 1987

Section 6: Well Construction Details

Borehole dimensions From To Diameter 0 153

Casina

From	То	Diameter	Wall Thickness	Pressure Rating	Joint	Туре
-2	70	12				50 LB STEEL
-2	153	10				STEEL
7	119	10				STEEL

Completion (Perf/Screen) # of Size of Diameter Openings Openings Description FromITo STAINLESS STAIN 119 10 SCREEN

Annular Space (Spal/Grout/Packer)

Amiu	ai .	Space (Seal/Group acke	
			Cont.
From	То	Description	Fed?
0	51	CEMENT & BENTONITE	

Driller Certification

All work performed and reported in this well log is in compliance with the Montana well construction standards. This report is true to the best of my knowledge.

Name:

Company: POTTS DRILLING INC

License No: WWC-150

Date 10/16/1987

Completed:

MONTANA WELL LOG REPORT

This well log reports the activities of a licensed Montana well driller, serves as the official record of work done within the borehole and casing, and describes the amount of water encountered. This report is compiled electronically from the contents of the Ground Water Information Center (GWIC) database for this site. Acquiring water rights is the well owner's responsibility and is NOT accomplished by the filing of this report.

Other Options

Return to menu Plot this site in State Library Digital Atlas Plot this site in Google Maps View field visits for this site View water quality for this site

Site Name: CITY OF EAST HELENA - MCCLELLAN

CREEK INFILTRATION GALLERIES

GWIC Id: 139051

DNRC Water Right: P070576-00

Section 1: Well Owner(s)

1) CITY OF EAST HELENA (MAIL)

PO BOX 1170

EAST HELENA MT 59635 [12/30/1992]

Section 2: Location

Township Range Section **Quarter Sections** 09N 02W NW1/4 NE1/4 SE1/4 SE1/4 7 County Geocode

JEFFERSON

Latitude Longitude Geomethod Datum NAD27 46.5467 -111.8948 MAP

Ground Surface Altitude Ground Surface Method Datum Date

4100

Addition Block Lot

Section 3: Proposed Use of Water

PUBLIC WATER SUPPLY (1)

Section 4: Type of Work

Drilling Method: Status: NEW WELL

Section 5: Well Completion Date

Date well completed: N/A

Section 6: Well Construction Details

There are no borehole dimensions assigned to this well. There are no casing strings assigned to this well. There are no completion records assigned to this well.

Annular Space (Seal/Grout/Packer)

There are no annular space records assigned to this well.

Section 7: Well Test Data

Total Depth: 16 Static Water Level: Water Temperature:

Unknown Test Method *

Yield 600 gpm. Pumping water level _ feet. Time of recovery _ hours. Recovery water level _ feet.

* During the well test the discharge rate shall be as uniform as possible. This rate may or may not be the sustainable yield of the well. Sustainable yield does not include the reservoir of the well casing.

Section 8: Remarks

MCCLELLAN CREEK INFILTRATION GALLERIES - DATA FROM DEQ AND DNRC.

Section 9: Well Log **Geologic Source**

110ALVM - ALLUVIUM (QUATERNARY)

Lithology Data

There are no lithologic details assigned to this well.

Driller Certification

All work performed and reported in this well log is in compliance with the Montana well construction standards. This report is true to the best of my knowledge.

Name: Company: License No: -Date

Completed:

Ground-Water Information Center

Site Name: CITY OF EAST HELENA - MCCLELLAN CREEK INFILTRATION GALLERIES

Infil tration Gallery

Oxygen (O18 of Sulfate):

NR

Notes

Isotope Tracer Report Report Date: 12/21/2017

Location Information

Sample Id/Site Id: 1992R1351 / 139051 Sample Date: 9/25/1992 Location (TRS): 09N 02W 07 DDAB Agency/Sampler: MBMG / KJM

Latitude/Longitude: 46° 32' 48" N 111° 53' 41" W Field Number: EH 01C Datum: NAD27 Lab Date: 9/27/1992 Altitude: 4100 Lab/Analyst: MBMG / SFM

County/State: JEFFERSON / MT Sample Method/Handling: / 1000 Site Type: WELL Procedure Type: DISSOLVED Geology: 110ALVM Total Depth (ft): 16

USGS 7.5' Quad: EAST HELENA SWL-MP (ft): NR PWS Id: 00196005 Depth Water Enters (ft): NR

Project: RADON, PWSINV

Radon (Rn222 - pC/L): Argon (Ar39): NR 542.000 Carbon (C13): NR Silicon (Si32): NR Carbon (C14): NR Chlorine (Cl36): NR Tritium (H3 - TU): Lithium (Li6): NR NR H3/He3 Ratio: NR Krypton (Kr85): NR Deuterium (H2): Boron (B11) NR NR Oxygen (O18): NR Strontium (Sr87) NR Sulphur (S34): NR Chloro-fluorocarbon (CFC-11): NR Iodine (I129): NR Chloro-fluorocarbon (CFC-12): NR Chloro-fluorocarbon (CFC-113): Nitrogen (N15): NR NR Oxygen (O18 of Nitrate): Nitrogen (N15 of Nitrate): NR NR

Sample Condition:

Field Remarks: RADON SAMPLE

Lab Remarks:

Explanation: pC/L = picocuries per Liter; TU = Tritium Units; NR = No Reading in GWIC

Sulphur (S34 of Sulfate):

Disclaimer

These data represent the contents of the GWIC databases at the Montana Bureau of Mines and Geology at the time and date of the retrieval. The information is considered unpublished and is subject to correction and review on a daily basis. The Bureau warrants the accurate transmission of the data to the original end user. Retransmission of the data to other users is discouraged and the Bureau claims no responsibility if the material is retransmitted.

NR

APPENDIX C – PRECIPITATION RECORDS

HELENA AIRPORT ASOS, MT

Total of Precipitation (Inches)

(244055)

File last updated on February 27, 2018

a = 1 day missing, b = 2 days missing, c = 3 days, ..etc..,

z = 26 or more days missing, A = Accumulations present

Long-term means based on columns; thus, the monthly row may not sum (or average) to the long-term annual value.

MAXIMUM ALLOWABLE NUMBER OF MISSING DAYS: 5

Individual Months not used for annual or monthly statistics if more than 5 days are missing. Individual Years not used for annual statistics if any month in that year has more than 5 days missing.

YEAR (S)	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC	ANN
1938	Z	Z	Z	0.31	3.10	2.38	1.18	1.43	0.65	1.79	0.28	0.06	11.18 c
1939	0.06	$0.41\mathrm{p}$	0.23 u	0.47	1.22	2.28	0.50	0.58	0.97	1.05	0.01	0.20	7.34b
1940	0.35	0.40	1.15	0.86	1.37	1.46	1.79	0.00	2.00	0.42	0.36	0.04	10.20
1941	0.25	0.15	0.31	1.74	1.67	2.86	2.29	0.61	2.27	0.88	0.40	0.77	14.20
1942	0.60	0.49	0.51	0.55	2.35	1.96	0.48	0.60	0.66	0.58	0.87	0.29	9.94
1943	1.09	0.38	0.39	1.45	0.67	2.49	0.18	0.89	0.78	0.51	0.23	0.19	9.25
1944	0.03	0.47	0.51	0.55	1.79	4.74	1.42	1.62	0.82	0.04	0.47	0.37	12.83
1945	0.08	0.07	0.90	0.58	1.94	2.79	0.29	0.46	1.46	0.23	0.25	0.60	9.65
1946	0.20	0.21	0.56	0.33	2.40	1.27	1.41	0.48	2.51	1.24	0.89	0.94	12.44
1947	0.34	0.37	1.10	0.81	0.48	4.34	0.95	0.50	3.05	0.55	1.40	0.27	14.16
1948	0.51	0.22	0.49	0.58	2.58	3.40	1.85	1.02	0.31	0.05	0.61	0.80	12.42
1949	0.66	0.59	0.69	0.61	2.18	1.56	0.33	0.66	1.08	0.28	0.15	0.37	9.16
1950	1.05	0.14	0.82	1.25	1.36	2.18	0.72	1.35	0.99	0.43	1.50	0.61	12.40
1951	0.38	0.24	0.84	1.58	1.00	1.61	1.81	1.58	0.81	0.79	0.31	1.08	12.03
1952	0.15	0.56	1.27	0.37	2.16	1.34	0.62	0.66	0.18	0.35	1.05	0.28	8.99
1953	0.51	1.02	0.22	0.83	2.72	1.76	0.14	0.59	0.34	0.13	0.20	0.42	8.88
1954	1.26	0.10	0.46	0.73	1.17	2.15	1.14	1.35	0.65	0.86	0.48	0.13	10.48
1955	0.19	0.20	1.28	1.32	1.02	2.19	2.70	0.24	0.24	0.19	1.22	1.13	11.92
1956	0.64	0.09	0.42	0.67	1.28	1.80	1.04	1.43	0.16	1.02	0.12	0.46	9.13
1957	0.95	0.30	1.19	0.67	3.25	2.23	0.79	1.23	1.85	1.27	0.61	0.31	14.65
1958	0.16	0.95	1.13	0.83	1.34	4.28	1.26	0.59	0.42	0.20	0.74	1.01	12.91
1959	0.43	1.13	0.02	0.35	1.93	1.90	0.11	0.36	0.46	0.95	1.45	0.28	9.37
1960	0.23	0.25	0.22	1.56	0.94	0.25	1.02	2.12	0.13	0.26	0.19	0.34	7.51
1961	0.12	0.06	1.03	0.90	1.36	0.78	1.05	0.62	1.16	0.16	0.37	0.55	8.16
1962	0.67	0.51	0.69	0.90	3.77	2.50	1.27	1.80	0.31	0.95	0.57	0.14	14.08
1963	0.50	0.25	0.44	0.81	1.34	2.59	0.80	0.80	1.10	1.39	0.29	1.27	11.58

1964	0.31	0.27	0.51	1.56	3.52	2.98	0.83	1.91	0.16	0.04	0.53	0.99	13.61
1965	0.36	0.49	0.85	0.98	2.20	3.85	0.60	1.92	3.37	0.13	0.62	0.15	15.52
1966	0.46	0.33	0.28	0.51	0.43	0.96	0.32	0.42	0.34	0.75	1.04	0.62	6.46
1967	0.61	0.62	1.43	2.38	2.08	2.36	0.46	0.58	0.68	1.50	0.31	1.39	14.40
1968	0.59	0.16	0.53	1.21	1.62	2.68	0.26	2.00	2.22	0.23	0.92	0.75	13.17
1969	2.78	0.22	0.57	0.60	1.13	3.50	1.77	0.38	0.33	1.06	0.04	0.31	12.69
1970	0.51	0.67	0.96	0.81	1.20	2.11	0.93	0.63	0.36	0.58	0.44	0.54	9.74
1971	1.38	0.63	0.41	0.58	1.77	0.93	0.56	1.22	0.89	0.39	0.34	1.02	10.12
1972	1.12	0.54	0.63	0.41	0.77	1.12	0.56	1.63	0.08	0.57	0.33	0.46	8.22
1973	0.22	0.13	0.05	0.66	1.08	0.73	0.08	0.56	0.43	0.66	1.03	0.63	6.26
1974	0.66	0.23	0.38	0.76	2.07	0.34	0.49	4.23	0.22	0.51	0.30	0.26	10.45
1975	1.26	0.72	0.88	3.00	1.95	2.83	3.89	2.47	0.47	2.68	0.48	0.31	20.94
1976	0.26	0.38	0.41	1.34	0.87	2.74	0.29	1.58	1.82	0.04	0.30	0.04	10.07
1977	0.65	0.13	1.11	0.10	1.82	1.37	1.37	0.72	1.93	0.17	0.48	1.48	11.33
1978	0.96	0.61	0.31	0.94	1.20	0.44	2.83	0.59	1.11	0.02	1.19	0.76	10.96
1979	0.77	0.72	1.34	2.26	0.29	2.75	0.32	0.79	0.12	0.38	0.06	0.59	10.39
1980	0.62	0.74	0.88	0.63	4.32	3.16	1.92	0.28	2.57	1.21	0.32	0.40	17.05
1981	0.15	0.10	1.10	0.75	6.09	1.15	1.78	0.10	0.90	0.82	0.54	0.33	13.81
1982	0.80	0.58	1.62	0.54	1.77	2.99	0.49	0.74	2.74	0.35	0.31	1.05	13.98
1983	0.24	0.07	0.36	0.29	1.79	2.20	3.48	2.67	1.56	0.35	0.26	0.76	14.03
1984	0.17	0.15	0.49	1.45	1.03	2.14	0.11	1.11	0.73	0.74	0.47	0.41	9.00
1985	0.16	0.38	0.32	0.46	0.75	0.08	0.10	2.64	2.11	0.76	0.84	0.35	8.95
1986	0.32	1.20	0.49	1.08	0.83	1.56	1.37	1.84	2.45	0.03	0.54	0.38	12.09
1987	0.00	0.03	1.19	0.76	1.90	1.50	2.88	0.38	0.80	0.05	0.12	0.42	10.03
1988	0.27	0.50	0.45	1.32	1.82	1.50	0.36	0.02	2.09	0.69	0.69	0.32	10.03
1989	1.42	0.82	1.35	0.72	1.00	1.43	1.55	1.61	1.31	0.54	0.26	0.48	12.49
1990	0.47	0.14	0.91	0.43	1.54	0.92	0.40	2.57	0.11	0.11	0.36	0.47	8.43
1991	0.27	0.02	0.90	0.75	1.71	3.27	0.72	0.70	1.26	0.65	0.88	0.79	11.92
1992	0.29	0.10	0.60	0.55	0.64	2.36	1.06	1.01	0.09	1.87	0.19	0.57	9.33
1993	0.80	1.03	0.56	1.63	1.71	3.14	4.70	2.79	1.25	0.71	0.36	0.13	18.81
1994	0.20	0.40	0.32	1.45	1.23	0.84	0.71	0.47	0.09	1.14	0.55 a	0.07	7.47
1995	0.20	0.08	0.49	1.15	3.09	2.93	1.51	0.33	1.59	0.10a	0.62	0.32	12.41
1996	0.55	0.11	0.58	0.70	2.42	1.20	1.27	0.89	0.51	0.04	0.84	0.61	9.72
1997	0.28	0.10	0.10	0.20	2.35	2.43	1.25	1.79	0.31	1.62	0.13	0.01	10.57
1998	0.49	0.12	0.39	0.64	2.27	3.03	2.96	0.50	0.82	0.14	1.07	0.14	12.57
1999	0.38	0.26	0.02	1.05	2.19	2.15	0.41	1.92	0.54	0.39	0.13	0.10	9.54
2000	0.26	0.32	0.26	0.73	0.98	1.42	0.73	0.43	0.54	2.12	0.36	0.23	8.38
2001	0.27	0.17	0.44	1.39	1.23	2.11	1.94	0.43	1.38	0.54	0.13	0.28	10.31
2002	0.04	0.29	0.52	0.61	1.86	4.36	1.61	1.32	1.22	0.16	0.50	0.05	12.54
2003	0.41	0.29	0.74	2.27	1.25	1.49	0.23	1.03	0.74	0.34	0.20	0.35	9.34
2004	0.26	0.17	0.37	1.82	2.21	1.07	0.68	2.84	1.76	0.41	0.10	0.36	12.05
2005	0.26	0.06	0.86	0.90	2.11	4.55	0.07	0.29	0.72	0.94	0.77	0.63	12.16
2006	0.22	0.24	0.60	2.95	1.77	2.69	0.39	0.25	1.17	1.32	0.55	0.38	12.53
2007	0.09	0.63	0.14	0.82	3.25	1.44	0.31	0.39	1.69 a	0.96	0.63	0.01	10.36

2008	0.49	0.31	0.12	0.49	2.62	1.58	0.47	0.45	0.70	0.38	0.86	0.77	9.24
2009	0.40	0.22	1.17	0.60	0.43	1.45	1.82	1.86	0.97	0.89	0.13	0.31	10.25
2010	0.50	0.14	0.24	0.74	2.13	2.85	0.40	2.59	0.83	0.46	1.33	0.76	12.97
2011	0.22	0.92	0.41	0.78	2.81	4.05	1.68	0.98	0.04	0.55	0.77	0.07	13.28
2012	1.28	0.55	0.89	0.59	1.35	0.54	0.61	0.66	0.00	0.65	1.78	0.87	9.77
2013	0.35	0.32	0.09	0.78	2.04	1.95	0.88	1.71	1.46	0.56	0.15	0.29	10.58
2014	0.55	1.98	0.80	0.87	0.28	1.71	0.56	2.11	1.10	0.40	1.07	0.81	12.24
2015	0.64	0.38	0.15	0.53	2.36	0.50	1.28	0.28	2.08	0.13	0.83	0.74	9.90
2016	0.31	0.16	0.19	1.01	1.45	1.38	0.78	0.92	0.97	1.68	0.02	1.28	10.15
2017	0.62	0.68	0.42	0.72	1.39	1.25	0.19	0.00	1.92	0.44	1.06	1.83	10.52
2018	0.34	1.09b	Z	Z	Z	Z	Z	Z	Z	Z	Z	Z	1.43 j
]	Period o	of Reco	ord Stat	istics					
MEAN	0.50	0.40	0.63	0.94	1.78	2.09	1.08	1.10	1.04	0.64	0.55	0.52	11.28
S.D.	0.42	0.34	0.38	0.57	0.95	1.06	0.92	0.83	0.79	0.54	0.39	0.38	2.55
SKEW	2.46	1.78	0.54	1.64	1.48	0.46	1.60	1.13	0.85	1.32	0.91	1.06	0.99
MAX	2.78	1.98	1.62	3.00	6.09	4.74	4.70	4.23	3.37	2.68	1.78	1.83	20.94
MIN	0.00	0.02	0.02	0.10	0.28	0.08	0.07	0.00	0.00	0.02	0.01	0.01	6.26
YRS	80	79	78	80	80	80	80	80	80	80	80	80	78

APPENDIX D – SOURCE WATER PROTECTION PLAN

City of East Helena Public Water Supply

Public Water Supply ID# MT0000196

Source Water Delineation and Assessment Report (SWDAR)

Jim Rice Certified Operator

7 East Main St. East Helena, Montana 59635

Phone: 227-5321



November 2002

Table of Contents

<u>0 – Introduction</u>
0 – Background
0 – Hydrogeologic Setting and Delineation
<u>0 – Inventory</u>
0 – Susceptibility Assessment
<u>0 – References</u>
lossary
Figure 1 – East Helena Location Map Figure 2 – Helena Valley, Prickly Pear Creek Watershed and McClellan Creek Watershed Figure 3 – East Helena PWS Source Locations Figure 4 – Generalized Geologic Map of Study Area Figure 5 – Generalized Potentiometric Surface Map, Helena Valley Aquifer Figure 6 – Generalized Cross Section, Helena Valley Aquifer Figure 7A – Delineated Source Water Protection Management Areas Figure 7B – Delineated Source Water Protection Management Areas Figure 8 – Land Use Classification Figure 9 – Septic System Density and Limits of City Sewer Area Figure 10 – Inventory Location Map
Table 3 – Summary of Inventory Results for East Helena PWS Table 4 – Significant Potential Contaminant Sources for East Helena PWS Table 5 – Relative Susceptibility to Specific Contaminant Sources as Determined by Hazard and the Presence of Barriers Table 6 – Relative Hazards for Non-Point Potential Contaminant Sources Table 7 – Susceptibility Assessment of Significant Potential Contaminant Sources
Appendix A – Sanitary Survey for East Helena PWS, with Additional Data Appendix B – Well logs for PWS well and area wells from MBMG-GWIC Appendix C – Water Quality Data for PWS and Area Wells from MBMB-GWIC Appendix D – Time of Travel Calculation Summary Appendix E – Inventory Process Summary Description and Summary Tables Appendix F – Inventory Summary Sheets for Significant Potential Contaminant Sources

List of Acronyms

BMP - Best Management Practices

CAFO - Confined Animal Feeding Operation

CECRA - Comprehensive Environmental Cleanup and Responsibility Act

CERCLA - Comprehensive Environmental Response, Compensation, and Liability Act

LUST - Leaking Underground Storage Tank

MCL - Maximum Contaminant Level

MBMG-GWIC - Montana Bureau of Mines and Geology - Ground Water Information Center

MPDES - Montana Pollutant Discharge Elimination System

NPDES - National Pollutant Discharge Elimination System

PWS - Public Water System.

RCRA - Resource Conservation and Recovery Act

SMCL - Secondary Maximum Contaminant Levels

SWDAR - Source Water Delineation and Assessment Report.

SWPP - Source Water Protection Plan

SWL - Static Water Level

SOC - Synthetic Organic Compounds

TMDL - Total Maximum Daily Load

UST - Underground Storage Tank

VOC - Volatile Organic Compounds

See glossary at end of text for definitions of acronyms and other terms used in this report

1.0 INTRODUCTION

The Safe Drinking Water Act (SDWA) Amendments of 1996 require states to develop and implement Source Water Assessment Programs (SWAP) to analyze existing and potential threats to the quality of the public drinking water supplies throughout the state. The Montana SWAP was formally approved by the US Environmental Protection Agency (EPA) in November 1999. The Montana SWAP was developed from the former Wellhead Protection Program, but includes surface water sources and requires a more rigorous inventory of potential contaminant sources. For communities that have already developed wellhead protection plans, SWAP revises these plans to meet the expanded requirements. DEQ also works with other groups such as Montana Rural Water Systems, Inc., and Midwest Assistance Programs to implement the program.

SWAP addresses only public water systems (PWS) regulated according to the Federal Safe Drinking Water Act. A public water supply system is defined, according to Federal and Montana regulations, as a system that supplies water for human consumption. A public water supply system has at least 15 service connections or regularly provides water to at least 25 persons daily for a minimum of 60 days in a calendar year. There are three types of public water supply systems:

- Community water systems provide water on a year-round basis, and have a minimum of 15 service connections or regularly serve at least 25 residents. In addition to incorporated towns, community systems may serve smaller areas such as housing subdivisions or trailer courts.
- Non-transient non-community systems do not serve communities, but provide water regularly to a minimum of 25 of the same people for at least 6 months of a year. These systems serve public buildings such as schools and hospitals, where people are employed but do not reside.
- Transient non-community systems do not serve communities, and do not regularly serve a minimum of 25 of the same people for at least 6 months of the year. These systems are usually seasonal, and are located in areas such as campgrounds and parks.

Source water protection is a common sense approach to guarding public health by protecting drinking water supplies. In the past, water suppliers have used most of their resources to treat water from rivers, lakes, and underground sources before supplying it to the public as drinking water. Source water protection means preventing contamination and reducing the need for treatment of drinking water supplies. Source water protection also means taking positive steps to manage potential sources of contaminants and contingency planning for the future by determining alternate sources of drinking water. Protecting source water is an active step towards safe drinking water; a source water protection program (along with treatment, if necessary) is important for a community's drinking water supply. A community may decide to develop a source water protection program based on the results of a source water assessment, which includes the delineation of the area to be protected and an inventory of the potential contaminants within that area.

The Montana Source Water Protection Program is intended to be a practical and cost-effective approach to help public drinking water supplies protect their water source from contamination.

The Montana Source Water Protection Program is responsible for completing delineation and assessment reports for all public water supplies in Montana. The Source Water Delineation and Assessment Report (SWDAR) compiles the appropriate data and other technical information about an area to allow communities to develop source water protection plans. Delineation is a process whereby areas that contribute water to aquifers or surface waters used for drinking water, called source water protection areas, are identified on a map. Geologic and hydrologic conditions are evaluated in order to delineate source water protection areas. Assessment involves identifying potential contaminant sources in delineated source water protection areas, and evaluating the potential for contamination of drinking water from these sources under "worst-case" conditions such as a flood, fire or human error. Although voluntary, source water protection plans are the ultimate focus of source water delineation and assessment. This delineation and assessment report is written to encourage and facilitate the East Helena area communities and public water supply operators develop source water protection plans that meets their specific needs.

Scope and Purpose

This report presents the source water delineation and assessments for the municipal public water supply for the City of East Helena, in Lewis and Clark County, Montana. This report is intended to meet the technical requirements for the completion of the delineation and assessment report for this PWS, as required by the Montana Source Water Protection Program (DEQ, 1999) and the federal Safe Drinking Water Act (SDWA) Amendments of 1996 (P.L. 104-182).

This report addresses the East Helena area with a watershed-type approach, recognizing that potential contaminant sources may threaten more than one public water supply. The report presents all of the information for the East Helena area, and will be used as a basis to develop SWDARs for additional public water supply sources in the area that have overlapping source water protection areas with similar threats.

Acknowledgements

This report was prepared by James Swierc with the University of Montana – Helena (UM-Helena) as part of a cooperative agreement with the Lewis and Clark Water Quality Protection District, using funding provided by the Source Water Protection Program of the Montana Department of Environmental Quality. Kathy Moore with the Lewis and Clark Water Quality Protection District provided support to completion of the report and project. The East Helena Source Water Project was designed to evaluate all of the public water supplies in the East Helena area. Inventory data for the project was researched and compiled by UM-Helena project intern April Navarro. UM-Helena interns April Navarro and Scott Smith conducted the "windshield" survey for the project. The operator for the East Helena PWS, Mr. Jim Rice, provided valuable information on the operational status of the system.

Limitations

This report was prepared to assess threats to the East Helena public water supply and is based on published information, and information obtained from local residents familiar with the community. The terms "drinking water supply" or "drinking water source" refer specifically to sources for regulated public water supplies, and not any other type of water supply. The inventory of potential contaminant sources focuses on the management areas delineated for the

public water supplies in this report. As a result, other potential sources of contamination to surface and ground water in the area may not be identified.

The term "contaminant" is used in this report to refer to any chemical or biologic constituent in water that are listed as regulated under state and federal regulations. Water constituents are generally regulated based on health effects that may occur when ingested at certain levels. Water quality standards are based on maximum contaminant level goals (MCLGs) for a compound, which represents a concentration where adverse health effects are not considered likely to occur when ingested. However, as natural waters contain many dissolved constituents and MCLGs are frequently not attainable using economically viable water treatment alternatives, maximum concentration levels (MCLs) are used. MCLs represent concentrations that may result in chronic or acute health problems when ingested. MCLs are based on the relative risk, or likelihood that health problems may occur, and economics associated with a treatment technology for a specific constituent of water. In some cases, sources for constituents with Secondary MCLs are also evaluated in this report. Secondary MCLs are non-regulatory guidelines regarding cosmetic effects (such as tooth or skin discoloration) or aesthetic effects (such as taste, odor, or color) of drinking water.

2.0 BACKGROUND

The Community

The City of East Helena is located in the southeastern part of Lewis and Clark County, in the southern part of the Helena Valley within the southeastern part of the Lewis & Clark County Water Quality Protection District.. The population of East Helena was estimated at 1,642 people in the 2000 census. East Helena is located approximately five miles east of Helena, and serves as a bedroom community to the Helena area, as many residents of East Helena work at locations across the valley. East Helena has multiple small businesses, with a limited amount of industry. A limited amount of agriculture is present in the area surrounding East Helena. Major industry in East Helena formerly included the ASARCO smelter, which recently closed in operation; and the American Chemet Company. The major highway through East Helena is US Highway 12, which crosses through town in an east-west direction. Montana Highway 518 runs south from East Helena towards Montana City.

Wastewater in East Helena is collected with a sanitary sewer system, that pumps to treatment lagoons located north of town. The wastewater lagoons discharge into the Prickly Pear Creek at a location due west of the treatment lagoons. Areas outside of the city limits are typically served by septic systems. The Eastgate Village area east of East Helena is serviced by a small municipal service system.

Geographic setting

East Helena is located at approximately 45.588° North latitude and 111.912° West longitude, in Section 250 of Township 10 North, Range 3 West. The East Helena area is located at the southern end of the Helena Valley, with the Elkhorn Mountains located approximately 5 miles south of town. The Big Belt Mountains are located on the east side of the valley, with smaller hills and mountains located around the remaining sides of the valley (Figure 2). Prickly Pear Creek (USGS HUC#100300101120) flows from a watershed south of East Helena northward through town towards Lake Helena, the lowest elevation in the Helena Valley. All surface water in the Helena Valley flows towards Lake Helena, which discharges into Hauser Reservoir behind a dam to the north flowing Missouri River (USGS HUC#100300101) in this area. The elevation of the town is 3,980 feet above sea level. The elevation of the Elkhorn Mountains rise as high as 9,000 feet above sea level in the upper reaches of the Prickly Pear Creek Watershed. Surface drainage in East Helena generally flows north. Several irrigation ditches, including water derived from Prickly Pear Creek, are present in the area.

The climate in the area is typical for southwestern Montana. Weather data is reported for Helena, located five miles west of East Helena. Data for Helena is available from 1893 to 2001. Helena receives an average of 11.99 inches of precipitation annually, with the wettest months in May and June averaging 1.92 and 2.10 inches. The driest months are November through February, with averages between 0.48 and 0.62 inches per month. East Helena receives an average total of 51.3 inches of snowfall per year. The temperature ranges from an average high of 82.4° F in July (minimum July average of 53.3° F) to an average of 29.5° F in January (minimum January average of 11.1° F).

Figure 1 – East Helena Location

General description of the Source Water

The East Helena PWS currently obtains water from two separate sources. The first source is an infiltration gallery (Source IG 002) located approximately five miles south of East Helena, in the McClellan Creek drainage. The infiltration gallery draws water into two collection systems installed into alluvium near the creek. The alluvium represents an unconfined aquifer. Ground water flow in alluvium near McClellan Creek flows northward, generally parallel to the flow direction of the creek. McClellan Creek flows into Prickly Pear Creek approximately one mile north of the infiltration galleries. Recharge to McClellan Creek occurs in the Elkhorn Mountains, with the watershed shown in Figure 2.

The second source comprises three wells (Sources WL 002-004) located north of East Helena. These wells are installed into Helena Valley fill alluvium a regional unconfined aquifer comprising the valley fill sediments of the Helena Valley. Ground water flow in the East Helena area is generally northward, to the lowest elevation of the valley in Lake Helena. Prickly Pear Creek flows northward through the East Helena area. Water flow in Prickly Pear Creek responds to seasonal changes in ground water elevation. The Prickly Pear Creek watershed is located in the Elkhorn Mountains, as depicted in Figure 2.

The Public Water Supply

The East Helena PWS serves an estimated resident population of 1671 through an estimated 698 service connections. The system has four sources, including three active source wells located northwest of town and an infiltration gallery located south of town. The location of the water sources, the storage tanks, and the limits of the service area for the PWS are shown in Figure 3. A copy of the most recent sanitary survey for the system is included in Appendix A. The well logs for the PWS wells are included in Appendix B. Water from both the well source and the infiltration gallery source is blended together within the distribution system for the town, with water from the wells entering on the west side of town, and water from the infiltration gallery entering from the southeast part of town.

Figure 2 – Helena Valley, Prickly Pear Creek Watershed and McClellan Creek Watershed

Water from the three wells is blended together in the distribution system north of East Helena. The water from the wells is disinfected with chlorine gas injected directly into the distribution system lines. Water flows directly into the East Helena system from the west side of East Helena, with three main distribution lines carrying water into town. Overflow water flows into a 1,000,000 gallon storage tank (constructed in 1999) located south of East Helena. The pressure from the well pumps keeps the system pressurized. The wells provide approximately two-thirds of the water for the East Helena PWS system. The three well sources can be described as follows:

• Well 1 (Source WL 002) was installed in 1965 to a depth of 110 feet, with a yield of 600 gpm,

- Well 2 (Source WL 003) was installed in 1965 to a depth of 92 feet, and has a yield of 600 gpm. This well is used as a backup well at the time this report was written.
- Well 3 (Source WL 004) was installed in 1986 to a depth of 153 feet, and has a yield of 550 gpm.

Figure 3 – PWS Well Locations

Water from two infiltration gallery collection systems is pumped from each well into two adjacent storage tanks; a 250,000 gallon tank and a 300,000 gallon tank. The water is chlorinated in the line from the infiltration gallery into the tanks, with an orthophosphate added as an inhibitor for corrosion control. Water flows by gravity from the storage tanks into the distribution system in town. The infiltration gallery provides approximately one-third of the water for the PWS system. Both of the collection systems were installed in 1991 to an approximate depth of 18 feet, with 8-foot diameter casings placed into the alluvium

Water Quality

Every PWS is required to perform monitoring for contamination to their water supply. The monitoring parameters typically include coliforms (as an indicator of pathogenic organisms), nitrates, metals and multiple chemicals. The monitoring schedule depends on many factors such as the size of the system, the water source for the PWS, the number of sources (e.g. wells), and land use in the area

A specific monitoring program is designed for each PWS that follows the general protocols for operation of a PWS defined by DEQ following the guidelines originally established in the federal Safe Drinking Water Act. A review of the DEQ PWS database of monitoring results for the East Helena PWS indicates no violations of any drinking water quality standards (Appendix C).

Water quality data for the East Helena area was obtained electronically from the Montana Bureau of Mines and Geology (MBMG) database (GWIC). Table 1 lists the data for the sections proximal to the East Helena PWS Wells, and from surface water sampling locations at McClellan Creek and Prickly Pear Creek. This data is considered to represent background concentrations for ground water near the East Helena PWS sources. The entire GWIC database for the East Helena area is included in Appendix C, which also includes tables of the concentrations of common constituents of water from the routing sampling for the East Helena PWS from 2000 to 2001.

East Helena currently has several sites where ground water contamination is present. The closure of the ASARCO plant in East Helena is associated with the discovery of a plume of arsenic present in ground water in the area beneath the town. The locations of the East Helena PWS sources away from the central part of town place them in a position away from this contamination. The data on ground water in the area proximal to the ASARCO plant is not present in the GWIC database, and therefore is not included in Table 1. However, the presence of elevated levels of arsenic has been determined north of the plant area, and elevated levels of other metals such as lead, zinc and copper have been detected in the water beneath the plant area. The second site is an Underground Storage Tank release, which has impacted ground water in

central East Helena with petroleum hydrocarbons. This site has an ongoing ground water remediation system present at the time of preparation of this report. The nature of contamination and potential impacts of the ASARCO plant and the petroleum site to the East Helena PWS are discussed in the inventory and susceptibility assessment portions of this document.

Table 1 – Background Water Quality in East Helena Area

Sample Information

				_					
Site Name	Twn	Rng	Sec	Q Sec	Туре	Depth (ft)	Sample Date	Lab pH	Lab SC
Surface Water Data									
McClellan Creek	09N	02W	7	ACD	Stream		9-Jul-91	7.21	125.4
Prickly Pear Creek	09N	03W	1	ADD	Stream		9-Jul-91	7.79	183.9
Ground Water Data									
PWS - 0.5 Mi S. of E. Helena	09N	03W	1	ABAB	Well		18-Nov-80	7.77	509.1
Maronic	10N	03W	23	DAAD	Well	180	9-Aug-90	6.98	945.7
L & C County Lagoons, E. Helena	10N	03W	24	DBD	Well	67.5	5-Sep-90	7.24	320.5
Jensen, David - North Well	10N	03W	25	CDBA	Well	82	13-Aug-90	6.96	1276.3
Jensen, David - South Well	10N	03W	25	CDBA	Well	160	8-Aug-90	6.93	587.6

Anion/Cation and Nutrient Data

Site Name	Ca	Mg	Na	K	Fe	Mn	Si	нсоз	SO4	Cl	NO3	F	OPO4	TDS
Site Name	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l
Surface Water Data														
McClellan Creek	14.7	2.7	3.7	1	0.009	0.008	17.5	41.6	20.7	0.9	0.189	0.11	< 0.05	82.01
Prickly Pear Creek	19.8	4.2	7.7	1.7	0.019	0.049	18.1	64.4	29.6	1.2	0.059	0.27	< 0.05	114.73
Ground Water Data														
PWS - 0.5 Mi S. of E. H.	58.7	13.3	25.2	4.6	0.015	0.001	25.8	213	62	11.2	0.73	0.72		307.21
Maronic	39.27	8.68	14.44	4.79	0.302	0.242	48.1	115	66.6	4.5	0.56	0.3		244.62
L & C County Lagoons	31.3	7.91	18.8	2.58	0.013	0.01	23.9	112.7	59.7	4.7	0.84	0.29	<.1	205.61
Jensen, David - North Well	140	33.63	93.55	8.97	4.176	2.314	25.7	170	485	43.8	1.09	0.16		922.27
Jensen, David - South Well	76.27	16.58	20.96	5.14	<.004	<.002	51.3	142	161	17.8	0.28	0.3		419.58

Metals Data

Site Name	Ag	Al	As	В	Ba	Br	Cd	Cr	Cu	Li	Mo	Ni	Pb	Sr	Ti	Zn
Site Name	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l
Surface Water Data																
McClellan Creek	<6.	<100.	1.3	<100.	15	<100.	<6.	<6.	<6.	<6.	<40.	<20.	<100.	105	<6.	<6.
Prickly Pear Creek	<6.	290	6.1	<100.	19	<100.	<6.	<6.	<6.	10	<40.	<20.	<100.	153	<6.	21
Ground Water Data																
PWS - 0.5 Mi S. of E. H.	<2.	<30.		70			<2.	<2.	22	11	<20.	<10.	<40.	320	6	<4.
Maronic	<4.	186		40	78	<100.	<5.	<5.	<4.	14	<40.	<20.		255	<4.	<6.
L & C County Lagoons	<4.	40		51	25	<100.	<5.	<5.	<4.	16	<40.	<20.	<50.	249	19	12
Jensen, David - North Well	<4.	133		251	40	3400	<5.	<5.	<4.	37	<40.	<20.		839	6	<6.
Jensen, David - South Well	<4.	<40.		<40.	92	400	<5.	<5.	<4.	18	<40.	<20.		509	<4.	<6.

3.0 HYDROGEOLOGIC SETTING AND DELINEATION

The source water protection area, the land area that contributes water to the East Helena PWS, is identified in this chapter. For all of the PWS sources, three management areas are identified within the source water protection area; the control zone, inventory region, and recharge region. Since the source aquifer is unconfined and ultimately recharged by surface water, surface water buffer zones are also delineated around McClellan Creek upstream from the Infiltration Gallery; and around Prickly Pear Creek upgradient from the wells.

The control zone, also known as the exclusion zone, is an area at least 100-foot radius around the wells and gallery intakes. The inventory region for the wells and infiltration gallery are delineated based on a three year time of travel distance for ground water to the sources. The recharge region represents the area where the aquifer(s) are replenished. The surface water buffer zones represent the area of a one-half mile wide buffer on each side of a surface water body, for a distance of ten miles upstream from the PWS source.

Hydrogeologic Conditions

The information presented in this section is based predominantly on the assessments of the hydrogeology of the area performed by the United States Geological Survey (USGS) and Montana Bureau of Mines and Geology (MBMG). This includes a study of the Helena Valley alluvial aquifer presented in Briar and Madison (1992), and Bedrock Aquifers in the Helena Area presented in Thamke (2000). The area east of East Helena is reviewed in a Wellhead Protection document for Eastgate Village prepared for DEQ by MBMG (1996). Additional hydrogeologic information was obtained for the area proximal to the ASARCO Plant from remedial investigation documents obtained from the United States Environmental Protection Agency. A geologic map of the Prickly Pear Creek Watershed Region showing the major units is depicted in Figure 4.

The sediments that are the source aquifer for infiltration gallery are present as a sequence of unconsolidated alluvium present over bedrock in the area. The alluvium filling the McClellan Creek Valley represents an extension of the valley fill material of the Helena Valley into the Elkhorn Mountains (Stickney, 1988). The Boulder Batholith and the Volcanic Rocks that characterize the Elkhorn Mountains dominate the geology of the McClellan Creek watershed. Sedimentary rocks of various formations, as shown in Figure 4, cover the areas along the edge of the mountains. Recharge to the alluvial aquifer that supplies the infiltration gallery occurs in the Elkhorn Mountains. Ground water in the igneous rocks of the Elkhorn Mountains is interpreted to flow primarily through fractures, with little primary porosity present. Ground water in the mountains is recharged by infiltration of surface water from snowmelt and other precipitation. As ground water flows away from the recharge areas, it discharges into the streams. McClellan Creek gains flow from recharge in the mountains, and is interpreted to be a gaining stream in the area near the infiltration gallery. This interpretation is based on the classification of the infiltration as ground water, based on testing of water quality for Ground Water Under the Direct Influence of Surface Water (GWUDISW) testing (Appendix A).

Ground water in the alluvium is interpreted to flow generally parallel to the direction of stream flow in McClellan Creek. However, there is a component of ground water flow towards the

stream which cannot be quantified at this time as there is no data for the area. The hydraulic gradient is interpreted as the gradient of the stream in the area.

Ground water in the Helena Valley near East Helena is present as an unconfined alluvial aquifer. The Helena Valley is a structural basin with bedrock present along each boundary. The central part of the valley is filled with up to 6,000 feet of sediments derived from the bedrock in the area. The valley is filled with a thick sequence of interlayered fine and coarse grained Tertiary sediments; which is overlain by up to 100 feet of Quaternary alluvium. In the East Helena area, the thickness of the alluvium increases northward away from town. Studies on the stratigraphy in the area surrounding the ASARCO plant in East Helena have evaluated the upper part of the water table aquifer separately from the lower part as "upper" and "intermediate" aquifers. A review of well logs from the area (Appendix D) does not show any distinct stratigraphic separation for the two aquifers. As a result, for purposes of this Source Water assessment, they are considered as a single aquifer since pumping from the lower part of the aquifer will induce vertical flow within the aquifer. The base of the alluvial aquifer is identified by the presence of an Oligocene volcanic tuff overlying the additional Tertiary beds. Water in the Tertiary beds is considered to represent a "lower" aquifer in the area. Additional pediment surfaces are present in areas south of East Helena, and they are considered part of the alluvial aquifer for this assessment.

Ground water in the East Helena area flows generally to the north, towards Lake Helena. There are some local variations in this general flow direction due to changes in local conditions. A potentiometric surface map showing the general direction for ground water flow in the area is presented in Figure 5. Water flow in the alluvium is primarily horizontal, with vertical hydraulic conductivities generally 1-3 orders of magnitude less (Briar and Madison, 1992). Recharge to the alluvial aquifer occurs from stream loss along the valley margins, direct infiltration of precipitation, leakage from irrigation canal and excess irrigation water, and from direct infiltration of water from bedrock aquifers in the subsurface. The depth to ground water in the East Helena area ranges from approximately 5 to 20 feet below the ground surface, and varies during the year.

Conceptual Model and Assumptions

A conceptual hydrogeologic model is a simplified representation of the hydrogeologic system. For the East Helena PWS, water is obtained from two general areas of the same unconfined aquifer. Generalized cross sections depicting the geology are shown in Figure 6. The infiltration gallery is present in an upgradient arm of the alluvial aquifer, where McClellan Creek feeds into Prickly Pear Creek which flows north to the Helena Valley. McClellan Creek is a gaining stream in this area, as ground water recharges the stream. Ground water is interpreted to generally flow parallel to the direction of the stream. Water from the wells is obtained at a position downgradient from East Helena. In this area, Prickly Pear Creek loses flow to the ground water system, with ground water flow generally parallel to the stream direction. Recharge to the aquifer occurs from stream loss from Prickly Pear Creek and other surface water bodies such as irrigation ditches. Both aquifers are considered to have a high source water sensitivity to contamination.

Figure 4 – Generalized Geologic Map of Study Area

Figure 5 – Generalized Potentiometric Surface Map, Helena Valley Aquifer

Figure 6 - Generalized Geologic Cross Section, Helena Valley Aquifer

Well(s) Information

The wells for the East Helena PWS are located north of town as depicted in <u>Figure 2</u>. The Infiltration Gallery is located south of town. Copies of the well logs showing stratigraphy and construction criteria are included in Appendix B. Well information is summarized in Table 2.

Table 2 - Source Well Information for East Helena.

	I WOLC = Source	wen mjormanon	Joi Bust Heterius	
Information	Well 1	Well 2	Well 3	Infiltration Gallery
PWS Source Code	002	003	004	005
Well Location	T10N, R3W,	T10N, R3W,	T10N, R3W,	T9N, R2W,
Well Location	Sec 14 DDDC	Sec 24 BCBB	Sec 24 CBCD	Sec 7 DDAB
	Lat 46.6173 N	Lat 46.6132 N	Lat 46.6066 N	Lat 46.5507 N
	Long 111.9363 W	Long 111.9348 W	Long 111.9369 W	Long 111.8985 W
MBMG/GWIC #	61839	62116	62125	139051
Water Right #	W113655	W113656	P062231	P070576-00
Date Completed	22 Mar 1965	10 Apr 1965	16 Oct 1987	16 Oct 1991 (refurbished)
Total Depth	110 feet	92 feet	153 feet	18 feet
Perforated Interval	90 – 110 feet	58 – 88 feet open bottom	71 – 119 feet	
Static Water Level	34 feet	39 feet	35 feet	8.8 feet
Pumping Water Level	54 feet	54 feet	80 feet	
Drawdown	20 feet	15 feet	45 feet	
Yield – Test Pumping Rate	600 gpm	600 gpm	550 gpm	600 gpm
Specific Capacity	Specific Capacity 30 gpm/ft 40		12.2 gpm/ft	
Pumping Rate				

Methods and Criteria

The methods and criteria used to delineate the source water protection zones for the East Helena water system are specified in the Montana Department of Environmental Quality Source Water Protection Program (DEQ, 1999). For both the infiltration gallery and the wells, the criteria for unconfined aquifer systems was applied. The control zone was established using a fixed radius of 100 feet around each wellhead. The inventory zone was delineated based on a ground water time of travel distance of three years. This distance was determined using a simple ground water flow model using the uniform flow equation (EPA, 1991). Conservative estimates for aquifer properties were made using available data from published reports, as discussed in the following. The inventory zones for the wells were broadened to reflect potential changes in the flow system during seasonal periods of high and/or low flow. The recharge area for the alluvial aquifers is considered to be the McClellan Creek Watershed for the infiltration galleries, and the entire Prickly Pear Creek Watershed above East Helena for the wells. The alluvial aquifer is present in the base of the streams, and is recharged by ground water from the higher elevation areas. The

ground water recharges the stream system, which loses water to the alluvial aquifer when it enters the Helena Valley. Surface water buffer zones are delineated around McClellan Creek and Prickly Pear Creek based on a standard distance criterion of ten miles upstream from the infiltration gallery and wells, with buffers encompassing the land area of one-half mile width on each side of the major streams.

Model Input

The values selected for the calculation of time of travel represent conservative assumptions made to identify areas that may potentially impact the East Helena PWS sources. These values assume that flow to both the infiltration gallery and the wells in the system reflect similar aquifer properties as both systems are in an alluvial aquifer. In addition, since there is no data available for the aquifer near the infiltration gallery, the delineation for the inventory zone for this source reflects similar aquifer criteria as for the wells. The criteria for selection of the values used for the delineation of the inventory zone for the infiltration galleries and wells are as follows:

Well Model Values:

- *Thickness*: The value for the thickness of the aquifer (b) is estimated at 60 feet, based on the estimated thickness of the aquifer and the depth to ground water from well logs.
- *Hydraulic Conductivity*: A value for hydraulic conductivity (K) was estimated for the aquifer by EPA for a ground water model for the ASARCO site at approximately 850 ft/day. Briar and Madison (1992) estimated the hydraulic conductivity at 200 ft/day for the East Helena area. For this assessment, an estimated value of 550 ft/day is used, representing an average between the two presented values.
- *Transmissivity*: The transmissivity value is estimated at 33,000 ft²/day based on the relationship T = K*b.
- *Hydraulic Gradient*: The hydraulic gradient was measured from the potentiometric surface map in Briar and Madison (1992) shown in <u>Figure 5</u>. The gradient shows an approximate change of 100 feet over a distance of 1.75 miles, for an estimated gradient of 0.0108. This study used a rounded value of 0.01.
- *Flow Direction*: The flow direction is considered due north, based on the map of Briar and Madison (1992).
- *Porosity*: The value for effective porosity is estimated from (Todd, 1980) at 30%. The estimated value is considered representative of medium to coarse grained gravel.
- *Pumping Rate*: The pumping rate for the wells was estimated at 200 gpm, which is a conservative estimate reflecting the needs of the system.

Infiltration Gallery Model Values (Differing from Well Values)

- *Hydraulic Gradient*: The hydraulic gradient was measured from the potentiometric surface map in Briar and Madison (1992) shown in <u>Figure 5</u>. The gradient shows an approximate change of 200 feet over a distance of 1.35 miles, for an estimated gradient of 0.028. This study used a rounded value of 0.03.
- *Flow Direction*: The flow direction is considered due northeast, following the direction of flow in McClellan Creek.

Delineation Results

The results of the calculations for the wells indicate an estimated distance of 6,800 feet (1.29 miles) for a one-year time of travel (TOT), and a distance of 20,250 feet (3.84 miles) for a three-year TOT. A summary of the time of travel calculations is included in Appendix D. The delineated inventory zone for the wells are depicted in Figure 7A and 7B. The inventory includes the mapped area of alluvium within the Prickly Pear Creek streambed, upstream to near the confluence with McClellan Creek. The aquifer considers the Quaternary alluvium and an older Tertiary pediment surface, as mapped by Stickney (1987). The limits of these units are considered as aquifer boundaries. A surface water buffer zone is also delineated for the wells, which encompasses Prickly Pear Creek upstream from where the stream crosses the inventory zone for the wells. In addition, for Well 3, a surface water buffer zone is delineated around the Helena Valley Irrigation Canal and the Helena Regulating Reservoir. The recharge region for the wells is considered to be the Prickly Pear Watershed area shown in Figure 2.

The results of the calculations for the infiltration gallery indicate an estimated distance of 20,100 feet (3.81 miles) for a one-year time of travel (TOT), and a distance of 60,250 feet (11.41 miles) for a three-year TOT. A summary of the time of travel calculations is included in Appendix D. The delineated inventory zone for the infiltration gallery is depicted in Figure 7A and Figure 7B. The inventory includes the mapped area of alluvium within the McClellan Creek streambed upstream from the infiltration gallery to the aquifer boundary. Stickney (1987) mapped this boundary at approximately two miles upstream from the infiltration gallery. A surface water buffer zone is also delineated for the infiltration gallery, which encompasses McClellan Creek upstream from where the inventory zone (Figure 7A and 7B). Since the stream is a gaining stream through this stretch, any potential contaminants released into the subsurface would discharge into the stream. The recharge region for the infiltration gallery is considered to be the McClellan Creek Watershed area shown in Figure 2.

Limiting Factors

The interaction of surface water in the Prickly Pear and McClellan Creek drainages with shallow alluvium is not completely understood at this time due to the limited amount of data on the system. In particular, the changes in the flow regime under seasonal conditions of high and low flow are not known. The delineation was completed using conservative assumptions to help ensure that the inventory zone reflects the actual area where contamination to the system may occur. In all cases, the interpretations and conclusions on ground water flow in the aquifer(s) are based on general principles of hydrogeology, and the mechanics of the actual ground water flow.

Figure 7A – Delineated Source Water Protection Management Areas

Figure 7B – Delineated Source Water Protection Management Areas

4.0 INVENTORY

An inventory of potential sources of contamination was conducted for East Helena PWS sources within the control and inventory zones. Potential sources of all primary drinking water contaminants, including pathogens, were identified. However, only significant potential contaminant sources based on criteria outlined in the Montana Source Water Protection Program (DEQ, 1999) were selected for detailed inventory. The inventory for the East Helena PWS focuses on all activities in the control zone, certain sites or land use activities in the inventory zones, and general land uses and large facilities in the recharge region. The inventory results from the various steps (Appendix E) are summarized in Table 4. The significant potential contaminants in the inventory region for the wells include petroleum from underground storage tanks, nitrates and pathogens from sanitary sewers, septic systems and agriculture; and herbicides and pesticides from cropped agricultural land. The significant potential contaminants in the inventory region for the infiltration galleries include nitrates and pathogens from septic systems and agriculture; and herbicides and pesticides from cropped agricultural land.

Inventory Method

The initial inventory steps comprise querying existing state and federal electronic databases for regulated facilities that use, store or release regulated chemicals. The steps to the database searches, and the results from each step are listed in Appendix E. The assessment of agriculture land use and urban areas, and major transportation routes through the area are shown on Figure 8. The limits of the municipal sewer system and relative density of septic systems in the area are shown on Figure 9. The database search is supplemented and verified with a "windshield survey" and a business directory search of the delineated inventory zones for each PWS in the study area. The results of the business directory search are included in Appendix E. This method helps ensure the inventory is a complete data collection exercise to identify all potential contaminant sources.

The results of the inventory process are summarized in Table 3, which summarizes the properties or sites within the inventory zone study area. The potential contaminants are listed, with a description of the potential release mechanism for the site. In all cases, releases may occur due to unavoidable conditions such as flooding, lightning or fire. The sites where this is the primary potential release mechanism are identified as concerns resulting from such a disaster. For other sites where other release mechanisms may be more common, the potential for a release from such a disaster is assumed.

The results of the "windshield survey" were consistent with the results from database searches, and did not indicate any additional facilities to review. Storm water drains were observed as french-drains, which represent injection wells of surface water into shallow ground water. Class V injection wells are classified as waste disposal conduits that discharge directly to shallow ground water. The evaluation of the use of Class V injection wells in Montana is currently the responsibility of the EPA.

The Montana Source Water Protection Program identifies specific types of potential contaminant sources as significant, for further evaluation of the susceptibility of the water source to these sources. The following categories of potential contaminant sources are considered significant:

- 1. Large quantity hazardous waste generators.
- 2. Landfills.
- 3. Underground storage tanks.
- 4. Underground injection wells.
- 5. Major roads or rail transportation routes.
- 6. Cultivated cropland greater than 20 % of the inventory region.
- 7. Known groundwater contamination (including open or closed hazardous waste sites, state or federal superfund sites, and UST leak sites).

8. Animal feeding operations.

- 9. Abandoned or active mines, and gravel pits.
- 10. Septic systems.
- 11. Sewer mains.
- 12. Storm sewer outflows.
- 13. Wastewater treatment facilities, sludge handling sites, or land application areas.

Inventory Results/Control Zones

The control zone represents the most critical point to protecting the integrity of a wellhead for ground water sources. The significant potential contaminant sources are listed in Table 4, with the locations shown on <u>Figure 10</u>. The land around the control zones for the wells is predominantly urban, with Well 1 located near a gravel pit. All of the wells are located near roads with significant local traffic. All of the wells are present in secure buildings; however the land in the control zones around each wellhead is not otherwise protected.

The control zone for the land around the infiltration gallery is undeveloped land within the floodplain of the McClellan Creek. The area around each collection gallery is fenced; and the entire area surrounding the gallery is also secured with a fence.

Inventory Results/Inventory Regions

The inventory region represents the area near the source wells or collection system where any contamination spilled onto the ground or subsurface has the potential to migrate directly into the PWS source aquifer. A summary of the inventory results of significant potential contaminant sources are listed in Table 4, with the locations shown on <u>Figure 10</u>. Completed inventory summary sheets for the significant potential contaminant sources are included in Appendix F.

The inventory region for the wells is the area upgradient from each wellhead, defined by the distance ground water will travel to the well in three years. Land use in this area is classified as predominantly agriculture, with the urban area of the East Helena city limits present (Figure 8). The identified potential contaminant sources include the roads, railroad tracks, the sewer system, septic tanks, UST sites, LUST sites, several automobile repair shops, the former ASARCO Smelter plant, and American Chemet (Figure 10).

The LUST sites and the ASARCO Smelter site represent areas where ground water contamination has been identified in the source aquifer for the East Helena PWS wells. The LUST site, Schiller's Service on East Main, currently has a ground water remediation system present. A review of DEQ site files indicate that free-phase petroleum hydrocarbons are present on the water table surface. The remediation system was operating at the time of preparation of this report, indicating that remediation of the system is an ongoing process.

Table 3 - Summary of Inventory Results for East Helena PWS.

Source Type	Potential Contaminants	Description/Concern
Step 1 Results		
Agricultural Land Use	Pathogens and Nitrates; Pesticides and Herbicides	Non-point source pollution, concentration of fertilizers/chemicals in surface/ground water
Urban Land Use	Spills of various chemicals	Non-point source pollution, small spills of household chemicals
Sanitary Sewer System	Pathogens and Nitrates	Leakage from sewer lines
Wastewater Treatment Ponds and Discharge Line	Pathogens and Nitrates	Leakage from treatment cells or discharge lines
Septic Systems	Pathogens and Nitrates	Non-point source pollution, loading of ground water system with effluent
Storm Water Discharge Points	Various chemicals	Non-point source releases from urban land use concentrated into point source to ground water; storm sewer system discharges to Tobacco River
EPA Envirofacts Sites (Step 2)		
ASARCO Smelter (Closed)	Metals, Various Chemicals	Arsenic Plume from plant; additional metal contamination at facility; possible chemicals
American Chemet	Various Chemicals	Storage and processing of various chemicals at site
EPA-PCSs Sites (Step 3)	No sites identified	
DEQ Database (Step 4)		
Active USTs – 5 Sites	Petroleum Hydrocarbons	Spill or leak from USTs and piping
LUST Site – 2 Active Sites	Petroleum Hydrocarbons	Existing contamination in surface and ground water
LUST Site – 7 Closed Sites	Petroleum Hydrocarbons	Existing contamination, or residual contamination after site closure
CECRA Sites	No sites identified	
Landfills – 1 Active Landfill	Various Chemicals	Landfill provides direct conduit for contamination to shallow ground water system
Business SIC Code	e Search Results* (Step 5)	
Automotive Repair (4)	Various VOCs	Accidental spill of small quantity of chemicals/fuels
Miscellaneous Others, includin	g Step 6	
Major Roads	Spills of various chemicals	Disaster – spill/release of chemicals and fuels transported on Highway
Railroad Lines	Spills of various chemicals	Disaster – spill/release of chemicals and fuels transported on railroad line
Yellowstone Pipeline	Petroleum Hydrocarbons	Disaster – break in pipeline resulting in release of transported fuels
Gravel Pits (2)	Various chemicals	Provides a conduit for direct discharge of chemicals or waste into shallow ground water
Class V Injection Wells	Various chemicals	Direct discharge of chemical to shallow ground water system

^{*} Note: Sites identified from multiple search queries are listed with the first step that identified the specific site. The results of the business SIC code search reflect types of facilities, with the number of facilities indicated in parentheses. Individual sites identified as significant potential contaminant sources are evaluated in Chapter 5.

<u>Figure 8 – Land Use Classification</u> <u>Figure 9 – Septic System Density and Limits of City Sewer Area</u>

Source	Contaminants	Description	
Significant Potential Contan	ninant Sources for Wells		
Agricultural Land Use	Pathogens and Nitrate; Pesticide/Herbicides (SOCs)	Primary concern in cultivated and grazing lands in Prickly Pear Creek watershed upstream from wells.	
Urban Land Use	Various	The majority of the East Helena urban area is upgradient from the well.	
Sanitary Sewer Main	Pathogens and Nitrate	The East Helena City area is sewered, within the inventory zone for the wells. Concern from leaks and backfill around sewers providing a preferred conduit for other contaminants to migrate.	
Wastewater Treatment System and Discharge Line	Pathogens and Nitrate	The discharge line crosses the inventory zone, discharging into Prickly Pear Creek near Well 3 Concern from leaks and backfill around sewers providing a preferred conduit for other contaminants to migrate.	
Septic Systems	Pathogens and Nitrate	Area south of wells with moderate density, within well inventory zone. Limited areas of high density; including within Surface Water Buffer Zone	
Storm Water Discharge Points	Various organic chemicals	Not inventoried at this time	
ASARCO Smelter	Metals and Various Chemicals	Arsenic plume from site under investigation as ground water is contaminated leaving site. Site closed with significant levels of soil metals contamination.on-site.	
American Chemet	Various Chemicals	Operating Plant with process for chemicals; including chemicals stored on site.	
Active UST Sites	Petroleum Hydrocarbons	At several locations within inventory zone	
LUST Sites	Petroleum Hydrocarbons	At several locations within inventory zone	
Landfill	Various	Infiltration of leachate from buried wastes of unknown type.	
Major Roads	Various Chemicals	Transportation corridors through town, concern over an accident and spill of any transported chemicals	
Railroad Lines	Various Chemicals	Transportation corridors through town, concern over an accident and spill of any transported chemicals	
Yellowstone Pipeline	Petroleum Hydrocarbons	Crosses through southern part of inventory zone, south of East Helena	
Gravel Pit	Various Chemicals	Provides a conduit for chemicals directly into shallow ground water system	
Class V Injection Wells	Various organic chemicals	Not inventoried at this time (EPA responsibility); may provide conduits for chemicals into subsurface	
Significant Potential Contan			
Agricultural Land Use	Pathogens and Nitrate; Pesticide/Herbicides (SOCs)	Primary concern in cultivated and grazing lands in McClellan Creek watershed upstream from wells.	
Septic Systems	Pathogens and Nitrate	Small are of moderate density within Surface Water Buffer Zone	

A plume with elevated Arsenic concentrations is present from the location of the former ASARCO Smelter. The Arsenic plume includes concentrations several orders of magnitude greater than the Federal and Montana State drinking water standard for Arsenic, which has recently been set at 10 parts per billion. Arsenic levels of more than 7,000 parts per billion have been detected in monitoring wells in ground water within East Helena. At the time of preparation of this report, the nature and extent of the Arsenic plume was still under investigation. Due to the size and extent of contamination at the ASARCO facility, investigation and remediation of contamination will be an ongoing process for several years. This includes the Arsenic plume, which has the potential to continue to migrate northward through East Helena.

The inventory region for the Infiltration Gallery is defined by limits of the shallow alluvial aquifer where the infiltration gallery is present. Land use in this area is classified primarily as non-agricultural, with limited areas of agricultural land. There are no point potential contaminant sources identified in this area using the standard database searches.

Inventory Results/Surface Water Buffer Zones

The surface water buffer zone is the area of one half mile on each side of the surface water bodies for a distance of ten miles upstream from the PWS sources. For the wells, this area includes parts of both the Prickly Pear Creek and McClellan Creek drainages, as shown in Figure 7A and 7B. The surface water buffer zone for the Infiltration Gallery comprises the majority of the McClellan Creek drainage. The inventory of the surface water buffer zones focuses on potential contaminants with acute health risks, such as pathogens or nitrates. All of the delineated areas include areas with septic systems, and limited agricultural development with related potential contaminants.

Inventory Results/Recharge Regions

The recharge region for the wells and the infiltration gallery are the Prickly Pear Creek Watershed and McClellan Creek Watersheds, respectively. The East Helena landfill is present within the watershed area, south of East Helena but north of the Infiltration Gallery. The area within both watersheds is predominantly national forest land, with a limited amount of agriculture. A limited amount of mining has occurred within both watersheds.

Inventory Update

The certified operator for the East Helena PWS will update the inventory every year. Changes in land uses or potential contaminant sources will be noted and additions made as needed. The complete inventory will be submitted to DEQ every five years to ensure re-certification of the source water delineation and assessment report.

Inventory Limitations

The inventory is limited by the accuracy of information in databases used for the assessment. The windshield survey provides a level of quality assurance that the information presented reflects current conditions at the time of preparation of this report. The location of Class V injection wells is not complete at this time, and is currently being compiled by EPA for the area. The data from the MBMG-GWIC database on wells in the area may not be complete, as not all wells are included in the database.

5.0 SUSCEPTIBILITY ASSESSMENT

Susceptibility is the potential for a public water supply to draw water contaminated by inventoried sources at concentrations that would pose concern. Susceptibility is assessed in order to prioritize potential pollutant sources for management actions by local entities, in this case the East Helena PWS.

The goal of Source Water Management is to protect the source water by 1) controlling activities in the control zone, 2) managing significant potential contaminant sources in the Inventory Region, and 3) ensuring that land use activities in the Recharge Region pose minimal threat to the source water. Management priorities in the Inventory Region are determined by ranking the significant potential contaminant sources identified in the previous chapter according to susceptibility. Alternative management approaches that could be pursued by the East Helena PWS to reduce susceptibility are recommended.

Susceptibility is determined by considering the hazard rating for each potential contaminant source and the existence of barriers that decrease the likelihood that contaminated water will flow to the East Helena PWS sources (Table 5). Susceptibility ratings are presented individually for each significant potential contaminant source and each associated contaminant (Table 7). The susceptibility of each well to each potential contaminant source is assessed separately.

Table 5 - Relative susceptibility to specific contaminant sources as determined by hazard and the presence of barriers.

Presence Of Barriers	Hazard			
	High	Moderate	Low	
No Barriers	Very High	High	Moderate	
	Susceptibility	Susceptibility	Susceptibility	
One Barrier	High	Moderate	Low	
	Susceptibility	Susceptibility	Susceptibility	
Multiple Barriers	Moderate	Low	Very Low	
	Susceptibility	Susceptibility	Susceptibility	

For point sources, the relative hazard for the potential contaminant sources is assigned based on the type of aquifer. For unconfined aquifers, the relative hazards for point source are based on the location of the potential contaminant source relative to the well. Potential sources within a one-year time of travel distance to the well are assigned a relative hazard of high. Potential contaminant sources located between a one-year and thee-year time of travel distance are assigned a relative hazard of moderate. Any other potential contaminant sources within the recharge area are assigned a relative hazard of low.

After the relative hazard of a potential contaminant source is assigned, the relative susceptibility is determined based on the presence of barriers that may mitigate the potential for a contaminant

source to impact a water source. Barriers may represent natural conditions, engineered barriers or management actions. Natural barriers include anything that can be demonstrated as effective in mitigating the migration of any chemicals released at the surface, such as thick clay-rich soils or surface flowing artesian conditions. Engineered barriers represent man-made structure to contain chemicals if they are released, such as spill containment for underground storage tanks. Management barriers are plans that prohibit or control potentially polluting activities, but only if there is a plan or approach that has been formally implemented.

For the East Helena PWS sources, no natural barriers were identified present due to the coarse grained and highly transmissive nature of the source aquifer. A barrier for operating USTs is compliance with the 1998 EPA regulations for containment and spill prevention; and a barrier for the operating Landfill is compliance with existing operating regulations.

For non-point sources, the relative hazard is assigned based on the relative concentrations present within the delineated inventory zone for the aquifers, following the criteria listed in Table 6.

Table 6 – Relative Hazards for Non-Point Potential Contaminant Sources

Source Type	High Hazard	Moderate Hazard	Low Hazard
Septic Systems	> 300 per sq. mi.	50 – 300 per sq. mi.	< 50 per sq. mi.
Municipal Sanitary Sewer (% Land Use)	> 50% of region	20% – 50% of region	< 20% of region
Cropped Agricultural Land (% Land Use)	> 50% of region	20% – 50% of region	< 20% of region

Susceptibility Assessment Results

The results of the susceptibility assessment for the East Helena PWS are listed in Table 7, which reviews the relative hazard, barriers and susceptibility ranking of each potential source. Management actions are recommended that may be implemented as management barriers to help reduce the relative susceptibility of the wells to each potential contaminant source.

The assessment for the infiltration gallery indicates that agricultural land use and septic systems in the McClellan Creek Watershed are the only threats to the water source. The susceptibility for each of these sources is rated as moderate. The location of the infiltration gallery in an undeveloped area helps to minimize the potential risks to water quality from this source.

For the wells, the primary threats identified within the one-year time of travel distance are agricultural land use, the sanitary sewer system, and the wastewater treatment system and discharge pipe. The proximity of these sources results in the classification of the potential susceptibility of the wells as very high to contamination from each of these sources. The location of the railroad tracks, Yellowstone petroleum pipeline, and roads within the area all represent potential threats with a high to very high susceptibility rating, where an accidental spill or leak could impact water quality in the source aquifer. Within the remainder of the inventory zone for the wells, the LUST site and the ASARCO Smelter represent areas where ground water in the source aquifer has been contaminated. The susceptibility of these sites is rated as high.

The potential threats in the surface water buffer zones are from septic systems and agricultural land use. The relative susceptibility within the Prickly Pear Creek watershed is moderate, and very high around the Helena Valley Irrigation Canal proximal to Well 3.

Table 7. Susceptibility assessment of significant potential contaminant sources.

Tavie	? 7. Susceptibility	assessmeni oj	signijica	ini potentiai c	oniaminani Se	jurces.
Source	Contaminant	Hazard	Hazard Rating	Barriers	Susceptibility	Management
Control Zone	e –Infiltration Galler	y				
Agricultural Land	Pesticides/ Herbicides/ Nitrates and Pathogens	Leaching and Runoff	Low	None	Moderate	Fence control zone around infiltration gallery
Control Zone	e – Wells					
Agricultural Land	Pesticides/ Herbicides/ Nitrates and Pathogens	Infiltration and Runoff	Low	None	Moderate	Promote the use and development of agricultural BMPs for the area
Inventory Zo	ne – Infiltration Gal	lery				
Agricultural Land	Pesticides/ Herbicides/ Nitrates and Pathogens	Infiltration and Runoff	Low	None	Moderate	Promote the use and development of agricultural BMPs for the area
Septic Systems	Pathogens and Nitrate	Infiltration and Runoff	Low	None	Moderate	Monitor integrity of sewer lines
Inventory Zo	ne - Wells				-	
Agricultural Land	Pesticides/ Herbicides/ Nitrates and Pathogens	Infiltration and Runoff	High	None	Very High	Promote the use and development of agricultural BMPs for the area
Sanitary Sewer Main	Pathogens and Nitrate	Infiltration and Runoff	High	None	Very High	Monitor integrity of sewer lines
Wastewater Treatment System and Discharge Line	Pathogens and Nitrate	Infiltration and Runoff	High	None	Very High	Monitor system operation, and integrity of discharge lines
Septic Systems	Pathogens and Nitrate	Infiltration and Runoff	Moderate	None	High	Connect to Sanitary Sewer System; monitor septic system performance
Active USTs	Petroleum Hydrocarbons	Leakage, Infiltration and Runoff	High	Compliance with 1998 EPA upgrade regulations	High	Monitor operating compliance results
LUST Sites	Various Chemicals	Infiltration and runoff	Moderate	None	High	Review and monitor status of remediation system; including ground water monitoring results


Table 7. Susceptibility assessment of significant potential contaminant sources (continued)

Tuble 7. Di	Table 7. Susceptibility assessment of significant potential contaminant sources (continued)						
Source	Contaminant	Hazard	Hazard Rating	Barriers	Susceptibility	Management	
Inventory Zo	ne – Wells (continue	ed)					
Landfill	Various Chemicals	Infiltration and runoff	Moderate	Compliance with operation regulations.	Moderate	Monitor waste disposed in landfill, and downgradient water quality	
ASARCO Smelter	Arsenic, Various Other Metals and Various Chemicals	Existing ground water and soil contamination and potential for further ground water contamination	Moderate	None	High	Monitor progress of investigation and remediation of ground water plume and facility in general, include a review of ground water monitoring results	
American Chemet	Various Chemicals	Spills of Various Chemicals	Moderate	Compliance with operating regulations	Moderate	Prepare emergency response and notification plan with plant in case of accidental spill of chemicals	
Major Roads	Various Chemicals	Spills	High	None	Very high	Develop emergency response plan	
Railroad Lines	Various Chemicals	Spills	Moderate	None	High	Develop emergency response plan	
Yellowstone Pipeline	Petroleum Hydrocarbons	Spills	Moderate	None	High	Develop emergency response plan	
Gravel Pit	Various Chemicals	Direct infiltration	Moderate	None	High	Restrict access to the gravel pit	
Recharge Ar	ea and Surface Wate	er Buffer Zone	s for Prickl	y Pear Creek W	atershed	1	
Cropped Agricultural Land	Pesticides/ Herbicides/ Nitrates and Pathogens	Infiltration and Runoff	Low	None	Moderate	Promote the use and development of agricultural BMPs for the area	
Septic Systems	Pesticides/ Herbicides/ Nitrates and Pathogens	Infiltration and Runoff	Low	None	Moderate	Monitor septic system performance	
Recharge Ar	ea and Surface Wate	er Buffer Zone	s for Helen	a Valley Irrigati	ion Canal		
Cropped Agricultural Land	Pesticides/ Herbicides/ Nitrates and Pathogens	Infiltration and Runoff	High	None	Very High	Promote the use and development of agricultural BMPs for the area	
Septic Systems	Pesticides/ Herbicides/ Nitrates and Pathogens	Infiltration and Runoff	High	None	Very High	Monitor septic system performance	

6.0 REFERENCES

- Alden, W.C., 1953. Physiography and Glacial Geology of Western Montana and Adjacent Areas; U.S. Geological Survey Professional Paper 231.
- Briar, D.W., and J.P. Madison, 1992. Hydrogeology of the Helena Valley-Fill Aquifer System, West-Central Montana; U.S. Geological Survey Water Resources Investigations Report 92-4023.
- Fetter, C.W., 1994. Applied Hydrogeology, Macmillan College Publishing Co., New York, NY.
- Heath, R., 1982. Basic Ground Water Hydrology, U.S. Geological Survey Water Supply Paper 2220.
- Madison, J.P., 1993. Hydrologic Model of an Intermontane Basin, Helena Valley, Western Montana; University of Montana Masters Thesis.
- Montana Bureau of Mines and Geology (MBMG), 1996. May Activity Report to Montana Department of Environmental Quality, Wellhead Protection Program, Task Order 430007-TO-27.
- Montana Department of Environmental Quality (DEQ), 1999. Montana Source Water Protection Program.
- Montana Department of Natural Resources and Conservation, 1986. Montana Water Use in 1980: Helena.
- Moreland, J.A., and R.B. Leonard, 1980. Evaluation of shallow aquifers in the Helena Valley, Montana; U.S. Geological Survey Professional Paper 1316.
- Ross, C.P., Andrews, D.A., and I.J. Witkind, 1955. Geologic Map of Montana; United States Geological Survey, in cooperation with the Montana Bureau of Mines and Geology.
- Stickney, M.C., 1987. Quaternary Geology of the Helena Valley, Montana; Montana Bureau of Mines and Geology, Geologic Map Series 46.
- Thamke, J.N., 2000. Hydrology of the Helena Area Bedrock, West-Central Montana 1993-1998; with a section on Geologic Setting and Generalized Bedrock Geologic Map by Mitchell Reynolds. U.S. Geological Survey Water Resources Investigations Report 00-4212.
- Todd, D.K., 1980, Ground Water Hydrology, John Wiley and Sons, New York, NY.
- United States Environmental Protection Agency (EPA), 1993. Seminar Publication Wellhead Protection: A Guide for Small Communities, EPA/625/R-93/002.
- United States Geological Survey, 2000. Preliminary land use classification data for Montana

APPENDIX E – 2016 SANITARY SURVEY INSPECTION OF THE CITY OF EAST HELENA (MT0000196)





City of East Helena Attn: Jim Schell PO Box 1170 East Helena MT 59635

Re: Sanitary Survey Inspection of the City of East Helena, (PWSID:MT0000196).

Dear Daniel,

I would like to thank Scott St. Clair and Steve Leitzke for assisting me during the sanitary survey inspection of the City of East Helena public water supply system. As a community public water supply, your facility is required to have a sanitary survey inspection every three years. These routine inspections offer us an opportunity to look for sanitary deficiencies that have the potential to cause contamination in the water system, as well as pointing out operation and maintenance concerns. Below are a few comments relating to the sanitary survey conducted on April 14, 2016.

SOURCE(s):

The city of East Helena has five active sources. Two infiltration gallery wells are located south of town off Mockel Road and near McClellan Creek. These are engineered wells or infiltration wells. Each well has a subsurface concrete caisson and submersible pump that pumps water to the treatment facility and two buried concrete storage tanks located on Mockel Road. The north well (WL005) is located approximately 100 feet from the creek. Small buildings have been erected over each caisson entry hatch. The vault at well 5 (WL006) appears to be dry above the caisson.

The other three wells are located on Wylie Drive. Well 1 is located at the corner of Canyon Ferry Road and Wylie Drive. Well 2 is located midway between well 1 and well 3 and on the east side of Wylie Drive. Well 3 is located on the west side of Wylie Drive about ½ mile north of town pump. Well 1 has oil spattered around the entire pump area.

Management and operators of the system progressively maintain the source water transmission mains, site security and general housekeeping. They also proactively identify potential source contamination, source quantity and quality of the East Helena source water supply.

TREATMENT:

All records are in acceptable ranges and are submitted to the state as required. All equipment appears to be in good operating condition and well maintained.

There are two treatment facilities for the PWS. One facility is located next to the storage tanks on Mockel Road; the second treatment facility is located at the well 3 pump house. At the present time, both use chlorine gas as the disinfectant. The measured free chlorine residual at the City Hall was 0.56 ppm and at TP001 it was 0.81 ppm. There are continuous analyzers at both treatment facilities.

DISTRIBUTION: Distribution system (DS001)

The distribution system appears to have a history of adequate function and operation. It is noted that leaks are typically detected and fixed immediately. The distribution system consists of ductile iron and PVC pipe in a looped configuration. Chlorine levels in the distribution system are at acceptable levels. No issues were noted during this inspection.

STORAGE:

Three partially buried concrete tanks provide water storage for the PWS. The tanks are routinely cleaned by Liquid Engineering. No visible sediment was observed in the tanks including Highway 282 (ST003) and the two tanks (ST002 and ST004). Tanks ST002 and ST004 are located north of Mockel Road miles south of town. The overflow for the ST002 and ST003 tanks is located south of Mockel Road.

The clearwell, storage tank integrity, site security and potential sanitary risks are mitigated through the professional management and operations of the City of East Helena public water supply operators. Proper maintenance procedures, operation and inspections are routinely performed assuring the operational readiness of the public water supply.

PUMPS, PUMP FACILITIES and CONTROLS:

The pressure control facility's and pumping facility's maintenance indicate overall exceptional care and proper operation. The pump controls, alarms and monitoring are SCADA managed with automated backup control. The levels in the storage tanks control the operation of all of the well pumps. There are no booster pumping facilities or pressure tanks. A SCADA system is in operation.

MONITORING, REPORTING and DATA VERIFICATION:

Public water systems must conduct routine monitoring for contaminants in accordance with Federal Safe Drinking Water Act requirements. Parameters such as coliform bacteria, lead, copper, nitrate, nitrite, volatile organic chemicals, inorganic chemicals, synthetic organic chemicals, and radiological contaminants must be sampled in community PWSs in accordance with schedules specified in the Administrative Rules of Montana. Within the past five years, no positive fecal coliform samples were collected during routine contaminant monitoring. No MCL exceedances were noted for any other constituents monitored over the past five years. Monitoring and reporting appeared excellent and no outstanding violations exist. Data is well organized and very efficient. Sampling and reporting is completed as required.

MAINTENANCE, MANAGEMENT, SAFETY and OPERATION:

The system is very well managed and certified operators are retained as required. The system is quite complex and the operators are commended for their dedication to producing a high quality safe water. The evidence of pride in the water system and demonstration of knowledge by the staff during this inspection was very much appreciated.

OPERATOR COMPLIANCE WITH STATE REQUIREMENTS:

The current certified operators meeting all requirements. All previous survey recommendations have been addressed.

SIGNIFICANT DEFICIENCIES

No significant deficiencies were noted during this inspection.

WASTEWATER

Wastewater from the community is collected in a sanitary sewer system. The sewer system discharges to treatment ponds located.

If you have any questions about this report or public water supply regulations please give me a call at (406) 444-5881.

Sincerely,

Gerard Gernand

Land Genary

Environmental Science Specialist Surface Water Treatment Inspector

DEQ PWS, Helena Phone: (406) 444-5881 Fax: (406) 444-1374

CC: Helena PWS file

Lewis and Clark Sanitarian

SANITARY SURVEY	Page 1 of <u>13</u>			
PWSID MT0000196	SYSTEM NAME East Helena			
DATE OF SURVEY 4/21/2016	COUNTY Lewis and Clark	SURVEYOR NAME Gerard Gernand		
(SYSTEM REPRESENTATIVE) Scott St.Clair		(OTHER REPRESENTATIVE) <u>Steve Leitzke</u>		
Addressee <u>East Helena</u> Street <u>PO BOX 1170</u> City <u>East Helena</u> State <u>MT</u> Zip <u>596</u>		SYSTEM OWNER Addressee East Helena Owners Address Street PO Box 1170 City East Helena State MT Zip 59635 Owner Phone (406) 227-5321 Fax ()		
LOCATION OF SYSTEM Nearest City <u>Helena, MT</u> Descri	otion or Physical Address <u>Main ST, Ea</u>	st Helena	□ seasonal operation dates:to □ year round operation	
OPERATOR OF SYSTEM Name Scott St. Clair Certified Operator?	⊠ No Certification #	ALTERNATE OPERATOR OF SYSTEM Name Steve Leitzke Certified Operator?		
SYSTEM: A = Active P = Proposed I = Inactive	status d (Add New System)	SYSTEM CLASS C = Community		
Total Service Connections: Residen	tial / Non-Transient: <u>729</u> Transient : <u>75</u>	Resident Population (Number of permanent residents utilizing PWS daily)	<u>2114</u>	
_	tial / Non-Transient: 729 Transient: 75 es No Percent Metered %	Non-Transient Population (Maximum number of non-transient persons utilizing PWS daily) Transient Population (Maximum number of transient persons served by PWS daily)		
1 Federal Government 2 Private Subdivision, Investor, Trust, Co 3 State Government	opperative, Water Association, etc. 4 5 6	ER TYPE Local Government Authority, Commission, Distric Mixed Public/Private Native American	t, Municipality, City, etc.	
BR Bar DC Day Care Center DI Dispenser HS Head Start HA Homeowners Assoc. HM Hotel/Motel HR Highway Rest Area IC Interstate Carrier IN Institution MF Medical Facility MH Mobile Home Park MU Municipality OA Other Area OR Other Residential Area Service Category Description	PA Recreation Areas RA Residential Area RE Retail Employees RS Restaurant RV RV Park SC School SI Sanitary Improvement District SK Summer Camp SR Secondary Residences SS Service Station SU Subdivision WBWater Bottler WH Wholesaler (Sells Water) Average Daily Visitors TNC)	Comments:		

SANITARY SURVEY FORM - WATER SYSTEM FACILITIES

Page 2 of <u>13</u>

PWSID **MT0000196**

SYSTEM NAME East Helena

Water System Facilities (WSF) numbers are WSF Type Codes plus an assigned number. (i.e. source facility numbering starts with <u>002</u> and all non-source facilities start with <u>001</u>). See instruction sheet for a list of WSF Type Codes. When a source is operational it is considered **A**ctive, this includes systems that are seasonal. **I**nactive sources are those which are shut down but can return to active status, such as a system out of business. **P**roposed sources are those that have been identified through the Plan Review process, but are not connected to the water system.

A water source facility is a well, spring, intake, infiltration gallery or consecutive connections from which a system draws or purchases water:

Total Number of Source Facilities <u>5</u>

WATER SYSTEM FACILITIES SUMMARY (WSF)

WSF ID	Facility Name	Water Type Code	Purchased	Seller PWSID	Activity Status*
DS001 WL005 WL006 WL002 WL003 WL004 ST002 ST003 ST004 TP001 TP002 CH001 CH002 TM001	Distribution System Infiltration Gallery Well 4 McClellan Cr North Infiltration Gallery Well 4 McClellan Cr South Well 1 North Wylie Well 2 Middle Wylie Well 3 South Wylie Storage Tank McClellan 1 250K Storage Tank Wylie Wells 1MG Storage Tank McClellan 2 300K Treatment for Wylie Wells Treatment For McClellan Cr WL005/WL006 Common Header For Wylie Wells Common Header For McClellan Wells 2 Mile Transmission-McClellan Storage To Tov	vn	Yes	Seller PWSID	Activity Status* A
WL002/WL003/WL004>	stem Facility flow: <u>WL005/WL006>CH001>TP0</u> -CH001>TP001 <ds001>ST003>DS001</ds001>	<u>J2>\$1002>\$1004>1K</u>	1001>DS001 and		
Notes:					
(Example: WL002 and	WL003 > CH001 > TP001 > ST001 > PC001 > D	S001)			
*(A)Active, (I)Inactive, (F	P)Proposed				
	EMER	GENCY POWER			
Does the system have e	emergency power? Yes Mounted Diesel Generator	No		Freque	ency of testing: annual
Record of primary powe Comments:	er failures: in last year		Switchover: A	utomatic 🗵 Manua	al

SANITARY SURVEY FORM – WELLS & WELL PUMPS

Page <u>3</u> of <u>13</u>

PWSID **MT0000196**

SYSTEM NAME East Helena

(Please copy this sheet for additional wells & pumps)				
COMPLETE ONE PAGE FOR EACH SOURCE		STATUS OF SOURCE (A)ctive	☐ (I)nactive	☐ (P) roposed
WSF ID WL002 These are State assigned identification numbers Entry Point ID EP502		Log Available? ⊠ Yes □ No	Log SWL 34ft (static) expressed in feet b	elow ground elevation
Source Name Well 1 North Example: Well 1 or South well, etc.		Average Production 600gpm Indicate units	Log PWL 54ft (pumping) expressed in fe	
Location of Water Source (TRS or street address) <u>T101</u>	N,R3W,S14	Maximum Production	Test Pump Rate	expressed in gallons per min
Entry Point Name Entry Point For Wells 1,2,3 Example: EP for North Well 1 & South Well 2		Date Drilled 3.22.1965 if well date drilled	Intake Type Ste	eel Louver Screen screen, slots, perforations, open
Entry Point is at WSF ID TP001 EP is at the first water system facility with finished water.		Casing Size 48in to 30ft, 16in to 90ft	Intake Interval 9	
Available Perm Emerg Interim Seasonal If seasonal: to	☐ Other	size of casing installed in well Case Depth 90ft	Well Yield 600g	pm ump tested in gallons per minute
GWUDISW PA completed with this inspection ☐ Yes [⊠ No	Well Depth 110ft	Latitude 46.617	23° in decimal degrees
OWODIOW FA completed with this inspection in Fes g	<u> </u>	depth of well expressed in feet	Longitude -111.	93627° in decimal degrees
		Grout Depth <u>unknown</u> depth of grout used to seal well walls		
WELLS		PUN	/IPS	
Is well metered?	Yes No Unk N/A □ □ □	Type 75 HP vertical turbine pump wit (example: 30 hp line shaft turbin Rated Capacity		
Is well site protected from flooding?		Nated Sapacity		Yes No Unk N/A
Is well protected from potential sources of pollution (includes: surface water, known chemical		Are pumps operable?		
spills, agricultural use, etc.)?		How frequently are pump(s) replaced?	as needed	
If no explain		Are backup pumps/motors provided?		
Does casing extend at least ☐18 inches above outside ground level;		Are controls functioning properly and a protected?	dequately	\bowtie \sqcap \sqcap \sqcap
☐ 12 inches above finished floor inside well house; and ☐ 3 feet above 100 year flood elevation? (Check for appropriate distance)		Do underground compartments have a	ı drain?	
Is top of the well casing properly sealed? (sanitary seal)		Is facility properly protected against tre vandalism?	spassing and	
Is well vented? Is well vent properly screened and terminated		Are pump records maintained (amp, di		
in a downward position?		pressure, maintenance schedule, man	,	
Does well have suitable sampling tap? Raw Wate Treated		Is the plumbing adequately painted to excessive corrosion?	prevent	
Are check valves, blow-off valves and water meters maintained and operating properly?		Are adequate heating, lighting, and ver	ntilation provided?	
Is upper termination of well protected (housed or		Is a preventive maintenance program i	n operation?	
fenced)?		Are recommended spare parts on hand	?t	
Is intake located below the maximum drawdown?		Cross connection protection provided?		
Comment:		Explain Controls: The float in the stora pumps on as need Comment: This well is located inside a inside a 6 ft high security fenced/locke	ed. They alternate	which well is first.

SANITARY SURVEY FORM - WELLS & WELL PUMPS Page 4 of 13 PWSID MT0000196 SYSTEM NAME East Helena (Please copy this sheet for additional wells & pumps) COMPLETE ONE PAGE FOR EACH SOURCE STATUS OF SOURCE (A)ctive ☐ (I)nactive ☐ (P)roposed Log SWL 39ft WSF ID WL003 Entry Point ID EP502 Log Available? ⊠ Yes □ No identification numbers Log PWL 54ft synressed in feet below ground elevation Average Production _____indicate units Source Name Well 2 Middle GWIC 62116 Maximum Production ______indicate units Test Pump Rate expressed in gallons per min Location of Water Source (TRS or street address) 2995 Wylie Road - 1/2 mile south of Canyon Ferry Road Date Drilled 4.10.1965 if well. date drilled Intake Type Steel Louver Screen example: screen, slots, perforations, open Entry Point Name entry point for wells 1,2,3 Intake Interval 55-88ft bgl expressed in feet below ground elevation Casing Size 48in to 30ft, 16in to Entry Point is at WSF ID TP001 88ft Well Yield 600gpm pump tested in gallons per minute size of casing installed in wel Case Depth 88ft depth of casing installed in well Available ☐ Perm ☐ Emerg ☐ Interim ☐ Seasonal ☐ Other If seasonal: to Latitude 46.61317° Well Depth 92ft depth of well expressed in feet n decimal degrees Longitude -111.93546° in decimal degrees GWUDISW PA completed with this inspection ☐ Yes ☒ No Grout Depth unknown depth of grout used to seal well walls **WELLS PUMPS** Type 60 HP vertical turbine pump with Goulds Motor Yes No Unk N/A (example: 30 hp line shaft turbine) Is well metered? Rated Capacity _____ \sqcap \sqcap \sqcap \sqcap Is well site protected from flooding? Yes No Unk N/A Are pumps operable? Is well protected from potential sources of pollution (includes: surface water, known chemical How frequently are pump(s) replaced? as needed spills, agricultural use, etc.)? \square \square \square \square Are backup pumps/motors provided? If no . . explain ___ Are controls functioning properly and adequately Does casing extend at least protected? \square \square \square ☐ 18 inches above outside ground level; 12 inches above finished floor inside well house; and Do underground compartments have a drain? ☐3 feet above 100 year flood elevation? (Check for appropriate distance) Is facility properly protected against trespassing and Is top of the well casing properly sealed? (sanitary seal) vandalism? Is well vented? Are pump records maintained (amp, drawdown, discharge Is well vent properly screened and terminated pressure, maintenance schedule, manuals, etc.)? in a downward position? Is the plumbing adequately painted to prevent Raw Water 🗵 🔲 🔲 Treated 🔯 🔲 🔲 Does well have suitable sampling tap? excessive corrosion? Are check valves, blow-off valves and water meters Are adequate heating, lighting, and ventilation provided? maintained and operating properly? Is a preventive maintenance program in operation? Is upper termination of well protected (housed or fenced)? Are recommended spare parts on hand? Is intake located below the maximum drawdown? \square \square \square Cross connection protection provided? Comment: ___ Explain Controls: The float in the storage tank ST003 turns the Wylie well pumps on as needed. They alternate which well is first. Comment: This well is located inside a locked building which is inside a 6 ft high security fenced/locked compound.

SANITARY SURVEY FORM – WELLS & WELL PUMPS

Page <u>5</u> of <u>13</u>

PWSID MT0000196

SYSTEM NAME East Helena

(Pleas	e copy this sheet for	r additional wells & pumps)			
COMPLETE ONE PAGE FOR EACH SOURCE		STATUS OF SOURCE (A)ctive	☐ (I)nactive [(P)roposed	
WSF ID WL004 These are State assigned identification numbers Entry Point ID EP502		Log Available? ⊠ Yes ☐ No	Log SWL 35ft (static) expressed in feet be	elow ground elevation	
Source Name Well 3 South Example: Well 1 or South well, etc. GWIC 62125		Average Production unk indicate units	Log PWL 80ft (pumping) expressed in fee	t below ground elevation	
Location of Water Source (TRS or street address) 2700	Wylie Drive –	Maximum Production	Test Pump Rate	expressed in gallons per min	
located on the west side of the road at the curve		Date Drilled 10.16.1987		Screen screen, slots, perforations, open	
Entry Point Name entry point for wills 1,2,3 Example: EP for North Well 1 & South Well 2	l	Casing Size 12in to 70ft, 10in to	Intake Interval 7	1-119ft bgl	
Entry Point is at WSF ID TP001 EP is at the first water system facility with finished water.		153ft size of casing installed in well	Well Yield 600gr	in feet below ground elevation	
Available Perm Emerg Interim Seasonal If seasonal:	☐ Other	Case Depth 153ft depth of casing installed in well	Latitude 46.6060	mp tested in gallons per minute	
GWUDISW PA completed with this inspection Yes	⊼l N∩	Well Depth 156ft depth of well expressed in feet	Longitude -111.9	n decimal degrees	
	7 140	Grout Depth unknown depth of grout used to seal well walls	ir	in decimal degrees	
WELLS		PUM	IPS		
	Yes No Unk N/A	Type 60 HP vertical turbine pump with			
Is well metered?		(example: 30 hp line shaft turbine Rated Capacity))		
Is well site protected from flooding?				Yes No Unk N/A	
Is well protected from potential sources of pollution (includes: surface water, known chemical		Are pumps operable?			
spills, agricultural use, etc.)?		How frequently are pump(s) replaced?	as needed_		
If no explain		Are backup pumps/motors provided?			
Does casing extend at least ☐18 inches above outside ground level;		Are controls functioning properly and adprotected?	dequately	м п п п	
☐ 12 inches above finished floor inside well house; and		·	drain?		
3 feet above 100 year flood elevation? (Check for appropriate distance)		Do underground compartments have a			
Is top of the well casing properly sealed? (sanitary seal)		Is facility properly protected against tree vandalism?	spassing and		
Is well vented?		Are pump records maintained (amp, dra			
Is well vent properly screened and terminated in a downward position?		pressure, maintenance schedule, manu	,		
Does well have suitable sampling tap? Raw Wate Treated	#	Is the plumbing adequately painted to pexcessive corrosion?	revent		
Are check valves, blow-off valves and water meters maintained and operating properly?		Are adequate heating, lighting, and ven	ntilation provided?		
		Is a preventive maintenance program in	n operation?		
Is upper termination of well protected (housed or fenced)?		Are recommended spare parts on hand	i?		
Is intake located below the maximum drawdown?		Cross connection protection provided?			
Comment:		Explain Controls: The float in the stora pumps on as neede	ed. They alternate	which well is first.	
		Comment: This well is located inside a inside a 6 ft high security fenced/locked	-	iich is	

SANITARY SURVEY FORM - SURFACE WATER, SPRINGS & INFILTRATION GALLERIES

Page <u>6</u> of <u>13</u>

PWSID MT0000196	SYSTEM NAME Eas	st Helena		
SOURCES			STATUS OF SOURCE	☐ (I)nactive ☐ (P)roposed
WSF ID WL005 These are State assigned identification numbers	oint ID <u>EP505</u>		Location of Entry Point TP002	Average Production 500gpm indicate units
Source Name Infiltration Gallery well Mo	cClellan Creek Nor	<u>th</u>	Available ⊠ Perm ☐ Emerg ☐ Interim ☐ Seasonal ☐ Other	Maximum Production indicate units
Location of Water Source (TRS or street	address)		If seasonal: to	Latitude <u>46.55099</u> ° Longitude <u>-111.89880</u> °
Entry Point Name Name of EP - Example: Entry point for North Well 1 & South Wel	II 2		GWUDISW PA Completed? ☑ Yes ☐ No ☐ Unk ☐ N/A	
SURFACE SOURCES			SPRINGS & INFILTRATION GA	ALLERIES
What is the nature of watershed?			La marchaeta do	Yes No Unk N/A
☐ Agricultural Name ☐ Industrial			Is recharge area protected? If Yes, how? <u>City owns 20 acres that the content of the content of</u>	he two buildings sit on.
☐ Forest ☐ Residential ☐ Other			Ownership Fencing Ordinances	
What is the size of the owned/protected	area of the watersh	ned?	Other	
How is watershed controlled? Ownership Ordinances Zoning Other			What is the nature of recharge zones? ☑ Agricultural ☑ Industrial ☑ Forest ☑ Register tiel	
Has a source water protection plan been	ı developed?	Yes No Unk N/A	⊠ Residential □ Other	
Has management had a watershed survi	ey performed?		Is site protected from flooding?	
Is there an emergency spill response pla	ın?		Is there diversion of surface drainage f	from site?
Is the source adequate in quantity?			-	
Is the source adequate in quality?			Is collection chamber properly construc	cted?
Is the intake protected from sources of co	ontamination?		Does hatch cover overlap?	
Are multiple intakes, located at different utilized?	levels,		Is the overflow outlet screened?	
Is the highest quality water being drawn?	?			
Can the raw water transmission line bypa	ass treatment?		Vented and screened?	
How often are intakes inspected?	_		Is supply intake adequate?	
What conditions cause fluctuations in qu	ality?		Is site properly protected (from livestoc tampering, etc)?	ck, vandalism,
Comment:			What conditions cause changes to qua	ality of the water?
			Comment:	

SANITARY SURVEY FORM - SURFACE WATER, SPRINGS & INFILTRATION GALLERIES

Page <u>7</u> of <u>13</u>

& INITICITATION GALLERIES					
PWSID MT0000196	SYSTEM NAME Ea	st Helena			
SOURCES			STATUS OF SOURCE ⊠ (A)ctive	☐ (I)nactive	☐ (P)roposed
WSF ID WL006 These are State assigned identification numbers Source Name Infiltration Gallery well McClellan Creek North Name of Source - Example: Well 1 or South well, etc. Location of Water Source (TRS or street address) 100 yards south of Mockel Road Entry Point Name Entry point for WL005 and WL006 Name of EP - Example: Entry point for North Well 1 & South Well 2			Location of Entry Point TP002 Available	Average Produ Maximum Prod Latitude <u>46.55</u> Longitude <u>-111</u>	duction indicate units 013°
SURFACE SOURCES			SPRINGS & INFILTRATION G	ALLERIES	
What is the nature of watershed?					Yes No Unk N/A
☐ Agricultural Name ☐ Industrial ☐ Forest			Is recharge area protected? If Yes, how? City owns 20 acres that	the two buildings s	
☐ Residential ☐ Other			☐ Ownership ☐ Fencing ☐ Ordinances		
What is the size of the owned/protected	area of the waters	hed?	☐ Other		
How is watershed controlled? Ownership Ordinances Zoning Other		Yes No Unk N/A	What is the nature of recharge zones ☑ Agricultural ☑ Industrial ☑ Forest ☑ Residential ☐ Other	?	
Has a source water protection plan been	·		Is site protected from flooding?		
Has management had a watershed surv			To the protected from flooding.		
Is there an emergency spill response pla	in?		Is there diversion of surface drainage	from site?	
Is the source adequate in quantity?			Is collection chamber properly constru	uctod2	\boxtimes \square \square \square
Is the source adequate in quality?			is collection chamber properly constitu	ucteu :	
Is the intake protected from sources of c			Does hatch cover overlap?		
Are multiple intakes, located at different utilized?			Is the overflow outlet screened?		
Is the highest quality water being drawn?)		Variation and agreement O		
Can the raw water transmission line bypa	ass treatment?		Vented and screened?		
How often are intakes inspected?		Is supply intake adequate?			
What conditions cause fluctuations in quality?		Is site properly protected (from livestock, vandalism, tampering, etc)?			
Comment:			What conditions cause changes to qu	uality of the water?	
				-	
			Comment: Infiltration gallery is engine	<u>eered</u>	

SANITARY SURVEY FO	ORM - TREATMENT		Page 8 of 13		
PWSID MT0000196	SYSTEM NAME East Helena		<u> </u>		
Treatment Objective	WATER TREATMENT FACIL	ITIES			
B = Disinfection Byproduct Control		ment Plant Name	Treatment Objecti	ves and Code	
 C = Corrosion Control D = Disinfection E = Dechlorination F = Iron Removal I = Inorganics Removal M = Manganese Removal O = Organics Removal 		Wylie Wells ellan Creek Sources	D401 C445	- - - - -	
P = Particulate Removal R = Radionuclides Removal S = Softening (Hardness Removal) T = Taste / Odor Control	WSF ID Lo	cation Record in decimal degrees			
Z = Other	TP001 Latitude 46.606 TP002 Latitude 46.550 Latitude ° Latitude ° Latitude °	12° Longitude -111.89935° Longitude°			
Treatment plant description: IG002 and IG003 to TP002; Premia 75 polyphosphate is added for corrosion control (P75MPH2XAVTC2A5X)					
FOR SYSTEMS EMPLOYING FU	JLL-TIME DISINFECTION		AS CHLORINATION	Yes No Unk N/A	
What disinfectant is used? Gas chlorine	Yes No Unk N	/A Is a manifold provided to allow fee more than one cylinder?	ding gas from		
Is the disinfectant used NSF approved?		☐ Is there automatic switchover from	cylinder to cylinder?		
Is the amount of disinfectant used recorde		Are scales provided for weighing o	f containers?		
If Yes, amount used:lbs/day X p Is the amount of disinfectant used compar		Are chlorine storage and use areas other work areas?	s isolated from	$\boxtimes \Box \Box \Box$	
pumped to verify concentration?			ibeled?		
Is chemical storage adequate and safe? If No, explain		is room vented to the outdoors with			
Is disinfectant residual being monitored da	nily?	no more than 6 inches above the f	oor level?		
Are residual reports submitted monthly?					
ls 4-log removal (D361) required?		Is room containing chlorination treasulation sufficiently (DANGER signs, etc.)?		\boxtimes \square \square \square	
(D361) Minimum free chlorine residual cor		Is a view port provided into the roo	m storing chlorine?		
Is minimum free chlorine residual maintair		is a means of leak detection provid	led?		
Is the disinfection equipment being operat maintained properly?	ed and $oxtime oxtless ox oxtless ox oxtless ox ox oxtless ox ox ox ox ox ox ox ox ox ox$	Type?	estus susilable for		
Is operational standby equipment provided	d? □□□		atus avaliable for		
If not, are critical spare parts on hand?					
Has disinfection system been free from fai during the past year – no interruption?	lure	Are personnel trained to use apparamental Are all doors hinged outward and e			
If No, give dates of interruptions		bars?			
Describe provisions for providing contact the first point of use: 1 mile of 10 inch pipmiles of 10 inch pipe from McClellan Treat treated prior to storage from the McClellan	e from Wylie Wells to first users; ment to most users. Water is				
Comment: The McClellan Creek sources	have the addition of ortho-polyph	osphate prior to chlorination.			

SANITARY SURVEY FORM - STORAGE Page 9 of 13 PWSID MT0000196 SYSTEM NAME East Helena COMPLETE ONE SECTION FOR EACH STORAGE FACILITY Total storage provided 1.55 M gallons Total treated storage provided 1.55 M gallons Storage provides 3 days of water reserve STORAGE FACILITY STORAGE FACILITY WSF ID ST002 WSF ID ST004 Location 43 Mockel Road Location 43 Mockel Road Description 250,000 gallon partially buried concrete tank Description 300,000 gallon partially buried concrete tank in decimal degrees in decimal degrees Latitude: 46.55523° Latitude: : 46.55529° in decimal degrees in decimal degrees Longitude: -111.89939° Longitude: -111.89931° Storage Volume 250,000 gallons Storage Volume 300,000 gallons Year constructed: 1928 Year constructed: 1964 Condition: ☐Good ☐Fair ☐Poor ☐Not accessible Condition: ☐Good ☐Fair ☐Poor ☐Not accessible Yes No Unk N/A Yes No Unk N/A Does surface runoff and underground drainage drain Does surface runoff and underground drainage drain away? away? Is the site protected against flooding? Is the site protected against flooding? Is the site protected against trespass/vandalism? Is the site protected against trespass/vandalism? Ladders caged and locked? Ladders caged and locked? Are overflow lines, air vents, drainage lines or clean Are overflow lines, air vents, drainage lines or clean out pipes turned downward or covered, screened and out pipes turned downward or covered, screened and terminated a minimum of 3 diameters above the ground terminated a minimum of 3 diameters above the ground or storage tank surface? or storage tank surface? Overflow pad? Overflow pad? Is access hatch sealed properly and locked? Is access hatch sealed properly and locked? Are surface coatings in contact with water ANSI / NSF Are surface coatings in contact with water ANSI / NSF approved? approved? Is tank protected against icing and corrosion? Is tank protected against icing and corrosion? Can tank be isolated from system? Can tank be isolated from system? Is all treated water storage covered? Is all treated water storage covered? Are tanks disinfected after repairs are made? Are tanks disinfected after repairs are made? What is cleaning frequency for tanks? 3-5 yrs What is cleaning frequency for tanks? 3-5 yrs Is tank inspected every 5 years by a structural engineer Is tank inspected every 5 years by a structural engineer for structural integrity? for structural integrity? Date of last inspection Date of last inspection By whom By whom Comments: Level in this tank kicks on the well pumps: at 17' shuts off; 14' Comments: ___ kicks them on. Tank levels initiate pumping from the Wyle wells (1, 2, and

3).

SANITARY SURVEY FORM - STORAGE Page <u>10</u> of <u>13</u> PWSID MT0000196 SYSTEM NAME East Helena COMPLETE ONE SECTION FOR EACH STORAGE FACILITY Total storage provided 1.55 M gallons Total treated storage provided 1.55 M gallons Storage provides 3 days of water reserve STORAGE FACILITY STORAGE FACILITY WSF ID ___ WSF ID ST003 Location along Highway 282 Road Location Description partially buried concrete tank Description ____ in decimal degrees Latitude: ° in decimal degrees Latitude: : 46.57387° Longitude: _____o in decimal degrees Longitude: -111.93526° Storage Volume ____ gallons Storage Volume 1,000,000 gallons Year constructed: 1999 Year constructed: ____ Condition: ☐Good ☐Fair ☐Poor ☐Not accessible Condition: ☐Good ☐Fair ☐Poor ☐Not accessible Yes No Unk N/A Yes No Unk N/A Does surface runoff and underground drainage drain Does surface runoff and underground drainage drain away? awav? Is the site protected against flooding? Is the site protected against flooding? Is the site protected against trespass/vandalism? Is the site protected against trespass/vandalism? Ladders caged and locked? Ladders caged and locked? Are overflow lines, air vents, drainage lines or clean Are overflow lines, air vents, drainage lines or clean out pipes turned downward or covered, screened and out pipes turned downward or covered, screened and terminated a minimum of 3 diameters above the ground terminated a minimum of 3 diameters above the ground or storage tank surface? or storage tank surface? Overflow pad? Overflow pad? Is access hatch sealed properly and locked? Is access hatch sealed properly and locked? Are surface coatings in contact with water ANSI / NSF Are surface coatings in contact with water ANSI / NSF approved? approved? Is tank protected against icing and corrosion? Is tank protected against icing and corrosion? Can tank be isolated from system? Can tank be isolated from system? Is all treated water storage covered? Is all treated water storage covered?

 \square \square \square \square

Are tanks disinfected after repairs are made?

Is tank inspected every 5 years by a structural engineer

By whom

What is cleaning frequency for tanks?

for structural integrity?

Date of last inspection

Comments: _____

Comments: <u>Level in this tank kicks on the well pumps</u>: at 17' shuts off; 14' kicks them on. Tank levels initiate pumping from the Wyle wells (1, 2, and

Are tanks disinfected after repairs are made?

What is cleaning frequency for tanks? 3-5 yrs

for structural integrity?

Date of last inspection

Is tank inspected every 5 years by a structural engineer

By whom

<u>3).</u>

SANITARY SURVEY FORM - MISCELLANEOUS

Page <u>11</u> of <u>13</u>

PWSID **MT0000196**

SYSTEM NAME East Helena

DISTRIBUTION SYSTEM EVALUATION	,	SAFETY		
		Were confined spaces observed?	Yes No Unk N/A	
WSF ID The distribution system consists of primarily ductil	<u>e iron and PVC</u> Yes No Unk N/A	Describe any confined energy changed all storage table		
System drawings available?		Describe any confined spaces observed <u>all storage tank</u> gallery caissons and vaults; all valve vaults and chlorinati	ion facilities	
Accurate As-Built drawing(s) on-site?		Confined space safety adequate?	$\boxtimes \square \square \square$	
Lines adequately sized?				
Adequate pressure maintained?		Fall risks adequately mitigated?		
Mains protected from freezing?		Note all safety deficiencies (consider items such as ladde		
Distribution system free of leaks?		guards on rotating electrical equipment, lightning protecti etc.)	on for pumps,	
Asbestos concrete pipe used?				
Fire hydrants?				
Dead end lines minimized by looping mains?				
Flushing program?				
Pressure reducing stations? Number				
Booster stations? Number				
Are individual booster pumps on any service lines? (see DEQ-1 6.4.4)				
Were cross connections observed?				
Describe distribution:				
Comments:				
MONITORING AND RECORDKEEPING EVALU	IATION	MANAGEMENT		
Door the gretom have a current Manitaring Schodule?	Yes No Unk N/A	Are there sufficient personnel?	Yes No Unk N/A	
Does the system have a current Monitoring Schedule? Bacti monitoring records maintained? (5 years)				
Bacti Sample Site Plan submitted?		Are operators properly certified?		
Familiar with repeat sampling?		Are personnel adequately trained?		
Chemical monitoring records maintained? (10 years)		Is there a current O&M manual on-site?		
System specific records / plans maintained?		Is an emergency plan on-site and workable?		
(DBP, PB/CU, treatments, waivers, violations, etc.) Familiar with Public Notice requirements?		Has system addressed concerns from previous sanitary survey(s) or technical visit(s)?		
Did Surveyor take a bacteriological sample?		Budget exists?		
If Vac data of Camples Time of Camples				
If Yes, date of Sample: Time of Sample:		Does system maintain an emergency fund?		
Comments:		Does system maintain an emergency fund? Does system contribute to facility replacement fund?		
		Does system contribute to facility replacement fund?		

REPORT SUMMAR	•	Page <u>12</u> of

PWSID MT0000196 SYSTEM NAME East Helena

The State, or an authorized agent, must conduct sanitary surveys for all public water supply systems in Montana. DEQ believes that periodic sanitary surveys, along with appropriate corrective actions, are indispensable for assuring the long-term quality and safety of drinking water. When properly conducted, sanitary surveys can provide important information on a water system's design and operations and can identify minor and significant deficiencies for correction before they become major problems.

Minor deficiencies do not pose serious health threats. However, corrective action of minor deficiencies can be critical in the long-term operation and safety of a public water system. Minor deficiencies are generally described as suggested or recommended corrections in the letter to system owner(s).

Significant deficiencies can be defined as a defective water supply component(s) having or likely to have an adverse influence on public health. Significant deficiencies require immediate corrective action in efforts to protect consumers.

EPA and ASDWA guidance identifies eight broad components that should be covered in a sanitary survey. Using these eight broad components as a guide, minor and significant deficiencies should be described in the letter to system owner(s).

1) Source

5) Pumps, pump facilities, and controls

2) Treatment

- 6) Monitoring and reporting, and data verification
- 3) Distribution system
- 7) System management and operation

4) Finished water storage


8) Operator compliance with State requirements


With consideration that significant deficiencies may influence regulatory decisions and monitoring requirements, please list all significant deficiencies observed and corrective action(s) taken below.

Comments: NO Significant Deficiencies Observed

PRV

To distribution





MONTANA WELL LOG REPORT

This well log reports the activities of a licensed Montana well driller, serves as the official record of work done within the borehole and casing, and describes the amount of water encountered. This report is complied electronically from the contents of the Ground-Water Information Center (GWIC) database for this site. Acquiring water rights is the well owner's responsibility and is NOT accomplished by the filing of this report.

Other Options

Plot this site on a topographic map View scanned well log (10/23/2006 1:34:47 PM)

Site Name: EAST HELENA CITY OF

GWIC Id: 61839

Well 1

DNRC Water Right: W113655-00

Total Depth: 110 Static Water Level: 34

Water Temperature:

Section 7: Well Test Data

Section 1: Well Owner

Owner Name

EAST HELENA CITY OF

Mailing Address

2970 CANYON FERRY RD

City

State Zip Code EAST HELENA 59635 MT

Pump Test *

Depth pump set for test _ feet.

600 gpm pump rate with _ feet of drawdown after 12 hours of

Time of recovery hours.

Recovery water level _ feet. Pumping water level 54 feet.

Section 2: Location

Township Range Section **Quarter Sections** 10N 03W SE1/4 SE1/4 SE1/4 Geocode County

LEV

Addition

NIS AND CLAR	K		
Latitude	Longitude	Geomethod	Datum
46.6177	111.9371	MAP	NAD27
Altitude	Method	Datum	Date
3796			

Block

* During the well test the discharge rate shall be as uniform as possible. This rate may or may not be the sustainable yield of the well. Sustainable yield does not include the reservoir of the well casing.

Section 8: Remarks

Section 3: Proposed Use of Water

PUBLIC WATER SUPPLY (1)

Section 4: Type of Work

Drilling Method: CAISSON DRILLED

Section 5: Well Completion Date

Date well completed: Monday, March 22, 1965

Section 6: Well Construction Details

Borehole dimensions From To Diameter 0 110

Casing

From	То	Diameter	Wall Thickness	Pressure Rating	Joint	Туре
0	30	48				STEEL
0	90	16				STEEL

Completion (Perf/Screen)

			# of	Size of	
From	То	Diameter	Openings	Openings	Description
90	110	16			SS LOUVER SCREEN

Annular Space (Seal/Grout/Packer)

			Cont.
From	То	Description	Fed?
0	0	CEMENT	

Section 9: Well Log **Geologic Source**

110ALVM - ALLUVIUM (QUATERNARY)

From	То	Description
0	37	ROCKS SAND & BOULDERS
37	46	ROCK SAND BOULDERS W/ CLAY STREAKS
46	51	HARDPAN & ROCK
51	110	ROCK SAND BOULDERS W/ STREAKS OF CLAY

Driller Certification

All work performed and reported in this well log is in compliance with the Montana well construction standards. This report is true to the best of my knowledge.

Company:LAYNE-MINNESOTA

License No:WWC-76 Date Completed: 3/22/1965

MONTANA WELL LOG REPORT

This well log reports the activities of a licensed Montana well driller, serves as the official record of work done within the borehole and casing, and describes the amount of water encountered. This report is complied electronically from the contents of the Ground-Water Information Center (GWIC) database for this site. Acquiring water rights is the well owner's responsibility and is NOT accomplished by the filing of this report.

Other Options

Plot this site on a topographic map View scanned well log (10/31/2006 9:12:03 AM)

Site Name: EAST HELENA CITY OF

GWIC Id: 62116

well 2

Quarter Sections

DNRC Water Right: W113656-00

Total Depth: 92 Static Water Level: 39 Water Temperature:

Section 7: Well Test Data

Section 1: Well Owner

Owner Name

EAST HELENA CITY OF Mailing Address

2995 WYLIE DR City

Zip Code EAST HELENA 59635

Range

Pump Test *

Depth pump set for test _ feet.

600 gpm pump rate with _ feet of drawdown after 12 hours of

Time of recovery _ hours. Recovery water level _ feet. Pumping water level 54 feet.

Section 2: Location

Township

Addition

10N	03W	24 SE1/4	NW¼ NW¼
	County		Geocode
LEWIS AND CLAF	RK		
Latitude	Longitude	Geomethod	Datum
46.6128	111.9345	MAP	NAD27
Altitude	Metho	d Datum	Date
3807			

Block

Section

* During the well test the discharge rate shall be as uniform as possible. This rate may or may not be the sustainable yield of the well. Sustainable yield does not include the reservoir of the well casing.

Section 8: Remarks

Section 3: Proposed Use of Water

PUBLIC WATER SUPPLY (1)

Section 4: Type of Work

Drilling Method: CAISSON

Section 5: Well Completion Date

Date well completed: Saturday, April 10, 1965

Section 6: Well Construction Details

Borehole dimensions From To Diameter

0 92

Casing

From	То		Wall Thickness	Pressure Rating	Joint	Туре
0	30	48				STEEL
0	88	16				STEEL

Completion (Perf/Screen)

			# of	Size of	
From	Τo	Diameter	Openings	Openings	Description
58	88	0			OPEN BOTTOM
58	88	16			SS LOUVER SCREEN

Annular Space (Seal/Grout/Packer)

			Cont.
From	То	Description	Fed?
0	0	CEMENT	

Section 9: Well Log **Geologic Source**

110ALVM - ALLUVIUM (QUATERNARY)

TIVAL	/IVI - AL	LUVIUW (QUATERNART)
From	То	Description
0	38	TOPSOIL ROCK BOULDERS AND SANDY CLAY
38	45	ROCK BOULDERS SAND WITH STREAKS OF CLAY
45	69	ROCK CLAY SAND AND HARDPAN
69	92	ROCK SAND STREAKS OF CLAY

Driller Certification

All work performed and reported in this well log is in compliance with the Montana well construction standards. This report is true to the best of my knowledge.

Company:LAYNE-MINNESOTA License No:WWC-76

Date Completed:4/10/1965

MONTANA WELL LOG REPORT

Other Options

This well log reports the activities of a licensed Montana well driller, serves as the official record of work done within the borehole and casing, and describes the amount of water encountered. This report is complied electronically from the contents of the Ground-Water Information Center (GWIC) database for this site. Acquiring water rights is the well owner's responsibility and is NOT accomplished by the filing of this report.

Plot this site on a topographic map View scanned well log (10/31/2006 11:50:01 AM)

Site Name: EAST HELENA CITY OF

well 3

DNRC Water Right: P062231-00

Section 1: Well Owner

Ourse Name

Owner Name

GWIC Id: 62125

EAST HELENA CITY OF Mailing Address

2700 WYLIE DR

CityStateZip CodeEAST HELENAMT59635

Section 2: Location

Section 2. Loca	ation		
Township	Range	Section	Quarter Sections
10N	03W	24	SW1/4 NW1/4 SW1/4
	County		Geocode

LEWIS AND CLARK

WIS AND CLARK			
Latitude	Longitude	Geomethod	Datum
46.60591	111.93585	MAP	NAD83
Altitude	Method	Datum	Date

Addition Block Lot

Section 7: Well Test Data

Total Depth: 153
Static Water Level: 35
Water Temperature:

Pump Test *

Depth pump set for test _ feet.

550 gpm pump rate with _ feet of drawdown after 24 hours of

pumping.

Time of recovery _ hours.

Recovery water level _ feet.

Pumping water level <u>80</u> feet.

* During the well test the discharge rate shall be as uniform as possible. This rate may or may not be the sustainable yield of the well.

Sustainable yield does not include the reservoir of the well casing.

Section 8: Remarks

Section 3: Proposed Use of Water

PUBLIC WATER SUPPLY (1)

Section 4: Type of Work

Drilling Method: FORWARD ROTARY

Section 5: Well Completion Date

Date well completed: Friday, October 16, 1987

Section 6: Well Construction Details

Borehole dimensions
From To Diameter
0 153 16

Casing

			Wall	Pressure		
From	То	Diameter	Thickness	Rating	Joint	Type
-2	70	12				50 LB STEEL
-2	153	10				STEEL
7	119	10				STEEL

Completion (Perf/Screen)

			# of	Size of	
From	То	Diameter	Openings	Openings	Description
71	119	10			STAINLESS STAIN SCREEN

Annular Space (Seal/Grout/Packer)

			Cont.
From	То	Description	Fed?
0	51	CEMENT & BENTONITE	

Section 9: Well Log Geologic Source

120SDMS - SEDIMENTS (TERTIARY)

From	То	Description
0	20	SILTY LOAM WITH GRAVELS
20	35	GRAVELY CLAYS
35	54	FINE, SANDY CLAY
54	58	MED. GRAVELS
58	71	CLAY AND GRAVELS
71	74	COARSE GRAVELS
74	80	CLEAN GRAVELS
80	84	SILTY GRAVELS
84	88	COARSE GRAVELS
88	99	SILTY GRAVELS
99	107	COARSE TO FINE GRAVELS
107	119	FINE TO COARSE, SILTY CLAYBOUND AND GRAVELS
119	153	SOFT SILTSTONE

Driller Certification


All work performed and reported in this well log is in compliance with the Montana well construction standards. This report is true to the best of my knowledge.

Name:

Company:POTTS DRILLING INC

License No:WWC-150

Date Completed:10/16/1987







































































SANITARY SURVEY	FORM - INVENTORY		Page 1 of	
PWSID 00196	SYSTEM NAME East Helena			
DATE OF SURVEY 9/18/2013	COUNTY Lewis and Clark	SURVEYOR NAME -Luella B. Schultz		
(SYSTEM REPRESENTATIVE) Steve Lietzko	9	(OTHER REPRESENTATIVE) Emily Ewart		
Addressee Steve Lietzke Street PO Box 1170 City East Helena State MT Zip 59635	Address - Administrative contact Address 459-1816 Fax ()	Addressee City of East Helena Anthony Owners Ad Street PO Box 1170 City East Helena State MT Zip 59635 Owner Phone (406) 227-5321 Fax (<mark>' Strainer Mayor</mark> dress	
LOCATION OF SYSTEM Nearest City <u>Helena</u> Description	or Physical Address <u>Office is in Court H</u>	louse on Main St. East Helena	□ seasonal operation dates:to □ year round operation	
· ·	☐ No ☐ Not required ☐ No Certification # 6757 # ()	ALTERNATE OPERATOR OF SYS Name Ron Robertson Certified Operator? ☑ Yes ☐ Copy of Certificate? ☐ Yes ☐ Phone # (406) 227-5321 Cell Phone	No Not required No Certification # 8325	
SYSTEM A = Active P = Pending I = Inactive	status (Add New System)	SYSTEM CLASS C = Community NTNC = Non-Transient Non-Community TNC = Transient Non-Community		
	ial / Non-Transient: 729 Transient: 75 T ial / Non-Transient: 729	Resident Population (Number of permanent residents utilizing PWS daily) Non-Transient Population (Maximum number of non-transient persons utilizing PWS daily)		
Service Connections Metered? 🛛 Y Percent Metered 100 %	Transient: <u>75</u> es □ No	Transient Population (Maximum number of transient persons served by PWS daily)		
1 Federal Government 2 Private Subdivision, Investor, Trust, Co 3 State Government SERVICE AREA CHAI	operative, Water Association, etc. 4 5 6	ER TYPE Local Government Authority, Commission, District Mixed Public/Private Native American	t, Municipality, City, etc.	
BR Bar DC Day Care Center DI Dispenser HS Head Start HA Homeowners Assoc. HM Hotel/Motel HR Highway Rest Area IA Industrial/Agricultural IC Interstate Carrier IN Institution MF Medical Facility	PA Recreation Areas RA Residential Area RE Retail Employees RS Restaurant RV RV Park SC School	Comments: Chlorine residual was .56 ppm at the City Well 2 wasn't in operation the day of the done on the pump. The chlorinator at McClellan Creek is dos spare parts so he has them on hand. They abandoned the plan to convert to se chlorine gas for disinfection.	inspection because work is being wn for repairs. Steve has ordered	

SANITARY SURVI	EY FORM – WATER SYSTE	M FACILIT	IES		Page 2 of
PWSID 00196	SYSTEM NAME East Helena				
facilities start with <u>001</u>). See instru are seasonal. <i>I</i> nactive sources ar	mbers are WSF Type Codes plus an assignuction sheet for a list of WSF Type Codes. re those which are shut down but can return he Plan Review process, but are not conne	When a source is to active status.	s operational it is cor such as a svstem oւ	sidered Active this	s includes systems that
A water source facility is a well, sonsecutive connections from which	spring, intake, infiltration gallery or ch a system draws or purchases water:	Total Numb	per of Source Faciliti	es <u>5</u>	
	WATER SYSTEM FAC	ILITIES SUMMA	RY (WSF)		
WL005 Horizon WL006 Horizon WL002 Well #1 WL003 Well #2 WL004 Well #3 ST002 Storage ST003 Storage TP001 Treatme TP002 Treatme CH001 Commol CH002 Commol	Name ion System al well 4 McClellan Cr. north al well 5 McClellan Cr. south (north) Wylie (middle) Wylie (south) Wylie Tank McClellan #1 (250,000) Tank Wylie wells (1MG) Tank McClellan Cr. #2 (300K) nt for Wylie Wells nt for McClellan Cr. WL005 and WL006 Theader for Wylie Wells Theader for McClellan wells Theader for McClellan storage to town		Purchased Yes	Seller PWSID	Activity Status* A A A A A A A A A A A A A A A A A A A
Example: Well 1 (WL002) to comr	ty flow: WL005 and Wl006 to CH002 to TP 003 non header (CH001), Well 2 (WL003) to co 001) to storage tank (ST001) to distribution	mmon header (C	H001) to treatment r		
	EMERGEN	ICY POWER			
Does the system have emergency If yes, what type: <u>Trailer Mounted</u> Record of primary power failures: 1 Comments:	Diesel Generator		Switchover		ncy of testing: 1/yr

SANITARY SURVE	Y FORM – W	ELLS & WELL	PUMPS	Page	of	
PWSID 00196	SYSTEM NAME Eas	st Helena				
	(Plea	se copy this sheet fo	r additional wells & pumps)			
COMPLETE ONE PAGE FOR EAC	H SOURCE		STATUS OF SOURCE ☒ (A)ctive	☐ (I)nactive ☐	(P)roposed	
WSF ID WL002			Log Available? Yes No Average Production 600 gpm indicate units Maximum Production indicate units Date Drilled 3/22/1965 if well. date drilled Casing Size 48 inch to 30'; 16 inch to 90' size of casing installed in well Case Depth 90' depth of casing installed in well Well Depth 110' depth of well expressed in feet Grout Depth unknown depth of grout used to seal well walls	Log SWL 34' (static) expressed in feet below ground elevation Log PWL 54' (pumping) expressed in feet below ground elevation Test Pump Rate expressed in gallons per min Intake Type steel louver screen type of intake mechanism Screened Interval 90-110' expressed in feet below ground elevation Well Yield 600 gpm pump tested in gallons per minute Latitude 46.61723° Longitude 111.93627°		
W	ELLS		PUN	MPS		
Is well metered? Is well site protected from flooding? Is well protected from potential sour pollution (includes: surface water, k spills, agricultural use, etc.)? If no explain gravel pit nearby: Carbon casing extend at least 18 inches above outside ground 12 inches above finished floor included (Check for appropriate distance) Is top of the well casing properly set is well vent properly screened and the in a downward position? Does well have suitable sampling to Are check valves, blow-off valves a maintained and operating properly? Is upper termination of well protected fenced)? Is intake located below the maximum	rces of nown chemical anyon Ferry Road ver level; side well house; and ation? aled? (sanitary seal) erminated ap? Raw Water Treated and water meters		Type 75 HP vertical turbine pump with (example: 30 hp line shaft turbine Rated Capacity Are pumps operable? How frequently are pump(s) replaced? Are backup pumps/motors provided? Are controls functioning properly and a protected? Do underground compartments have a ls facility properly protected against tre vandalism? Are pump records maintained (amp, dr pressure, maintenance schedule, manuals the plumbing adequately painted to pexcessive corrosion? Are adequate heating, lighting, and veralls a preventive maintenance program in the Are recommended spare parts on hand cross connection protection provided?	Goulds motor e) Worked on in 2010 Idequately Idea drain? Ispassing and Irawdown, discharge, uals, etc.)? Index of the control of the contro	Yes No Unk N/A O	
Comment: RW sample tap inside well house. Regulating valve is leaking			Explain Controls: The float in the storage pumps on as need. Comment: This well is located inside inside a 6 ft high security fenced/locked	ed. They alternate value of the second of th	which well is first.	

MONTANA WELL LOG REPORT

This well log reports the activities of a licensed Montana well driller, serves as the official record of work done within the borehole and casing, and describes the amount of water encountered. This report is complied electronically from the contents of the Ground-Water Information Center (GWIC) database for this site. Acquiring water rights is the well owner's responsibility and is NOT accomplished by the filing of this report.

Other Options

Plot this site on a topographic map View scanned well log (10/23/2006 1:34:47 PM)

Site Name: EAST HELENA CITY OF

GWIC Id: 61839

Well 1

DNRC Water Right: W113655-00

Section 1: Well Owner

Owner Name

EAST HELENA CITY OF

Mailing Address

2970 CANYON FERRY RD

City

State

Zip Code

EAST HELENA

MT

59635

Section 2: Location

Township 10N

Range Section 03W 14 Quarter Sections SE'4 SE'4 SE'4

County

Geocode

LEWIS AND CLARK

Latitude 46.6177 Altitude Longitude 111.9371

tude Geomethod 371 MAP Method Datum Datum NAD27 Date

3796

Addition

Block

Lot

* During the well test the discharge rate shall be as uniform as possible. This rate may or may not be the sustainable yield of the well. Sustainable yield does not include the reservoir of the well casing.

600 gpm pump rate with _ feet of drawdown after 12 hours of

Section 8: Remarks

Section 7: Well Test Data

Depth pump set for test _ feet.

Time of recovery _ hours.

Recovery water level _ feet.

Pumping water level 54 feet.

Total Depth: 110 Static Water Level: 34

Pump Test *

pumping.

Water Temperature:

Section 3: Proposed Use of

Water

PUBLIC WATER SUPPLY (1)

Section 4: Type of Work

Drilling Method: CAISSON DRILLED

Section 5: Well Completion Date

Date well completed: Monday, March 22, 1965

Section 6: Well Construction Details

Borehole dimensions

From To Diameter

0 110

Casing

From	То	Diameter	Wall Thickness	Pressure Rating	Joint	Type
0	30	48			İ	STEEL
0	90	16				STEEL

Completion (Perf/Screen)

of Size of

From To Diameter Openings Openings Description

90 11016

SS LOUVER SCREEN

Annular Space (Seal/Grout/Packer)

Cont.

From To Description Fed?

0 CEMENT

Section 9: Well Log Geologic Source

110ALVM - ALLUVIUM (QUATERNARY)

From	То	Description
0	37	ROCKS SAND & BOULDERS
37	46	ROCK SAND BOULDERS W/ CLAY STREAKS
46	51	HARDPAN & ROCK
51	110	ROCK SAND BOULDERS W/ STREAKS OF CLAY
~~~		
<del></del>		

### **Driller Certification**

All work performed and reported in this well log is in compliance with the Montana well construction standards. This report is true to the best of my knowledge.

Name:

Company:LAYNE-MINNESOTA

License No:WWC-76

Date Completed:3/22/1965

SANITARY SURVE	Y FORM - WELL	S & WELI	LPUMPS	Page of
PWSID 00196	SYSTEM NAME East Hele	ena		
	(Please cop	y this sheet fo	or additional wells & pumps)	
COMPLETE ONE PAGE FOR EAC	H SOURCE		STATUS OF SOURCE (A)ctive	
WSF ID WL003 These are State assigned identification numbers  Source Name Well #2 (middle) Name of Source – Example: Well 1 or South well, etc.  Location of Water Source (TRS or street address) 2995 Wylie Road - 1/2 mile south of Canyon Ferry Road  Entry Point Name entry point for wells 1,2,3 Name of EP – Example: Entry point for North Well 1 & South Well 2  Location of Entry Point after TP001  Available Perm Emerg Interim Seasonal Other If seasonal: to GWUDISW PA Completed Yes No			Log Available? Yes No  Average Production	Log SWL 39' (static) expressed in feet below ground elevation  Log PWL 54' (pumping) expressed in feet below ground elevation  Test Pump Rate  expressed in gallons per min  Intake Type steel louvered screen hype of Intake mechanism  Screened Interval 55-88'  expressed in feet below ground elevation  Well Yield 600 gpm  pump tested in gallons per minute  Latitude 46.61317°  Longitude 111.93546°
W	ELLS		PUI	MPS
Is well metered?  Is well site protected from flooding?  Is well protected from potential sour pollution (includes: surface water, k spills, agricultural use, etc.)?  If no explain high pressure petrol	rces of nown chemical	No Unk N/A  □ □ □ □ □ □ □ □	Type 60 HP Goulds Pump vertical turb (example: 30 hp line shaft turbin Rated Capacity  Are pumps operable?  How frequently are pump(s) replaced?  Are backup pumps/motors provided?	Yes No Unk N/A
the well.  Does casing extend at least  18 inches above outside ground  12 inches above finished floor ins  3 feet above 100 year flood eleva (Check for appropriate distance)  Is top of the well casing properly set is well vented? Is well vented? Is well vent properly screened and to in a downward position?  Does well have suitable sampling to the check valves, blow-off valves at maintained and operating properly?  Is upper termination of well protected fenced)?	level; Side well house; and Setion? Setion		Middle well - #2 on Wylie. Small green well house belongs to the guy south of this building.	
Comment: Pump is pulled and draw assessment (note blank in above shope to have it on line by the end of	pipe so I have not made a ection). H&L is working on	complete	Comment: The gate to the property is so access is not r	s locked, but it is within a farm fence, estricted. Building is locked.

### MONTANA WELL LOG REPORT

This well log reports the activities of a licensed Montana well driller, serves as the official record of work done within the borehole and casing, and describes the amount of water encountered. This report is complied electronically from the contents of the Ground-Water Information Center (GWIC) database for this site. Acquiring water rights is the well owner's responsibility and is NOT accomplished by the filing of this report.

Other Options

Plot this site on a topographic map View scanned well log (10/31/2006 9:12:03 AM)

Site Name: EAST HELENA CITY OF

GWIC Id: 62116

well 2

DNRC Water Right: W113656-00

Section 1: Well Owner

**Owner Name** 

EAST HELENA CITY OF

**Mailing Address** 

2995 WYLIE DR

City

EAST HELENA

State

Zip Code

MT

59635

Section 2: Location

Township 10N

Range 03W County Section 24

**Quarter Sections** SE14 NW14 NW14

Geocode

LEWIS AND CLARK

Latitude 46.6128

Longitude 111.9345

Geomethod MAP Method

Datum NAD27 Datum Date

Altitude 3807

Addition

Block

Lot

* During the well test the discharge rate shall be as uniform as possible. This rate may or may not be the sustainable yield of the well. Sustainable yield does not include the reservoir of the well casing.

600 gpm pump rate with _ feet of drawdown after 12 hours of

Section 8: Remarks

Section 7: Well Test Data

Depth pump set for test _ feet.

Time of recovery _ hours.

Recovery water level _ feet.

Pumping water level 54 feet.

Total Depth: 92 Static Water Level: 39

Pump Test *

pumping.

Water Temperature:

Section 3: Proposed Use of

Water

PUBLIC WATER SUPPLY (1)

Section 4: Type of Work

Drilling Method: CAISSON

Section 5: Well Completion Date

Date well completed: Saturday, April 10, 1965

Section 6: Well Construction Details

Borehole dimensions

From To Diameter

0 92

56 Cacina

From	То	Diameter	Wall Thickness	Pressure Rating	Joint	Туре
0	30	48		İ		STEEL
0	88	16				STEEL

Completion (Perf/Screen)

# of

Size of

From To Diameter Openings Openings Description

88 0 58 **OPEN BOTTOM** 58 88 16 SS LOUVER SCREEN

Annular Space (Seal/Grout/Packer)

Cont.

From To Description Fed?

0 CEMENT

Section 9: Well Log **Geologic Source** 

110ALVM - ALLUVIUM (QUATERNARY)

From	То	Description
0	38	TOPSOIL ROCK BOULDERS AND SANDY CLAY
38	45	ROCK BOULDERS SAND WITH STREAKS OF CLAY
45	69	ROCK CLAY SAND AND HARDPAN
69	92	ROCK SAND STREAKS OF CLAY
		·
	1	
-		
ļ	İ	

### **Driller Certification**

All work performed and reported in this well log is in compliance with the Montana well construction standards. This report is true to the best of my knowledge.

Name:

Company:LAYNE-MINNESOTA

License No:WWC-76

Date Completed:4/10/1965

SANITARY SURVEY FORM – WELLS & WELL PUMPS				Page	e of
PWSID <b>00196</b>	PWSID 00196 SYSTEM NAME East Helena				
	(Plea	se copy this sheet fo	or additional wells & pumps)		
COMPLETE ONE PAGE FOR E	EACH SOURCE		STATUS OF SOURCE X (A)ctive		
WSF ID WL004 These are State assigned identification numbers  Source Name Well #3 (south) Name of Source - Example: Well 1 or South well, etc.  Location of Water Source (TRS or street address) 2700 Wylie Drive - located on the west side of the road at the curve  Entry Point Name entry point for wells 1,2,3 Name of EP - Example: Entry point for North Well 1 & South Well 2  Location of Entry Point after TP001  Available Perm Emerg Interim Seasonal Other If seasonal: to			Log Available?		
WELLS			PUMPS		
Is well metered?  Is well site protected from floodi Is well protected from potential s pollution (includes: surface wate spills, agricultural use, etc.)?  If no explain Gravel pit with s  Does casing extend at least 18 inches above outside grou 12 inches above finished floo 3 feet above 100 year flood e (Check for appropriate distance)  Is top of the well casing properly Is well vented? Is well vented? Is well vent properly screened at in a downward position?  Does well have suitable samplin  Are check valves, blow-off valve maintained and operating prope Is upper termination of well prote fenced)?  Is intake located below the maxi	sources of er, known chemical  standing water immediate and level; or inside well house; and elevation?  y sealed? (sanitary seal) and terminated ang tap? Raw Water Treated as and water meters erly? ected (housed or		Type Vertical Turbine - Goulds (example: 30 hp line shaft turbine Rated Capacity 60 HP  Are pumps operable? How frequently are pump(s) replaced? Are backup pumps/motors provided? Are controls functioning properly and a protected? Do underground compartments have a ls facility properly protected against tree vandalism? Are pump records maintained (amp, dr. pressure, maintenance schedule, manuals the plumbing adequately painted to pexcessive corrosion? Are adequate heating, lighting, and verals a preventive maintenance program in Are recommended spare parts on hand Cross connection protection provided?	dequately drain? spassing and awdown, discharge uals, etc.)? prevent ntilation provided? n operation?	Yes No Unk N/A
Comment: Need to down turn t	he vent.		Explain Controls: Tank levels start pum Comment: takes monthly static water le		

### MONTANA WELL LOG REPORT

This well log reports the activities of a licensed Montana well driller, serves as the official record of work done within the borehole and casing, and describes the amount of water encountered. This report is complied electronically from the contents of the Ground-Water Information Center (GWIC) database for this site. Acquiring water rights is the well owner's responsibility and is NOT accomplished by the filing of this report.

Other Options

Plot this site on a topographic map View scanned well log (10/31/2006 11:50:01

AM)

Site Name: EAST HELENA CITY OF

GWIC Id: 62125

well 3

DNRC Water Right: P062231-00

Section 1: Well Owner **Owner Name** 

EAST HELENA CITY OF

**Mailing Address** 

2700 WYLIE DR

City

EAST HELENA

State MT

Zip Code 59635

Section 2: Location

Township 10N

Range 03W County Section 24

Block

**Quarter Sections** SW1/4 NW1/4 SW1/4

Geocode

LEWIS AND CLARK

Latitude 46.60591

Altitude

Longitude 111.93585 Method Geomethod MAP Datum

Datum NAD83 Date

Addition

Lot

Section 3: Proposed Use of

Water

PUBLIC WATER SUPPLY (1)

Section 4: Type of Work

Drilling Method: FORWARD ROTARY

Section 5: Well Completion Date

Date well completed: Friday, October 16, 1987

Section 6: Well Construction Details

Borehole dimensions From To Diameter 0 153

Casing

From	То	Diameter	Wall Thickness	Pressure Rating	Joint	Туре
-2	70	12		ĺ		50 LB STEEL
-2	153	10				STEEL
7	119	10			-	STEEL

Completion (Perf/Screen)

# of Size of

From To Diameter Openings Openings Description

119 10

STAINLESS STAIN SCREEN

Annular Space (Seal/Grout/Packer)

From To Description

Fed?

51 CEMENT & BENTONITE

Section 7: Well Test Data

Total Depth: 153 Static Water Level: 35 Water Temperature:

Pump Test *

Depth pump set for test _ feet.

550 gpm pump rate with _ feet of drawdown after 24 hours of

pumping.

Time of recovery _ hours. Recovery water level _ feet. Pumping water level 80 feet.

* During the well test the discharge rate shall be as uniform as possible. This rate may or may not be the sustainable yield of the well. Sustainable yield does not include the reservoir of the well casing.

Section 8: Remarks

Section 9: Well Log Geologic Source

120SDMS - SEDIMENTS (TERTIARY)

rom	То	Description
0	20	SILTY LOAM WITH GRAVELS
20	35	GRAVELY CLAYS
35	54	FINE, SANDY CLAY
54	58	MED. GRAVELS
58	71	CLAY AND GRAVELS
71	74	COARSE GRAVELS
74	80	CLEAN GRAVELS
80	84	SILTY GRAVELS
84	88	COARSE GRAVELS
88	99	SILTY GRAVELS
99	107	COARSE TO FINE GRAVELS
107	119	FINE TO COARSE, SILTY CLAYBOUND AND GRAVELS
119	153	SOFT SILTSTONE

### **Driller Certification**

All work performed and reported in this well log is in compliance with the Montana well construction standards. This report is true to the best of my knowledge.

Name:

Company:POTTS DRILLING INC

License No:WWC-150

Date Completed:10/16/1987

SANITARY SURVEY FORM - SURFACE WATE & INFILTRATION GALLERIES	Page of	
SOURCES	STATUS OF SOURCE (A)ctive	☐ (I)nactive ☐ (P)roposed
WSF ID WL005 Entry Point ID EP505 These are State assigned identification numbers  Source Name horizontal well McClellan Creek (infiltration) North Name of Source - Example: Well 1 or South well, etc.  Location of Water Source (TRS or street address) 100 yards south of Mockel Road  Entry Point Name Entry point for WL005 and WL006 – after treatment (TP002) and storage (ST002 and ST004)  Name of EP - Example: Entry point for North Well 1 & South Well 2	Location of Entry Point TP002  Available	Average Production 500 gpm mdicate units  Maximum Production indicate units  Latitude 46.55099°  Longitude 111.89880°"
Gravity flow?	SPRINGS & INFILTRATION GA  Is recharge area protected?  If Yes, how? City only owns the 20 acre  Ownership Fencing	Yes No Unk N/A
Comments: There is no vent on the system; pressure gauges are rusted because of water problems in the past – should be replaced.	☐ Ordinances ☐ Other  What is the nature of recharge zones? ☐ Agricultural ☐ Industrial ☐ Forest ☐ Residential ☐ Other	
	Is site protected from flooding?  Is there diversion of surface drainage fr  Is collection chamber properly construc	
	Does hatch cover overlap?	
Infiltration well access under this new building!	Is the overflow outlet screened? There	is no overflow
	Vented and screened? No vent	
. 30/2010	Is supply intake adequate? Is site properly protected (from livestock tampering, etc)?	⊠ □ □ □ k, vandalism, ⊠ □ □ □
Caisson deck appears dry	What conditions cause changes to qual This well has frozen in the past year.  There is standing water in the vault abothinks it is ground water that has seeper tarred the sidewalls of the vault to try to The creek is approximately 35 paces (1)	ove the infiltration caisson. Steve d in. He will vacuum it out. Steve prevent groundwater from entering.

SANITARY SURVEY FORM - SURFACE WATE & INFILTRATION GALLERIES	
SOURCES	STATUS OF SOURCE ☒ (A)ctive ☐ (I)nactive ☐ (P)roposed
WSF ID WL006 engineered horizontal well These are State assigned identification numbers  Source Name horizontal well McClellan Creek (infiltration) south Name of Source - Example: Well 1 or South well, etc  Location of Water Source (TRS or street address) 100 yards south of Mockel Road  Entry Point Name Entry point for WL005 and WL006  Name of EP - Example: Entry point for North Well 1 & South Well 2	Location of Entry Point TP002  Available ⊠ Perm ☐ Emerg ☐ Interim ☐ Seasonal ☐ Other If seasonal: to  GWUDISW PA Completed? ☑ Yes ☐ No ☐ Unk ☐ N/A  Average Production 500 gpm indicate units  Maximum Production Latitude 46.55013° Longitude 111.89874
Gravity flow?	SPRINGS & INFILTRATION GALLERIES  Yes No Unk N/A Is recharge area protected?  If Yes, how? City only owns the 20 acres where the pump houses sit.  Ownership Fencing Ordinances Other
McGellan Creek  09/18/2013	What is the nature of recharge zones?  Agricultural Industrial Forest Residential Other  Is site protected from flooding? Is there diversion of surface drainage from site?  Is collection chamber properly constructed?  Does hatch cover overlap?  Is the overflow outlet screened?  Vented and screened?  Is supply intake adequate?
	Is site properly protected (from livestock, vandalism, tampering, etc)?  What conditions cause changes to quality of the water? Close proximity to McClellan Creek may influence the well.  Steve tarred the sidewalls of the vault to try to prevent groundwater from entering. He also patched around the air relief pipe with concrete to better seal it.

SANITARY SURVEY FO	ORM - TREATMENT	Page _	of			
PWSID <b>00196</b>	SYSTEM NAME East Helena					
Treatment Objective	s					
B = Disinfection Byproduct Control C = Corrosion Control			Objectives and Code			
D = Disinfection	TP001 Treatment Plant for Wyl	ie Wells D401				
E = Dechlorination	TP002 Treatment for McClellar	Creek Sources D401 C445	5			
F = Iron Removal I = Inorganics Removal						
M = Manganese Removal						
N = No Treatment at Source O = Organics Removal						
P = Particulate Removal						
R = Radionuclides Removal S = Softening (Hardness Removal)	WSF ID Location					
T = Taste / Odor Control	TP001 Latitude 46.60603° Latitude 46.55012°	Longitude 111.93530° (vault where chl. Injections Longitude 111.89935°	cted)			
Z = Other	l atituda 0	_'" Longitude'"				
	Latitude° Latitude° Latitude°	'" Longitude'" " Longitude"				
	201000000000000000000000000000000000000					
Treatment plant description: IG002 and IG	003 to TP002; Premia 75 polyphosph	ate is added for corrosion control (P75MPH2XAVTC	<u> </u>			
FOR SYSTEMS EMPLOYING FU	JLL-TIME DISINFECTION	IF USING GAS CHLORINA	ATION Yes No Unk N/A			
W/L 1 15 1 6 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	Yes No Unk N/A	Is a manifold provided to allow feeding gas from				
What disinfectant is used? Gas chlorine		more than one cylinder?				
Is the disinfectant used NSF approved?	X 🗆 🗆 🗆	Is there automatic switchover from cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinder to cylinde				
Is the amount of disinfectant used recorded If Yes, amount used:Ibs/day X pp		Are scales provided for weighing of containers?				
Is the amount of disinfectant used compare	1 17	Are chlorine storage and use areas isolated from other work areas?				
pumped to verify concentration?		Are stored cylinders capped and labeled?				
Is chemical storage adequate and safe? If No, explain	x 🗆 🗆 🗆	Is room vented to the outdoors with suction locate no more than 6 inches above the floor level?				
Is disinfectant residual being monitored da	ily? X 🗆 🗆 🗆	le vest inlet seer the edition?	— — — —			
Are residual reports submitted monthly?	x 🗆 🗆 🗆	Is vent inlet near the ceiling?				
Is the disinfection equipment being operate maintained properly?	ed and X 🔲 🔲 🗎	Is room containing chlorination treatment labeled sufficiently (DANGER signs, etc.)?				
Is operational standby equipment provided		Is a view port provided into the room storing chlor				
	X 🗆 🗆 🗆	Is a means of leak detection provided?				
If not, are critical spare parts on hand?  Has disinfection system been free from fail		Type? Chlorine detectors in the chlorine	rooms			
during the past year – no interruption?	X 🗆 🗆 🗆	Is a self-contained breathing apparatus available				
If No, give dates of interruptions		use during repair of leaks? Where? <u>use fire dept. in case of leaks</u>				
Describe provisions for providing contact ti	me between disinfection point and	Are personnel trained to use apparatus?				
the first point of use: 1 mile of 10 inch pipe	from Wylie Wells to first users; 2	Are all doors hinged outward and equipped with p	panic			
miles of 10 inch pipe from McClellan Treati treated prior to storage from the McClellan		bars?				
treated prior to storage from the woolellan	Sources.	Are all gas cylinders restrained near the top and a half way down by chaining to wall or by other mea				
The McClellan Creek sources have the add to chlorination.	dition of ortho-polyphosphate prior	nan way down by chaining to wan or by other mea				
	s .81 ppm. The TP002 chlorinator is o	lown for repairs. Steve said he has ordered back-u	p parts so that he always			
has them.						
The ortho-polyphosphate tank should be pr	roperly labeled and the MSDS sheets	kept at the site.				

### SANITARY SURVEY FORM - STORAGE USE: 500 000 and summer and 120 000 and winter

CANTAIN CONVETTORIN	OTORAGE	03E. 300,000 gpa sa	Page of	
Total storage provided? 1.55 MG gallons	How much treated storage is p	rovided <u>1.55MG</u> gallons	Storage provides <u>3</u> days of w	rater reserve
STORAGE FACIL	<u>ITY</u>	STORAGE FACILITY		
WSF ID <u>ST002</u>		WSF ID ST004		
Location: Description 250,000 gallon partially Mockel Road Latitude: 46.55529° Longitude: 111.8		Location: Description 300 Latitude: 46.55523°	.000 gallons 43 Mockel Road Longitude: 111.89931°	
Storage Volume? <u>250,000 gallons</u> Year constructed: <u>1928</u>		Storage Volume? 300,000 Year constructed: 1964 Condition: X Good	<u>) g</u> allons ]Fair  ∏Poor	
Condition: ☐Good X Fair ☐Poor	Yes No Unk N/A		inderground drainage drain	Yes No Unk N/A
Does surface runoff and underground drainag away?		away?  Is the site protected again	st flooding?	
Is the site protected against flooding?		Is the site protected again	20 <del>73</del>	× 🗆 🗆 🗆
Is the site protected against trespass/vandalis	m? X 🗆 🗆	Ladders caged and locked	d?	$\Box$ $\Box$ $\Box$ $x$
Ladders caged and locked?		Are overflow lines, air ven	te drainage lines or clean	
Are overflow lines, air vents, drainage lines or out pipes turned downward or covered, screer terminated a minimum of 3 diameters above the	clean ed and	out pipes turned downwar	d or covered, screened and diameters above the ground	x 🗆 🗆 🗆
or storage tank surface?	□ X □	Overflow pad?		$\square \times \square$
Overflow pad? cobble		Is access hatch sealed pro	operly and locked?	$\square \square X \square$
Is access hatch sealed properly and locked?		Are surface coatings in co approved?	entact with water ANSI / NSF	хппп
Are surface coatings in contact with water ANS approved?	SI/NSF X 🗆 🗆 🗆	Is tank protected against i	cing and corrosion?	x 🗆 🗆 🗆
Is tank protected against icing and corrosion?	× 🗆 🗆 🗆	Can tank be isolated from		x 🗆 🗆 🗆
Can tank be isolated from system?	x 🗆 🗆 🗆	Is all treated water storage	e covered?	x 🗆 🗆 🗆
Is all treated water storage covered?	x 🗆 🗆 🗆	Are tanks disinfected after	r repairs are made?	x 🗆 🗆 🗆
Are tanks disinfected after repairs are made?	x 🗆 🗆 🗆	What is cleaning frequenc	cy for tanks? 2010 - to schedul	e next year.
What is cleaning frequency for tanks? 2010 -	to schedule next year.	Is tank inspected every 5	years by a structural engineer	
Is tank inspected every 5 years by a structural	engineer	for structural integrity?		$\square \times \square \square$
for structural integrity?				
0		Date of last inspection	By whom	
Comments:		Comments: see the comm	nents to the left on this page.	
			ionio to the fort on the page.	
These tanks have a common overflow about 1 The overflow pipe has separated and there is enter the overflow. Since it is at ground level, identified as a significant deficiency.	a large gap where critters can			
The east tank fills first and then the west. The west tank.	transmission main is off the			
In the summer the tank is overflowed about evany pollen etc. from the top.	ery other month to remove			
There is sediment visible sediment on the bottom	om of the tanks.			
These tanks should be inspected by a structure deteriorating on the east tank.	al engineer. The concrete is			





### SANITARY SURVEY FORM - STORAGE

Page	of
raue	OI

### COMPLETE ONE SECTION FOR EACH STORAGE FACILITY

Total storage provided? 1.55 MG gallons

How much treated storage is provided 1.55 MG gallons

### STORAGE FACILITY

### WSF ID ST003

Location: Description partially buried concrete tank along Highway 282

Latitude: 46.57387°

Longitude: 111.93526°

Storage Volume? 1,000,000 gallons

Year constructed: 1999

Condition: X Good Fair Poor

Yes No Unk N/A

Does surface runoff and underground drainage drain away?

out pipes turned downward or covered, screened and terminated a minimum of 3 diameters above the ground

x 🗆 🗆 🗆

Is the site protected against flooding?

 $\square$   $\square$   $\square$  X

Is the site protected against trespass/vandalism? Ladders caged and locked? Are overflow lines, air vents, drainage lines or clean

or storage tank surface?

x 🗆 🗆 🗆

Overflow pad?

Is access hatch sealed properly and locked?

x 🗆 🗆 🗆

Are surface coatings in contact with water ANSI / NSF approved?

x 🗆 🗆 🗆

Is tank protected against icing and corrosion? Can tank be isolated from system?

x 🗆 🗆 🗆

Is all treated water storage covered?

x 🗆 🗆 🗆

Are tanks disinfected after repairs are made?

x 🗆 🗆 🗆

What is cleaning frequency for tanks? 2010 – Liquid Engineering – will

schedule next year.

Is tank inspected every 5 years by a structural engineer

for structural integrity?

hasn't been

Date of last inspection

By whom

Comments: This tank has a Bilco lid. They have changed the gaskets and added a bolt lock to bring the lid back down flat. This is an improvement. The inside was clean. They plan to put a small building over this hatch similar to the ones at the McClellan Creek facilities to keep out dirt.

This probably wasn't an appropriate hatch when built. It appears to be the type approved for wastewater facilities. The hatches on the Mockel Road tanks is the correct type – overlapping shoe box type.


Dimensions: 110 feet in diameter; 18 feet in depth.


Level in this tank kicks on the well pumps: at 17' shuts off; 14' kicks them on. Tank levels initiate pumping from the Wyle wells (1, 2, and 3).

There is a ¼ inch hole in the top of each of the vents which needs to be sealed to keep out precipitation and bird droppings.

There is no visible sediment in the tank.

This tank rides on the system.







East Helena

**PWSID 00196** 

9/18/2013

L. Schultz

page 15

SANITARY SUF	RVEY FORM - MISC	ELLANEOU	S Page	of		
PWSID 00196	SYSTEM NAME East Helena	a		V V		
DISTRIBUT	DISTRIBUTION SYSTEM EVALUATION		SAFETY			
Distribution description The distribution system consists of primarily ductile iron and PVC  System drawings available?  Accurate As-Built drawing(s) on-site?  Lines adequately sized?  Adequate pressure maintained?  Mains protected from freezing?  Distribution system free of leaks?  Asbestos concrete pipe used?  Fire hydrants?  Dead end lines minimized by looping mains?  Flushing program? Once a year  Pressure reducing stations? Number X  Booster stations? Number X  Are individual booster pumps on any service lines?  (see DEQ-1 8.9.2)  Were cross connections observed?  Comments: East Helena contracts with Peccia and Associate to do annual flow analysis and flush hydrants; they replace two		Were confined spaces observed?  Describe any confined spaces observed all storage tanks, infiltration galle caissons and vaults; all valve vaults and chlorination facilities  Confined space safety adequate?  Fall risks adequately mitigated?  Note all safety deficiencies (consider items such as ladders, tank supports guards on rotating electrical equipment, lightning protection for pumps, etc.)				
MONITORING AND	RECORDKEEPING EVALUA	ATION	MANAGEMENT			
Does the system have a currer Bacti monitoring records maint Bacti Sample Site Plan submit Familiar with repeat sampling? Chemical monitoring records n System specific records / plans (DBP, PB/CU, treatments, wain Familiar with Public Notice req Did Surveyor take a bacteriologist Yes, date of Sample:Comments:	tained? (5 years)  ted?  naintained? (10 years)  s maintained?  vers, violations, etc.)  uirements?  gical sample?  Time of Sample:	Yes No Unk N/A  X	Are there sufficient personnel?  Are operators properly certified?  Are personnel adequately trained?  Is there a current O&M manual on-site?  Is an emergency plan on-site and workable?  Has system addressed concerns from previous sanitary survey(s) or technical visit(s)?  Budget exists?  Does system maintain an emergency fund?  Does system contribute to facility replacement fund?  Are abandoned wells present?  Do abandoned wells appear to be properly abandoned? (see ARM 36.21.670)	Yes No Unk N/A X		
			Comments: Old well on Montana Avenue by the Smelter has not been properly abandoned.			

REPORT SUMMAR	Υ	Page	of
PWSID 00196	SYSTEM NAME East Helena		

The State, or an authorized agent, must conduct sanitary surveys for all public water supply systems in Montana. DEQ believes that periodic sanitary surveys, along with appropriate corrective actions, are indispensable for assuring the long-term quality and safety of drinking water. When properly conducted, sanitary surveys can provide important information on a water system's design and operations and can identify minor and significant deficiencies for correction before they become major problems.

Minor deficiencies do not pose serious health threats. However, corrective action of minor deficiencies can be critical in the long-term operation and safety of a public water system. Minor deficiencies are generally described as suggested or recommended corrections in the letter to system owner(s).

Significant deficiencies can be defined as a defective water supply component(s) having or likely to have an adverse influence on public health. Significant deficiencies require immediate corrective action in efforts to protect consumers.

EPA and ASDWA guidance identifies eight broad components that should be covered in a sanitary survey. Using these eight broad components as a guide, minor and significant deficiencies should be described in the letter to system owner(s).

- 1) Source
- 2) Treatment
- 3) Distribution system
- 4) Finished water storage
- 5) Pumps, pump facilities, and controls
- 6) Monitoring and reporting, and data verification
- 7) System management and operation
- 8) Operator compliance with State requirements

With consideration that significant deficiencies may influence regulatory decisions and monitoring requirements, please list all significant deficiencies observed and corrective action(s) taken below.

Comments. The following deficiencies were identified; corrective actions were taken and photographs were provided to DEQ.

- 1) Overflow for the McClellan Creek storage tanks (ST002 and ST004) had separated and there was a large gap between the pipes which could allow rodents, insects, etc. to enter the tank. This was identified as a significant deficiency at the time of the inspection and was repaired and photos provided to DEQ.
- 2) The two vent caps for the ST003 tank near HWY 282 have holes ¼ ½ inch in diameter on the top of the cap. This can allow precipitation (possibly bird droppings) to enter the tank.
- 3) The horizontal wells at McClellan Creek at times have standing water above the floor of the pumping vault which is directly over the water. The side walls of the vaults were sealed with tar.
- 4) The south horizontal well air relief valve was piped into the well below. There was a gap around the pipe which could allow the standing water mentioned in item 3 above to enter the well. A concrete patch was put around the air relief piping and eliminated the gap.


### **SANITARY SURVEY FORM - DIAGRAMS**

Page _____ of ___


PWSID 00196


SYSTEM NAME East Helena

Draw brief site plan showing location of well(s), springs(s), water storage, distribution system, pumphouse(s), entry point(s), treatment, etc. and label with appropriate facility designation. Include interconnections with other PWSs. Add sheets as needed.




Draw brief schematic of pumphouse facilities (pressure control assemblies, treatment(s) valves, filters, meters, electrical controls, etc.)




















# APPENDIX F – GROUNDWATER CLASSIFICATION CONFIRMATION LETTER FROM DEQ

# DEPARTMENT OF HEALTH AND ENVIRONMENTAL SCIENCES

WATER QUALITY BUREAU

STAN STEPHENS, GOVERNOR

ROOM A-206 COGSWELL BUILDING

# STATE OF MONTANA

PHONE: (406) 444-4549
FAX: (406) 444-1374 DECISION MEMORANDUM:

HELENA, MONTANA 59620

SAST HELENA'S MCCLELLAN CREEK INFILTRATION GALLERY

December 30, 1992

Prepared By:

Donna G. Jensen

Field Services Program Manager

Drinking Water/Subdivisions Section

### Purpose:

The 1986 Amendments to the federal Safe Drinking Water Act require, through the Surface Water Treatment Rule, that all public water systems using surface water or groundwater under the direct influence of surface water must disinfect, and may be required to filter, unless certain water quality source requirements and site specific conditions are met.

"Groundwater under the direct influence of surface water" is defined as:

"...any water beneath the surface of the ground that the department determines to have: a) significant occurrences of insects or other macroorganisms, algae, or large-diameter pathogens such as <u>Giardia lamblia</u>: or b) significant and relatively rapid shifts in water characteristics such as turbidity, temperature, conductivity, or pH in close correlation with climatological or surface water conditions."

Further, "surface water" is defined as:

"all water open to the atmosphere and subject to surface runoff".

The June 29, 1989 Federal Register contains the preamble and text for the Surface Water Treatment Rule. In this preamble, on page 27489, the statement is made that it may or may not be appropriate for a system determined to be groundwater under the direct influence of surface water to be required to comply with other NPDWRs pertaining to surface water supplies. The preamble advises that the characteristics of the system should be taken into consideration when determining subsequent regulatory requirements aside from those of the Surface Water Treatment Rule.

### Conclusion:

The East Helena McClellan Creek system has been determined to not be under the direct influence of surface water and has been classified as groundwater for regulatory purposes.

East Helena page 2

### Justification:

Construction details, Microscopic Particulate Analysis results and turbidity data have all been used to determine the susceptibility of the McClellan Creek Infiltration Gallery to contamination by Giardia cysts.

Turbidity:

Turbidity has been monitored daily since installation of the infiltration gallery. Turbidity initially was recorded from the wells in June, 1988. Turbidity began at 0.45 NTU for the first two days of the month and reduced to 0.30 NTU by the end of June of that year. Turbidity remained at 0.3 to 0.32 NTU through April 1989. Since the end of April 1989, the turbidity has consistently been 0.2 NTU, regardless of runoff conditions or water demand.

### Microscopic Particulate Examinations:

A MPE sample collected on 3/3/87 from a test well at the McClellan Creek site showed no organisms indicative of direct surface water influence in 672 gallons of water sampled.

A MPE Sample collected on 4/14/89 from the collector pumphouse showed no organisms indicative of direct surface water influence in 1880 gallons of water sampled. Total debris measured in the sample as about 1/4 ml. No algae or plant material were detected. Rotifers, nematodes and protozoa, organisms typical of shallow groundwater, were detected in moderate amounts. Turbidity at the time of sample collection was 0.32 NTU as measured on a WQB turbidimeter.

### Construction

Infiltration gallery collection laterals consist of 8-inch PVC Johnson Well Screen, 50 slot, 8.625-inch outside diameter. Filter fabric used was non-woven polymeric geotextile fabric, 4.5 0z/sy, Mirafi 140N or equal.

Alternating ten foot sections of well screen and solid PVC pipe were placed on one foot, two inches of filter gravel. End caps were placed on the end of each lateral. Filter gravel was placed around and over the pipe. Filter fabric was brought-up with the filter gravel and overlapped at least two feet. A seven foot layer of graded filter sand was backfilled above the filter fabric. A minimum one-foot layer of bentonite clay was placed over the filter sand and compacted tightly by hand-tamping. Native excavated material was mounded above the laterals to a height of two to three feet above ground level.

East Helena page 3

### Summary

Although the infiltration laterals are recharged by McClellan Creek, finished water quality from the laterals indicates the system is not at risk for <u>Giardia</u> passage to the potable water supply. Turbidity readings also document the laterals do not reflect significant or relatively rapid shifts in water quality in close correlation to the surface water (refer to the definition for groundwater under the direct influence of surface water).

The department recommends that turbidity continue to be monitored during runoff conditions and late summer conditions to indicate change or consistency in the turbidity of the collector water. It is also recommended that turbidity measurements be implemented following unusual flood events or other aberrations from the norm in creek flow, stream channelization or other environmental changes.

Other monitoring to meet NPDWRs is recommended to be that for groundwater supplies since there is limited industrial and agricultural use of the watershed. Limited use could be extrapolated to mean limited risk to the surface water supply and even less risk to the subsurface water collected by the infiltration gallery.

# DEPARTMENT OF HEALTH AND ENVIRONMENTAL SCIENCES

PWS
File

WATER QUALITY BUREAU



STAN STEPHENS, GOVERNOR

ROOM A-206 COGSWELL BUILDING

# STATE OF MONTANA

PHONE: (406) 444-4549 FAX: (406) 444-1374

HELENA, MONTANA 59620

December 30, 1992

Mayor Ed Stipich City of East Helena P.O. Box 1170 East Helena, MT 59635

RE: Classification of the McClellan Creek system (source 00196-005) as a groundwater source

Dear Mayor Stipich:

As you are probably aware, the 1986 Amendments to the Federal Safe Drinking Water Act required that subsurface water collectors be evaluated for their possible direct influence by surface water. Direct influence by surface water means a system would be prone to contamination by <u>Giardia</u> cyst passage from a surface water source to the underground collector. As the primacy agent for the Safe Drinking Water Act in Montana, this department is required to make those source reviews and determinations.

We have reviewed several years of data for turbidity and particulate analysis results for the McClellan Creek Collector at East Helena and have concluded that this source is appropriately classified as a groundwater source not directly influenced by surface water. As a result, effective immediately the East Helena system is considered to be groundwater and subject to the rules and regulations pertaining to a groundwater source. This will impact both turbidity and chemical monitoring requirements for the system (by reducing the monitoring frequency for many chemicals).

Although turbidity is not typically a required water quality parameter monitored by groundwater sources we feel it will be useful to demonstrate continued low turbidity from the collector and to indicate any turbidity aberrations which may warrant additional investigation. Therefore, we are requiring that East Helena monitor and report turbidity to this office no less than for one week during spring runoff conditions and one week during late summer. The turbidimeter must be calibrated using a primary standard prior to initiation of each of the two one-week intervals.

Please note this classification <u>does not</u> change the disinfection requirements currently imposed on your system. John Camden, of this office, may be reached at 444-4549 if you have any questions about disinfection or the turbidity monitoring requirements.

Mayor Stipich December 30, 1992 page 2

Please don't hesitate to contact me at 444-4114 if you have any questions regarding the basis for this determination.

Happy New Year to you and best wishes for East Helena in 1993!

Sincerely,

Donna G. Fensen

Field Services Program Manager Drinking Water/Subdivision Section

cc: John Camden
Co. Sanitarian
PWS File
Rosie Fossum, Certification Officer

# **APPENDIX G – WATER RIGHTS**

### STATE OF MONTANA

### DEPARTMENT OF NATURAL RESOURCES AND CONSERVATION

1424 9TH AVENUE P.O.BOX 201601 HELENA, MONTANA 59620-1601

# GENERAL ABSTRACT

Water Right Number: 411 113654-00 STATEMENT OF CLAIM

Version: 1 -- ORIGINAL RIGHT

**Version Status: ACTIVE** 

Owners: EAST HELENA, CITY OF

PO BOX 1170

EAST HELENA, MT 59635-1170

**Priority Date:** AUGUST 2, 1954

Enforceable Priority Date: AUGUST 2, 1954

Type of Historical Right: FILED

Purpose (use): MUNICIPAL
Maximum Flow Rate: 100.00 GPM
Maximum Volume: 162.22 AC-FT

Source Name: GROUNDWATER

Source Type: GROUNDWATER

ALSO KNOWN AS MUNICIPAL WELL NO. 2

### Point of Diversion and Means of Diversion:

<u>ID</u> <u>Govt Lot</u> <u>Qtr Sec</u> <u>Sec</u> <u>Twp</u> <u>Rge</u> <u>County</u>

1 SWNESE 25 10N 3W LEWIS AND CLARK

Period of Diversion: JANUARY 1 TO DECEMBER 31

Diversion Means:WELLWell Depth:100.00 FEETStatic Water Level:80.00 FEETCasing Diameter:6.00 INCHES

Period of Use: JANUARY 1 to DECEMBER 31

### Place of Use:

<u>ID</u>	<u>Acres</u>	Govt Lot	<b>Qtr Sec</b>	<u>Sec</u>	<b>Twp</b>	Rge	<b>County</b>
1			SW	30	10N	2W	LEWIS AND CLARK
2			S2	25	10N	3W	LEWIS AND CLARK
3			NW	31	10N	3W	LEWIS AND CLARK
4			NE	36	10N	3W	LEWIS AND CLARK

THE CITY'S WATER DISTRIBUTION SYSTEM SUPPLEMENTALLY SUPPLIES BOTH THE ASARCO AND CHEMET PLANTS IN NE SEC 36 TWP 10N RGE 03W.

THE PLACE OF USE IS THE CITY OF EAST HELENA.

### Remarks:

THE WATER RIGHTS FOLLOWING THIS STATEMENT ARE ASSOCIATED WHICH MEANS THE RIGHTS SHARE THE SAME OTHER.

62231-00 113654-00 113655-00 113656-00 113657-00 113658-00 113659-00

STARTING IN 2008, PERIOD OF DIVERSION WAS ADDED TO MOST CLAIM ABSTRACTS, INCLUDING THIS ONE.

WHENEVER THE WATER RIGHTS FOLLOWING THIS STATEMENT ARE COMBINED TO SUPPLY WATER FOR THE CLAIMED PURPOSE, EACH IS LIMITED TO THE HISTORICAL FLOW RATE AND PLACE OF USE OF THAT INDIVIDUAL RIGHT. THE SUM TOTAL OF THE VOLUME OF THESE WATER RIGHTS SHALL NOT EXCEED THE AMOUNT PUT TO HISTORICAL AND BENEFICIAL USE. W113654-00, W113655-00, W113659-00.

THIS CLAIMED WATER RIGHT MAY BE QUESTIONABLE. ACCORDING TO INFORMATION IN THE CLAIM FILE, THE RIGHT WAS LAST USED IN THE 1970'S.

THE COMBINED CLAIMED VOLUME FOR THE FOLLOWING CLAIMS IS 2,967.00 GALLONS PER CAPITA PER DAY (GCPD) BASED ON THE 1970 CENSUS POPULATION OF 1,651 PEOPLE AND A TOTAL CLAIMED VOLUME OF 5,503.25 ACRE-FEET. THIS APPEARS EXCESSIVE FOR THE CLAIMED PURPOSE. W113654-00, W113655-00, W113656-00, W113659-00.

### Remarks:

THE CLAIMED VOLUME MAY BE EXCESSIVE FOR THE CLAIMED PURPOSE AND CANNOT BE CONFIRMED DUE TO LACK OF DATA.

THE CLAIMED VOLUME EXCEEDS MAXIMUM FEASIBLE VOLUME. BASED ON THE FLOW RATE AND PERIOD OF USE, THE MAXIMUM VOLUME POSSIBLE IS 161.74 ACRE-FEET PER YEAR.

### STATE OF MONTANA

### DEPARTMENT OF NATURAL RESOURCES AND CONSERVATION

1424 9TH AVENUE P.O.BOX 201601 HELENA, MONTANA 59620-1601

# GENERAL ABSTRACT

Water Right Number: 411 113655-00 STATEMENT OF CLAIM

Version: 1 -- ORIGINAL RIGHT

**Version Status: ACTIVE** 

Owners: EAST HELENA, CITY OF

PO BOX 1170

EAST HELENA, MT 59635-1170

**Priority Date:** MARCH 22, 1965

Enforceable Priority Date: MARCH 22, 1965

Type of Historical Right: FILED

Purpose (use): MUNICIPAL
Maximum Flow Rate: 600.00 GPM
Maximum Volume: 973.33 AC-FT

Source Name: GROUNDWATER

Source Type: GROUNDWATER

ALSO KNOWN AS LAYNE WELL NO. 1

Point of Diversion and Means of Diversion:

<u>ID</u> <u>Govt Lot</u> <u>Qtr Sec</u> <u>Sec</u> <u>Twp</u> <u>Rge</u> <u>County</u>

1 SESESE 14 10N 3W LEWIS AND CLARK

Period of Diversion: JANUARY 1 TO DECEMBER 31

**Diversion Means: WELL** 

A STORAGE WATER TOWER LOCATED IN THE SWNW SEC 36 TWP 10N RGE 03W

WITH A 312,000 GALLON CAPACITY IS PART OF THIS RIGHT.

Period of Use: JANUARY 1 to DECEMBER 31

Place of Use:

<u>ID</u>	<u>Acres</u>	Govt Lot	<b>Qtr Sec</b>	<u>Sec</u>	<b>Twp</b>	Rge	<b>County</b>
1			NWNE	31	10N	2W	LEWIS AND CLARK
2			NW	31	10N	2W	LEWIS AND CLARK
3			S2	25	10N	3W	LEWIS AND CLARK
4			SW	30	10N	3W	LEWIS AND CLARK
5			NE	36	10N	3W	LEWIS AND CLARK

THE CITY'S WATER DISTRIBUTION SYSTEM SUPPLEMENTALLY SUPPLIES BOTH THE ASARCO AND CHEMET PLANTS IN THE NE OF SEC 36 TWP 10N RGE 03W.

THE PLACE OF USE IS THE CITY OF EAST HELENA.

### Remarks:

THE WATER RIGHTS FOLLOWING THIS STATEMENT ARE ASSOCIATED WHICH MEANS THE RIGHTS SHARE THE SAME PLACE OF USE.

70576-00 70577-00 113655-00 113656-00 113657-00 113658-00 113659-00

THE WATER RIGHTS FOLLOWING THIS STATEMENT ARE ASSOCIATED WHICH MEANS THE RIGHTS SHARE THE SAME PLACE OF USE.

62231-00 70576-00 70577-00 113655-00 113656-00 113657-00 113658-00

113659-00

THE WATER RIGHTS FOLLOWING THIS STATEMENT ARE ASSOCIATED WHICH MEANS THE RIGHTS SHARE THE SAME OTHER.

62231-00 113654-00 113655-00 113656-00 113657-00 113658-00 113659-00

ADDITIONAL MAPS AND DOCUMENTATION CAN BE OBTAINED BY REVIEWING FILE NO. W113654-00. STARTING IN 2008, PERIOD OF DIVERSION WAS ADDED TO MOST CLAIM ABSTRACTS, INCLUDING THIS ONE.

WHENEVER THE WATER RIGHTS FOLLOWING THIS STATEMENT ARE COMBINED TO SUPPLY WATER FOR THE CLAIMED PURPOSE, EACH IS LIMITED TO THE HISTORICAL FLOW RATE AND PLACE OF USE OF

#### Remarks:

THAT INDIVIDUAL RIGHT. THE SUM TOTAL OF THE VOLUME OF THESE WATER RIGHTS SHALL NOT EXCEED THE AMOUNT PUT TO HISTORICAL AND BENEFICIAL USE. W113654-00, W113655-00, W113659-00.

THE PRIORITY DATE IS IN QUESTION. THE DATE OF FILING THE FORM GW2, NOTICE OF COMPLETION OF GROUNDWATER APPROPRIATION, IS AUGUST 6, 1965.

THE COMBINED CLAIMED VOLUME FOR THE FOLLOWING CLAIMS IS 2,967.00 GALLONS PER CAPITA PER DAY (GCPD) BASED ON THE 1970 CENSUS POPULATION OF 1,651 PEOPLE AND A TOTAL CLAIMED VOLUME OF 5,503.25 ACRE-FEET. THIS APPEARS EXCESSIVE FOR THE CLAIMED PURPOSE. W113654-00, W113655-00, W113656-00, W113657-00, W113658-00, W113659-00.

THE CLAIMED VOLUME EXCEEDS MAXIMUM FEASIBLE VOLUME. BASED ON THE FLOW RATE AND PERIOD OF USE, THE MAXIMUM VOLUME POSSIBLE IS 970.45 ACRE-FEET PER YEAR.

THE CLAIMED VOLUME MAY BE EXCESSIVE FOR THE CLAIMED PURPOSE AND CANNOT BE CONFIRMED DUE TO LACK OF DATA.

### STATE OF MONTANA

### DEPARTMENT OF NATURAL RESOURCES AND CONSERVATION

1424 9TH AVENUE P.O.BOX 201601 HELENA, MONTANA 59620-1601

# **GENERAL ABSTRACT**

Water Right Number: 411 113656-00 STATEMENT OF CLAIM

Version: 1 -- ORIGINAL RIGHT

**Version Status: ACTIVE** 

Owners: EAST HELENA, CITY OF

PO BOX 1170

EAST HELENA, MT 59635-1170

**Priority Date:** APRIL 10, 1965

Enforceable Priority Date: APRIL 10, 1965

Type of Historical Right: FILED

Purpose (use): MUNICIPAL
Maximum Flow Rate: 600.00 GPM
Maximum Volume: 973.33 AC-FT

Source Name: GROUNDWATER

**Source Type:** GROUNDWATER

ALSO KNOWN AS LAYNE WELL NO. 2

Point of Diversion and Means of Diversion:

<u>ID</u> <u>Govt Lot</u> <u>Qtr Sec</u> <u>Sec</u> <u>Twp</u> <u>Rge</u> <u>County</u>

1 NWSWNW 24 10N 3W LEWIS AND CLARK

Period of Diversion: JANUARY 1 TO DECEMBER 31

Diversion Means:WELLWell Depth:88.00 FEETStatic Water Level:39.00 FEETCasing Diameter:42.00 INCHES

A STORAGE WATER TOWER LOCATED IN THE SWNW SEC 36 TWP 10N RGE 03W

WITH A 312,000 GALLON CAPACITY IS PART OF THIS RIGHT.

Period of Use: JANUARY 1 to DECEMBER 31

Place of Use:

<u>ID</u>	<u>Acres</u>	Govt Lot	Qtr Sec	<u>Sec</u>	<b>Twp</b>	Rge	<b>County</b>
1			SW	30	10N	2W	LEWIS AND CLARK
2			NWNE	31	10N	2W	LEWIS AND CLARK
3			NW	31	10N	2W	LEWIS AND CLARK
4			S2	25	10N	3W	LEWIS AND CLARK
5			NE	36	10N	3W	LEWIS AND CLARK

THE CITY'S WATER DISTRIBUTION SYSTEM SUPPLEMENTALLY SUPPLIES BOTH THE ASARCO AND CHEMET PLANTS IN THE NE OF SEC 36 TWP 10N RGE 03W.

THE PLACE OF USE IS THE CITY OF EAST HELENA.

### Remarks:

THE WATER RIGHTS FOLLOWING THIS STATEMENT ARE ASSOCIATED WHICH MEANS THE RIGHTS SHARE THE SAME PLACE OF USE.

70576-00 70577-00 113655-00 113656-00 113657-00 113658-00 113659-00

THE WATER RIGHTS FOLLOWING THIS STATEMENT ARE ASSOCIATED WHICH MEANS THE RIGHTS SHARE THE SAME PLACE OF USE.

62231-00 70576-00 70577-00 113655-00 113656-00 113657-00 113658-00

113659-00

THE WATER RIGHTS FOLLOWING THIS STATEMENT ARE ASSOCIATED WHICH MEANS THE RIGHTS SHARE THE SAME OTHER.

62231-00 113654-00 113655-00 113656-00 113657-00 113658-00 113659-00

ADDITIONAL MAPS AND DOCUMENTATION CAN BE OBTAINED BY REVIEWING FILE NO. W113654-00. STARTING IN 2008, PERIOD OF DIVERSION WAS ADDED TO MOST CLAIM ABSTRACTS, INCLUDING THIS

### Remarks:

ONE.

WHENEVER THE WATER RIGHTS FOLLOWING THIS STATEMENT ARE COMBINED TO SUPPLY WATER FOR THE CLAIMED PURPOSE, EACH IS LIMITED TO THE HISTORICAL FLOW RATE AND PLACE OF USE OF THAT INDIVIDUAL RIGHT. THE SUM TOTAL OF THE VOLUME OF THESE WATER RIGHTS SHALL NOT EXCEED THE AMOUNT PUT TO HISTORICAL AND BENEFICIAL USE. W113654-00, W113655-00, W113659-00.

THE PRIORITY DATE IS IN QUESTION. THE DATE OF FILING THE FORM GW2, NOTICE OF COMPLETION OF GROUNDWATER APPROPRIATION, IS AUGUST 6, 1965.

THE COMBINED CLAIMED VOLUME FOR THE FOLLOWING CLAIMS IS 2,967.00 GALLONS PER CAPITA PER DAY (GCPD) BASED ON THE 1970 CENSUS POPULATION OF 1,651 PEOPLE AND A TOTAL CLAIMED VOLUME OF 5,503.25 ACRE-FEET. THIS APPEARS EXCESSIVE FOR THE CLAIMED PURPOSE. W113654-00, W113655-00, W113656-00, W113657-00, W113658-00, W113659-00.

THE CLAIMED VOLUME MAY BE EXCESSIVE FOR THE CLAIMED PURPOSE AND CANNOT BE CONFIRMED DUE TO LACK OF DATA.

THE CLAIMED VOLUME EXCEEDS MAXIMUM FEASIBLE VOLUME. BASED ON THE FLOW RATE AND PERIOD OF USE, THE MAXIMUM VOLUME POSSIBLE IS 970.45 ACRE-FEET PER YEAR.

#### DEPARTMENT OF NATURAL RESOURCES AND CONSERVATION

1424 9TH AVENUE P.O.BOX 201601 HELENA, MONTANA 59620-1601

## **GENERAL ABSTRACT**

Water Right Number: 411 113657-00 STATEMENT OF CLAIM

Version: 1 -- ORIGINAL RIGHT

**Version Status: ACTIVE** 

Owners: EAST HELENA, CITY OF

PO BOX 1170

EAST HELENA, MT 59635-1170

Priority Date: JULY 22, 1955

Enforceable Priority Date: JULY 22, 1955

Type of Historical Right: FILED

Purpose (use): MUNICIPAL
Maximum Flow Rate: 100.00 GPM
Maximum Volume: 162.22 AC-FT

Source Name: GROUNDWATER

Source Type: GROUNDWATER

ALSO KNOWN AS MUNICIPAL WELL NO. 9

Point of Diversion and Means of Diversion:

ID Govt Lot Qtr Sec Sec Twp Rge County

1 NESENE 36 10N 3W LEWIS AND CLARK

Period of Diversion: JANUARY 1 TO DECEMBER 31

Diversion Means:WELLWell Depth:170.00 FEETStatic Water Level:85.00 FEETCasing Diameter:5.00 INCHES

Period of Use: JANUARY 1 to DECEMBER 31

Place of Use:

<u>ID</u>	<u>Acres</u>	Govt Lot	<b>Qtr Sec</b>	<u>Sec</u>	<b>Twp</b>	Rge	<b>County</b>
1			SW	30	10N	2W	LEWIS AND CLARK
2			NWNE	31	10N	2W	LEWIS AND CLARK
3			NW	31	10N	2W	LEWIS AND CLARK
4			S2	25	10N	3W	LEWIS AND CLARK
5			NE	36	10N	3W	LEWIS AND CLARK

THE CITY'S WATER DISTRIBUTION SYSTEM SUPPLEMENTALLY SUPPLIES BOTH THE ASARCO AND CHEMET PLANTS IN NE SEC 36 TWP 10N RGE 03W.

THE PLACE OF USE IS THE CITY OF EAST HELENA.

#### Remarks:

THE WATER RIGHTS FOLLOWING THIS STATEMENT ARE ASSOCIATED WHICH MEANS THE RIGHTS SHARE THE SAME PLACE OF USE.

70576-00 70577-00 113655-00 113656-00 113657-00 113658-00 113659-00

THE WATER RIGHTS FOLLOWING THIS STATEMENT ARE ASSOCIATED WHICH MEANS THE RIGHTS SHARE THE SAME PLACE OF USE.

62231-00 70576-00 70577-00 113655-00 113656-00 113657-00 113658-00

113659-00

THE WATER RIGHTS FOLLOWING THIS STATEMENT ARE ASSOCIATED WHICH MEANS THE RIGHTS SHARE THE SAME OTHER.

62231-00 113654-00 113655-00 113656-00 113657-00 113658-00 113659-00

ADDITIONAL MAPS AND DOCUMENTATION CAN BE OBTAINED BY REVIEWING FILE NO. W113654-00. STARTING IN 2008, PERIOD OF DIVERSION WAS ADDED TO MOST CLAIM ABSTRACTS, INCLUDING THIS ONE.

WHENEVER THE WATER RIGHTS FOLLOWING THIS STATEMENT ARE COMBINED TO SUPPLY WATER

FOR THE CLAIMED PURPOSE, EACH IS LIMITED TO THE HISTORICAL FLOW RATE AND PLACE OF USE OF THAT INDIVIDUAL RIGHT. THE SUM TOTAL OF THE VOLUME OF THESE WATER RIGHTS SHALL NOT EXCEED THE AMOUNT PUT TO HISTORICAL AND BENEFICIAL USE. W113654-00, W113655-00, W113659-00.

THE COMBINED CLAIMED VOLUME FOR THE FOLLOWING CLAIMS IS 2,967.00 GALLONS PER CAPITA PER DAY (GCPD) BASED ON THE 1970 CENSUS POPULATION OF 1,651 PEOPLE AND A TOTAL CLAIMED VOLUME OF 5,503.25 ACRE-FEET. THIS APPEARS EXCESSIVE FOR THE CLAIMED PURPOSE. W113654-00, W113655-00, W113656-00, W113657-00, W113658-00, W113659-00.

THE CLAIMED VOLUME MAY BE EXCESSIVE FOR THE CLAIMED PURPOSE AND CANNOT BE CONFIRMED DUE TO LACK OF DATA.

THE CLAIMED VOLUME EXCEEDS MAXIMUM FEASIBLE VOLUME. BASED ON THE FLOW RATE AND PERIOD OF USE, THE MAXIMUM VOLUME POSSIBLE IS 161.74 ACRE-FEET PER YEAR.

#### DEPARTMENT OF NATURAL RESOURCES AND CONSERVATION

1424 9TH AVENUE P.O.BOX 201601 HELENA, MONTANA 59620-1601

## GENERAL ABSTRACT

Water Right Number: 411 113658-00 STATEMENT OF CLAIM

Version: 2 -- CHANGE AUTHORIZATION

**Version Status: ACTIVE** 

THIS AUTHORIZATION IS LIMITED TO THE AMOUNT OF THE HISTORIC USE RECOGNIZED BY THE DEPARTMENT IN THIS PROCEEDING AS SUBJECT TO CHANGE, AND WILL THEREAFTER NOT EXCEED THAT AMOUNT. IF THE HISTORIC USE IS REDUCED UNDER ADJUDICATION PROCEEDINGS PURSUANT TO TITLE 85, CHAPTER 2, PART 2, MCA, THIS AUTHORIZATION WILL BE LIMITED TO A LESSER

AMOUNT.

Owners: EAST HELENA, CITY OF

PO BOX 1170

EAST HELENA, MT 59635-1170

Priority Date: AUGUST 1, 1866

Enforceable Priority Date: AUGUST 1, 1866

Purpose (use): MUNICIPAL Maximum Flow Rate: 3.13 CFS

Maximum Volume: 2,258.44 AC-FT

Source Name: MCCLELLAN CREEK
Source Type: SURFACE WATER

Point of Diversion and Means of Diversion:

IDGovt LotQtr SecSecTwpRgeCounty1NENWNE209N2WJEFFERSON

Period of Diversion: JANUARY 1 TO DECEMBER 31

**Diversion Means:** DIVERSION DAM

2 N2N2SE 7 9N 2W JEFFERSON

**Period of Diversion:** JANUARY 1 TO DECEMBER 31 **Diversion Means:** INFILTRATION GALLERY

WATER IS CONVEYED FROM THE POINT OF DIVERSION BY PIPELINE TO TWO WATER TANKS, AND THEN FURTHER CONVEYED BY PIPELINE TO THE PLACE OF

USE.

TWO CONCRETE STORAGE TANKS WITH A COMBINED CAPACITY OF 550,000 LOCATED IN SENWNE OF SEC 7, TWP 09N, RGE 02W ARE PART OF THIS WATER

RIGHT.

Period of Use: JANUARY 1 to DECEMBER 31

#### Place of Use:

<u>ID</u>	Acres	Govt Lot	<b>Qtr Sec</b>	<u>Sec</u>	<b>Twp</b>	Rge	<b>County</b>
1			NWNE	31	10N	2W	LEWIS AND CLARK
2			NW	31	10N	2W	LEWIS AND CLARK
3			NE	36	10N	2W	LEWIS AND CLARK
4			S2	25	10N	3W	LEWIS AND CLARK
5			SW	30	10N	3W	LEWIS AND CLARK

THE CITYS WATER DISTRIBUTION SYSTEM SUPPLEMENTALLY SUPPLIES BOTH THE ASARCO AND CHEMET PLANTS IN THE NE OF SEC 36, TWP 10N, RGE 03W,

LEWIS AND CLARK COUNTY.

THE PLACE OF USE IS THE CITY OF EAST HELENA.

#### Remarks:

THE WATER RIGHTS FOLLOWING THIS STATEMENT ARE ASSOCIATED WHICH MEANS THE RIGHTS SHARE THE SAME PLACE OF USE.

70576-00 70577-00 113655-00 113656-00 113657-00 113658-00 113659-00

THE WATER RIGHTS FOLLOWING THIS STATEMENT ARE ASSOCIATED WHICH MEANS THE RIGHTS SHARE THE SAME PLACE OF USE.

62231-00 70576-00 70577-00 113655-00 113656-00 113657-00 113658-00 113659-00

THE WATER RIGHTS FOLLOWING THIS STATEMENT ARE ASSOCIATED WHICH MEANS THE RIGHTS SHARE THE SAME OTHER.

62231-00 113654-00 113655-00 113656-00 113657-00 113658-00 113659-00

THE VOLUME WAS AMENDED BY THE CLAIMANT ON 12/30/1986.

TURNER, DIMA, S.A. ADMX OF THE DAVIS G TURNER ESTATE: STIPULATION- CLAIMANT IS ENTITLED TO CONVEY THE WATERS AWAY FROM THE WATER SHED OF THE STREAMS NAMED, TO THE PLACE WHERE THE SAME HAS BEEN HERETOFORE USED, AND MAY USE THE SAME BOTH FOR MINING & IRRIGATION PURPOSES, AND AFTER JUNE 1ST, OF EACH YEAR CLAIMANT MAY DURING THE REMAINDER OF THE IRRIGATING SEASON TAKE THE AMOUNT OF WATER, ABSOLUTELY REGARDLESS OF DATES OF APPROPRIATION. THE JACKSON CREEK HERE REFERRED TO IS THE ONE FROM WHICH CLAIMANT NOW DIVERTS WATER, AND IS NOT THE JACKSON CREEK REFERRED TO IN CONNECTION WITH THE MITCHELL & THIES RIGHTS.

THIS RIGHT IS SUBJECT TO THE AUTHORITY OF COURT APPOINTED WATER COMMISSIONERS, IF AND WHEN APPOINTED, TO ADMEASURE AND DISTRIBUTE TO THE PARTIES USING WATER IN THE SOURCE OF SUPPLY, THE WATER TO WHICH THEY ARE ENTITLED. THE APPROPRIATOR SHALL PAY HIS PROPORTIONATE SHARE OF THE FEES, COMPENSATION AND EXPENSES, AS FIXED BY THE DISTRICT COURT, INCURRED IN THE DISTRIBUTION OF THE WATERS.

ADDITIONAL MAPS AND DOCUMENTATION CAN BE OBTAINED BY REVIEWING CLAIM NO. 113654-00.

THE APPROPRIATOR SHALL INSTALL AN ADEQUATE HEADGATE OR DIVERSION STRUCTURE AT THE POINT THE WATER IS DIVERTED FROM THE SOURCE OF SUPPLY.

WHENEVER THE WATER RIGHTS FOLLOWING THIS STATEMENT ARE COMBINED TO SUPPLY WATER FOR THE CLAIMED PURPOSE, EACH IS LIMITED TO THE HISTORICAL FLOW RATE AND PLACE OF USE OF THAT INDIVIDUAL RIGHT. THE SUM TOTAL OF THE VOLUME OF THESE WATER RIGHTS SHALL NOT EXCEED THE AMOUNT PUT TO HISTORICAL AND BENEFICIAL USE. 113654-00, 113655-00, 113659-00.

THE APPROPRIATOR SHALL INSTALL AN ADEQUATE WATER FLOW MEASURING DEVICE AT A SUITABLE LOCATION AS NEAR AS PRACTICABLE TO THE POINT WHERE THE WATER IS DIVERTED FROM THE SOURCE OF SUPPLY IN ORDER TO RECORD THE FLOW RATE AND VOLUME OF WATER DIVERTED. THE APPROPRIATOR SHALL KEEP A WRITTEN RECORD OF THE FLOW RATE AND VOLUME OF ALL WATERS DIVERTED, INCLUDING THE TIME PERIOD, AND SHALL SUBMIT SAID RECORDS TO THE DEPARTMENT UPON REQUEST.

#### DEPARTMENT OF NATURAL RESOURCES AND CONSERVATION

1424 9TH AVENUE P.O.BOX 201601 HELENA, MONTANA 59620-1601

## GENERAL ABSTRACT

Water Right Number: 411 113658-00 STATEMENT OF CLAIM

Version: 2 -- CHANGE AUTHORIZATION

**Version Status: ACTIVE** 

THIS AUTHORIZATION IS LIMITED TO THE AMOUNT OF THE HISTORIC USE RECOGNIZED BY THE DEPARTMENT IN THIS PROCEEDING AS SUBJECT TO CHANGE, AND WILL THEREAFTER NOT EXCEED THAT AMOUNT. IF THE HISTORIC USE IS REDUCED UNDER ADJUDICATION PROCEEDINGS PURSUANT TO TITLE 85, CHAPTER 2, PART 2, MCA, THIS AUTHORIZATION WILL BE LIMITED TO A LESSER

AMOUNT.

Owners: EAST HELENA, CITY OF

PO BOX 1170

EAST HELENA, MT 59635-1170

Priority Date: AUGUST 1, 1866

Enforceable Priority Date: AUGUST 1, 1866

Purpose (use): MUNICIPAL Maximum Flow Rate: 3.13 CFS

Maximum Volume: 2,258.44 AC-FT

Source Name: MCCLELLAN CREEK
Source Type: SURFACE WATER

Point of Diversion and Means of Diversion:

IDGovt LotQtr SecSecTwpRgeCounty1NENWNE209N2WJEFFERSON

Period of Diversion: JANUARY 1 TO DECEMBER 31

**Diversion Means:** DIVERSION DAM

2 N2N2SE 7 9N 2W JEFFERSON

**Period of Diversion:** JANUARY 1 TO DECEMBER 31 **Diversion Means:** INFILTRATION GALLERY

WATER IS CONVEYED FROM THE POINT OF DIVERSION BY PIPELINE TO TWO WATER TANKS, AND THEN FURTHER CONVEYED BY PIPELINE TO THE PLACE OF

USE.

TWO CONCRETE STORAGE TANKS WITH A COMBINED CAPACITY OF 550,000 LOCATED IN SENWNE OF SEC 7, TWP 09N, RGE 02W ARE PART OF THIS WATER

RIGHT.

Period of Use: JANUARY 1 to DECEMBER 31

#### Place of Use:

<u>ID</u>	Acres	Govt Lot	<b>Qtr Sec</b>	<u>Sec</u>	<b>Twp</b>	Rge	<b>County</b>
1			NWNE	31	10N	2W	LEWIS AND CLARK
2			NW	31	10N	2W	LEWIS AND CLARK
3			NE	36	10N	2W	LEWIS AND CLARK
4			S2	25	10N	3W	LEWIS AND CLARK
5			SW	30	10N	3W	LEWIS AND CLARK

THE CITYS WATER DISTRIBUTION SYSTEM SUPPLEMENTALLY SUPPLIES BOTH THE ASARCO AND CHEMET PLANTS IN THE NE OF SEC 36, TWP 10N, RGE 03W,

LEWIS AND CLARK COUNTY.

THE PLACE OF USE IS THE CITY OF EAST HELENA.

#### Remarks:

THE WATER RIGHTS FOLLOWING THIS STATEMENT ARE ASSOCIATED WHICH MEANS THE RIGHTS SHARE THE SAME PLACE OF USE.

70576-00 70577-00 113655-00 113656-00 113657-00 113658-00 113659-00

THE WATER RIGHTS FOLLOWING THIS STATEMENT ARE ASSOCIATED WHICH MEANS THE RIGHTS SHARE THE SAME PLACE OF USE.

62231-00 70576-00 70577-00 113655-00 113656-00 113657-00 113658-00 113659-00

THE WATER RIGHTS FOLLOWING THIS STATEMENT ARE ASSOCIATED WHICH MEANS THE RIGHTS SHARE THE SAME OTHER.

62231-00 113654-00 113655-00 113656-00 113657-00 113658-00 113659-00

THE VOLUME WAS AMENDED BY THE CLAIMANT ON 12/30/1986.

TURNER, DIMA, S.A. ADMX OF THE DAVIS G TURNER ESTATE: STIPULATION- CLAIMANT IS ENTITLED TO CONVEY THE WATERS AWAY FROM THE WATER SHED OF THE STREAMS NAMED, TO THE PLACE WHERE THE SAME HAS BEEN HERETOFORE USED, AND MAY USE THE SAME BOTH FOR MINING & IRRIGATION PURPOSES, AND AFTER JUNE 1ST, OF EACH YEAR CLAIMANT MAY DURING THE REMAINDER OF THE IRRIGATING SEASON TAKE THE AMOUNT OF WATER, ABSOLUTELY REGARDLESS OF DATES OF APPROPRIATION. THE JACKSON CREEK HERE REFERRED TO IS THE ONE FROM WHICH CLAIMANT NOW DIVERTS WATER, AND IS NOT THE JACKSON CREEK REFERRED TO IN CONNECTION WITH THE MITCHELL & THIES RIGHTS.

THIS RIGHT IS SUBJECT TO THE AUTHORITY OF COURT APPOINTED WATER COMMISSIONERS, IF AND WHEN APPOINTED, TO ADMEASURE AND DISTRIBUTE TO THE PARTIES USING WATER IN THE SOURCE OF SUPPLY, THE WATER TO WHICH THEY ARE ENTITLED. THE APPROPRIATOR SHALL PAY HIS PROPORTIONATE SHARE OF THE FEES, COMPENSATION AND EXPENSES, AS FIXED BY THE DISTRICT COURT, INCURRED IN THE DISTRIBUTION OF THE WATERS.

ADDITIONAL MAPS AND DOCUMENTATION CAN BE OBTAINED BY REVIEWING CLAIM NO. 113654-00.

THE APPROPRIATOR SHALL INSTALL AN ADEQUATE HEADGATE OR DIVERSION STRUCTURE AT THE POINT THE WATER IS DIVERTED FROM THE SOURCE OF SUPPLY.

WHENEVER THE WATER RIGHTS FOLLOWING THIS STATEMENT ARE COMBINED TO SUPPLY WATER FOR THE CLAIMED PURPOSE, EACH IS LIMITED TO THE HISTORICAL FLOW RATE AND PLACE OF USE OF THAT INDIVIDUAL RIGHT. THE SUM TOTAL OF THE VOLUME OF THESE WATER RIGHTS SHALL NOT EXCEED THE AMOUNT PUT TO HISTORICAL AND BENEFICIAL USE. 113654-00, 113655-00, 113659-00.

THE APPROPRIATOR SHALL INSTALL AN ADEQUATE WATER FLOW MEASURING DEVICE AT A SUITABLE LOCATION AS NEAR AS PRACTICABLE TO THE POINT WHERE THE WATER IS DIVERTED FROM THE SOURCE OF SUPPLY IN ORDER TO RECORD THE FLOW RATE AND VOLUME OF WATER DIVERTED. THE APPROPRIATOR SHALL KEEP A WRITTEN RECORD OF THE FLOW RATE AND VOLUME OF ALL WATERS DIVERTED, INCLUDING THE TIME PERIOD, AND SHALL SUBMIT SAID RECORDS TO THE DEPARTMENT UPON REQUEST.

#### DEPARTMENT OF NATURAL RESOURCES AND CONSERVATION

1424 9TH AVENUE P.O.BOX 201601 HELENA, MONTANA 59620-1601

## **GENERAL ABSTRACT**

Water Right Number: 411 113659-00 STATEMENT OF CLAIM

Version: 2 -- CHANGE AUTHORIZATION

**Version Status: ACTIVE** 

THIS AUTHORIZATION IS LIMITED TO THE AMOUNT OF THE HISTORIC USE RECOGNIZED BY THE DEPARTMENT IN THIS PROCEEDING AS SUBJECT TO CHANGE, AND WILL THEREAFTER NOT EXCEED THAT AMOUNT. IF THE HISTORIC USE IS REDUCED UNDER ADJUDICATION PROCEEDINGS PURSUANT TO TITLE 85, CHAPTER 2, PART 2, MCA, THIS AUTHORIZATION WILL BE LIMITED TO A LESSER

AMOUNT.

Owners: EAST HELENA, CITY OF

PO BOX 1170

EAST HELENA, MT 59635-1170

Priority Date: APRIL 1, 1865

Enforceable Priority Date: APRIL 1, 1865

Purpose (use): MUNICIPAL Maximum Flow Rate: 1.38 CFS

Maximum Volume: 993.71 AC-FT

Source Name: MCCLELLAN CREEK
Source Type: SURFACE WATER

Point of Diversion and Means of Diversion:

IDGovt LotQtr SecSecTwpRgeCounty1NENWNE209N2WJEFFERSON

Period of Diversion: JANUARY 1 TO DECEMBER 31

**Diversion Means:** DIVERSION DAM

2 N2N2SE 7 9N 2W JEFFERSON

Period of Diversion:

**Diversion Means: INFILTRATION GALLERY** 

WATER IS CONVEYED FROM THE POINT OF DIVERSION BY PIPE- LINE TO TWO WATER TANKS AND THEN FURTHER CONVEYED BY PIPELINE TO THE PLACE OF

USE.

TWO CONCRETE STORAGE TANKS WITH A COMBINED CAPACITY OF 550,000 LOCATED IN SENWNE OF SEC 7, TWP 09N, RGE 02W, ARE PART OF THIS WATER

RIGHT.

Period of Use: JANUARY 1 to DECEMBER 31

#### Place of Use:

<u>ID</u>	<u>Acres</u>	Govt Lot	Qtr Sec	<u>Sec</u>	<b>Twp</b>	Rge	<b>County</b>
1			SW	30	10N	2W	LEWIS AND CLARK
2			NWNE	31	10N	2W	LEWIS AND CLARK
3			NW	31	10N	2W	LEWIS AND CLARK
4			S2	25	10N	3W	LEWIS AND CLARK
5			NE	36	10N	3W	LEWIS AND CLARK

THE CITYS WATER DISTRIBUTION SYSTEM SUPPLEMENTALLY SUPPLIES BOTH THE ASARCO AND CHEMET PLANTS IN THE NE OF SEC 36, TWP 10N, RGE 03W,

LEWIS AND CLARK COUNTY.

THE PLACE OF USE IS THE CITY OF EAST HELENA.

#### Remarks:

THE WATER RIGHTS FOLLOWING THIS STATEMENT ARE ASSOCIATED WHICH MEANS THE RIGHTS SHARE THE SAME PLACE OF USE.

70576-00 70577-00 113655-00 113656-00 113657-00 113658-00 113659-00

THE WATER RIGHTS FOLLOWING THIS STATEMENT ARE ASSOCIATED WHICH MEANS THE RIGHTS SHARE THE SAME PLACE OF USE.

62231-00 70576-00 70577-00 113655-00 113656-00 113657-00 113658-00 113659-00

THE WATER RIGHTS FOLLOWING THIS STATEMENT ARE ASSOCIATED WHICH MEANS THE RIGHTS SHARE THE SAME OTHER.

62231-00 113654-00 113655-00 113656-00 113657-00 113658-00 113659-00

THE FOLLOWING ELEMENTS WERE AMENDED BY THE CLAIMANT ON 12/30/1986: VOLUME, SOURCE.

A NOTE ON THE INDEX INDICATES THERE MAY HAVE BEEN A TRANSPORTATION LOSS OF 10 MINERS INCHES FROM THIS RIGHT WHEN IT WAS SOLD.

THIS RIGHT IS SUBJECT TO THE AUTHORITY OF COURT APPOINTED WATER COMMISSIONERS, IF AND WHEN APPOINTED, TO ADMEASURE AND DISTRIBUTE TO THE PARTIES USING WATER IN THE SOURCE OF SUPPLY, THE WATER TO WHICH THEY ARE ENTITLED. THE APPROPRIATOR SHALL PAY HIS PROPORTIONATE SHARE OF THE FEES, COMPENSATION AND EXPENSES, AS FIXED BY THE DISTRICT COURT, INCURRED IN THE DISTRIBUTION OF THE WATERS.

ADDITIONAL MAPS AND DOCUMENTATION CAN BE OBTAINED BY REVIEWING CLAIM NO. 113654-00.

THE APPROPRIATOR SHALL INSTALL AN ADEQUATE HEADGATE OR DIVERSION STRUCTURE AT THE POINT THE WATER IS DIVERTED FROM THE SOURCE OF SUPPLY.

WHENEVER THE WATER RIGHTS FOLLOWING THIS STATEMENT ARE COMBINED TO SUPPLY WATER FOR THE CLAIMED PURPOSE, EACH IS LIMITED TO THE HISTORICAL FLOW RATE AND PLACE OF USE OF THAT INDIVIDUAL RIGHT. THE SUM TOTAL OF THE VOLUME OF THESE WATER RIGHTS SHALL NOT EXCEED THE AMOUNT PUT TO HISTORICAL AND BENEFICIAL USE. 113654-00, 113655-00, 113659-00.

THE APPROPRIATOR SHALL INSTALL AN ADEQUATE WATER FLOW MEASURING DEVICE AT A SUITABLE LOCATION AS NEAR AS PRACTICABLE TO THE POINT WHERE THE WATER IS DIVERTED FROM THE SOURCE OF SUPPLY IN ORDER TO RECORD THE FLOW RATE AND VOLUME OF WATER DIVERTED. THE APPROPRIATOR SHALL KEEP A WRITTEN RECORD OF THE FLOW RATE AND VOLUME OF ALL WATERS DIVERTED, INCLUDING THE TIME PERIOD, AND SHALL SUBMIT SAID RECORDS TO THE DEPARTMENT UPON REQUEST.

#### DEPARTMENT OF NATURAL RESOURCES AND CONSERVATION

1424 9TH AVENUE P.O.BOX 201601 HELENA, MONTANA 59620-1601

## **GENERAL ABSTRACT**

Water Right Number: 411 113659-00 STATEMENT OF CLAIM

Version: 2 -- CHANGE AUTHORIZATION

**Version Status: ACTIVE** 

THIS AUTHORIZATION IS LIMITED TO THE AMOUNT OF THE HISTORIC USE RECOGNIZED BY THE DEPARTMENT IN THIS PROCEEDING AS SUBJECT TO CHANGE, AND WILL THEREAFTER NOT EXCEED THAT AMOUNT. IF THE HISTORIC USE IS REDUCED UNDER ADJUDICATION PROCEEDINGS PURSUANT TO TITLE 85, CHAPTER 2, PART 2, MCA, THIS AUTHORIZATION WILL BE LIMITED TO A LESSER

AMOUNT.

Owners: EAST HELENA, CITY OF

PO BOX 1170

EAST HELENA, MT 59635-1170

Priority Date: APRIL 1, 1865

Enforceable Priority Date: APRIL 1, 1865

Purpose (use): MUNICIPAL Maximum Flow Rate: 1.38 CFS

Maximum Volume: 993.71 AC-FT

Source Name: MCCLELLAN CREEK
Source Type: SURFACE WATER

Point of Diversion and Means of Diversion:

IDGovt LotQtr SecSecTwpRgeCounty1NENWNE209N2WJEFFERSON

Period of Diversion: JANUARY 1 TO DECEMBER 31

**Diversion Means:** DIVERSION DAM

2 N2N2SE 7 9N 2W JEFFERSON

Period of Diversion:

**Diversion Means: INFILTRATION GALLERY** 

WATER IS CONVEYED FROM THE POINT OF DIVERSION BY PIPE- LINE TO TWO WATER TANKS AND THEN FURTHER CONVEYED BY PIPELINE TO THE PLACE OF

USE.

TWO CONCRETE STORAGE TANKS WITH A COMBINED CAPACITY OF 550,000 LOCATED IN SENWNE OF SEC 7, TWP 09N, RGE 02W, ARE PART OF THIS WATER

RIGHT.

Period of Use: JANUARY 1 to DECEMBER 31

#### Place of Use:

<u>ID</u>	<u>Acres</u>	Govt Lot	Qtr Sec	<u>Sec</u>	<b>Twp</b>	Rge	<b>County</b>
1			SW	30	10N	2W	LEWIS AND CLARK
2			NWNE	31	10N	2W	LEWIS AND CLARK
3			NW	31	10N	2W	LEWIS AND CLARK
4			S2	25	10N	3W	LEWIS AND CLARK
5			NE	36	10N	3W	LEWIS AND CLARK

THE CITYS WATER DISTRIBUTION SYSTEM SUPPLEMENTALLY SUPPLIES BOTH THE ASARCO AND CHEMET PLANTS IN THE NE OF SEC 36, TWP 10N, RGE 03W,

LEWIS AND CLARK COUNTY.

THE PLACE OF USE IS THE CITY OF EAST HELENA.

#### Remarks:

THE WATER RIGHTS FOLLOWING THIS STATEMENT ARE ASSOCIATED WHICH MEANS THE RIGHTS SHARE THE SAME PLACE OF USE.

70576-00 70577-00 113655-00 113656-00 113657-00 113658-00 113659-00

THE WATER RIGHTS FOLLOWING THIS STATEMENT ARE ASSOCIATED WHICH MEANS THE RIGHTS SHARE THE SAME PLACE OF USE.

62231-00 70576-00 70577-00 113655-00 113656-00 113657-00 113658-00 113659-00

THE WATER RIGHTS FOLLOWING THIS STATEMENT ARE ASSOCIATED WHICH MEANS THE RIGHTS SHARE THE SAME OTHER.

62231-00 113654-00 113655-00 113656-00 113657-00 113658-00 113659-00

THE FOLLOWING ELEMENTS WERE AMENDED BY THE CLAIMANT ON 12/30/1986: VOLUME, SOURCE.

A NOTE ON THE INDEX INDICATES THERE MAY HAVE BEEN A TRANSPORTATION LOSS OF 10 MINERS INCHES FROM THIS RIGHT WHEN IT WAS SOLD.

THIS RIGHT IS SUBJECT TO THE AUTHORITY OF COURT APPOINTED WATER COMMISSIONERS, IF AND WHEN APPOINTED, TO ADMEASURE AND DISTRIBUTE TO THE PARTIES USING WATER IN THE SOURCE OF SUPPLY, THE WATER TO WHICH THEY ARE ENTITLED. THE APPROPRIATOR SHALL PAY HIS PROPORTIONATE SHARE OF THE FEES, COMPENSATION AND EXPENSES, AS FIXED BY THE DISTRICT COURT, INCURRED IN THE DISTRIBUTION OF THE WATERS.

ADDITIONAL MAPS AND DOCUMENTATION CAN BE OBTAINED BY REVIEWING CLAIM NO. 113654-00.

THE APPROPRIATOR SHALL INSTALL AN ADEQUATE HEADGATE OR DIVERSION STRUCTURE AT THE POINT THE WATER IS DIVERTED FROM THE SOURCE OF SUPPLY.

WHENEVER THE WATER RIGHTS FOLLOWING THIS STATEMENT ARE COMBINED TO SUPPLY WATER FOR THE CLAIMED PURPOSE, EACH IS LIMITED TO THE HISTORICAL FLOW RATE AND PLACE OF USE OF THAT INDIVIDUAL RIGHT. THE SUM TOTAL OF THE VOLUME OF THESE WATER RIGHTS SHALL NOT EXCEED THE AMOUNT PUT TO HISTORICAL AND BENEFICIAL USE. 113654-00, 113655-00, 113659-00.

THE APPROPRIATOR SHALL INSTALL AN ADEQUATE WATER FLOW MEASURING DEVICE AT A SUITABLE LOCATION AS NEAR AS PRACTICABLE TO THE POINT WHERE THE WATER IS DIVERTED FROM THE SOURCE OF SUPPLY IN ORDER TO RECORD THE FLOW RATE AND VOLUME OF WATER DIVERTED. THE APPROPRIATOR SHALL KEEP A WRITTEN RECORD OF THE FLOW RATE AND VOLUME OF ALL WATERS DIVERTED, INCLUDING THE TIME PERIOD, AND SHALL SUBMIT SAID RECORDS TO THE DEPARTMENT UPON REQUEST.

#### DEPARTMENT OF NATURAL RESOURCES AND CONSERVATION

1424 9TH AVENUE P.O.BOX 201601 HELENA, MONTANA 59620-1601

### GENERAL ABSTRACT

Water Right Number: 411 44698-00 GROUND WATER CERTIFICATE

Version: 1 -- ORIGINAL RIGHT

Version Status: ACTIVE

Owners: EAST HELENA, CITY OF

PO BOX 1170

EAST HELENA, MT 59635-1170

**Priority Date:** MAY 5, 1982 at 08:46 A.M.

**Enforceable Priority Date:** MAY 5, 1982 at 08:46 A.M.

Purpose (use): MUNICIPAL
Maximum Flow Rate: 10.00 GPM
Maximum Volume: 0.70 AC-FT

Source Name: GROUNDWATER

Source Type: GROUNDWATER

**LAGOON WELL** 

Point of Diversion and Means of Diversion:

<u>ID</u> <u>Govt Lot</u> <u>Qtr Sec</u> <u>Sec</u> <u>Twp</u> <u>Rge</u> <u>County</u>

1 SESWSE 24 10N 3W LEWIS AND CLARK

Period of Diversion: JANUARY 1 TO DECEMBER 31

**Diversion Means:** WELL **Well Depth:** 75.00 FEET **Static Water Level:** 40.00 FEET **Casing Diameter:** 6.00 INCHES

Flowing: NO

Well Location: 3303 PLANT RD

Purpose (Use): MUNICIPAL

**Volume:** 0.70 AC-FT

Period of Use: JANUARY 1 to DECEMBER 31

Place of Use:

ID Acres Govt Lot Qtr Sec Sec Twp Rge County

1 SESWSE 24 10N 3W LEWIS AND CLARK

#### DEPARTMENT OF NATURAL RESOURCES AND CONSERVATION

1424 9TH AVENUE P.O.BOX 201601 HELENA, MONTANA 59620-1601

## **GENERAL ABSTRACT**

Water Right Number: 411 62231-00 PROVISIONAL PERMIT

Version: 1 -- ORIGINAL RIGHT

**Version Status: ACTIVE** 

Owners: EAST HELENA, CITY OF

PO BOX 1170

EAST HELENA, MT 59635-1170

**Priority Date:** MAY 19, 1986 at 11:30 A.M.

Enforceable Priority Date: MAY 19, 1986 at 11:30 A.M.

Purpose (use): MUNICIPAL

Maximum Flow Rate: 450.00 GPM

Maximum Volume: 160.00 AC-FT

Source Name: GROUNDWATER

Source Type: GROUNDWATER

WYLIE WELL #3

Point of Diversion and Means of Diversion:

<u>ID</u> <u>Govt Lot</u> <u>Qtr Sec</u> <u>Sec</u> <u>Twp</u> <u>Rge</u> <u>County</u>

1 SWNWSW 24 10N 3W LEWIS AND CLARK

Period of Diversion: JANUARY 1 TO DECEMBER 31

**Diversion Means: WELL** 

Well Depth: 153.00 FEET Static Water Level: 35.00 FEET Casing Diameter: 10.00 INCHES

Flowing: NO

Well Location: 2700 WYLIE DR

**Purpose** (Use): MUNICIPAL Volume: 160.00 AC-FT

Period of Use: JANUARY 1 to DECEMBER 31

Place of Use:

<u>ID</u>	<u>Acres</u>	Govt Lot	<u>Qtr Sec</u>	<u>Sec</u>	<u>Twp</u>	<u>Rge</u>	<b>County</b>
1			S2	25	10N	3W	LEWIS AND CLARK
2			SW	24	10N	3W	LEWIS AND CLARK
3			SW	30	10N	2W	LEWIS AND CLARK
4			NW	31	10N	2W	LEWIS AND CLARK
5			NE	36	10N	3W	LEWIS AND CLARK
6			NWNE	31	10N	2W	LEWIS AND CLARK

#### Remarks:

THE WATER RIGHTS FOLLOWING THIS STATEMENT ARE ASSOCIATED WHICH MEANS THE RIGHTS SHARE THE SAME PLACE OF USE.

62231-00 70576-00 70577-00 113655-00 113656-00 113657-00 113658-00

113659-00

THE WATER RIGHTS FOLLOWING THIS STATEMENT ARE ASSOCIATED WHICH MEANS THE RIGHTS SHARE THE SAME OTHER.

62231-00 113654-00 113655-00 113656-00 113657-00 113658-00 113659-00

#### **ASSOCIATED RIGHT**

THIS CERTIFICATE IS ASSOCIATED WITH W-113654-41I THROUGH W-113659-41I AND G-113658-41I.

#### **FINAL ORDER**

THIS WATER RIGHT IS SUBJECT TO THE FINAL ORDER OF THE DEPARTMENT.

#### IMPORTANT INFORMATION

THIS WELL WILL SUPPLEMENT THE EXISTING WATER SUPPLY OF THE CITY OF EAST HELENA; CLAIM NO.S W113656-41I AND W113655-41I.

#### **WATER MEASUREMENT - ANNUAL DATA**

ANNUAL RECORDS FOR 2002 STATIC LEVEL 11/30/01 - 44' 7" 10/31/02 - 36' 10"

#### **WATER MEASUREMENT - ANNUAL DATA**

ANNUAL RECORDS FOR 2003

2003 STATIC LEVEL 11/26/02 - 38' 2" 10/29/03 - 41' 4"

#### **WATER MEASUREMENT - ANNUAL DATA**

MEASUREMENT DATA: 1997 04506.00 GPM 00116.70 AC-FT 1998 450.00 GPM 59.00 AC-FT

#### **WATER MEASUREMENT - ANNUAL DATA**

MEASUREMENT DATA: 1999 00500.00 GPM 00064.05 AC-FT STATIC LEVEL IS 41.88

#### **WATER MEASUREMENT - ANNUAL DATA**

MEASUREMENT DATA: 2001 00400.00 GPM 00031.07 AC-FT STATIC LEVEL 10/30/00 - 46'1.25" 10/25/01 43' 5.25"

#### **WATER MEASUREMENT - ANNUAL DATA**

MEASUREMENT DATA: 2000 00400.00 GPM 00087.40 AC-FT STATIC LEVEL 11/30/99 - 44'4" 9/28/00 - 52'2"

#### SPECIAL MEASUREMENT REPORT TYPE INFORMATION

REPORT 02 & 08 NEEDED

#### **WATER MEASUREMENT REQUIREMENT - UNIQUE TYPE**

AN OBSERVATION WELL SHALL BE DRILLED WITHIN THREE HUNDRED (300) FEET OF THE PRODUCTION WELL AUTHORIZED BY THIS CERTIFICATE. THE STATIC WATER LEVEL SHALL BE MEASURED IN THE OBSERVATION WELL AT THE END OF EVERY MONTH. THE MEASUREMENTS SHALL BE MADE FROM A COMMON DATUM (FIXED LEVEL REFERENCE POINT). A WRITTEN REPORT OF THE MEASUREMENTS SHALL BE MADE TO THE HELENA WATER RESOURCES REGIONAL OFFICE EACH YEAR. THE REPORT SHALL INCLUDE THE DISTANCE FROM THE DATUM TO THE STATIC WATER LEVEL AND THE DATE AND TIME OF THE MEASUREMENT. THE RECORDS FOR THE PREVIOUS NOVEMBER THROUGH OCTOBER OF THE REPORTING YEAR, INCLUSIVE, SHALL BE SUBMITTED BY NOVEMBER 30 OF EACH YEAR.

#### WATER MEASUREMENT REQUIREMENT - UNIQUE TYPE

THE APPROPRIATOR SHALL INSTALL AN ADEQUATE FLOW METERING DEVICE IN ORDER TO ALLOW THE FLOW RATE AND VOLUME OF WATER DIVERTED TO BE RECORDED. THE FLOW RATE AND ACCUMULATED VOLUME SHALL BE RECORDED AT OR NEAR THE END OF EVERY MONTH. THE APPROPRIATOR SHALL KEEP A WRITTEN RECORD OF THE FLOW RATE AND VOLUME OF ALL WATERS DIVERTED, INCLUDING THE DATE AND TIME, AND SHALL SUBMIT THESE RECORDS TO THE HELENA WATER RESOURCES REGIONAL OFFICE BY NOVMEBER 30 OF EACH YEAR. THE SUBMITTED RECORDS SHALL INCLUDE ALL REQUIRED DATA FOR THE PERIOD COVERING NOVEMBER OF THE PREVIOUS YEAR THROUGH OCTOBER OF THE REPORTING YEAR.

#### DEPARTMENT OF NATURAL RESOURCES AND CONSERVATION

1424 9TH AVENUE P.O.BOX 201601 HELENA, MONTANA 59620-1601

## **GENERAL ABSTRACT**

Water Right Number: 411 70576-00 PROVISIONAL PERMIT

Version: 1 -- ORIGINAL RIGHT

**Version Status: ACTIVE** 

Owners: EAST HELENA, CITY OF

PO BOX 1170

EAST HELENA, MT 59635-1170

**Priority Date:** DECEMBER 12, 1988 at 11:17 A.M.

Enforceable Priority Date: DECEMBER 12, 1988 at 11:17 A.M.

Purpose (use): MUNICIPAL
Maximum Flow Rate: 600.00 GPM
Maximum Volume: 840.00 AC-FT

Source Name: GROUNDWATER

Source Type: GROUNDWATER

Point of Diversion and Means of Diversion:

IDGovt LotQtr SecSecTwpRgeCounty1N2N2SE79N2WJEFFERSON

Period of Diversion: JANUARY 1 TO DECEMBER 31

**Diversion Means: WELL** 

INFILTRATION GALLERY AND PUMP

**Purpose** (Use): MUNICIPAL **Volume:** 840.00 AC-FT

Period of Use: JANUARY 1 to DECEMBER 31

Place of Use:

<u>Acres</u>	Govt Lot	<u>Qtr Sec</u>	<u>Sec</u>	<u>Twp</u>	<u>Rge</u>	<b>County</b>
		SW	30	10N	2W	LEWIS AND CLARK
		NW	31	10N	2W	LEWIS AND CLARK
		NWNE	31	10N	2W	LEWIS AND CLARK
		SW	24	10N	3W	LEWIS AND CLARK
		S2	25	10N	3W	LEWIS AND CLARK
		NE	36	10N	3W	LEWIS AND CLARK
	Acres	Acres Govt Lot	SW NW NWNE SW S2	SW 30 NW 31 NWNE 31 SW 24 S2 25	SW 30 10N NW 31 10N NWNE 31 10N SW 24 10N S2 25 10N	SW 30 10N 2W NW 31 10N 2W NWNE 31 10N 2W SW 24 10N 3W S2 25 10N 3W

#### Remarks:

THE WATER RIGHTS FOLLOWING THIS STATEMENT ARE ASSOCIATED WHICH MEANS THE RIGHTS SHARE THE SAME PLACE OF USE.

70576-00 70577-00 113655-00 113656-00 113657-00 113658-00 113659-00

THE WATER RIGHTS FOLLOWING THIS STATEMENT ARE ASSOCIATED WHICH MEANS THE RIGHTS SHARE THE SAME PLACE OF USE.

62231-00 70576-00 70577-00 113655-00 113656-00 113657-00 113658-00

113659-00

#### **ASSOCIATED RIGHT**

THIS PERMIT IS ASSOCIATED WITH BENEFICIAL WATER USE PERMIT 41I-P070577-00. THE COMBINED APPROPRIATION AS GRANTED SHALL NOT EXCEED A TOTAL OF 650 GALLONS PER MINUTE UP TO 1048.45 ACRE-FEET OF WATER PER YEAR. THIS PERMIT AND WATER RIGHTS 41I-P070577-00, 41I-P062231-00, 41I-W113655-00, 41I-W113656-00, 41I-W113657-00, 41I-W113658-00 AND 41I-W113659-00 HAVE OVERLAPPING PLACES OF USE.

#### **DECREED STREAM - COMMISSIONER**

THIS RIGHT IS SUBJECT TO THE AUTHORITY OF COURT APPOINTED WATER COMMISSIONERS, IF AND WHEN APPOINTED, TO ADMEASURE AND DISTRIBUTE TO THE PARTIES USING WATER IN THE SOURCE OF SUPPLY, THE WATER TO WHICH THEY ARE ENTITLED. THE APPROPRIATOR SHALL PAY HIS PROPORTIONATE SHARE OF THE FEES, COMPENSATION AND EXPENSES, AS FIXED BY THE DISTRICT COURT, INCURRED IN THE DISTRIBUTION OF THE WATERS.

#### **FINAL ORDER**

THIS WATER RIGHT IS SUBJECT TO THE FINAL ORDER OF THE DEPARTMENT.

#### **IMPORTANT INFORMATION**

THIS PERMIT IS SUBJECT TO SECTION 85-2-505, MCA, REQUIRING THAT ALL WELLS BE CONSTRUCTED SO THEY WILL NOT ALLOW WATER TO BE WASTED, OR CONTAMINATE OTHER WATER SUPPLIES OR SOURCES, AND ALL FLOWING WELLS SHALL BE CAPPED OR EQUIPPED SO THE FLOW OF THE WATER MAY BE STOPPED WHEN NOT BEING PUT TO BENEFICIAL USE.

#### **WATER MEASUREMENT - ANNUAL DATA**

MEASUREMENT DATA: 1997 00600.00 GPM 00277.00 AC-FT 1998 600.00 GPM 550.00 AC-FT

#### **WATER MEASUREMENT - ANNUAL DATA**

MEASUREMENT DATA: 1999 00425.00 GPM 00245.44 AC-FT

#### **WATER MEASUREMENT - ANNUAL DATA**

MEASUREMENT DATA: 2001 00500.00 GPM 00147.06 AC-FT

#### **WATER MEASUREMENT - ANNUAL DATA**

MEASUREMENT DATA: 2000 00500.00 GPM 00182.70 AC-FT

#### **OBJECTION INFORMATION**

13-104

#### **WATER MEASUREMENT REQUIREMENT - UNIQUE TYPE**

THIS PERMIT IS SUBJECT TO THE CONDITION THAT THE PERMITTEE SHALL INSTALL AN ADEQUATE FLOW METERING DEVICE IN ORDER TO ALLOW THE FLOW RATE AND VOLUME OF WATER DIVERTED TO BE RECORDED. THE PERMITTEE SHALL KEEP A WRITTEN RECORD OF THE FLOW RATE AND VOLUME OF ALL WATERS DIVERTED, INCLUDING THE PERIOD OF TIME, AND SHALL SUBMIT SAID RECORDS UPON REQUEST AND BY NOVEMBER 30 OF EACH YEAR TO THE WATER RESOURCES REGIONAL OFFICE AT HELENA, MT PH: (406) 449-0944

#### POSSIBLE COMPLAINT RECEIVED

IF AT ANY TIME AFTER THIS RIGHT IS ISSUED, A WRITTEN COMPLAINT IS RECEIVED BY THE DEPARTMENT ALLEGING THAT DIVERTING FROM THIS SOURCE IS ADVERSELY AFFECTING A PRIOR WATER RIGHT, THE DEPARTMENT MAY MAKE A FIELD INVESTIGATION OF THE PROJECT. IF DURING THE FIELD INVESTIGATION THE DEPARTMENT FINDS SUFFICIENT EVIDENCE SUPPORTING THE ALLEGATION, IT MAY CONDUCT A HEARING IN THE MATTER ALLOWING THE APPROPRIATOR TO SHOW CAUSE WHY THE RIGHT SHOULD NOT BE MODIFIED OR REVOKED. THE DEPARTMENT MAY THEN MODIFY OR REVOKE THIS RIGHT TO PROTECT EXISTING RIGHTS OR LEAVE THIS RIGHT UNCHANGED IF THE HEARING OFFICER DETERMINES NO EXISTING WATER RIGHTS ARE BEING ADVERSELY AFFECTED.

#### LIABILITY WAIVER

THE ISSUANCE OF THIS RIGHT BY THE DEPARTMENT SHALL NOT REDUCE THE APPROPRIATOR'S LIABILITY FOR DAMAGES CAUSED BY THE APPROPRIATOR'S EXERCISE OF THIS RIGHT. NOR DOES THE DEPARTMENT IN ISSUING THE RIGHT IN ANY WAY ACKNOWLEDGE LIABILITY FOR DAMAGE CAUSED BY THE APPROPRIATOR'S EXERCISE OF THIS RIGHT.

#### DEPARTMENT OF NATURAL RESOURCES AND CONSERVATION

1424 9TH AVENUE P.O.BOX 201601 HELENA, MONTANA 59620-1601

## **GENERAL ABSTRACT**

Water Right Number: 411 70577-00 PROVISIONAL PERMIT

Version: 1 -- ORIGINAL RIGHT

**Version Status: ACTIVE** 

Owners: EAST HELENA, CITY OF

PO BOX 1170

EAST HELENA, MT 59635-1170

**Priority Date:** DECEMBER 12, 1988 at 11:16 A.M.

Enforceable Priority Date: DECEMBER 12, 1988 at 11:16 A.M.

Purpose (use): MUNICIPAL
Maximum Flow Rate: 600.00 GPM
Maximum Volume: 840.00 AC-FT

Source Name: GROUNDWATER

Source Type: GROUNDWATER

Point of Diversion and Means of Diversion:

IDGovt LotQtr SecSecTwpRgeCounty1N2N2SE79N2WJEFFERSON

Period of Diversion: JANUARY 1 TO DECEMBER 31

**Diversion Means: WELL** 

INFILTRATION GALLERY AND PUMP

**Purpose** (Use): MUNICIPAL **Volume:** 840.00 AC-FT

Period of Use: JANUARY 1 to DECEMBER 31

Place of Use:

<u>y</u>
S AND CLARK
S AND CLARK
S AND CLARK
S AND CLARK
S AND CLARK
S AND CLARK

#### Remarks:

THE WATER RIGHTS FOLLOWING THIS STATEMENT ARE ASSOCIATED WHICH MEANS THE RIGHTS SHARE THE SAME PLACE OF USE.

70576-00 70577-00 113655-00 113656-00 113657-00 113658-00 113659-00

THE WATER RIGHTS FOLLOWING THIS STATEMENT ARE ASSOCIATED WHICH MEANS THE RIGHTS SHARE THE SAME PLACE OF USE.

62231-00 70576-00 70577-00 113655-00 113656-00 113657-00 113658-00

113659-00

#### **ASSOCIATED RIGHT**

THIS PERMIT IS ASSOCIATED WITH BENEFICIAL WATER USE PERMIT 41I-P070576-00. THE COMBINED APPROPRIATION AS GRANTED SHALL NOT EXCEED A TOTAL OF 650 GALLONS PER MINUTE UP TO 1048.45 ACRE-FEET OF WATER PER YEAR. THIS PERMIT AND WATER RIGHTS 41I-P070576-00 41I-W062231-00, 41I-W113655-00, 41I-W113656-00, 41I-W113657-00, 41I-W113658-00 AND 41I-W113659-00 HAVE OVERLAPPING PLACES OF USE.

#### **DECREED STREAM - COMMISSIONER**

THIS RIGHT IS SUBJECT TO THE AUTHORITY OF COURT APPOINTED WATER COMMISSIONERS, IF AND WHEN APPOINTED, TO ADMEASURE AND DISTRIBUTE TO THE PARTIES USING WATER IN THE SOURCE OF SUPPLY, THE WATER TO WHICH THEY ARE ENTITLED. THE APPROPRIATOR SHALL PAY HIS PROPORTIONATE SHARE OF THE FEES, COMPENSATION AND EXPENSES, AS FIXED BY THE DISTRICT COURT, INCURRED IN THE DISTRIBUTION OF THE WATERS.

#### **FINAL ORDER**

THIS WATER RIGHT IS SUBJECT TO THE FINAL ORDER OF THE DEPARTMENT.

#### **IMPORTANT INFORMATION**

THIS PERMIT IS SUBJECT TO SECTION 85-2-505, MCA, REQUIRING THAT ALL WELLS BE CONSTRUCTED TO THEY WILL NOT ALLOW WATER TO BE WASTED, OR CONTAMINATE OTHER WATER SUPPLIES OR SOURCES, AND ALL FLOWING WELLS SHALL BE CAPPED OR EQUIPPED SO THE FLOW OF THE WATER MAY BE STOPPED WHEN NOT BEING PUT TO BENEFICIAL USE.

#### **OBJECTION INFORMATION**

13-105

#### **WATER MEASUREMENT REQUIREMENT - UNIQUE TYPE**

THIS PERMIT IS SUBJECT TO THE CONDITION THAT THE PERMITTEE SHALL INSTALL AN ADEQUATE FLOW METERING DEVICE IN ORDER TO ALLOW THE FLOW RATE AND VOLUME OF WATER DIVERTED TO BE RECORDED. THE PERMITTEE SHALL KEEP A WRITTEN RECORD OF THE FLOW RATE AND VOLUME OF ALL WATERS DIVERTED, INCLUDING THE PERIOD OF TIME, AND SHALL SUBMIT SAID RECORDS UPON REQUEST AND BY NOVEMBER 30 OF EACH YEAR TO THE WATER RESOURCES REGIONAL OFFICE AT HELENA, MT. PH: (406) 449-0944.

#### POSSIBLE COMPLAINT RECEIVED

IF AT ANY TIME AFTER THIS RIGHT IS ISSUED, A WRITTEN COMPLAINT IS RECEIVED BY THE DEPARTMENT ALLEGING THAT DIVERTING FROM THIS SOURCE IS ADVERSELY AFFECTING A PRIOR WATER RIGHT, THE DEPARTMENT MAY MAKE A FIELD INVESTIGATION OF THE PROJECT. IF DURING THE FIELD INVESTIGATION THE DEPARTMENT FINDS SUFFICIENT EVIDENCE SUPPORTING THE ALLEGATION, IT MAY CONDUCT A HEARING IN THE MATTER ALLOWING THE APPROPRIATOR TO SHOW CAUSE WHY THE RIGHT SHOULD NOT BE MODIFIED OR REVOKED. THE DEPARTMENT MAY THEN MODIFY OR REVOKE THIS RIGHT TO PROTECT EXISTING RIGHTS OR LEAVE THIS RIGHT UNCHANGED IF THE HEARING OFFICER DETERMINES NO EXISTING WATER RIGHTS ARE BEING ADVERSELY AFFECTED.

#### **LIABILITY WAIVER**

THE ISSUANCE OF THIS RIGHT BY THE DEPARTMENT SHALL NOT REDUCE THE APPROPRIATOR'S LIABILITY FOR DAMAGES CAUSED BY THE APPROPRIATOR'S EXERCISE OF THIS RIGHT. NOR DOES THE DEPARTMENT IN ISSUING THE RIGHT IN ANY WAY ACKNOWLEDGE LIABILITY FOR DAMAGE CAUSED BY THE APPROPRIATOR'S EXERCISE OF THIS RIGHT.

#### DEPARTMENT OF NATURAL RESOURCES AND CONSERVATION

1424 9TH AVENUE P.O.BOX 201601 HELENA, MONTANA 59620-1601

## **GENERAL ABSTRACT**

Water Right Number: 411 71895-00 WATER RESERVATION

Version: 1 -- ORIGINAL RIGHT

**Version Status: ACTIVE** 

Owners: EAST HELENA, CITY OF

PO BOX 1170

EAST HELENA, MT 59635-1170

**Priority Date:** JULY 1, 1985 at 12:00 A.M.

Enforceable Priority Date: JULY 1, 1985 at 12:00 A.M.

Purpose (use): MUNICIPAL
Maximum Flow Rate: 417.00 GPM
Maximum Volume: 258.00 AC-FT

Source Name: GROUNDWATER

Source Type: GROUNDWATER

Point of Diversion and Means of Diversion:

<u>ID</u> <u>Govt Lot</u> <u>Qtr Sec</u> <u>Sec</u> <u>Twp</u> <u>Rge</u> <u>County</u>

1 SE 14 10N 3W LEWIS AND CLARK

Period of Diversion:
Diversion Means: WELL

Purpose (Use): MUNICIPAL

Volume: 258.00 AC-FT
Perfected Flow Rate:

Perfected Volume:

Period of Use: JANUARY 1 to DECEMBER 31

Place of Use:

<u>ID</u>	Acres	Govt Lot	<b>Qtr Sec</b>	<u>Sec</u>	<b>Twp</b>	Rge	County
1				30	10N	2W	LEWIS AND CLARK
2				25	10N	3W	LEWIS AND CLARK
3				26	10N	3W	LEWIS AND CLARK

#### Remarks:

THE BOXES PERTAINING TO THIS WATER RESERVATION ARE LOCATED AT MERGANTHALERS IN THE NEW APPROPRIATIONS, MISCELLANEOUS SERIES.

RESERVATION GRANTED JUNE 29, 1992.

## APPENDIX H – BILLED MONTHLY USAGE AND WELL PRODUCTION TOTALS FOR 2017

usertype	avg_accts_	jan_2017	feb_2017	mar_2017	apr_2017	may_2017	jun_2017	jul_2017	aug_2017	sep_2017	oct_2017	nov_2017	dec_2017 t	otal
	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Water Usage Summary From Billing	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Routes: All	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Billing Usage Period: From JAN-2017 to	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	0	0	0	0	0	. 0	. 0	0	0	0	0	0	0	0
WATER	0	0	0	0	0	0	0	0	0	0	0	0	0	0
C-SERVICE-BUSINESS	1	0	1000	1000	0	3000	7000	12000	9000	4000	7000	1000	0	45000
COMMERCIAL	47	788000	900000	840000	772000	1984000	2566000	2943000	2904000	1792000	439000	364000	367000	16659000
R-APARTMENT	42	513000	550000	491000	453000	724000	1476000	1603000	1965000	1438000	761000	492000	495000	10961000
R-DUPLEX	16	84000	100000	86000	73000	113000	204000	205000	198000	180000	87000	63000	74000	1467000
R-TRIPLEX	5	36000	39000	37000	32000	71000	86000	108000	139000	84000	41000	37000	39000	749000
RESIDENTIAL	680	7737000	2790000	2736000	2499000	5767000	14006000	15308000	17103000	8061000	2615000	2083000	2192000	82897000
Subtotal for WATER	791	9158000	4380000	4191000	3829000	8662000	18345000	20179000	22318000		3950000	3040000	3167000	112778000
	0	0	0	0	0	0	0	0	0	0	. 0	0	0	0

1.1.1.

FEB O 1 2018

CITY OF A. MT

#### FLOW METER REPORT

WATER RIGHT OWNERS NAME:

CITY OF EAST HELENA

PERMIT NO:

411-P062231-00

LOCATION

SWNWSW SEC 24 T10 R03W

**USER INFORMATION** 

MUNUCUPAL WELL (WYLIE WELLS)

**MEASUREMENTS REQUIRED** 

MONTHLY FLOW METER RECORDS FROM NOVEMBER OF PRERVIOUS

**NOVEMBER THRU OCTOBER OF CURRENT YEAR** 

DATE	TIME	PERIOD OF OPERATION	FLOW RATE	METER READ 74440000	VOLUME IN GAL
Jan-17	13:45	31 DAYS	400 GPM AVE	79363000 86740000	7377000
Feb-17	12:45	29 DAYS	400 GPM AVE	89575000	2835000
Mar-17	14:10	31 DAYS	<b>400 GPM AVE</b>	92498000	2923000
Apr-17	13:00	30 DAYS	<b>400 GPM AVE</b>	95456000	2958000
May-17	10:45	31 DAYS	<b>400 GPM AVE</b>	103340000	7884000
Jun-17	11:00	30 DAYS	<b>400 GPM AVE</b>	117171000	13831000
Jul-17	13:30	31 DAYS	<b>400 GPM AVE</b>	132431000	15260000
Aug-17	12:30	31 DAYS	<b>400 GPM AVE</b>	148750000	16319000
Sep-17	13:45	30 DAYS	<b>400 GPM AVE</b>	156707000	7957000
Oct-17	11:30	31 DAYS	<b>400 GPM AVE</b>	159782000	3075000
Nov-17	10:00	30 DAYS	<b>400 GPM AVE</b>	162183000	2401000
Dec-17	12:15	31 DAYS	400 GPM AVE	164628000	2445000
				YEAR END TOTAL JAN-DEC	85265000

## WATER MEASUREMENT FLOW METER REPORT (SUPPLEMENTAL PAGE)

DATE

WATER RIGHT OWNERS NAME:

**CITY OF EAST HELENA** 

**PERMIT NO:** 

411-P070576-00, 411-P070577-00, AND 411-G(W)113658-00

LOCATION

N2N2SE SEC7, T09N, R02W

**USER INFORMATION** 

MCCLELLAN CREEK DIVERSION

**MEASURI MENTS REQUIRED** 

MONTHLY FLOW RATE, PERIOD OF DIVERSION AND VOLUME OF WATER DIVERTED NOVEMBER THRU OCTOBER OF CURRENT YEAR

(i) :	TIME	PERIOD OF OPERATION	FLOW RATE	METER READ	<b>VOLUME IN GAL</b>
166, 47	13:15	31 DAYS	500 GPM AVE	105157000	3019300
Fab 17	10:45	29 DAYS	500 GPM AVE	110218900	5061900
Mar 17	14:15	31 DAYS	<b>500 GPM AVE</b>	113969400	3750500
Apr-17	13:00	30 DAYS	<b>500 GPM AVE</b>	117635500	3666100
.May-17	9:45	31 DAYS	500 GPM AVE	123512400	5876900
Jun-17	11:30	30 DAYS	<b>500 GPM AVE</b>	132022800	8510400
Jul-17	13:00	31 DAYS	<b>500 GPM AVE</b>	143864200	11841400
Aug-17	13:00	31 DAYS	<b>500 GPM AVE</b>	152935300	9071100
Sep-17	13:00	30 DAYS	<b>500 GPM AVE</b>	159801400	6866100
Oct-17	12:00	31 DAYS	500 GPM AVE	163706000	3904600
Nov-17	10:30	30 DAYS	500 GPM AVE	167590400	3884400
Dec-17	12:30	31 DAYS	500 GPM AVE	171572400	3982000
				YEAR END TOTAL	69434700

## **APPENDIX I – CALCULATIONS**

Project Number: Date: CO ZO18	
Scale:	
	Water Demand
Annual Water produced (2017) = 154,699,700	
Average Day Demand (2017) = 154,699,700_ 423,835 gpd )	
423,835 = 294 gpm	
1440 = 274 gpm	
Population 2010 = 1984	
2017 estimate = 1.45% annual growth rate = 2194	
┍┩┍╫╍╫╼╫╼╫╼╫╼╫╼╫╼╫╼╫╼╫╼╫╼╫╼╫╼╫╼╫╼╫╼╫╼╫╼╫╼╫	
Average Day Demand per Capita = 423,835 god = 193 gpc	30
2.94	
Peak Day Demand (maximum Day Demand) = 2.5 times as	ivrage day demand
423,835 x 2.5 = [1059.58]	8 god)
1,059,588 _ 136gpm	
Peak Hour Demand = 6 times average day demand	
423835god x Ce = 2543010 god)	
2543010 = [1746 gpm]	
Projected (2037) Avarage Day Damand	
2037 population estimate = 2926	
= 193apcd x 2926 = 56471	8 gpd
564 118 = (392 ga	
Projected (2037) Peak Day Demand = 564718 x 2.5= 1,411	795 am
1410 = 980 gpm	
	22020
Projected (2037) Peak How Demand = 564118 x 6 = [	5,300,300 (9,00)
3388308 <u>722</u>	53gm)

DOAT	By:Project: East Halana W	16tr mater Dan	
	Project Number: Date: Warch 2018	704	
	Scale:		
		Leakage.	
mcciellan Tar	rks leakage = 43.	844 gallons/day	1
43,844 90	Mons 365 days	= 16003060 gations year	+
	day year	= 16003.060 gallons   year	+
			Ŧ
unaccounted -t	or-water 16 = ( water	water produced waterusc) x100	t
		Nas Procueza	+
water produced	d= 154,699,700 gall	ions/year	Ŧ
metered water	rused = 112,778,000 a	ations/year	1
			1
	1511 60700	00)x100 = [27.1% leaxage]	-
	159677100		1
			I
without tank	100Voca		+
		38696640 gallons/year	+
		+ -   -   -   -   -   -   -   -   -   -	1
	8646640-1127180	00 ) 100 = 118-170 waxage)	1
	138696640		+
Add Non-met	red accounts		+
		4949088 water used gallons/year	1
		1,100 = [9.27 lestage]	+
	154 499 700	)* <del>1911-1913-1</del>	Ŧ
			+
Non metered a	ccounts without to	nt leakage	+
/ 1380	9640-124949,088	)x 100 = 9.97 · Laxage	‡
	138696640		Ŧ
			1
			+
			+
			1
			+
			+
			+
			I
			+
			+
			1

By: Project: Fast Hulena Water Mayter Plan	
Project Number:	
Date: Feb 2018 Scale:	
	(Non-Metered Accounts)
Assumptions: Growing season runs and may through mid-S	
urrigate I water per week	
26 acres of Park land - per Growth Policy lyngation accounts - 0.2 acres each	
lyngation accounts - 0.2 acres each	
CHY Pool is 100,000 gallons and is refilled 2	4 times per Season
City Parks	
26 acres = 1132,560 sq.ft x0.083 ft = 9400 ft 3 x 7.481 = 1	10/37.33 gailons/week
703,233 gallons/week x 16 weeks = [11,251,728 gallons]	
7 40 7 200 S = 1 4 200 S = 52272 S2 F4 80 083 F4 = 4339	C 3
Imagation Accounts 7 x 0.2 acres = 1.4 acres = 52,272 sq.fx x 0.083 ft = 4,339 4,339 ft 3 x 7.481 = 32,460 gallons/week x 16 weeks = [519] 3	(a) actions
CHy Root	
100,000 gallons x 4 = [400,000 gallons)	
Total = 11,251,728 gailons	
519,360 gallons + 400,000 gallons	
112 m 088 galions)	

REA	By: Project: East Helena Water Waster Plan Project Number:	
	Date: Feb 2018	
	Scale: Storage Regurements	
	m storage required = average daily demand plus fire flow	$rac{1}{1}$
Storage current	Hy available = 250 000 gailons	1
	Hy available = 250,000 gallons 300,000 gallons 1,000,000 gallons	Ħ
		Ħ
	1,550,000 gallons	H
Average Day Den	nand 2017 = 423,835 gpd	
Tire Flow requ	ured = 3,500 gpn for 3 hours x 60 min = 210,000 gal perhaur x 3 hours = 630,000 gallons	##
Jocaph	V COMIN 210,000 gas of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the same of the sam	#
Storage requir	ea = 423,835 +630,000 = (1053,835 gallons)	H
J J J L		#
		#
Average Day O	emand 2037 = 564,718gpd	H
		H
siorage requi	red 2037 = 564,718 + 630,000 = (1,194,718 gallons)	11
		17
Storage with r	new trunk of 1,000,000 gallons = 1,000,000 gallons	1
	T 1,000,000 gallons	+
	2,000,000 gallons	#
		1
		Ħ
		$\pm$
		#
		11
		##
		#
		#
		#
		#
		#
		++
		H
		#
		H
		H
		للل



#### **ROBERT PECCIA & ASSOCIATES**

By:		
Project	East Holenawater Muster Pl	S
Project	Number:	
Date:	March 2018	
Caples		

Contact Time Recommended chlorine concentration = 0.5mg1L pipe diameter = 10'=0.83' Length = 1500' Area = 0.83? 17 = 0.54 Ft² Flow = 450 gpm x 0.0022 fr3/sec = 0.99 8.3/sec Valocity = flow = 0.99 fr3/sec = 1.83fr/sec area 0.54 &= 1.83fr/sec time = length
Velocity & Go sec/min +me= 1500 PF = 13.71 minutes Concentration = Contact Time (Ct) 0.5mg/L = _C1_ CT= 6.9 mg/L. min

#### East Helena - McClellan Tank Leakage Testing

Tanks - 10/2	4/17	Tanks and M	lain - 10/25/17					
	Level		Level					
Time	(feet)	Time	(feet)	Tank #1	250,000	gallons	Tank #2	300,000 gallons
10:00 AM	18.22	11:15 AM	18.44	Diameter	40	feet	Diameter	50 feet
12:00 PM	18.06	1:15 PM	18.28	gallons lost	17,110	gallons	gallons lost	26,734 gallons
2:00 PM	17.91	3:15 PM	18.13					
4:00 PM	17.75	5:15 PM	17.97					
8:00 PM	17.45	9:15 AM	16.77	total gallons lost	43,844	gallons		
8:00 AM	16.56	11:15 AM	16.62	over 24 hrs				
10:00 AM	16.40							
	1.82 feet		1.82 feet					

## East Helena - Highway 282 Tank Leakage Testing

Time	Level (feet)
9:00 AM	17
11:00 AM	16.99
1:00 AM	16.99
3:00 AM	16.99
7:00 AM	17.01
9:00 AM	16.99

0.01 feet

## **APPENDIX J – ISO REPORT FOR EAST HELENA**



t 1.800.444.4554 Opt 2 f 1.800.777.3929

July 27, 2015

Mr. Jamie Schell, Mayor E. Helena PO Box 1170 E. Helena, Montana, 59635



RE: E. Helena, Lewis & Clark County, Montana

Public Protection Classification: 05/5X Effective Date: November 01, 2015

Dear Mr. Jamie Schell,

We wish to thank you Mr. Scott St. Clair and Mr. Elroy Golemon for your cooperation during our recent Public Protection Classification (PPC) survey. ISO has completed its analysis of the structural fire suppression delivery system provided in your community. The resulting classification is indicated above.

If you would like to know more about your community's PPC classification, or if you would like to learn about the potential effect of proposed changes to your fire suppression delivery system, please call us at the phone number listed below.

ISO's Public Protection Classification Program (PPC) plays an important role in the underwriting process at insurance companies. In fact, most U.S. insurers – including the largest ones – use PPC information as part of their decision- making when deciding what business to write, coverage's to offer or prices to charge for personal or commercial property insurance.

Each insurance company independently determines the premiums it charges its policyholders. The way an insurer uses ISO's information on public fire protection may depend on several things – the company's fire-loss experience, ratemaking methodology, underwriting guidelines, and its marketing strategy.

Through ongoing research and loss experience analysis, we identified additional differentiation in fire loss experience within our PPC program, which resulted in the revised classifications. We based the differing fire loss experience on the fire suppression capabilities of each community. The new classifications will improve the predictive value for insurers while benefiting both commercial and residential property owners. We've published the new classifications as "X" and "Y" — formerly the "9" and "8B" portion of the split classification, respectively. For example:

- A community currently graded as a split 6/9 classification will now be a split 6/6X classification; with the "6X" denoting what was formerly classified as "9."
- Similarly, a community currently graded as a split 6/8B classification will now be a split 6/6Y classification, the "6Y" denoting what was formerly classified as "8B."
- Communities graded with single "9" or "8B" classifications will remain intact.

PPC is important to communities and fire departments as well. Communities whose PPC improves may get lower insurance prices. PPC also provides fire departments with a valuable benchmark, and is used by many departments as a valuable tool when planning, budgeting and justifying fire protection improvements.

ISO appreciates the high level of cooperation extended by local officials during the entire PPC survey process. The community protection baseline information gathered by ISO is an essential foundation upon which determination of the relative level of fire protection is made using the Fire Suppression Rating Schedule.

The classification is a direct result of the information gathered, and is dependent on the resource levels devoted to fire protection in existence at the time of survey. Material changes in those resources that occur after the survey is completed may affect the classification. Although ISO maintains a pro-active process to keep baseline information as current as possible, in the event of changes please call us at 1-800-444-4554, option 2 to expedite the update activity.

ISO is the leading supplier of data and analytics for the property/casualty insurance industry. Most insurers use PPC classifications for underwriting and calculating premiums for residential, commercial and industrial properties. The PPC program is not intended to analyze all aspects of a comprehensive structural fire suppression delivery system program. It is not for purposes of determining compliance with any state or local law, nor is it for making loss prevention or life safety recommendations.

If you have any questions about your classification, please let us know.

Sincerely,

## Dominic Santanna

Dominic Santanna Manager -National Processing Center

cc:

Mr. Scott St. Clair, Water Superintendent, E. Helena Water Department

Mr. Elroy Golemon, Chief, East Helena Fire Department Mr. Peter Callahan, Manager, City of Helena 911 Center

## **Public Protection Classification**

(PPCTM)

**Summary Report** 

RECEIVED
SEP 3 1 2016
MELENA WIT

E. Helena

MONTANA

Prepared by

Insurance Services Office, Inc. 4B Eves Drive, Suite 200 P.O. Box 961 Marlton, New Jersey 08053-3112 (856) 985-5600

July 2015

### **Background Information**

#### Introduction

ISO collects and evaluates information from communities in the United States on their structure fire suppression capabilities. The data is analyzed using our Fire Suppression Rating Schedule (FSRS) and then a Public Protection Classification (PPC™) grade is assigned to the community. The surveys are conducted whenever it appears that there is a possibility of a PPC change. As such, the PPC program provides important, up-to-date information about fire protection services throughout the country.

The FSRS recognizes fire protection features only as they relate to suppression of first alarm structure fires. In many communities, fire suppression may be only a small part of the fire department's overall responsibility. ISO recognizes the dynamic and comprehensive duties of a community's fire service, and understands the complex decisions a community must make in planning and delivering emergency services. However, in developing a community's PPC grade, only features related to reducing property losses from structural fires are evaluated. Multiple alarms, simultaneous incidents and life safety are not considered in this evaluation. The PPC program evaluates the fire protection for small to average size buildings. Specific properties with a Needed Fire Flow in excess of 3,500 gpm are evaluated separately and assigned an individual PPC grade.

A community's investment in fire mitigation is a proven and reliable predictor of future fire losses. Statistical data on insurance losses bears out the relationship between excellent fire protection — as measured by the PPC program — and low fire losses. So, insurance companies use PPC information for marketing, underwriting, and to help establish fair premiums for homeowners and commercial fire insurance. In general, the price of fire insurance in a community with a good PPC grade is substantially lower than in a community with a poor PPC grade, assuming all other factors are equal.

ISO is an independent company that serves insurance companies, communities, fire departments, insurance regulators, and others by providing information about risk. ISO's expert staff collects information about municipal fire suppression efforts in communities throughout the United States. In each of those communities, ISO analyzes the relevant data and assigns a PPC grade — a number from 1 to 10. Class 1 represents an exemplary fire suppression program, and Class 10 indicates that the area's fire suppression program does not meet ISO's minimum criteria.

ISO's PPC program evaluates communities according to a uniform set of criteria, incorporating nationally recognized standards developed by the National Fire Protection Association and the American Water Works Association. A community's PPC grade depends on:

- Needed Fire Flows, which are representative building locations used to determine the theoretical amount of water necessary for fire suppression purposes.
- > Emergency Communications, including emergency reporting, telecommunicators, and dispatching systems.
- Fire Department, including equipment, staffing, training, geographic distribution of fire companies, operational considerations, and community risk reduction.
- ➤ Water Supply, including inspection and flow testing of hydrants, alternative water supply operations, and a careful evaluation of the amount of available water compared with the amount needed to suppress fires up to 3,500 gpm.

## **Data Collection and Analysis**

ISO has evaluated and classified over 48,000 fire protection areas across the United States using its FSRS. A combination of meetings between trained ISO field representatives and the dispatch center coordinator, community fire official, and water superintendent is used in conjunction with a comprehensive questionnaire to collect the data necessary to determine the PPC grade. In order for a community to obtain a grade better than a Class 9, three elements of fire suppression features are reviewed. These three elements are Emergency Communications, Fire Department, and Water Supply.

A review of the **Emergency Communications** accounts for 10% of the total classification. This section is weighted at **10 points**, as follows:

6	Emergency Reporting	3 points
•	Telecommunicators	4 points
•	Dispatch Circuits	3 points

A review of the **Fire Department** accounts for 50% of the total classification. ISO focuses on a fire department's first alarm response and initial attack to minimize potential loss. The fire department section is weighted at **50 points**, as follows:

		-, 40 10110110.
•	Engine Companies	6 points
•	Reserve Pumpers	0.5 points
•	Pump Capacity	3 points
•	Ladder/Service Companies	4 points
•	Reserve Ladder/Service Trucks	0.5 points
•	Deployment Analysis	10 points
•	Company Personnel	15 points
•	Training	9 points
•	Operational considerations	2 points
•	Community Risk Reduction	5.5 points (in addition to the 50 points above

A review of the **Water Supply** system accounts for 40% of the total classification. ISO reviews the water supply a community uses to determine the adequacy for fire suppression purposes. The water supply system is weighted at **40 points**, as follows:

•	Credit for Supply System	30 points	
•	Hydrant Size, Type & Installation	3 points	
•	Inspection & Flow Testing of Hydrants	7 points	

There is one additional factor considered in calculating the final score - Divergence.

Even the best fire department will be less than fully effective if it has an inadequate water supply. Similarly, even a superior water supply will be less than fully effective if the fire department lacks the equipment or personnel to use the water. The FSRS score is subject to modification by a divergence factor, which recognizes disparity between the effectiveness of the fire department and the water supply.

The Divergence factor mathematically reduces the score based upon the relative difference between the fire department and water supply scores. The factor is introduced in the final equation.

#### **PPC Grade**

The PPC grade assigned to the community will depend on the community's score on a 100-point scale:

PPC	Points
1	90.00 or more
2	80.00 to 89.99
3	70.00 to 79.99
4	60.00 to 69.99
5	50.00 to 59.99
6	40.00 to 49.99
7	30.00 to 39.99
8	20.00 to 29.99
9	10.00 to 19.99
10	0.00 to 9.99

The classification numbers are interpreted as follows:

- Class 1 through (and including) Class 8 represents a fire suppression system that includes an FSRS creditable dispatch center, fire department, and water supply.
- Class 8B is a special classification that recognizes a superior level of fire
  protection in otherwise Class 9 areas. It is designed to represent a fire protection
  delivery system that is superior except for a lack of a water supply system
  capable of the minimum FSRS fire flow criteria of 250 gpm for 2 hours.
- Class 9 is a fire suppression system that includes a creditable dispatch center, fire department but no FSRS creditable water supply.
- Class 10 does not meet minimum FSRS criteria for recognition, including areas that are beyond five road miles of a recognized fire station.

# New PPC program changes effective July 1, 2014

We have revised the PPC program to capture the effects of enhanced fire protection capabilities that reduce fire loss and fire severity in Split Class 9 and Split Class 8B areas (as outlined below). This new structure benefits the fire service, community, and property owner.

#### **New classifications**

Through ongoing research and loss experience analysis, we identified additional differentiation in fire loss experience within our PPC program, which resulted in the revised classifications. We based the differing fire loss experience on the fire suppression capabilities of each community. The new PPC classes will improve the predictive value for insurers while benefiting both commercial and residential property owners. Here are the new classifications and what they mean.

#### Split classifications

When we develop a split classification for a community — for example 5/9 — the first number is the class that applies to properties within 5 road miles of the responding fire station and 1,000 feet of a creditable water supply, such as a fire hydrant, suction point, or dry hydrant. The second number is the class that applies to properties within 5 road miles of a fire station but beyond 1,000 feet of a creditable water supply. We have revised the classification to reflect more precisely the risk of loss in a community, replacing Class 9 and 8B in the second part of a split classification with revised designations.

## What's changed with the new classifications?

We've published the new classifications as "X" and "Y" — formerly the "9" and "8B" portion of the split classification, respectively. For example:

- A community currently displayed as a split 6/9 classification will now be a split 6/6X classification; with the "6X" denoting what was formerly classified as "9".
- Similarly, a community currently graded as a split 6/8B classification will now be a split 6/6Y classification, the "6Y" denoting what was formerly classified as "8B".
- Communities graded with single "9" or "8B" classifications will remain intact.

Prior Classification	New Classification
1/9	1/1X
2/9	2/2X
3/9	3/3X
4/9	4/4X
5/9	5/5X
6/9	6/6X
7/9	7/7X
8/9	8/8X
9	9

Prior Classification	New Classification
1/88	1/17
2/88	2/29
3/88	· 3/3Y
4/8B	4/49
5/8B	5/5Y
6/8B	6/6Y
7/8B	7/74
8/8B	8/89
8B	88

#### What's changed?

As you can see, we're still maintaining split classes, but it's how we represent them to insurers that's changed. The new designations reflect a reduction in fire severity and loss and have the potential to reduce property insurance premiums.

#### Benefits of the revised split class designations

- To the fire service, the revised designations identify enhanced fire suppression capabilities used throughout the fire protection area
- To the community, the new classes reward a community's fire suppression efforts by showing a more reflective designation
- To the individual property owner, the revisions offer the potential for decreased property insurance premiums

#### New water class

Our data also shows that risks located more than 5 but less than 7 road miles from a responding fire station with a creditable water source within 1,000 feet had better loss experience than those farther than 5 road miles from a responding fire station with no creditable water source. We've introduced a new classification —10W — to recognize the reduced loss potential of such properties.

#### What's changed with Class 10W?

Class 10W is property-specific. Not all properties in the 5-to-7-mile area around the responding fire station will qualify. The difference between Class 10 and 10W is that the 10W-graded risk or property is within 1,000 feet of a creditable water supply. Creditable water supplies include fire protection systems using hauled water in any of the split classification areas.

#### What's the benefit of Class 10W?

10W gives credit to risks within 5 to 7 road miles of the responding fire station and within 1,000 feet of a creditable water supply. That's reflective of the potential for reduced property insurance premiums.

#### What does the fire chief have to do?

Fire chiefs don't have to do anything at all. The revised classifications went in place automatically effective July 1, 2014 (July 1, 2015 for Texas).


#### What if I have additional questions?

Feel free to contact ISO at 800.444.4554 or email us at PPC-Cust-Serv@iso.com.

#### **Distribution of PPC Grades**

The 2015 published countrywide distribution of communities by the PPC grade is as follows:

#### Countrywide



#### **Assistance**

The PPC program offers help to communities, fire departments, and other public officials as they plan for, budget, and justify improvements. ISO is also available to assist in the understanding of the details of this evaluation.

The PPC program representatives can be reached by telephone at (800) 444-4554. The technical specialists at this telephone number have access to the details of this evaluation and can effectively speak with you about your questions regarding the PPC program. What's more, we can be reached via the internet at <a href="https://www.isomitigation.com/talk/">www.isomitigation.com/talk/</a>.

We also have a website dedicated to our Community Hazard Mitigation Classification programs at <a href="www.isomitigation.com">www.isomitigation.com</a>. Here, fire chiefs, building code officials, community leaders and other interested citizens can access a wealth of data describing the criteria used in evaluating how cities and towns are protecting residents from fire and other natural hazards. This website will allow you to learn more about the PPC program. The website provides important background information, insights about the PPC grading processes and technical documents. ISO is also pleased to offer Fire Chiefs Online — a special, secured website with information and features that can help improve your PPC grade, including a list of the Needed Fire Flows for all the commercial occupancies ISO has on file for your community. Visitors to the site can download information, see statistical results and also contact ISO for assistance.

In addition, on-line access to the FSRS and its commentaries is available to registered customers for a fee. However, fire chiefs and community chief administrative officials are given access privileges to this information without charge.

To become a registered fire chief or community chief administrative official, register at <a href="https://www.isomitigation.com">www.isomitigation.com</a>.

#### **PPC Review**

ISO concluded its review of the fire suppression features being provided for E. Helena. The resulting community classification is **Class 05/5X**.

If the classification is a single class, the classification applies to properties with a Needed Fire Flow of 3,500 gpm or less in the community. If the classification is a split class (e.g., 6/XX):

- The first class (e.g., "6" in a 6/XX) applies to properties within 5 road miles of a recognized fire station and within 1,000 feet of a fire hydrant or alternate water supply.
- The second class (XX or XY) applies to properties beyond 1,000 feet of a fire hydrant but within 5 road miles of a recognized fire station.
- Alternative Water Supply: The first class (e.g., "6" in a 6/10) applies to properties within 5 road miles of a recognized fire station with no hydrant distance requirement.
- Class 10 applies to properties over 5 road miles of a recognized fire station.
- Class 10W applies to properties within 5 to 7 road miles of a recognized fire station with a recognized water supply within 1,000 feet.
- > Specific properties with a Needed Fire Flow in excess of 3,500 gpm are evaluated separately and assigned an individual classification.

FSRS Feature	Earned Credit	Credit Available
Emergency Communications		
414. Credit for Emergency Reporting	2.40	3
422. Credit for Telecommunicators	3.20	4
432. Credit for Dispatch Circuits	2.85	3
440. Credit for Emergency Communications	8.45	10
Fire Department		
513. Credit for Engine Companies	0.70	6
523. Credit for Reserve Pumpers	0.00	0.50
532. Credit for Pump Capacity	0.94	3
549. Credit for Ladder Service	3.33	4
553. Credit for Reserve Ladder and Service Trucks	0.00	0.50
561. Credit for Deployment Analysis	6.11	10
571. Credit for Company Personnel	2.22	15
581. Credit for Training	2.48	9
730. Credit for Operational Considerations	2.00	2
590. Credit for Fire Department	17.78	50
Water Supply		
616. Credit for Supply System	25.71	30
621. Credit for Hydrants	2.80	3 7
631. Credit for Inspection and Flow Testing	4.80	7
640. Credit for Water Supply	33.31	40
Divergence	-9.54	
1050. Community Risk Reduction	2.53	5.50
Total Credit	52.53	105.50

#### **Emergency Communications**

Ten percent of a community's overall score is based on how well the communications center receives and dispatches fire alarms. Our field representative evaluated:

- · Communications facilities provided for the general public to report structure fires
- Enhanced 9-1-1 Telephone Service including wireless
- · Computer-aided dispatch (CAD) facilities
- · Alarm receipt and processing at the communication center
- Training and certification of telecommunicators
- · Facilities used to dispatch fire department companies to reported structure fires

	Earned Credit	Credit Available
414. Credit Emergency Reporting	2.40	3
422. Credit for Telecommunicators	3.20	4
432. Credit for Dispatch Circuits	2.85	3
Item 440. Credit for Emergency Communications:	8.45	10

#### Item 414 - Credit for Emergency Reporting (3 points)

The first item reviewed is Item 414 "Credit for Emergency Reporting (CER)". This item reviews the emergency communication center facilities provided for the public to report fires including 911 systems (Basic or Enhanced), Wireless Phase I and Phase II, Voice over Internet Protocol, Computer Aided Dispatch and Geographic Information Systems for automatic vehicle location. ISO uses National Fire Protection Association (NFPA) 1221, Standard for the Installation, Maintenance and Use of Emergency Services Communications Systems as the reference for this section.

Earned Credit	Credit Available
20.00	20
Line parties and the second	
25.00	25
10.00	25
10.00	15
15.00	15
80.00	100
	20.00 25.00 10.00

#### Item 422- Credit for Telecommunicators (4 points)

The second item reviewed is Item 422 "Credit for Telecommunicators (TC)". This item reviews the number of Telecommunicators on duty at the center to handle fire calls and other emergencies. All emergency calls including those calls that do not require fire department action are reviewed to determine the proper staffing to answer emergency calls and dispatch the appropriate emergency response. NFPA 1221, Standard for the Installation, Maintenance and Use of Emergency Services Communications Systems, recommends that ninety-five percent of emergency calls shall be answered within 15 seconds and ninety-nine percent of emergency calls shall be answered within 40 seconds. In addition, NFPA recommends that ninety percent of emergency alarm processing shall be completed within 60 seconds and ninety-nine percent of alarm processing shall be completed within 90 seconds of answering the call.

To receive full credit for operators on duty, ISO must review documentation to show that the communication center meets NFPA 1221 call answering and dispatch time performance measurement standards. This documentation may be in the form of performance statistics or other performance measurements compiled by the 9-1-1 software or other software programs that are currently in use such as Computer Aided Dispatch (CAD) or Management Information System (MIS).

Item 420. Telecommunicators (CTC)	Earned Credit	Credit Available
A1. Alarm Receipt (AR)	20.00	20
Receipt of alarms shall meet the requirements in accordance with the criteria of NFPA 1221		
A2. Alarm Processing (AP)	20.00	20
Processing of alarms shall meet the requirements in accordance with the criteria of NFPA 1221		
B. Emergency Dispatch Protocols (EDP)	10.00	20
Telecommunicators have emergency dispatch protocols (EDP) containing questions and a decision-support process to facilitate correct call categorization and prioritization.		
C. Telecommunicator Training and Certification (TTC)	20.00	20
Telecommunicators meet the qualification requirements referenced in NFPA 1061, Standard for Professional Qualifications for Public Safety Telecommunicator, and/or the Association of Public-Safety Communications Officials - International (APCO) Project 33.  Telecommunicators are certified in the knowledge, skills, and abilities corresponding to their job functions.		
D. Telecommunicator Continuing Education and Quality Assurance (TQA)	10.00	20
Telecommunicators participate in continuing education and/or in-service training and quality-assurance programs as appropriate for their positions		
Review of Telecommunicators total:	80.00	100

#### Item 432 - Credit for Dispatch Circuits (3 points)

The third item reviewed is Item 432 "Credit for Dispatch Circuits (CDC)". This item reviews the dispatch circuit facilities used to transmit alarms to fire department members. A "Dispatch Circuit" is defined in NFPA 1221 as "A circuit over which an alarm is transmitted from the communications center to an emergency response facility (ERF) or emergency response units (ERUs) to notify ERUs to respond to an emergency". All fire departments (except single fire station departments with full-time firefighter personnel receiving alarms directly at the fire station) need adequate means of notifying all firefighter personnel of the location of reported structure fires. The dispatch circuit facilities should be in accordance with the general criteria of NFPA 1221. "Alarms" are defined in this Standard as "A signal or message from a person or device indicating the existence of an emergency or other situation that requires action by an emergency response agency".

There are two different levels of dispatch circuit facilities provided for in the Standard – a primary dispatch circuit and a secondary dispatch circuit. In jurisdictions that receive 730 alarms or more per year (average of two alarms per 24-hour period), two separate and dedicated dispatch circuits, a primary and a secondary, are needed. In jurisdictions receiving fewer than 730 alarms per year, a second dedicated dispatch circuit is not needed. Dispatch circuit facilities installed but not used or tested (in accordance with the NFPA Standard) receive no credit.

The score for Credit for Dispatch Circuits (CDC) is influenced by monitoring for integrity of the primary dispatch circuit. There are up to 0.90 points available for this Item. Monitoring for integrity involves installing automatic systems that will detect faults and failures and send visual and audible indications to appropriate communications center (or dispatch center) personnel. ISO uses NFPA 1221 to guide the evaluation of this item. ISO's evaluation also includes a review of the communication system's emergency power supplies.

Item 432 "Credit for Dispatch Circuits (CDC)" = 2.85 points

#### Fire Department

Fifty percent of a community's overall score is based upon the fire department's structure fire suppression system. ISO's field representative evaluated:

- · Engine and ladder/service vehicles including reserve apparatus
- · Equipment carried
- Response to reported structure fires
- Deployment analysis of companies
- · Available and/or responding firefighters
- Training

	Earned Credit	Credit Available
513. Credit for Engine Companies	0.70	6
523. Credit for Reserve Pumpers	0.00	0.5
532. Credit for Pumper Capacity	0.94	3
549. Credit for Ladder Service	3.33	4
553. Credit for Reserve Ladder and Service Trucks	0.00	0.5
561. Credit for Deployment Analysis	6.11	10
571. Credit for Company Personnel	2.22	15
581. Credit for Training	2.48	9
730. Credit for Operational Considerations	2.00	2
Item 590. Credit for Fire Department:	17.78	50

#### **Basic Fire Flow**

The Basic Fire Flow for the community is determined by the review of the Needed Fire Flows for selected buildings in the community. The fifth largest Needed Fire Flow is determined to be the Basic Fire Flow. The Basic Fire Flow has been determined to be 2000 gpm.

#### Item 513 - Credit for Engine Companies (6 points)

The first item reviewed is Item 513 "Credit for Engine Companies (CEC)". This item reviews the number of engine companies, their pump capacity, hose testing, pump testing and the equipment carried on the in-service pumpers. To be recognized, pumper apparatus must meet the general criteria of NFPA 1901, *Standard for Automotive Fire Apparatus* which include a minimum 250 gpm pump, an emergency warning system, a 300 gallon water tank, and hose. At least 1 apparatus must have a permanently mounted pump rated at 750 gpm or more at 150 psi.

The review of the number of needed pumpers considers the response distance to built-upon areas; the Basic Fire Flow; and the method of operation. Multiple alarms, simultaneous incidents, and life safety are not considered.

The greatest value of A, B, or C below is needed in the fire district to suppress fires in structures with a Needed Fire Flow of 3,500 gpm or less: **2 engine companies** 

- a) 1 engine companies to provide fire suppression services to areas to meet NFPA 1710 criteria or within 1½ miles.
- b) 2 engine companies to support a Basic Fire Flow of 2000 gpm.
- c) **2 engine companies** based upon the fire department's method of operation to provide a minimum two engine response to all first alarm structure fires.

The FSRS recognizes that there are 1 engine companies in service.

The FSRS also reviews Automatic Aid. Automatic Aid is considered in the review as assistance dispatched automatically by contractual agreement between two communities or fire districts. That differs from mutual aid or assistance arranged case by case. ISO will recognize an Automatic Aid plan under the following conditions:

- It must be prearranged for first alarm response according to a definite plan. It is preferable to have a written agreement, but ISO may recognize demonstrated performance.
- The aid must be dispatched to all reported structure fires on the initial alarm.
- The aid must be provided 24 hours a day, 365 days a year.

FSRS Item 512.D "Automatic Aid Engine Companies" responding on first alarm and meeting the needs of the city for basic fire flow and/or distribution of companies are factored based upon the value of the Automatic Aid plan (up to 1.00 can be used as the factor). The Automatic Aid factor is determined by a review of the Automatic Aid provider's communication facilities, how they receive alarms from the graded area, inter-department training between fire departments, and the fire ground communications capability between departments.

For each engine company, the credited Pump Capacity (PC), the Hose Carried (HC), the Equipment Carried (EC) all contribute to the calculation for the percent of credit the FSRS provides to that engine company.

Item 513 "Credit for Engine Companies (CEC)" = 0.70 points

#### Item 523 - Credit for Reserve Pumpers (0.50 points)

The item is Item 523 "Credit for Reserve Pumpers (CRP)". This item reviews the number and adequacy of the pumpers and their equipment. The number of needed reserve pumpers is 1 for each 8 needed engine companies determined in Item 513, or any fraction thereof.

Item 523 "Credit for Reserve Pumpers (CRP)" = 0.00 points

#### Item 532 - Credit for Pumper Capacity (3 points)

The next item reviewed is Item 532 "Credit for Pumper Capacity (CPC)". The total pump capacity available should be sufficient for the Basic Fire Flow of 2000 gpm. The maximum needed pump capacity credited is the Basic Fire Flow of the community.

Item 532 "Credit for Pumper Capacity (CPC)" = 0.94 points

#### Item 549 - Credit for Ladder Service (4 points)

The next item reviewed is Item 549 "Credit for Ladder Service (CLS)". This item reviews the number of response areas within the city with 5 buildings that are 3 or more stories or 35 feet or more in height, or with 5 buildings that have a Needed Fire Flow greater than 3,500 gpm, or any combination of these criteria. The height of all buildings in the city, including those protected by automatic sprinklers, is considered when determining the number of needed ladder companies. Response areas not needing a ladder company should have a service company. Ladders, tools and equipment normally carried on ladder trucks are needed not only for ladder operations but also for forcible entry, ventilation, salvage, overhaul, lighting and utility control.

The number of ladder or service companies, the height of the aerial ladder, aerial ladder testing and the equipment carried on the in-service ladder trucks and service trucks is compared with the number of needed ladder trucks and service trucks and an FSRS equipment list. Ladder trucks must meet the general criteria of NFPA 1901, Standard for Automotive Fire Apparatus to be recognized.

The number of needed ladder-service trucks is dependent upon the number of buildings 3 stories or 35 feet or more in height, buildings with a Needed Fire Flow greater than 3,500 gpm, and the method of operation.

The FSRS recognizes that there are **0 ladder companies** in service. These companies are needed to provide fire suppression services to areas to meet NFPA 1710 criteria or within 2½ miles and the number of buildings with a Needed Fire Flow over 3,500 gpm or 3 stories or more in height, or the method of operation.

The FSRS recognizes that there are 1 service companies in service.

Item 549 "Credit for Ladder Service (CLS)" = 3.33 points

#### Item 553 - Credit for Reserve Ladder and Service Trucks (0.50 points)

The next item reviewed is Item 553 "Credit for Reserve Ladder and Service Trucks (CRLS)". This item considers the adequacy of ladder and service apparatus when one (or more in larger communities) of these apparatus are out of service. The number of needed reserve ladder and service trucks is 1 for each 8 needed ladder and service companies that were determined to be needed in Item 540, or any fraction thereof.

Item 553 "Credit for Reserve Ladder and Service Trucks (CRLS)" = 0.00 points

#### Item 561 - Deployment Analysis (10 points)

Next, Item 561 "Deployment Analysis (DA)" is reviewed. This Item examines the number and adequacy of existing engine and ladder-service companies to cover built-upon areas of the city.

To determine the Credit for Distribution, first the Existing Engine Company (EC) points and the Existing Engine Companies (EE) determined in Item 513 are considered along with Ladder Company Equipment (LCE) points, Service Company Equipment (SCE) points, Engine-Ladder Company Equipment (ELCE) points, and Engine-Service Company Equipment (ESCE) points determined in Item 549.

Secondly, as an alternative to determining the number of needed engine and ladder/service companies through the road-mile analysis, a fire protection area may use the results of a systematic performance evaluation. This type of evaluation analyzes computer-aided dispatch (CAD) history to demonstrate that, with its current deployment of companies, the fire department meets the time constraints for initial arriving engine and initial full alarm assignment in accordance with the general criteria of in NFPA 1710, Standard for the Organization and Deployment of Fire Suppression Operations, Emergency Medical Operations, and Special Operations to the Public by Career Fire Departments.

A determination is made of the percentage of built upon area within 1½ miles of a first-due engine company and within 21/2 miles of a first-due ladder-service company.

Item 561 "Credit Deployment Analysis (DA)" = 6.11 points

#### Item 571 - Credit for Company Personnel (15 points)

Item 571 "Credit for Company Personnel (CCP)" reviews the average number of existing firefighters and company officers available to respond to reported first alarm structure fires in the city.

The on-duty strength is determined by the yearly average of total firefighters and company officers on-duty considering vacations, sick leave, holidays, "Kelley" days and other absences. When a fire department operates under a minimum staffing policy, this may be used in lieu of determining the yearly average of on-duty company personnel.

Firefighters on apparatus not credited under Items 513 and 549 that regularly respond to reported first alarms to aid engine, ladder, and service companies are included in this item as increasing the total company strength.

Firefighters staffing ambulances or other units serving the general public are credited if they participate in fire-fighting operations, the number depending upon the extent to which they are available and are used for response to first alarms of fire.

On-Call members are credited on the basis of the average number staffing apparatus on first alarms. Off-shift career firefighters and company officers responding on first alarms are considered on the same basis as on-call personnel. For personnel not normally at the fire station, the number of responding firefighters and company officers is divided by 3 to reflect the time needed to assemble at the fire scene and the reduced ability to act as a team due to the various arrival times at the fire location when compared to the personnel on-duty at the fire station during the receipt of an alarm.

The number of Public Safety Officers who are positioned in emergency vehicles within the jurisdiction boundaries may be credited based on availability to respond to first alarm structure fires. In recognition of this increased response capability the number of responding Public Safety Officers is divided by 2.

The average number of firefighters and company officers responding with those companies credited as Automatic Aid under Items 513 and 549 are considered for either on-duty or on-call company personnel as is appropriate. The actual number is calculated as the average number of company personnel responding multiplied by the value of AA Plan determined in Item 512.D.

The maximum creditable response of on-duty and on-call firefighters is 12, including company officers, for each existing engine and ladder company and 6 for each existing service company.

Chief Officers are not creditable except when more than one chief officer responds to alarms; then extra chief officers may be credited as firefighters if they perform company duties.

The FSRS recognizes **0.00 on-duty personnel** and an average of **4.00 on-call personnel** responding on first alarm structure fires.

Item 571 "Credit for Company Personnel (CCP)" = 2.22 points

# Item 581 - Credit for Training (9 points)

Train	ing	Earned Credit	Credit Available
	A. Facilities, and Use  For maximum credit, each firefighter should receive 18 hours per month in structure fire related subjects as outlined in NFPA 1001.	13.68	35
	B. Company Training  For maximum credit, each firefighter should receive 16 hours per month in structure fire related subjects as outlined in NFPA 1001.	4.16	25
	C. Classes for Officers  For maximum credit, each officer should be certified in accordance with the general criteria of NFPA 1021. Additionally, each officer should receive 12 hours of continuing education on or off site.	7.20	12
	D. New Driver and Operator Training  For maximum credit, each new driver and operator should receive 60 hours of driver/operator training per year in accordance with NFPA 1002 and NFPA 1451.	2.08	5
	E. Existing Driver and Operator Training  For maximum credit, each existing driver and operator should receive 12 hours of driver/operator training per year in accordance with NFPA 1002 and NFPA 1451.	0.00	5
	F. Training on Hazardous Materials  For maximum credit, each firefighter should receive 6 hours of training for incidents involving hazardous materials in accordance with NFPA 472.	0.00	1
	G. Recruit Training  For maximum credit, each firefighter should receive 240 hours of structure fire related training in accordance with NFPA 1001 within the first year of employment or tenure.	0.42	5
	H. Pre-Fire Planning Inspections For maximum credit, pre-fire planning inspections of each commercial, industrial, institutional, and other similar type building (all buildings except 1-4 family dwellings) should be made annually by company members. Records of inspections should include up-to date notes and sketches.	0.00	12

Item 580 "Credit for Training (CT)" = 2.48 points

#### Item 730 - Operational Considerations (2 points)

Item 730 "Credit for Operational Considerations (COC)" evaluates fire department standard operating procedures and incident management systems for emergency operations involving structure fires.

Operational Considerations	Earned Credit	Credit Available
Standard Operating Procedures	50	50
The department should have established SOPs for fire department general emergency operations		
Incident Management Systems	50	50
The department should use an established incident management system (IMS)		
Operational Considerations total:	100	100

Item 730 "Credit for Operational Considerations (COC)" = 2.00 points

# Water Supply

Forty percent of a community's overall score is based on the adequacy of the water supply system. The ISO field representative evaluated:

- the capability of the water distribution system to meet the Needed Fire Flows at selected locations up to 3,500 gpm.
- size, type and installation of fire hydrants.
- · inspection and flow testing of fire hydrants.

	Earned Credit	Credit Available
616. Credit for Supply System	25.71	30
621. Credit for Hydrants	2.80	3
631. Credit for Inspection and Flow Testing	4.80	7
Item 640. Credit for Water Supply:	33.31	40

#### Item 616 - Credit for Supply System (30 points)

The first item reviewed is Item 616 "Credit for Supply System (CSS)". This item reviews the rate of flow that can be credited at each of the Needed Fire Flow test locations considering the supply works capacity, the main capacity and the hydrant distribution. The lowest flow rate of these items is credited for each representative location. A water system capable of delivering 250 gpm or more for a period of two hours plus consumption at the maximum daily rate at the fire location is considered minimum in the ISO review.

Where there are 2 or more systems or services distributing water at the same location, credit is given on the basis of the joint protection provided by all systems and services available.

The supply works capacity is calculated for each representative Needed Fire Flow test location, considering a variety of water supply sources. These include public water supplies, emergency supplies (usually accessed from neighboring water systems), suction supplies (usually evidenced by dry hydrant installations near a river, lake or other body of water), and supplies developed by a fire department using large diameter hose or vehicles to shuttle water from a source of supply to a fire site. The result is expressed in gallons per minute (gpm).

The normal ability of the distribution system to deliver Needed Fire Flows at the selected building locations is reviewed. The results of a flow test at a representative test location will indicate the ability of the water mains (or fire department in the case of fire department supplies) to carry water to that location.

The hydrant distribution is reviewed within 1,000 feet of representative test locations measured as hose can be laid by apparatus.

For maximum credit, the Needed Fire Flows should be available at each location in the district. Needed Fire Flows of 2,500 gpm or less should be available for 2 hours; and Needed Fire Flows of 3,000 and 3,500 gpm should be obtainable for 3 hours.

Item 616 "Credit for Supply System (CSS)" = 25.71 points

#### Item 621 - Credit for Hydrants (3 points)

The second item reviewed is Item 621 "Credit for Hydrants (CH)". This item reviews the number of fire hydrants of each type compared with the total number of hydrants.

There are a total of 102 hydrants in the graded area.

520. Hydrants, - Size, Type and Installation	Number of Hydrants
A. With a 6 -inch or larger branch and a pumper outlet with or without 2½ - inch outlets	
B. With a 6 -inch or larger branch and no pumper outlet but two or more 2½ -inch outlets, or with a small foot valve, or with a small barrel	6
C./D. With only a 2½ -inch outlet or with less than a 6 -inch branch	7
E./F. Flush Type, Cistern, or Suction Point	0

#### Item 621 "Credit for Hydrants (CH)" = 2.80 points

#### Item 630 - Credit for Inspection and Flow Testing (7 points)

The third item reviewed is Item 630 "Credit for Inspection and Flow Testing (CIT)". This item reviews the fire hydrant inspection frequency, and the completeness of the inspections. Inspection of hydrants should be in accordance with AWWA M-17, Installation, Field Testing and Maintenance of Fire Hydrants.

Frequency of Inspection (FI): Average interval between the 3 most recent inspections.

Frequency	Points
1 year	30
2 years	20
3 years	10
4 years	5
5 years or more	No Credit

**Note**: The points for inspection frequency are reduced by 10 points if the inspections are incomplete or do not include a flushing program. An additional reduction of 10 points are made if hydrants are not subjected to full system pressure during inspections. If the inspection of cisterns or suction points does not include actual drafting with a pumper, or back-flushing for dry hydrants, 20 points are deducted.

Total points for Inspections = 2.40 points

**Frequency of Fire Flow Testing (FF):** Average interval between the 3 most recent inspections.

Frequency	Points
5 years	40
6 years	30
7 years	20
8 years	10
9 years	5
10 years or more	No Credit

Total points for Fire Flow Testing = 2.40 points

Item 631 "Credit for Inspection and Fire Flow Testing (CIT)" = 4.80 points

#### Divergence = -9.54

The Divergence factor mathematically reduces the score based upon the relative difference between the fire department and water supply scores. The factor is introduced in the final equation.

### Community Risk Reduction

	Earned Credit	Credit Available
1025. Credit for Fire Prevention and Code Enforcement (CPCE)	0.41	2.2
1033. Credit for Public Fire Safety Education (CFSE)	1.18	2.2
1044. Credit for Fire Investigation Programs (CIP)	0.94	1.1
Item 1050. Credit for Community Risk Reduction	2.53	5.50

Item 1025 – Credit for Fire Prevention Code Adoption and Enforcement (2.2 points)	Earned Credit	Credit Available
Fire Prevention Code Regulations (PCR)  Evaluation of fire prevention code regulations in effect.	1.06	10
Fire Prevention Staffing (PS)  Evaluation of staffing for fire prevention activities.	0.62	8
Fire Prevention Certification and Training (PCT)  Evaluation of the certification and training of fire prevention code enforcement personnel.	0.00	6
Fire Prevention Programs (PCP) Evaluation of fire prevention programs.	5.80	16
Review of Fire Prevention Code and Enforcement (CPCE) subtotal:	7.48	40

Item 1033 – Credit for Public Fire Safety Education (2.2 points)	Earned Credit	Credit Available
Public Fire Safety Educators Qualifications and Training (FSQT)  Evaluation of public fire safety education personnel training and qualification as specified by the authority having jurisdiction.	3.33	10
Public Fire Safety Education Programs (FSP) Evaluation of programs for public fire safety education.	18.11	30
Review of Public Safety Education Programs (CFSE) subtotal:	21.44	40

Item 1044 – Credit for Fire Investigation Programs (1.1 points)	Earned Credit	Credit Available
Fire Investigation Organization and Staffing (IOS)  Evaluation of organization and staffing for fire investigations.	8.00	8
Fire Investigator Certification and Training (IQT) Evaluation of fire investigator certification and training.	3.00	6
Use of National Fire Incident Reporting System (IRS)  Evaluation of the use of the National Fire Incident Reporting  System (NFIRS) for the 3 years before the evaluation.	6.00	6
Review of Fire Prevention Code and Enforcement (CPCE) subtotal:	17.00	20

### Summary of PPC Review




# E. Helena

FSRS Item	Earned Credit	Credit Available
Emergency Communications		
414. Credit for Emergency Reporting	2.40	3
422. Credit for Telecommunicators	3.20	4
432. Credit for Dispatch Circuits	2.85	3
440. Credit for Emergency Communications	8.45	10
Fire Department		
513. Credit for Engine Companies	0.70	6
523. Credit for Reserve Pumpers	0.00	0.5
532. Credit for Pumper Capacity	0.94	3
549. Credit for Ladder Service	3.33	4
553. Credit for Reserve Ladder and Service Trucks	0.00	0.5
561. Credit for Deployment Analysis	6.11	10
571. Credit for Company Personnel	2.22	15
581. Credit for Training	2.48	9
730. Credit for Operational Considerations	2.00	2
590. Credit for Fire Department	17.78	50
Water Supply		
616. Credit for Supply System	25.71	30
621. Credit for Hydrants	2.80	3
631. Credit for Inspection and Flow Testing	4.80	7
640. Credit for Water Supply	33.31	40
Divergence	-9.54	1
1050. Community Risk Reduction	2.53	5.50
Total Credit	52.53	105.5

# **Final Community Classification = 05/5X**

# **APPENDIX K – TANK INSPECTIONS**





#### SUPPLEMENTAL REPORT

East Helena 200kg below grade concrete June 21, 2017

The 200kg tank appears to be in satisfactory condition. Little or no sediment was noted in the tank. All air vents and overflows are properly screened. There is an internal stainless steel ladder that appears to be in good condition. The four columns that support the roof area in good condition. There are expansion joints around each column base and around the perimeter of the tank. I found no signs of cracking on the floor walls or roof area. There may be a little separation of the expansion joint around the perimeter. (See photos.) The exterior roof appears to be sealed properly as well.

The interior plumbing components show signs of corrosion. There is a floor drain located in the center of the tank behind a small baffle wall in a sump area. The floor shows areas of pop outs and exposed aggregate. The hatch is a retrofitted bilco style have that is properly sealed and secured.

Recommendation would be to inspect every 3 years and clean as needed.



Jason Fowler 406-405-3742 + jsn.fowler@gmall.com 1063 Sunny Vista Rd , Helena, MT 59602

# General Inspection Form

Date: June 21, 2017 Tank Name: Concrete Below Grade Gallons: 200kg

Utility: City of East Helena City: East Helena State: MT

Utility: City of East Helena		City: East Helena	City: East Helena State: MT	e: MT
Components	Number	Good/Fair/Poor	Discrepancies	Recommendation
Access Hatches		Good	None	None
Ladder(s) Safety climb system	1	Notched Rail	None	None
Man ways / cleanouts hatches	0	N/A	N/A	N/A
Interior walls	1	Fair	Staining	None
Interior columns	4	Good	None	None
Interior roof	1	Good	None	None
Air vent	1	Good	None	None
Overflow	0	N/A	None	None
Inlet/Outlet	1	Good	None	None
Exterior roof	1	Good	None	None
Exterior walls	1	Good	None	None
Antennas	None	N/A	N/A	None
Aviation lights	0	N/A	None	None
Balconies/ Rail	0	N/A	None	None
Estimated amount of sediment and type	No sediment	Good	None	None
Interior floor if visible	1	Good	None	None
Cathodic protection system if present	None	N/A	None	None
Footing Ring	1	Good	None	None
Floor Drain	4	Good	None	None

Notes: Does not appear to have an over flow. Must be crossed over to the older 250kg tank.

^{*} Any areas marked as poor have a corresponding picture to that component to help monitor the rate of deterioration.





# SANITATION SURVEY East Helena 200kg Concrete below grade June 21, 2017

Components	Number	Good/Fair/Poor	Sealed or Screen	Comments
Air Vents/Screen	1	Good	Screened	None
Cathodic Covers	None	N/A	N/A	N/A
Over Flow/Screen	None	N/A	N/A	N/A
Hatch & lid lip	1	Good	Sealed	None
Telemetry Penetrations	1	Good	Sealed	None
Man Ways	Below Grade	N/A	N/A	N/A
Miscellaneous Penetrations	None	N/A	N/A	N/A
Waters hue	Clear			

#### **SAFETY AND SECURITY**

Components	Condition	Secure	Size / Dimension	Comments
Internal Ladder	Good	Bolted	Standard	None
External Ladder	Below Grade	N/A	N/A	N/A
Hatches	Good	Padlocked	36x48"	N/A
Man Ways	Below Grade	N/A	N/A	N/A
Balcony / Railing	None	N/A	N/A	N/A
Vandal Guard	N/A	N/A	N/A	N/A
Perimeter Fence	Good	Yes	8ft	N/A
Antennas	None	N/A	N/A	N/A
Light fixtures	None	N/A	N/A	N/A
Safety Climb system Internal	Good	Yes	Notched Rail	N/A
Trees/Shrubs	Good	N/A	N/A	N/A
Signs of Trespass	None	N/A	N/A	N/A



































#### SUPPLEMENTAL REPORT

East Helena 250 kg Concrete below Grade June 21, 2017

The 250kg below grade appears to be in satisfactory condition. I noted spalling along the exterior roof in all four quadrants with some rebar exposed in some areas. The plumbing components show signs of corrosion on the surface. The common inlet outlet is at 6 o'clock, opposite from the access hatch penetrating the wall. No obstructions were noted. The columns are in a 4 bolt pattern, one in each quadrant. There appears to be expansion joints at each column base which is also flush with the floor as well as a footing ring around the perimeter.

A top coat of gunite was applied on the interior walls. There are many areas of that coating that is falling away around the perimeter. All expansion joints appear to be in good condition. I found no signs of ground subsidence on the exterior of the tank. The overflow is located at the 9 o'clock position relative to the access hatch. Both air vents have screens that are intact and the penetrations are properly sealed. There is a Bilco access hatch that is 36x36 inches that appears to be in good condition. The amount of sediment is none. The tanks must fill from the 1.0 mg where the sediment settle's there first. The interior ladder is stainless steel and appears to be firmly fastened to the wall.



Jason Fowler 406 465-3742 • jsn.fawler@gmall.com 1063 Sunny Vista Rd., Helena, MT 59602

General Inspection Form


Date: June 21, 2017 Tank Name: Concrete Below Grade Gallons: 250kg

Utility: City of East Helena City: East Helena State: MT

Utility: City of East Helena		City: East Helena	State: MT		City: East Helena State: N	ie: MT	
Components	Number	Good/Fair/Poor	Discrepancies	Recommendation			
Access Hatches		Good	None	None			
Ladder(s) Safety climb system	1	Notched Rail	None	None			
Man ways / cleanouts hatches	0	N/A	N/A	N/A			
Interior walks	1	Fair	Gunite falling away	None			
Interior columns	4	Good	None	None			
Interior roof	1	Good	None	None			
Air vent	2	Good	None	None			
Overflow	1	Good	None	None			
Inlet/Outlet	1	Good	None	None			
Exterior roof	1	Fair	Spalling Noted	None			
Exterior walls	1	Good	None	None			
Antennas	None	N/A	N/A	None			
Aviation lights	0	N/A	None	None			
Balconies/ Rail	0	N/A	None	None			
Estimated amount of sediment and type	No sediment	Good	None	None			
Interior floor if visible	1	Good	None	None			
Cathodic protection system if present	None	N/A	None	None			
Footing Ring	1	Good	None	None			
Floor Drain	1	Good	None	None			

Notes: Areas of exposed aggregate. Column base have expansion joints.

^{*} Any areas marked as poor have a corresponding picture to that component to help monitor the rate of deterioration.





# SANITATION SURVEY East Helena 250kg Concrete below grade June 21, 2017

Components	Number	Good/Fair/Poor	Sealed or Screen	Comments
Air Vents/Screen	2	Good	Screened	None
Cathodic Covers	None	N/A	N/A	N/A
Over Flow/Screen	Internal	Good	N/A	N/A
Hatch & lid lip	1	Good	Sealed	None
Telemetry Penetrations	1	Good	Sealed	None
Man Ways	0	N/A	N/A	N/A
Miscellaneous Penetrations	None	N/A	N/A	N/A
Waters hue	Clear			

#### SAFETY AND SECURITY

Components	Condition	Secure	Size / Dimension	Comments
Internal Ladder	Good	Bolted	Standard	None
External Ladder	Below Grade	N/A	N/A	N/A
Hatches	Good	Padlocked	36x36"	N/A
Man Ways	Below Grade	N/A	N/A	N/A
Balcony / Railing	None	N/A	N/A	N/A
Vandal Guard	N/A	N/A	N/A	N/A
Perimeter Fence	Good	Yes	8ft	N/A
Antennas	None	N/A	N/A	N/A
Light fixtures	None	N/A	N/A	N/A
Safety Climb system Internal	Good	Yes	Notched Rail	N/A
Trees/Shrubs	Good	N/A	N/A	N/A
Signs of Trespass	None	N/A	N/A	N/A






























# SUPPLEMENTAL REPORT/ East Helena 1.0 MG June 21, 2017

The East Helena 1.0 MG concrete below grade reservouir appears to be in excellent condition. All components are in good working order. I found one small settling crack on the interior roof area. The sediment accumulation is minimal. I would estimate ¼ inch or less of silt and iron evenly distributed around the tank. The common inlet outlet has a small buildup of sand around it, less than ½ inch. The overflow shows some signs of corrosion in the form of nodules which are a result it the checks and cracks in the coating. All the other metal components are of stainless steel construction and are in new like condition. All columns and bases appear to be in good condition as well with no signs of degradation. The interior walls show no signs of cracking

The exterior of the tank appears to be in good condition overall. There is a 4x6 Bilco access hatch that has been retrofitted along with the stainless steel components of the tank that show little signs of wear. The air vents both have screens on them and the covers are firmly fastened. No large trees or shrubs were noted around the tank that might impact the structure. No signs of trespass was noted, and the access gate was locked.



Jason Fowler 406-465-3742 • jsn.fowlerekgmail.com 1063 Sunny Vista Rd , Helena, MT 59602

Date: June 21, 2017 Tank Name: East Helena

# General Inspection Form Gallons: 1.0 MG

Utility: City of East Helena City: East Helena State: MT

Utility: City of E		y: East Helena	State: MT	
Components	Number	Good/Fair/Poor	Discrepancies	Recommendation
Access Hatches	1	Good	None	None
Ladder(s) Safety climb system/Internal	i	Good	None	None
Man ways / cleanouts hatches	Below Grade	None	None	None
Interior walls	1	Good	None	None
Interior columns	8	Good	None	None
Interior roof	1	Good	One small Settling crack noted	None
Air vent	2	Good	None	None
Overflow	1	Good	Internal	None
Inlet/Outlet	1	Good	None	None
Exterior roof	1	Good	None	None
Exterior walls	Below-Grade	Good	None	None
Antennas	0	N/A	N/A	None
Aviation lights	0	N/A	N/A	None
Balconies/ Rail	0	N/A	None	None
Estimated amount of sediment and type	¼ inch silt/iron	Good	None	None
Interior floor if visible	1	Good	None	None
Floor Drain	1	Good	None	None
Signs of Subsidence	0	Good	None	None
Trees/shrubs/ brush	0	Good	None	None

Notes: One small settling crack was noted on the interior roof area. (See photo). All metal components are in good condition. Some corrosion forming on the riser of the overflow

^{*} Any areas marked as poor have a corresponding picture to that component to help monitor the rate of deterioration.






# SANITATION SURVEY/East Helena 1.0 MG Concrete below Grade June 21, 2017


Components	Number	Good/Fair/Poor	Sealed or Screen	Comments
Air Vents/Screen	2	Good	Screened	None
Cathodic Covers	0	N/A	N/A	None
Over Flow/Screen	Internal	Good	Good	None
Hatch & lid lip	1	Good	Sealed	None
Telemetry Penetrations	1	Good	Sealed	None
Man Ways	0	Below Grade	N/A	N/A
Miscellaneous Penetrations	0	N/A	N/A	N/A
Waters hue	Clear			

## **SAFETY AND SECURITY**

Components	Condition	Secure	Size / Dimension	Comments
Internal Ladder	Good	Yes	Standard	None
External Ladder	Below Grade	N/A	N/A	None
Hatches	Good	Padlocked	4ftx6ft	None
Man Ways	None	N/A	N/A	N/A
Balcony / Railing	None	N/A	N/A	N/A
Vandal Guard	None	N/A	N/A	N/A
Perimeter Fence	Good	Padlocked	8ft	None
Antennas	None	N/A	N/A	N/A
Light fixtures	None	N/A	N/A	N/A
Safety Climb system/Internal	Good	Yes	Notched Rail	N/A
Tank Access	Good	Yes	Maintained Road	N/A
Signs of Trespass	None	N/A	N/A	N/A






























#### SUPPLEMENTAL REPORT

East Helena 250 kg Concrete below Grade June 21, 2017

The 250kg below grade appears to be in satisfactory condition. I noted spalling along the exterior roof in all four quadrants with some rebar exposed in some areas. The plumbing components show signs of corrosion on the surface. The common inlet outlet is at 6 o'clock, opposite from the access hatch penetrating the wall. No obstructions were noted. The columns are in a 4 bolt pattern, one in each quadrant. There appears to be expansion joints at each column base which is also flush with the floor as well as a footing ring around the perimeter.

A top coat of gunite was applied on the interior walls. There are many areas of that coating that is falling away around the perimeter. All expansion joints appear to be in good condition. I found no signs of ground subsidence on the exterior of the tank. The overflow is located at the 9 o'clock position relative to the access hatch. Both air vents have screens that are intact and the penetrations are properly sealed. There is a Bilco access hatch that is 36x36 inches that appears to be in good condition. The amount of sediment is none. The tanks must fill from the 1.0 mg where the sediment settle's there first. The interior ladder is stainless steel and appears to be firmly fastened to the wall.



Jason Fowler 406 465-3742 • jan.fawler@gmall.com 1063 Sunny Vista Rd., Helena, MT 59602

# General Inspection Form


Date: June 21, 2017 Tank Name: Concrete Below Grade Gallons: 250kg

Utility: City of East Helena City: East Helena State: MT

Utility: City of E	y: City of East Helena City: East Helena State: MT		State: MT	
Components	Number	Good/Fair/Poor	Discrepancies	Recommendation
Access Hatches		Good	None	None
Ladder(s) Safety climb system	1	Notched Rail	None	None
Man ways / cleanouts hatches	0	N/A	N/A	N/A
Interior walks	1	Fair	Gunite falling away	None
Interior columns	4	Good	None	None
Interior roof	1	Good	None	None
Air vent	2	Good	None	None
Overflow	1	Good	None	None
Inlet/Outlet	1	Good	None	None
Exterior roof	1	Fair	Spalling Noted	None
Exterior walls	1	Good	None	None
Antennas	None	N/A	N/A	None
Aviation lights	0	N/A	None	None
Balconies/ Rail	0	N/A	None	None
Estimated amount of sediment and type	No sediment	Good	None	None
Interior floor if visible	1	Good	None	None
Cathodic protection system if present	None	N/A	None	None
Footing Ring	1	Good	None	None
Floor Drain	i	Good	None	None

^{*} Any areas marked as poor have a corresponding picture to that component to help monitor the rate of deterioration.

Notes: Areas of exposed aggregate. Column base have expansion joints.





# SANITATION SURVEY East Helena 250kg Concrete below grade June 21, 2017

Components	Number	Good/Fair/Poor	Sealed or Screen	Comments
Air Vents/Screen	2	Good	Screened	None
Cathodic Covers	None	N/A	N/A	N/A
Over Flow/Screen	Internal	Good	N/A	N/A
Hatch & lid lip	1	Good	Sealed	None
Telemetry Penetrations	1	Good	Sealed	None
Man Ways	0	N/A	N/A	N/A
Miscellaneous Penetrations	None	N/A	N/A	N/A
Waters hue	Clear			

### SAFETY AND SECURITY

Components	Condition	Secure	Size / Dimension	Comments
Internal Ladder	Good	Bolted	Standard	None
External Ladder	Below Grade	N/A	N/A	N/A
Hatches	Good	Padlocked	36x36"	N/A
Man Ways	Below Grade	N/A	N/A	N/A
Balcony / Railing	None	N/A	N/A	N/A
Vandal Guard	N/A	N/A	N/A	N/A
Perimeter Fence	Good	Yes	8ft	N/A
Antennas	None	N/A	N/A	N/A
Light fixtures	None	N/A	N/A	N/A
Safety Climb system Internal	Good	Yes	Notched Rail	N/A
Trees/Shrubs	Good	N/A	N/A	N/A
Signs of Trespass	None	N/A	N/A	N/A






























# SUPPLEMENTAL REPORT/ East Helena 1.0 MG June 21, 2017

The East Helena 1.0 MG concrete below grade reservouir appears to be in excellent condition. All components are in good working order. I found one small settling crack on the interior roof area. The sediment accumulation is minimal. I would estimate ¼ inch or less of silt and iron evenly distributed around the tank. The common inlet outlet has a small buildup of sand around it, less than ½ inch. The overflow shows some signs of corrosion in the form of nodules which are a result it the checks and cracks in the coating. All the other metal components are of stainless steel construction and are in new like condition. All columns and bases appear to be in good condition as well with no signs of degradation. The interior walls show no signs of cracking

The exterior of the tank appears to be in good condition overall. There is a 4x6 Bilco access hatch that has been retrofitted along with the stainless steel components of the tank that show little signs of wear. The air vents both have screens on them and the covers are firmly fastened. No large trees or shrubs were noted around the tank that might impact the structure. No signs of trespass was noted, and the access gate was locked.



Jason Fowler 406-465-3742 • jsn.fowlerekgmail.com 1063 Sunny Vista Rd , Helena, MT 59602

Date: June 21, 2017 Tank Name: East Helena


General Inspection Form Gallons: 1.0 MG

Utility: City of East Helena City: East Helena State: MT

Utility: City of E	Number	y: East Helena Good/Fair/Poor	State: MT	n
Components	Number		Discrepancies	Recommendation
Access Hatches	1	Good	None	None
Ladder(s) Safety climb system/Internal	1	Good	None	None
Man ways / cleanouts hatches	Below Grade	None	None	None
Interior walls	1	Good	None	None
Interior columns	8	Good	None	None
Interior roof	1	Good	One small Settling crack noted	None
Air vent	2	Good	None	None
Overflow	1	Good	Internal	None
Inlet/Outlet	I	Good	None	None
Exterior roof	1	Good	None	None
Exterior walls	Below-Grade	Good	None	None
Antennas	0	N/A	N/A	None
Aviation lights	0	N/A	N/A	None
Balconies/ Rail	0	N/A	None	None
Estimated amount of sediment and type	¼ inch silt/iron	Good	None	None
Interior floor if visible	1	Good	None	None
Floor Drain	1	Good	None	None
Signs of Subsidence	0	Good	None	None
Trees/shrubs/ brush	0	Good	None	None

Notes: One small settling crack was noted on the interior roof area. (See photo). All metal components are in good condition. Some corrosion forming on the riser of the overflow

^{*} Any areas marked as poor have a corresponding picture to that component to help monitor the rate of deterioration.






# SANITATION SURVEY/East Helena 1.0 MG Concrete below Grade June 21, 2017


Components	Number	Good/Fair/Poor	Sealed or Screen	Comments
Air Vents/Screen	2	Good	Screened	None
Cathodic Covers	0	N/A	N/A	None
Over Flow/Screen	Internal	Good	Good	None
Hatch & lid lip	1	Good	Sealed	None
Telemetry Penetrations	1	Good	Sealed	None
Man Ways	0	Below Grade	N/A	N/A
Miscellaneous Penetrations	0	N/A	N/A	N/A
Waters hue	Clear			

#### **SAFETY AND SECURITY**

Components	Condition	Secure	Size / Dimension	Comments
Internal Ladder	Good	Yes	Standard	None
External Ladder	Below Grade	N/A	N/A	None
Hatches	Good	Padlocked	4ftx6ft	None
Man Ways	None	N/A	N/A	N/A
Balcony / Railing	None	N/A	N/A	N/A
Vandal Guard	None	N/A	N/A	N/A
Perimeter Fence	Good	Padlocked	8ft	None
Antennas	None	N/A	N/A	N/A
Light fixtures	None	N/A	N/A	N/A
Safety Climb system/Internal	Good	Yes	Notched Rail	N/A
Tank Access	Good	Yes	Maintained Road	N/A
Signs of Trespass	None	N/A	N/A	N/A

























## **Steel Potable Water Reservoir Immediate Needs Assessment**

Job Number: 46310	Utility: City of East Helena	Tank:	#1 Below Grade
Inspector: R. Martin	Dive Controller: Z. Reeves	Date:	07/11/14
1. Health and Safety Items Safety Climb System Installation:			
☐ Vent Screen Repairs:			
2. Testing Items			
Dye Testing for Leak Evaluation:			
Presence of Lead Test (Interior/Ex	terior):		
3. Destructive Testing Items			
☐ % of Lead Test (Interior/Exterior)	(Coating samples are removed for labora	itory analysis)	
Coating Adhesion Test (Interior/E	xterior):		
Specific written authorization req	uired to perform destructive testing. Dest	tructive tests include to	ouch-up of coating system.
4. Repair Items			
Epoxy Coating Repairs:			
☐ Temporary Leak Repairs:			
Float Operated Level Indicator Re	pairs / Maintenance:		
Hypalon Repairs:			
5. Security Related Items (Critical secur  Tank vents are not equipped with	rity upgrade information is immediately and a security vent shroud:	vailable)	
☐ Tank hatches are not equipped w	rith a security hatch locking device:		
☐ Tank perimeter not adequately se	ecured:		
The above mentioned additional work is considered in conjunction with work currently being performance.		ended to be completed. S	ome items may be completed
Res	servoir Inspection Condition	Supplemental	

Overall the tank was in good condition we just recommend a clean and inspect in 3 years

## **Potable Water Reservoir Contamination, Health and Safety Report**

Job Number: 46310	Utility: City of East Helena	Tank: #1 Below Gra	de
Inspector: R. Martin	Dive Controller: Z. Reeves	Date: 07/11/14	Team #: <u>13</u>

Complies With: Av	WWW - OSHA - AN	SI - INIUSH - IVAV	TAC TINFFA	e de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de la companya de l
MANWAYS				
	Tvpe:	Size(s):	ı	n. <i>(24"</i> – 18'x22" min)
Support Structure:	Condition(s):	Lea	1ks:	
NOTES:				
EXTERIOR LADDER				
Quantity:	Attachment type:	Atta	chment Condition:	
Condition: Offset Landing:	Height:			
Vandal Guard: Locked:	Safety Climb:	Safe	ety Climb Condition:	
Rail Condition:	Rung Condition:	_	Rung Type:	
Rung Spacing: in. (max 12")	Rung Toe Depth:	in. (min 7")		
Rail Width: in. (min 2")	Rail Thickness:	in. (min 1/4")	Rail to Rail:	in. (min 16")
NOTES:				
WALL INTEGRITY				
Holes: NO Cracking: YES	Leaks: N	10	Overflow Air break: NC	)
Overflow Screened: YES Mesh Size: SMALL	Screen Condition G	OOD	Overflow Flapper: NC	)
NOTES:				
BALCONY / RAILING / DECKING				
Туре(s):	Condition:		Width:	
Hand Rail Condition:	Top Rail Height:	in. (min 42")	Mid Rail Height:	in. (min 24")
Toe Rail Condition:	Toe Rail Gap:	in. (min ¾")	Height:	in. (min 4")
Attachment Condition:	Width:			_
NOTES:				
HATCHES				
Type: SQUARE Quantity: 1	Size(s): 5	4"x30"	in	. (24" – 24'x15" min)
Hatch Lip Height: 5" in. (min 4")	Lid Lip Height: 2	in.	(min 2")	
Secured Property: YES	Properly Sealed: Y	'ES		
NOTES:				
WATER CONDITION				
Odor: None Appearance: clear			Floating Debris: No	<u> </u>
NOTES:				
ROOF				
Holes: NO Cracking: YES	Standing Water: 1	10	Safety Tie-Off Qty: N	/A
Roof / Wall Joint: Sealed: YES	Antennas Qty: N	1/A	Antenna Type(s):	
Vent Type(s): J Tube Quantity: 2	Screen Condition(s):	SOOD	Mesh Size: S	
Cathodic Cover Qty: N/A Gasketed: N/A Se	aled: N/A Telemetr	y Penetrations Qty: N/	Gasketed: N/	A Sealed: N/A
NOTES:				
FLOATING COVER				
Condition: Holes:	Tears:			
NOTES:				

#### **Concrete Water Reservoir Interior Condition Survey**

Job Number: 46310

Utility: City of East Helena

Tank: #1 Below Grade

Inspector: R. Martin

Dive Controller: Z. Reeves

Date: 07/11/14

AMERICAN CONCRETE INSTITUTE  ACI 201.1R-08 / 311.1R			and the said
ACI 201.1R-08 / 311.1R		AMERICAN CONCRETE INSTITUTE	
ALI 201.1R-08 / 311.1R	the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the s	actions an and read an	
CONTROL OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE PROPERTY OF THE		ACI ZULIR-08 / SILIK	

CONCRETE CONDITION CODE A - Abrasion D - Cracking **G** - contraction J - Curling M - Void P - Pitting S - Bugholes V - Exudation Y - Corrosion N - Cold Pour Q - Spalling T - Chalking W - Efflorescence Z - Exposed E - Deflection H - Deformation K - Checking B - Erosion C - Blistering F - Expansion 1 - Settling L - Delamination O - Honeycomb R - Popouts U - Leaching X - Stains Reinforcement

QUADRANT 1 QUADRANT 2 QUADRANT 3 QUADRANT INTERIOR RESERVOIR ROOF Roof Slab(s) ID,A, ID,A ID,A ID,A Expansion Joint(s) Support Beam(s) Beam Joint(s) Roof-Column Joint A General Appearance: Good Coating: N/A Vents: Good Level Sensors: Good All expansion Joints Uniform width: -Uniform Level: -Gaskets Intact: INTERIOR RESERVOIR WALLS Wall-Roof Joint A.X.Y A,X,Y A,X,Y A,X,Y Wall Structure A,X,Y A,X,Y A,X,Y A,X,Y General Appearance: Good Coating: N/A Ladder: Good Leaking: None observed Dye Tested: No -All-expansion Joints -- Uniform width: -Uniform Level: ** Gaskets Intact: --INTERIOR RESERVOIR SUPPORT COLUMNS S S

Columns Clmn Floor Plates | A Dye Tested: No General Appearance: Good Coating: N/A ColumnBase Leaking: None observed

Uniform Level: Gaskets Intact: .. -All expansion Joints - Uniform width: -----

#### INTERIOR RESERVOIR FLOOR

Perimeter Joint R,S,X R,S,X R,5,X R,S,X R,S,X R,S,X R,S,X R,S,X Floor Slabs

General Appearance: Good Coating: N/A Inlet Structure: Good **Outlet Structure: Good** Dye Tested: No Overflow Structure: Good Sump System: -----Leaking: None observed All expansion Joints - Uniform width: -- Uniform Level:-Gaskets-Intact

#### **Additional Interior Notes / Comments**

There were some small pieces of concrete on the floor that came from the interior roof.

#### **Concrete Water Reservoir Exterior Condition Survey**

Job Number: 46310

Utility: City of East Helena

Tank: #1 Below Grade

Inspector: R. Martin

Dive Controller: Z. Reeves

Date: 07/11/14

#### **AMERICAN CONCRETE INSTITUTE** ACI 201.1R-08 / 311.1R

#### **CONCRETE CONDITION CODE**

Y - Corrosion A - Abrasion D - Cracking G - contraction J - Curling M - Vold P - Pitting S - Bugholes V - Exudation W - Efflorescence Z – Exposed K - Checking N - Cold Pour Q - Spalling T - Chalking H - Deformation **B** – Erosion E - Deflection L - Delamination O - Honeycomb R - Popouts **U** - Leaching X - Stains Reinforcement **C** - Blistering F - Expansion 1 - Settling

QUADRANT 2 QUADRANT 3 QUADRANT 4 QUADRANT 1 EXTERIOR RESERVOIR ROOF Roof Slab(s) X.D.Q.B X,D,Q,B X,D,Q,B X,D,Q,B Expansion Joint(s) X,D,Q,B X,D,Q,B X,D,Q,B X,D,Q,B **Roof-Wall Joint** General Appearance: Good Coating: N/A Vents: Good Level Indicator: N/A Hatch Cage & Railing: Good Hatch & Gaskets: Good Hatch hinges: Good Lock & Hasp: Good All expansion Joints Uniform width: **Uniform Level:** Gaskets Intact: EXTERIOR RESERVOIR WALLS

Wall-Roof Joint **Wall Structure** General Appearance: -----Coating: N/A Ladder: -----Safety Climb: ----Overflow Structure: -----Clean out hatch: -----Leaking: ------Uniform-Level: --Gaskets Intact: All expansion Joints Uniform width: -----

#### EXTERIOR RESERVOIR FOOTINGS / FOUNDATION

Perimeter Joint Floor Slab **Footing Ring** Sump-Valve Vault Coating: N/A Leaking: ----Ground Subsidence: ----General Appearance: -----

All expansion Joints - Uniform width: ----Uniform Level: ----Gaskets Intact: -Overflow:


**Additional Exterior Notes / Comments** 

## Circular Tank Diagram / Information Worksheet

Job Number 46310

Utility Name City of East Helena

Tank Name #1 Below Grade



DISCLAIMER

# Steel Potable Water Reservoir Security / Measurement Worksheet

Job Number 46310

Utility Name City of East Helena


Tank Name #1 Below Grade

Floor

## Security

Yes
Yes
Yes
N/A
N/A
No
No
Yes
Yes
No

#### Measurements



#### DISCLAIMER

Floor

Floor

## **Steel Potable Water Reservoir Immediate Needs Assessment**

Job Number: 46310		Utility: City of E	ast Helena	Tank:	#2 Below Grade
Inspector: C. Cooper		Dive Controller:	R. Martin	Date:	07/11/14
1.	Health and Safety Items Safety Climb System Installation: Vent Screen Repairs:				
2.	Testing Items  ☐ Dye Testing for Leak Evaluation: ☐ Presence of Lead Test (Interior/Exter	ior}:			
3.	Destructive Testing Items  Mof Lead Test (Interior/Exterior) (Co Coating Adhesion Test (Interior/Exterior)  Specific written authorization require	rior):	are removed for laboratory analysis) estructive testing. Destructive tests inc	lude to	ouch-up of coating system.
4.	Repair Items  Epoxy Coating Repairs: Temporary Leak Repairs: Float Operated Level Indicator Repair Hypalon Repairs:	rs / Maintenan	ce:		
5.	Security Related Items (Critical security of Tank vents are not equipped with a security of Tank hatches are not equipped with Tank perimeter not adequately secure above mentioned additional work is considered.	security vent sh a security hatcl red:	roud: h locking device:	P hote	ome items may be completed
	onjunction with work currently being performe	d while the crew	•		ome items may be completed
	110001	poc	sa		

Overall the tank was in good condition we just recommend a clean and inspect in 3 years

# **Potable Water Reservoir Contamination, Health and Safety Report**

Job Number: 46310	Utility: City of East Helena	Tank: #2 Below Grade
Inspector: C. Cooper	Dive Controller: R. Martin	Date: 07/11/14 Team #: 13
2 W. Pang White and Hardwhite Street, Sci.		

compiles stilling	AVVVA - OSHA - ANSI	MOSII - HAVIAG	, TRIFA
MANWAY5			
Quantity: Location:	Type:	Size(s):	in. (24" – 18'x22" min)
Support Structure:	Condition(s):	Leaks: –	
NOTES:			
EXTERIOR LADDER			
Quantity:Location:	Attachment type:	Attachme	ent Condition:
Condition: Offset Landing:	Height:		
Vandal Guard: Locked:	Safety Climb: ——	Safety Cli	imb Condition:
Rail Condition:	Rung Condition:		Rung Type:
Rung Spacing: in. (max 12")	Rung Toe Depth:	in. ( <i>min 7"</i> )	
Rail Width: in. (min 2")	Rail Thickness:	in. <i>(min 1/4")</i>	Rail to Rail: in. (min 16")
NOTES:			
WALL INTEGRITY			
Holes: NO Cracking: YES	Leaks: NO	Overfl	low Air break: NO
Overflow Screened: YES Mesh Size: SMALL	Screen Condition GOO	D Over	rflow Flapper: NO
NOTES:			
BALCONY / RAILING / DECKING			
Type(s):	Condition:		Width:
Hand Rail Condition:	Top Rail Height:	in. <i>(min 42")</i> M	lid Rail Height: in. (min 24")
Toe Rail Condition:	Toe Rail Gap:	in. (min ¼")	Height: in. (min 4")
Attachment Condition:	Width:		
NOTES:			
<u>HATCHES</u>			
Type: SQUARE Quantity: 1	Size(s): <u>36"x3</u>	36"	in. (24" – 24'x15" min)
Hatch Lip Height: 5" in. (min 4")	Lid Lip Height: 2"	in. ( <i>min</i> 2	! <b>"</b> )
Secured Properly: YES	Properly Sealed: YES		
NOTES:			
WATER CONDITION			
Odor: None Appearance: clear		F	loating Debris: NO
NOTES:		102	
ROOF			
Holes: NO Cracking: YES	Standing Water: NO	Safe	ety Tie-Off Qty: N/A
Roof / Wall Joint: Sealed: YES	Antennas Qty: N/A	Ar	ntenna Type(s):
Vent Type(s): <u>J Tube</u> Quantity: <u>2</u>	Screen Condition(s): GOO	D	Mesh Size: SMALL
Cathodic Cover Qty: N/A Gasketed: N/A S	Sealed: N/A Telemetry Per	netrations Qty: N/A	Gasketed: N/A Sealed: N/A
NOTES:			
FLOATING COVER			
Condition: Holes:	Tears:		
NOTES:			

## **Concrete Water Reservoir Interior Condition Survey**

Job Number: 46310

Utility: City of East Helena

Tank: #2 Below Grade

Inspector: C. Cooper

Dive Controller: R. Martin

Date: 07/11/14

			Child by the contract of the party	N CONCRETE IN 201.1R-08 / 311.:	majorine communication (CS)			
B – Eroslon E - De	racking eflection kpansion	H - Deformation K	CONCRET Curling - Checking - Delamination	E CONDITIO M - Vold N - Cold Pour O - Honeycomb	N CODE P - Pitting Q - Spalling R - Popouts	S - Bugholes T - Chalking U - Leaching	V - Exudation W - Efflorescence X - Stains	Y - Corrosion Z – Exposed Reinforcemer
[	QUA	DRANT 1	QUAD	RANT 2	QUAD	RANT 3	QUAD	RANT 4
			INTEI	RIOR RES	ERVOII	ROOF		
Roof Slab(s) Expansion Joint(s)	ID,A,		ID,A		ID _i A		ID,A	
Support Beam(s)  Beam Joint(s)								
Roof-Column Joint	A		A		A	risus produ	A	
General Appearance	e: Good	Coating: N/A	Ve	nts: Good	Level Senso	rs: Good		
Wall-Roof Joint  Wall Structure	A,X,Y A,X,Y		<i>INTER</i> A,X,Y A,X,Y	IOR RESE	A,X,Y A,X,Y	WALLS	A,X,Y A,X,Y	
General Appearance		Coating: N/A	La Uniform Level	dder: Good	Leaking: N	None observed	Dye Tested: (	No
				 E S E R V O I I			LUMNS	
Columns	S A		S A	LSERVOII	S	OKT CO	S	
Seneral Appearance	e: Good	Coating: N/A	Co	lumnBase Leaking	: None observ	red Dye Tes	ited: No	
All expansion Joints	- Uniform	width:	<del>Uniform Level</del>		Gaskets Into	act:		
			INTE	RIOR RES	ERVOIR	RFLOOP	₹	
Perimeter Joint Floor Slabs	R,S,X R,S,X		R,S,X R,S,X		R,S,X R,S,X		R,S,X R,S,X	
		Coating: N/A		et Structure: Goo		ıtlet Structure:		
General Appearanc	e: Good				_			

## **Additional Interior Notes / Comments**

There were some small pieces of concrete on the floor that came from the interior roof.

## **Concrete Water Reservoir Exterior Condition Survey**

Job Number: 46310

Utility: City of East Helena

Tank: #2 Below Grade

Inspector: C. Cooper

Roof Slab(s)

Roof-Wall Joint

Dive Controller: R. Martin

Date: 07/11/14

#### **AMERICAN CONCRETE INSTITUTE** ACI 201.1R-08 / 311.1R

# **CONCRETE CONDITION CODE**

D - Cracking J - Curling M - Void P - Pitting A – Abrasion G - contraction S - Bugholes V - Exudation Y - Corrosion B - Erosion E - Deflection N - Cold Pour **H** - Deformation K - Checking Q - Spalling T - Chalking W - Efflorescence Z - Exposed C - Blistering I - Settling F - Expansion L - Delamination O - Honeycomb R - Popouts U - Leaching X - Stains Reinforcement

QUADRANT 2 QUADRANT 3 QUADRANT 4 QUADRANT 1 EXTERIOR RESERVOIR ROOF X,D,Q,B X,D,Q,B X,D,Q,B X,D,Q,B Expansion Joint(s) X,D,Q,B X,D,Q,B X,D,Q,B X,D,Q,B General Appearance: Good Level Indicator: N/A Coating: N/A Vents: Good Hatch & Gaskets: Good Hatch hinges: Good Hatch Cage & Railing: Good Lock & Hasp: Good All expansion Joints Uniform width:--- Uniform-Level: Gaskets Intact:

EXTERIOR RESERVOIR WALLS Wall-Roof Joint Wall Structure General Appearance: -----Coating: N/A Ladder: ----Safety Climb: -----Overflow Structure: -----Clean out hatch: -----Leaking: -----

Uniform Level: --

#### EXTERIOR RESERVOIR FOOTINGS / FOUNDATION

Gaskets Intact:

Perimeter Joint Floor Slab **Footing Ring** Sump-Valve Vault General Appearance: -----Coating: N/A Leaking: -----Ground Subsidence: -----All-expansion Joints Uniform width: ..... Uniform Level: ..... Gaskets Intact: ----Overflow:

**Additional Exterior Notes / Comments** 


All expansion Joints Uniform width: -----

## **Circular Tank Diagram / Information Worksheet**

Job Number 46310

Utility Name City of East Helena

Tank Name #2 Below Grade



DISCLAIMER

# **Steel Potable Water Reservoir Security / Measurement Worksheet**

Job Number 46310

Floor

Utility Name City of East Helena


Tank Name #2 Below Grade

Floor

## Security

Yes
Yes
Yes
N/A
N/A
No
No
Yes
Yes
No

#### Measurements



#### DISCLAIMER

Floor

# Steel Potable Water Reservoir Immediate Needs Assessment

dot	Number: 46310	Utility: City of East Helena	Tank:	#3 1MG
Insp	pector: Z. Reeves	Dive Controller: R. Martin	Date:	07/12/14
1.	Health and Safety Items ☐ Safety Climb System Installation:			
	☐ Vent Screen Repairs:			
2.	Testing Items ☐ Dye Testing for Leak Evaluation:			
	Presence of Lead Test (Interior/Exte	rior):		
3.	Destructive Testing Items  % of Lead Test (Interior/Exterior) (C	oating samples are removed for labora	atory analysis)	
	Coating Adhesion Test (Interior/Ext	erior):		
	Specific written authorization requir	ed to perform destructive testing. Des	tructive tests include to	uch-up of coating system.
4.	Repair Items			
	Epoxy Coating Repairs:			
	☐ Temporary Leak Repairs:			
	Float Operated Level Indicator Repa	irs / Maintenance:		
	Hypalon Repairs:			
5.	Security Related Items (Critical security  Tank vents are not equipped with a		available)	
	Tank hatches are not equipped with	a security hatch locking device:		
	Tank perimeter not adequately secu	red:		
The in co	above mentioned additional work is consider onjunction with work currently being perform	ed immediately necessary and is recomme ad while the crew is on site.	ended to be completed. So	ome items may be completed
	Rese	voir Inspection Condition	Supplemental	
Clea	n and inspect in 3 years	-		

# **Potable Water Reservoir Contamination, Health and Safety Report**

Job Number: 46310	Utility: City of East Helena	Tank: #3 1MG	
Inspector: Z. Reeves	Dive Controller: R. Martin	Date: 07/12/14	Team #: 13

Compiles With: AW	/WA • OSHA • ANSI •	NIOSH • NA	VFAC • NFPA	
MANWAYS				· -
Quantity: — Location:	Туре	Size(s):		in. (24" – 18'x22" min)
Support Structure:	Condition(s):	le	aks:	
NOTES:				
EXTERIOR LADDER				
Quantity: Location:	Attachment type:	Att	achment Condition:	
Condition: — Offset Landing:	Height:			
Vandal Guard: Locked:	Safety Climb:	Saf	ety Climb Condition: —	
Rail Condition:	Rung Condition:		Rung Type:	
Rung Spacing: in. (max 12")	Rung Toe Depth:	in. (min 7")		
Rail Width: in. (min 2")	Rail Thickness:	in. <i>(min 1/4")</i>	Rail to Rail:	in. (min 16")
NOTES:				
WALL INTEGRITY				
Holes: NO Cracking: NO	Leaks: NO		Overflow Air break: N	0
Overflow Screened: YES Mesh Size: SMALL	Screen Condition GOOL	)	Overflow Flapper: N	0
NOTES:				
BALCONY / RAILING / DECKING				
Type(s):	Condition:		Width:	
Hand Rall Condition:	Top Rail Height:	in. <i>(min 42")</i>	Mid Rail Height:	in. (min 24")
Toe Rail Condition:	Toe Rail Gap:	in. (min ¾")	Height:	in. (min 4")
Attachment Condition:	Width:			
NOTES:		sasan II Al		
HATCHES				
Type: SQUARE Quantity: 1	Size(s): <u>36"x3</u>	6"	i	<u>n</u> . (24" – 24'x15" min)
Hatch Lip Height: 5" in. (min 4")	Lid Lip Height: 2"	in.	(min 2")	
Secured Properly: YES	Properly Sealed: YES			
NOTES:		9,5		
WATER CONDITION				
Odor: None Appearance: Clear	5. 2 8 7 1 1 1 1 1		Floating Debris: N	10
NOTES:		- 3111111111111111111111111111111111111		
ROOF				
Holes: NO Cracking: NO	Standing Water: NO		Safety Tie-Off Qty: N	N/A
Roof / Wall Joint: Sealed: YES	Antennas Qty:		Antenna Type(s):	
Vent Type(s): Mushroom Quantity: 2	Screen Condition(s): GOO	D	Mesh Size: S	SMALL
Cathodic Cover Qty: Gasketed: Sea	iled: Telemetry Pent	etrations Qty:	- Gasketed. –	Sealed
NOTES:				
FLOATING COVER				
Condition: Holes:	Tears:			
NOTES:				

## **Concrete Water Reservoir Interior Condition Survey**

Job Number: 46310

Utility: City of East Helena

Tank: #3 1MG

Inspector: Z. Reeves

Dive Controller: R. Martin

Date: 07/12/14

<b>AMERICAN CONCRETE INSTITUTE</b>	
ACI 201.1R-08 / 311.1R	

**CONCRETE CONDITION CODE** 

M - Void P - Pitting A - Abrasion D - Cracking G - contraction J - Curling S - Bugholes V - Exudation Y - Corrosion B - Erosion E - Deflection H - Deformation K - Checking N - Cold Pour Q - Spalling T - Chalking W - Efflorescence Z - Exposed C - Blistering O - Honeycomb L - Delamination R - Popouts U - Leaching Reinforcement F - Expansion 1 - Settling X - Stains

> QUADRANT 1 QUADRANT 2 QUADRANT 3 QUADRANT 4

#### INTERIOR RESERVOIR ROOF

Roof Slab(s)	ID,S,X	ID,S,X	ID,S,X	ID,S,X
Expansion Joint(s)			AND SECURITION AND SECURITION ASSESSMENT	
Support Beam(s)	Electric de la company			
Beam Joint(s)				
Roof-Column Joint	ID,S;X	ID,S,X	ID,S,X	ID,S,X

General Appearance: Good

Coating: N/A

Vents: Good

Level Sensors: Good

- All expansion Joints - Uniform width:

Uniform Level:

Gaskets Intact:

#### INTERIOR RESERVOIR WALLS

Wall-Roof Joint **Wall Structure** 

ID,S,X ID,S,X ID,S,X ID,S,X ID,S,X ID,S,X

ID,S,X ID,S,X

General Appearance: Good

Coating: N/A

Ladder: Good

Leaking: None observed

Dye Tested: No

-Uniform Level:

All expansion Joints Uniform width: -----

### INTERIOR RESERVOIR SUPPORT COLUMNS

Columns

ID,S,X Clmn Floor Plates | ID,S;X ID,S,X ID,S,X

ID;S,X ID,S,X

ID.S.X ID,S,X

General Appearance: Good

Coating: N/A

ColumnBase Leaking: None observed

Dye Tested: No

-All expansion Joints Uniform width: -----

Uniform-Level: --

Gaskets Intact: ***

#### INTERIOR RESERVOIR FLOOR

Perimeter Joint Floor Slabs

ID,S,X ID,S,X ID,S,X ID,S,X ID,S,X ID,S,X ID,S,X ID,S,X

General Appearance: Good

Coating: N/A

Inlet Structure: Good

**Outlet Structure: Good** 

Overflow Structure: Good

Sump System: -----

Leaking: None observed

Dye Tested: No

All expansion Joints Uniform width:

Gaskets Intact:

-Uniform Level:

**Additional Interior Notes / Comments** 

## **Concrete Water Reservoir Exterior Condition Survey**

Job Number: 46310

Utility: City of East Helena

Tank: #3 1MG

Inspector: Z. Reeves


Dive Controller: R. Martin

Date: 07/12/14

# AMERICAN CONCRETE INSTITUTE ACI 201.1R-08 / 311.1R

#### CONCRETE CONDITION CODE

G - contraction Y - Corrosion A - Abrasion D - Cracking J - Curling M - Void P - Pitting S - Bugholes V - Exudation W - Efflorescence Z – Exposed N - Cold Pour Q - Spalling T - Chalking K - Checking B - Erosion E - Deflection H - Deformation Reinforcement F - Expansion I - Settling L - Delamination O - Honeycomb R - Popouts U - Leaching X - Stains C - Blistering



**Additional Exterior Notes / Comments** 

## **Circular Tank Diagram / Information Worksheet**

Job Number 46310

Utility Name City of East Helena

Tank Name #3 1MG

Quadrant 1	Quadrant 2	Quadrant 3	Quadrant 4
	A few minor bugholes	and staining in all qua	drants
	ROOF Testing and	d Discrepancy Locations FI	LOOR
bughole	ere some minor s, but other than was in excellent	Q4 There were settling of	Q1 some minor cracks along staining in all
Q3	Q2	Q3	Q2
Skiff Skiff Skiff Skiff Skiff Skiff Skiff Skiff Skiff Skiff Cubic Yabic Skiff Skiff Skiff Skiff Skiff Skiff Skiff Cubic Yabic Skiff	ements taken	V=Vent D=Drain S=Sump L=Ladder H=Hatch P=Overflow F=Float Level Indicator T=Telemetry	Column Placement Type of Column

DISCLAIMER

## **Steel Potable Water Reservoir Security / Measurement Worksheet**

Job Number 46310


Utility Name City of East Helena

Tank Name #3 1MG

## Security

Yes
Yes
Yes
N/A
N/A
No
No
Yes
No
No

#### Measurements



#### DISCLAIMER

# **Concrete Water Reservoir Interior Condition Survey**

Job Number: 37107

Utility: City of E. Helena

Tank: NO.1 250KG BG

Inspector: J. Johnson

Dive Controller: E. Craig

Date: 4/26/2010

	5170	10111 VIIC11 4141B			utc. 1, 20, 2020	
	A	MERICAN CONCRETE IN ACI 201.1R-08 / 311.1	Table In the Party and Table In the			
A - Abrasion D - Cracking B - Erosion E - Deflection C - Blistering F - Expansion	G - contraction J - Curlin H - Deformation K - Chec	•	N CODE P - Pitting Q - Spalling R - Popouts	S - Bugholes T - Chalking U - Leaching	V - Exudation W - Efflorescence X - Stains	Y - Corrosion Z — Exposed Reinforcement
QU	ADRANT 1 Q	UADRANT 2	OUAD	RANT 3	QUAD	RANT 4
						<u> </u>
D (0114)		NTERIOR RES		ROOF		
Roof Slab(s) X	X		X		x	
Expansion Joint(s) Support Beam(s)						
Beam Joint(s)						
Roof-Column Joint N	N	_	N		N	
General Appearance: Good	Coating: N/A	Vents: Good	Level Senso			
All expansion Joints - Unifor		m Level:	Gaskets Inta			
Wall-Roof Joint N		ITERIOR RESE		WALLS		
Wall-Roof Joint N Wall Structure X, Q	N X, Q		N X, Q		N   X, Q	
General Appearance: Good	Coating: N/A	Ladder: Good		lone observed	Dye Tested: 1	
	m width:Unife		Gaskets Inta		Dye resteu. I	NO.
,				, , , , , , , , , , , , , , , , , , , ,	_	
	INTERIC	R RESERVOII	RSUPP	ORT CO	LUMNS	
Columns S, X, Q	S, X,	Q	5, X, Q		S, X, Q	
Cimn Floor Plates						
General Appearance: Good	Coating: N/A	ColumnBase Leaking	: None observ	ed Dye Test	ted: No	
All expansion-Joints Unifor	m width: Unifo	m Level:	- Gaskets Inta	eti	-	
	1.	NTERIOR RES	ERVOIR	FLOOR	<b>?</b>	
Perimeter Joint N, X	N, X		N, X		N, X	
Floor Slabs X	x		X		x	
General Appearance: Good	Coating: N/A	Inlet Structure: Good	d Ou	tlet Structure:	Good	
Overflow Structure: Good	Sump System: Good	Leaking: None o	observed	Dye Tested:	No	
All expansion Joints Unifo	m width: Unifo	m Level:	- Gaskets Inta	et:-	_	
Additional Interior Note:	s / Comments					
	// Comments					

## **Concrete Water Reservoir Exterior Condition Survey**

Job Number: 37107

Utility: City of E. Helena

Tank: NO.1 250KG BG

Inspector: J. Johnson

Dive Controller: E. Craig

Date: 4/26/2010

			Dive Controller				ate: 4/26/2010	
			Township Indiana	N CONCRETE IN 201.1R-08 / 311.	makes a recommend of the last			
			CONCRET	E CONDITIO	N CODE	4. 41		
		G - contraction	J - Curling	M - Void	P - Pitting	S - Bugholes	V - Exudation	Y - Corrosion
	Deflection Expansion	H - Deformation  I - Settling	K - Checking L - Delamination	N – Cold Pour O - Honeycomb	Q - Spalling R - Popouts	T - Chalking U - Leaching	W - Efflorescence X - Stains	Z – Exposed Reinforcemen
	- CAPOTISION	1 - Setting	L-Delamination	O - Honeycomb	N-Popouts	O - Ceacining	A - Status	Kennorcemen
	QUA	DRANT 1	QUADI	RANT 2	QUAD	RANT 3	QUAD	RANT 4
			EXTER	IOR RES	ERVOII	RROOF		
loof Slab(s)	X		х		X		x	
Ex <del>pansion Joint(s)</del>								
Roof-Wall Joint	N		N		N		N	
General Appearan	ice: Good	Coating: N/	'A Ven	its: Good	Level Indica	tor:		
Hatch & Gaskets:	Good	Hatch hinges:	Sood 1a	ock & Hasp: Good	1	Hatch Cage /	Railing,	
		3		•		materi ebbe i	~ · · · · · · · · · · · · · · · · · · ·	
All-expansion Join	ts - Uniform	width:	Uniform Level:		Gaskets Inte	ict:	_	
All expansion Join	ts Uniform	width:					-	
<del>All-expansion Join</del> Wall-Roof Joint	N Uniform	width:		IOR RESI			- :	
			EXTER	IOR RESI	RVOIR	WALLS		.5
Nall-Roof Joint Nall Structure	N Y, Z, X, Q, II		E X T E R  N Y, Z, X, Q, ID,	IOR RESI	R V O I R	WALLS ), s	N	S
Wall-Roof Joint Wall Structure General Appearan	N Y, Z, X, Q, II	D, S Coating: N/	E X T E R  N Y, Z, X, Q, ID, S	IOR RESI	N Y, Z, X, Q, IC	WALLS ), s	N	S
Wall-Roof Joint Wall Structure General Appearan Overflow Structur	N Y, Z, X, Q, II	D, S	EXTER  N Y, Z, X, Q, ID, S A Lad	OR RESI	R V O I R N Y, Z, X, Q, IC Safety Clir e observed	WALLS D, S	N	5
Wall-Roof Joint Wall Structure General Appearan Overflow Structur	N Y, Z, X, Q, II	D, S  Coating: N/  Clean out ha	EXTER  N Y, Z, X, Q, ID, S A Lad	OR RESI	R V O I R N Y, Z, X, Q, IC Safety Clir e observed	WALLS D, S	N	S
Wall-Roof Joint Wall Structure General Appearan Overflow Structur	N Y, Z, X, Q, II	D, S  Coating: N/  Clean out ha	N Y, Z, X, Q, ID, S A Lad teh:	OR RESI	R V O I R N Y, Z, X, Q, IE Safety Clir e observed Gaskets Int:	WALLS b, S mb:	N	,
Wall-Roof Joint Wall Structure General Appearan Overflow Structur All expansion Join	N Y, Z, X, Q, II	D, S  Coating: N/  Clean out ha	N Y, Z, X, Q, ID, S A Lad teh:	OR RESI	R V O I R N Y, Z, X, Q, IE Safety Clir e observed Gaskets Int:	WALLS b, S mb:	N Y, Z, X, Q, ID,	,
Wall-Roof Joint Wall Structure General Appearan Overflow Structur All expansion Join Perimeter Joint	N Y, Z, X, Q, II	D, S  Coating: N/  Clean out ha	N Y, Z, X, Q, ID, S A Lad teh:	OR RESI	R V O I R N Y, Z, X, Q, IE Safety Clir e observed Gaskets Int:	WALLS b, S mb:	N Y, Z, X, Q, ID,	,
Wall-Roof Joint Wall Structure General Appearan Overflow Structur All expansion Join Perimeter Joint Floor Slab	N Y, Z, X, Q, II	D, S  Coating: N/  Clean out ha	N Y, Z, X, Q, ID, S A Lad teh:	OR RESI	R V O I R N Y, Z, X, Q, IE Safety Clir e observed Gaskets Int:	WALLS b, S mb:	N Y, Z, X, Q, ID,	,
Wall-Roof Joint Wall Structure General Appearan Overflow Structur All expansion Join Perimeter Joint Floor Slab Footing Ring	N Y, Z, X, Q, II nce: Good re: Uniform	D, S  Coating: N/  Clean out ha	N Y, Z, X, Q, ID, S A Lad teh:	OR RESI	R V O I R N Y, Z, X, Q, IE Safety Clir e observed Gaskets Int:	WALLS b, S mb:	N Y, Z, X, Q, ID,	
Wall-Roof Joint Wall Structure General Appearan <del>Overflow Structur</del>	N Y, Z, X, Q, II nce: Good re: tts Uniform	D, S  Coating: N/  Clean out ha	EXTER  N Y, Z, X, Q, ID, 3 A Lad teh: Uniform Level:	OR RESI	R V O I R N Y, Z, X, Q, IE Safety Clir e observed Gaskets Int:	WALLS  D, S  This is a section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of the section of th	N Y, Z, X, Q, ID,	

**Additional Exterior Notes / Comments** 

## Potable Water Reservoir Contamination, Health and Safety Report

Job Number: 37107

Utility: City of E. Helena

Tank: NO.1 250KG BG

Inspector: J. Johnson

Dive Controller: E. Craig

Date: 4/26/2010

## Complies With: AWWA • OSHA • ANSI • NIOSH • NAVFAC • NFPAC

	co	NTAMIN	A 1	10	N & HEAL	TH	
Air Vents	Type: J-Tube		#:	1	Screen Condition	(s): Good	
Hatches	Type: Other		#:	1	Secured Properly	: Yes	Properly Sealed: Yes
Exterior Overflow	- Flapper:	-5creen:			Gasket:		Condition:
Cathodic Covers	In-Place.		#:		Gasket:		Properly Sealed:
Roof to Wall Joint	Welded: No	Properly Sealed:	Ye	;			
Roof Integrity	Holes: No	Cracking: No		Standi	ng Water: No		
Wall Integrity	Holes: No	Cracking: Yes					
Manway Integrity	Leaks:	Condition:					
Water Clarity	General Appearance	: Good				Odor: N	one
Floating Surface Debris	Type: None					Source:	N/A
Hypalon-Floating Cover	Condition:	Holes:	<del>_</del> Te	:ars: -			
Telemetry Penetrations	Properly Sealed:	_					


	FACIL	ITY SAF	ETY CON	A P L I A N C	Ε		
Exterior Ladder							
Overall-Ladder	Condition:	#	t: Offse	t Landing:	Height:		
Vandal Guard	Present:	Vanda	al Guard Locked:				
Ladder Rails & Rungs	Condition:	Missir	ng/Damaged Rur	185			
Rung Spacing & Depth	Spacing:	in. (max 12"	Foe Depth:	in. (min	7")		
Rail Spacing & Size	Width:	_in-(min 2")	Thickness	in. <i>(min 1</i>	/4") Rail to Rail:	in. <i>(m</i>	in 16")
Safety Climb System	Тур€:	Conc	lition:		_		
Number & Locations	Wall:	Leg:	Roof:	Riser Pipe:	Other:		
Ladder Attachments							
Manways							-
Type and size	Туре:	4	:	Size:	inches (24" – 18'x22	 ?" min)	
Support Structure	Туре:	Condi	tion:				
-Number & Locations	Wall:	Roof:	Riser Pipe:	Other			
<u>Hatches</u>						-	
Hatch Type & Size	Type: Other		#: 1	Size: 72x30	in. (24" – 24"x15"	min)	
Hatch & Lid Lip Height	Hatch: 5	in. (min 4")	Lid: 2	in. <i>(min 2")</i>			
Balconies & Railing							
Deck / Walkways	Condition:		Width:				
Hand Rails	Condition:		Height:	in. (min 42")	No. Rails:	(min 2)	
Toe Rail	Condition:		Height:	in. (min 4")			
- Welds / Attachments	Condition:						
Roof							
Safety Tie-Off Points	Condition		#:				
	Type:		#: -a				

## **Circular Tank Diagram / Information Worksheet**

Job Number 37107

Utility Name City of E. Helena

Tank Name NO.1 250KG BG



DISCLAIMER

# **Steel Potable Water Reservoir Security / Measurement Worksheet**

Job Number 37107


Utility Name City of E. Helena


Tank Name NO.1 250KG BG

## **Security**

Is the area surrounding the tank well lit?	No
Is the tank surrounded by a Security Fence?	Yes
Are the access gates locked?	Yes
Is the tank equipped with a Vandal Guard on the primary access ladder?	No
If so, is the Vandal Guard locked?	No
Are the vents equipped with security vent shrouds?	Yes
Are all of the hatches equipped with electronic monitoring devices?	No
Are the external plumbing components housed in a secure vault or out-building?	Yes
Does the surrounding geography of the tank obscure it from public view?	No
Does the exterior of the tank show signs of trespass?	No

### Measurements





DISCLAIMER

# **Steel Potable Water Reservoir Immediate Needs Assessment**

Job Number: 37107	Utility: City of E. Helena	Tank: NO.1 250KG	BG
Inspector: J. Johnson	Dive Controller: E. Craig	Date: 4/26/2010	
<ol> <li>Health and Safety Items         Safety Climb System Installation: N,</li> </ol>	/A-Below Grade		
Vent Screen Repairs: None			
2. Testing Items  Dye Testing for Leak Evaluation: No	ne Performed		
Presence of Lead Test (Interior/Exte	erior): N/A		
3. Destructive Testing Items  ☐ % of Lead Test (Interior/Exterior) (C	Coating samples are removed for labor	atory analysis) N/A	
Coating Adhesion Test (Interior/Ext	erior): N/A		
Specific written authorization requi	red to perform destructive testing. Des	tructive tests include touch-up of co	oating system.
4. Repair Items  Epoxy Coating Repairs: None Recom	mended		
Temporary Leak Repairs: None Need	ded		
Float Operated Level Indicator Repa	airs / Maintenance: N/A		
Hypalon Repairs: N/A			
5. Security Related Items (Critical security  Tank vents are not equipped with a		available)	
✓ Tank hatches are not equipped with	h a security hatch locking device:		
☐ Tank perimeter not adequately sec	ured:		
The above mentioned additional work is consider in conjunction with work currently being perform	red immediately necessary and is recomm ned while the crew is on site.	ended to be completed. Some items ma	ay be completed
Rese	rvoir Inspection Condition	Supplemental	
Clean and Inspect Every Three to Five Years			
Security Items Mentioned Above			

## **Concrete Water Reservoir Interior Condition Survey**

Job Number: 37107

Utility: City of E. Helena

Tank: No 2 250KG BG

Inspector: J. Bingham

Dive Controller: J. Johnson

Date: 4/26/2010

B - Erosion E - Deflection I - Deformation C - Bilistering F - Expansion I - Settling L - Delamination O - Honeycomb R - Popouts U - Leaching X - Stalins Reinforce    QUADRANT 1	Inspector: J. Bingham	Dive Co	introller: J. Johnson		D	ate: 4/26/2010	
A - Abrasion D - Cracking B - contraction B - Erosion E - Deflection H - Deformation K - Checking N - Cold Pour C - Spalling T - Chalking W - Efforescence Z - Exposis C - Bilstering F - Expansion I - Settling L - Defamination O - Honeycomb R - Popouts U - Leaching W - Efforescence Z - Exposis C - Bilstering F - Expansion I - Settling L - Defamination O - Honeycomb R - Popouts U - Leaching W - Efforescence Z - Exposis C - Bilstering F - Expansion I - Settling L - Defamination O - Honeycomb R - Popouts U - Leaching W - Efforescence Z - Exposis C - Bilstering R - Popouts U - Leaching W - Efforescence Z - Exposis C - Bilstering R - Popouts U - Leaching W - Efforescence Z - Exposis C - Bilstering R - Popouts U - Leaching W - Efforescence Z - Exposis C - Bilstering R - Popouts U - Leaching W - Efforescence Z - Exposis C - Bilstering R - Popouts U - Leaching W - Efforescence Z - Exposis R - Bilstering R - Popouts U - Leaching W - Efforescence Z - Exposis R - Bilstering R - Bilstering R - Popouts U - Leaching W - Efforescence Z - Exposis C - Bilstering R - Popouts U - Leaching W - Efforescence Z - Exposis R - Bilstering R - Popouts U - Leaching W - Efforescence Z - Exposis R - Bilstering R - Popouts U - Leaching W - Efforescence Z - Exposis R - Bilstering R - Popouts U - Leaching W - Efforescence Z - Exposis R - Bilstering R - Station R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R - Popouts R		AM					
INTERIOR RESERVOIR ROOF  Roof Slab(s) Expansion Joint(s) Support Beam(s) Beam Joint(s) Roof-Column Joint M.X.W  General Appearance: Good Coating: N/A Vents: Good Level-Sensors:  INTERIOR RESERVOIR WALLS  N.X. Wall-Roof Joint W.X. Wall-Roof Joint W.X. Wall Structure M.X. X. Q.S,Z  General Appearance: Good Coating: N/A Ladder: Good Leaking: None observed Dye Tested: No  INTERIOR RESERVOIR SUPPORT COLUMNS  Columns Gimn-Floor Plates General Appearance: Good Coating: N/A ColumnBase Leaking: None observed Dye Tested: No  All expansion Joints Uniform width: Uniform Level: Gaskets Intact:  INTERIOR RESERVOIR SUPPORT COLUMNS  Columns Gimn-Floor Plates General Appearance: Good Coating: N/A ColumnBase Leaking: None observed Dye Tested: No  All expansion Joints Uniform width: Uniform Level: Gaskets Intact:  INTERIOR RESERVOIR FLOOR  Perimeter Joint N,X X X X INTERIOR RESERVOIR FLOOR  Perimeter Joint N,X X X INTERIOR RESERVOIR FLOOR  N,X X X X INTERIOR RESERVOIR SUPPORT COLUMNS  Gaskets Intact:  INTERIOR RESERVOIR FLOOR  N,X X X X INTERIOR RESERVOIR FLOOR  N,X X X INTERIOR RESERVOIR FLOOR  N,X X X INTERIOR RESERVOIR SUPPORT COLUMNS  All expansion Joints Uniform width: Uniform Level: Gaskets Intact:  INTERIOR RESERVOIR FLOOR  N,X X X X INTERIOR RESERVOIR FLOOR  N,X X X X X X X X X X X X X X X X X X	B – Erosion E - Deflection H	- contraction J - Curling - Deformation K - Checki	M - Vold ng N – Cold Pour	P - Pitting Q - Spalling	T - Chalking	W - Efflorescence	Y - Corrosion Z – Exposed Reinforcemen
Roof Slab(s) Expansion Joint(s) Support Beam(s) Beam Joint(s) Roof-Column Joint Sepport Beam(s) Roof-Column Joint Sepport Beam(s) Roof-Column Joint Sepport Beam(s) Roof-Column Joint Sepport Beam(s) Roof-Column Resem Joint N,X,W N,X,W N,X,W N,X,W N,X,W N,X,W N,X,W N,X,W N,X,W N,X,W N,X,W N,X,W N,X,W N,X,W N,X,W N,X,W N,X,W N,X,W N,X,W N,X,W N,X,W N,X,W N,X,W N,X,W N,X,W N,X,W N,X,W N,X,W N,X,W N,X,W N,X,W N,X,W N,X,W N,X,W N,X,W N,X,W N,X,W N,X,W N,X,W N,X,W N,X,W N,X,W N,X,X,W N,X,W  QUAD	a — Artenas, Sea				QUAD	RANT 4	
Support Beam(s) Beam Joint(s) Roof-Column Joint N.X.W N.X.W N.X.W N.X.W N.X.W N.X.W  General Appearance: Good Coating: N/A Vents: Good Level-Sensors: All expansion Joints Uniform width: Yes Uniform Level: Yes Gaskets Intact: Yes  ### *********************************						X,Q,ID,W,B,Z	
General Appearance: Good Coating: N/A Vents: Good Level Sensors:  All expansion Joints Uniform width: Yes Uniform Level: Yes Gaskets Intact: Yes    INTERIOR RESERVOIR WALLS   N,X	Support Beam(s)						
All expansion Joints Uniform width: Yes Uniform Level: Yes Gaskets Intact: Yes    NTERIOR RESERVOIR WALLS   N,X						N,X,W	
Wall-Roof Joint Wall Structure  N,X X, Q,S,Z  General Appearance: Good Coating: N/A  Ladder: Good Leaking: None observed Dye Tested: No  INTERIOR RESERVOIR SUPPORT COLUMNS  Columns S, X  General Appearance: Good Coating: N/A  ColumnBase Leaking: None observed Dye Tested: No  INTERIOR RESERVOIR SUPPORT COLUMNS  S, X  General Appearance: Good Coating: N/A  ColumnBase Leaking: None observed Dye Tested: No  INTERIOR RESERVOIR FLOOR  Perimeter Joint N, X X  INTERIOR RESERVOIR FLOOR  Perimeter Joint N, X X  INTERIOR RESERVOIR FLOOR  INTERIOR RESERVOIR FLOOR  Outlet Structure: Good  Outlet Structure: Good		_					
Wall Structure  X, Q,S,Z  General Appearance: Good  All expansion Joints  Uniform Level:  INTERIOR RESERVOIR SUPPORT COLUMNS  Columns  S, X  General Appearance: Good  Coating: N/A  ColumnBase Leaking: None observed  Dye Tested: No  INTERIOR RESERVOIR SUPPORT COLUMNS  S, X  General Appearance: Good  Coating: N/A  ColumnBase Leaking: None observed  Dye Tested: No  All expansion Joints  Uniform Level:  Gaskets Intact:  INTERIOR RESERVOIR FLOOR  Perimeter Joint  N, X  X  INTERIOR RESERVOIR FLOOR  Perimeter Joint  N, X  X  INTERIOR RESERVOIR SUPPORT COLUMNS  S, X  S, X  S, X  S, X  INTERIOR RESERVOIR FLOOR  Perimeter Joint  N, X  X  INTERIOR RESERVOIR FLOOR  Perimeter Joint  N, X  X  Inlet Structure: Good  Outlet Structure: Good	Wall-Roof Joint N X		TERIOR RESI	and the same of	WALLS	- Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Control of the Cont	
All expansion Joints Uniform width: Uniform Level: Gaskets Intact:  INTERIOR RESERVOIR SUPPORT COLUMNS  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X	AND PROPERTY AND ADDRESS OF THE PARTY AND ADDR		5,Z	The state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the state of the s			
Columns  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S, X  S,	•••			_		Dye Tested: (	٧o
Columns  S, X  Climn Floor Plates  General Appearance: Good  Coating: N/A  ColumnBase Leaking: None observed  Dye Tested: No  All expansion Joints Uniform width:  Uniform Level:  S, X  ColumnBase Leaking: None observed  Dye Tested: No  All expansion Joints Uniform width:  INTERIOR RESERVOIR FLOOR  Perimeter Joint N, X X  N, X X  General Appearance: Good  Coating: N/A  Inlet Structure: Good  Outlet Structure: Good	, an expension source					LUMNS	
General Appearance: Good Coating: N/A ColumnBase Leaking: None observed Dye Tested: No  All expansion Joints Uniform width: Uniform Level: Gaskets Intact:  INTERIOR RESERVOIR FLOOR  Perimeter Joint N, X N, X X N, X X  General Appearance: Good Coating: N/A Inlet Structure: Good Outlet Structure: Good		and the same of the same					
Perimeter Joint N, X N, X N, X N, X N, X N, X X Seneral Appearance: Good Coating: N/A Inlet Structure: Good Outlet Structure: Good		Coating: N/A	ColumnBase Leaking	: None observ	ed Dye Tes	sted: No	•
Perimeter Joint N, X N, X N, X N, X X N, X X X X X X X	All expansion Joints—Uniform w	vidth: Uniform	n Level:	-Gaskets Inte	16t!	_	
Floor Slabs X X Inlet Structure: Good Outlet Structure: Good			ITERIOR RES		RFLOOI	R	
Overflow Structures Cond Super Systems Cond Legisland Non-Abound Due Tonted, No.	General Appearance: Good	Coating: N/A	Inlet Structure: Goo	d Oı	utlet Structure:	Good	
Overnow structure: Good Sump system: Good Leaking: None observed Dye rested: No	Overflow Structure: Good	Sump System: Good	Leaking: None	observed	Dye Tested	: No	

**Additional Interior Notes / Comments** 

## **Concrete Water Reservoir Exterior Condition Survey**

Job Number: 37107

Utility: City of E. Helena

Tank: No 2 250KG BG

Inspector: J. Bingham

Dive Controller: J. Johnson

Date: 4/26/2010

## AMERICAN CONCRETE INSTITUTE ACI 201.1R-08 / 311.1R

CONCRETE CONDITION CODE

A - Abrasion D - Cracking G - contraction J - Curling M - Void P - Pitting S - Bugholes V - Exudation Y - Corrosion B - Eroslon E - Deflection H - Deformation K - Checking N - Cold Pour Q - Spalling T - Chalking W - Efflorescence Z - Exposed C - Blistering F - Expansion R - Popouts 1 - Settling L - Delamination O - Honeycomb U - Leaching X - Stains Reinforcement

QUADRANT 1 QUADRANT 2 QUADRANT 3 QUADRANT 4

#### EXTERIOR RESERVOIR ROOF

Roof Slab(s)	X,Z,D,P,Q	X,Z,D,P,Q	X,Z,D,P,Q	X,Z,D,P,Q
Roof-Wall Joint	N,X,Z,D,P,Q	N,X,Z,D,P,Q	N,X,Z,D,P,Q	N,X,Z,D,P,Q

General Appearance: Good

Coating: N/A

Vents: Good

Level Indicator: -----

Hatch & Gaskets: Good

Hatch hinges: Good

Lock & Hasp: Good

Hatch Cage & Railing.

All expansion Joints - Uniform width:

Uniform Level: -

- Gaskets Intact: -

#### EXTERIOR RESERVOIR WALLS

Wall-Roof Joint Wall Structure N,X Y, X N,X Y, X N,X Y,X N,X Y, X

General Appearance: Good

Coating: N/A

Ladder:

Safety Climb:

Overflow Structure: ----


Clean out hotch:-

Leaking: None observed

All expansion Joints Uniform width:

Uniform Level:

Gaskets Intact:



**Additional Exterior Notes / Comments** 

# Potable Water Reservoir Contamination, Health and Safety Report

Job Number: 37107

Utility: City of E. Helena

Tank: No 2 250KG BG

Inspector: J. Bingham

Dive Controller: J. Johnson

Date: 4/26/2010

# Complies With: AWWA • OSHA • ANSI • NIOSH • NAVFAC • NFPAC

	С	ONTAMIN	ATI	ON & HEALT	ГН	
Air Vents	Type: J-Tube		#: 2	Screen Condition(	s): Good	
Hatches	Type: Other		#: 1	Secured Properly:	Yes	Properly Sealed: Yes
Exterior Overflow	Flapper:	Screen:		Gasket:	· · · · · ·	Condition:
Cathodic Covers	In- Place:		#: ====	Gasket:		Properly Sealed:
Roof to Wall Joint	Welded: No	Properly Sealed	: Yes			
Roof Integrity	Holes: No	Cracking: No	Star	ding Water: No		
Wall Integrity	Holes: No	Cracking: Yes				
Manway Integrity	Leaks:	Condition:				
Water Clarity	General Appearan	ce: Good			Odor: N	one
loating Surface Debris	Type: None				Source:	N/A
Hypalon-Floating Cover	Condition:	Holes:	Tears			
Telemetry Penetrations	Properly Sealed: •	-				


	FACILIT	YSAFE	ETY CON	1 P L I A N C	E		
Exterior Ladder							
Overall-Ladder	Condition:	#:	: Offset	: Landing:	Height:		
Vandal Guard	Present:	Vandal	Guard Locked:				
Ladder Rails & Rungs	Condition:	Missin	g/Damaged Run	gs.			
Rung Spacing & Depth	Spacing: in	. (max 12")	Toe Depth:	in. (min	7")		
Rail Spacing & Size	Width:in	(min 2")	Thickness:	in. (min 1	/4") Rail to Rail:	:	in. <i>(min 16")</i>
Safety Climb System	Type:	Condi	ition:		_		
Number & Locations	Wall: 1	.eg:	Roof:	Riser Pipe:	Other:		
Ladder Attachments							
Manways					_		
Type and size	Түре:	#:	****	Size:	inches (24" – 18'x2	2" min)	
Support Structure	Туре:	Condit	ion:				
- Number & Locations	Wall: F	Roof:	Riser Pipe:	Other			
<u>Hatches</u>							
Hatch Type & Size	Type: Other	#	h: 1	Size: 72x30	in. (24" - 24"x15"	min)	
Hatch & Lid Lip Height	Hatch: 5	in. <i>(min 4")</i>	Lid: 2	in. <i>(min 2")</i>			
Balconies & Railing							
Deck / Walkways	Condition:	1	Width:				
Hand Rails	Condition:		leight:	in. (min 42")	No. Rails:	(min 2)	
Toe Rail	Condition:	ŀ	Height:	in. (min 4")			
Welds / Attachments	Condition:						
Roof							
Safety Tie-Off Points	Condition:	,	¥:				
Antennas	Type:	#					

## **Circular Tank Diagram / Information Worksheet**

Job Number 37107

Utility Name City of E. Helena

Tank Name No 2 250KG BG



# Steel Potable Water Reservoir Security / Measurement Worksheet

Job Number 37107


Utility Name City of E. Helena


Tank Name No 2 250KG BG

## Security

Is the area surrounding the tank well lit?	No
Is the tank surrounded by a Security Fence?	Yes
Are the access gates locked?	Yes
Is the tank equipped with a Vandal Guard on the primary access ladder?	No
If so, is the Vandal Guard locked?	No
Are the vents equipped with security vent shrouds?	Yes
Are all of the hatches equipped with electronic monitoring devices?	No
Are the external plumbing components housed in a secure vault or out-building?	Yes
Does the surrounding geography of the tank obscure it from public view?	No
Does the exterior of the tank show signs of trespass?	No

## Measurements





#### DISCLAIMER

# **Steel Potable Water Reservoir Immediate Needs Assessment**

Job Ni	umber: 37107	Utility: City of E. Helena	Tank:	No 2 250KG BG
Insped	ctor: J. Bingham	Dive Controller: J. Johnson	Date:	4/26/2010
1. F	lealth and Safety Items  Safety Climb System Installation: N	I/A-Bełow Grade		
	Vent Screen Repairs: None			
	esting Items  Dye Testing for Leak Evaluation: N	one Performed		
	Presence of Lead Test (Interior/Ext	erior): N/A		
	Destructive Testing Items	Coating samples are removed for labora	tory analysis) N/A	
	Coating Adhesion Test (Interior/Ex	terior): N/A		
	Specific written authorization requ	ired to perform destructive testing. Dest	ructive tests include to	ouch-up of coating system.
4. F	Repair Items ☐ Epoxy Coating Repairs: None Recon	nmended		
	☐ Temporary Leak Repairs: None Nee	eded		
	☐ Float Operated Level Indicator Rep	pairs / Maintenance: N/A		
	Hypalon Repairs: N/A			
5. S	ecurity Related Items (Critical securit	ty upgrade information is immediately av a security vent shroud:	vailable)	
	✓ Tank hatches are not equipped with	th a security hatch locking device:		
	☐ Tank perimeter not adequately see	cured:		
The al	pove mentioned additional work is conside junction with work currently being perform	ered immediately necessary and is recommended while the crew is on site.	nded to be completed. So	ome items may be completed
	Rese	ervoir Inspection Condition S	Supplemental	
Clean	and Inspect Every Three to Five Years			
Securi	ty Items Mentioned Above			

## **Concrete Water Reservoir Interior Condition Survey**

Job Number: 37107

Utility: City of East Helena

Tank: No. 3(1 MG B/G)

Inspector: J. Bingham

Dive Controller: J. Johnson

Date: 4/27/2010

			DITE CONTROLL				ate//	
				N CONCRETE IN 201.1R-08 / 311.1	State of the State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of State of			
B – Erosion E -	Cracking Deflection Expansion	G - contraction H - Deformation I - Settling	CONCRET J - Curling K - Checking L - Delamination	E CONDITIO M - Void N – Cold Pour O - Honeycomb	N CODE P - Pitting Q - Spalling R - Popouts	S - Bugholes T - Chalking U - Leaching	V - Exudation W - Efflorescence X - Stains	Y - Corrosion Z – Exposed Reinforcement
	OUA	DRANT 1	QUAD	RANT 2	OUAL	RANT 3	QUAD	RANT 4
								KANI 4
D661.163				RIOR RES		ROOF		
Roof Slab(s)	X, ID, W		X, ID, W		X, ID, W		X, ID, W	
Expansion Joint(s) Support Beam(s)	Long and					Lagranoville		
Beam Joint(s)								
Roof-Column Join	X, N		X, N		X, N		X, N	
General Appearan		Coating: N	/A Ver	nts: Good	Level Senso	rs: Good		
All expansion Join	ts Uniforn	n width:	Uniform Level:		-Gaskets Inta	ct.	_	
Wall-Roof Joint	X, N	The second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second secon		IOR RESE		WALLS	(Antinius):	•
Wall Structure	X, S		X, N X, S		X, N X, S		X, N X, S	
General Appearar		Coating: N		ider: Good		lone observed		No.
All expansion Join		n width: Yes	Uniform Level:	Yes	Gaskets Inta		•	
		INT	ERIOR RI	ESERVOII	RSUPP	ORT CO	LUMNS	
Columns	X, S		X, S		X, S		X, S	
Clmn Floor Plates	X, S		X, S		X, S		X, S	
General Appearar		Coating: N	/A Col	lumnBase Leaking	: None observ	ed Dye Tes	ited: No	
<del>All expansion Join</del>	<del>ts Uniforn</del>	n width:	Uniform Level:		Gaskets-Inte	16t:	_	
			INTER	IOR RES	ERVOIR	RFLOOF	₹	
Perimeter Joint	X		X		X		x	
Floor Slabs	X, R		X, R		X, R		X, R	
General Appearar	nce: Good	Coating: N	/A Inle	et Structure: Goo	d Ou	ıtlet Structure:	Good	
Overflow Structur	e: Good	Sump System	11.	Leaking: None o	bserved	Dye Tested:	: No	
All expansion Join	ts Uniforn	n width: Yes	Uniform Level:	Yes	Gaskets Inta	act: Yes		
Additional Inter	ior Notes	/ Comments						
.aaitional inter	ior Notes ,	/ Comments						

## **Concrete Water Reservoir Exterior Condition Survey**

Job Number: 37107

Utility: City of East Helena

Tank: No. 3(1 MG B/G)

Ground Subsidence: -----

Overflow: -----

Inspector: J. Bingham			Dive Controller: J. Johnson			Date: 4/27/2010		
			The second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second secon	N CONCRETE IN 201.1R-08 / 311.:				
B – Erosion E - D	iracking eflection xpansion	G - contraction H - Deformation I - Settling	CONCRET J - Curling K - Checking L - Delamination	E CONDITIO M - Void N – Cold Pour O - Honeycomb	N CODE P - Pitting Q - Spalling R - Popouts	5 - Bugholes T - Chalking U - Leaching	V - Exudation W - Efflorescence X - Stains	Y - Corrosion Z – Exposed Reinforcement
Ī	QUA	DRANT 1	QUAD	RANT 2	QUAD	RANTS	QUAD	RANT 4
Pea-Gravel	covere	d	EXTER	IOR RES	ERVOII	RROOF		
Roof Slab(s)								
*Expansion Joint(s)* Roof-Wall Joint	X,S,ID,W		X,S,ID,W		X,S,ID,W		X,S,ID,W	
General Appearance	Charles - Maria Care	Coating: N		nts: Good	Level Indica	tor: Good	1,5,5,5,5	
Hatch & Gaskets: G		Hatch hinges:		ock & Hasp: Good		Hatch Cage	& Railing:	
All expansion Joints	<del>Uniform</del>	rwidth.	Uniform Level.		Gaskets Inta	rct.		
			EXTER	IOR RESI	RVOIR	WALLS		
Wall-Roof Joint	X,S,ID,W		X,S,ID,W		X,S,ID,W		X,S,ID,W	
-Wall-Structure								
General Appearance	e: Good	Coating: G	ood Lad	der:	Safety Clir	nb:	-1	
Overflow Structure	;	Clean out h	otch:	- Leaking: Non	e observed			
All expansion Joints	- Uniform	width:	Uniform Level:		Gaskets Into	ict.	<del></del>	
		EXTERI	OR RESE	RVOIR F	OOTING	55 / FO	UNDATIO	N
Perimeter Joint								
Floor Slab								
Footing Ring	Bah ye		+					

## **Additional Exterior Notes / Comments**

All expansion Joints Uniform width: -----

Coating: N/A

Unable to fully evaluate exterior-Buried

Sump-Valve Vault General Appearance: ----

Leaking: -----

Gaskets Intact: -----

Uniform Level: .....

# **Potable Water Reservoir Contamination, Health and Safety Report**

Job Number: 37107

Utility: City of East Helena

Tank: No. 3(1 MG B/G)

Inspector: J. Bingham

Dive Controller: J. Johnson

Date: 4/27/2010

## Complies With: AWWA • OSHA • ANSI • NIOSH • NAVFAC • NFPAC

	CO	NTAMIN	ATI	ON & HEALTH	
Air Vents	Type: Mushroom		#: 2	Screen Condition(s): G	iood
Hatches	Type: Other		#: 1	Secured Properly: Yes	Properly Sealed: Yes
Exterior Overflow	Flapper:	Screen:		Gasket:	Condition:
Cathodic Covers	In- Place:		#:	Gasket:	Properly Sealed:
Roof to Wall Joint	Welded: No	Properly Sealed:	Yes		
Roof Integrity	Holes: No	Cracking: No	Star	iding Water: No	
Wall Integrity	Holes:	Cracking:	-		
Manway Integrity	Leaks:	Condition: ***			
Water Clarity	General Appearance:	Good		Ode	or: None
Floating Surface Debris	Type: None			Sou	irce.
Hypelon Floating Cover	Condition:	Holes:	Tears	<del></del>	
<b>Telemetry Penetrations</b>	Properly Sealed: Yes				

	FACILI	ITY SAF	ETY CON	A P L I A N C	E	
Exterior Ladder						
Overall tadder	Condition:	*	: Offse	t Landing:	Height	
Vandal Guard	Present:	Vanda	l Guard Locked:			
Ladder Rails & Rungs	Condition:	Missir	ig/Damaged Rui	īgs:		
Rung Spacing & Depth	Spacing:	in. (max 12)	Toe Depth:	in. <i>(min</i>	7")	
Rail Spacing & Size	Width:	In. (min 2")	Thickness:	in. (min :	1/4") Rail to Rail:	: in. <i>(min 16")</i>
Safety Climb System	Type:	Cond	lition:			
Number & Locations	Wall:	Leg:	Roof:	Riser Pipe:	Other:	
Ladder Attachments						
Manways						
Type and size	Type:		:	Size:	inches (24" – 18'x2	2" min)
Support Structure	Type:	Condi	tion:			
Number & Locations	Wall:	Roof:	Riser Pipe:	Othe	-	
<u>Hatches</u>						
Hatch Type & Size	Type: Other		#: 1	Size: 72x48	in. (24" – 24"x15"	min)
Hatch & Lid Lip Height	Hatch: 10	in. <i>(min 4*)</i>	Lid: Flush	in. (min 2")		
Balconies & Railing						
Deck / Walkways	Condition:	_	Width:			
Hand Rails	Condition:		Height:	in. <i>(min 42")</i>	No. Rails:	(min 2)
Toe Rail	Condition:		Height:	in. ( <i>min 4")</i>		
	Condition:					
Roof						
Safety Tie-Off Points	Condition:		#:			
Antennas	Туре:		#:			

## **Circular Tank Diagram / Information Worksheet**

Job Number 37107	Utility Name City of East Helena	Tank Na	me No. 3(1 MG B/G)
Quadrant 1	Quadrant 2	Quadrant 3	Quadrant 4
Minor Staining Corrosion in all Quads			<b></b>
RO	DOF Testing and Disc	repancy Locations FL	OOR
Q4 Settling	Q1	Q4 Minor	Q1 Staining
Settling			1 Quadrants
Q3	Q2	Q3	Q2
1/8" 1/8" 1/8" 1/8" 1/8" 1/8" 1/8"	1/8"	T HL P XO	+ + + + + + + + + + + + + + + + + + + +
1/8" 1/8' Sediment Depth Meas	Plumb   O=Our   V=Ven   urements	ht D=Drain S=Sump der H=Hatch P=Overflow	Column Placement pe of Column
Average Sediment Depth = The sum of all divided by the number of measurements	rancesurements taken, rances Staken Tatelo	emetry To	p Structure 🖽 🗆 🚶 🗵
Avg. Depth 1/8" Cubic Yardage	Sediment Type Sands/Silt	Co	olumn Construction Concrete

## Steel Potable Water Reservoir Security / Measurement Worksheet

Job Number 37107


Utility Name City of East Helena

Tank Name No. 3(1 MG B/G)

## Security

<u> </u>	
Is the area surrounding the tank well lit?	No
Is the tank surrounded by a Security Fence?	Yes
Are the access gates locked?	Yes
Is the tank equipped with a Vandal Guard on the primary access ladder?	N/A
If so, is the Vandal Guard locked?	N/A
Are the vents equipped with security vent shrouds?	No
Are all of the hatches equipped with electronic monitoring devices?	No
Are the external plumbing components housed in a secure vault or out-building?	Yes
Does the surrounding geography of the tank obscure it from public view?	No
Does the exterior of the tank show signs of trespass?	No
	1

## Measurements



#### DISCLAIMER

# **Steel Potable Water Reservoir Immediate Needs Assessment**

lop	Number: 37107	Utility: City of East Helena	Tank:	No. 3(1 MG B/G)
Insp	ector: J. Bingham	Dive Controller: J. Johnson	Date:	4/27/2010
1.	Health and Safety Items Safety Climb System Installation: N/A	4		
	■ Vent Screen Repairs: Fine Mesh (Good	d Condition)		
2.	Testing Items  Dye Testing for Leak Evaluation: Nor	ne Performed		
	Presence of Lead Test (Interior/Exte	rior): N/A		
3.	Destructive Testing Items  Mof Lead Test (Interior/Exterior) (Co	oating samples are removed for labor	atory analysis) N/A	
	Coating Adhesion Test (Interior/Exte	erior): N/A		
	Specific written authorization requir	ed to perform destructive testing. Des	structive tests include to	ouch-up of coating system.
4.	Repair Items  Epoxy Coating Repairs: None Recomm	nended		
	☐ Temporary Leak Repairs: None Need	ed		
	☐ Float Operated Level Indicator Repa	irs / Maintenance: N/A		
	☐ Hypalon Repairs: N/A			
5.	Security Related Items (Critical security    Tank vents are not equipped with a	upgrade information is immediately a security vent shroud:	available)	
	✓ Tank hatches are not equipped with	a security hatch locking device:		
	☐ Tank perimeter not adequately secu	red:		
The in c	above mentioned additional work is considere on junction with work currently being performed to the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract of the contract o	ed immediately necessary and is recommo ed while the crew is on site.	ended to be completed. S	ome items may be completed
	Reser	voir Inspection Condition	Supplemental	
Clea	an and Inspect Every Three to Five Years			
Sec	urity Items Mentioned Above			



#### System Storage Tank General Condition Report (DEQ Supplemental)

Date: 7/21/07

System East 250K6-Concrete PWSID# Capacity 250 KG (In Gallons) General Condition of the Exterior Surfaces and Components Roof Walls Bowl Fair: Roof Walls Poor: Roof Walls **Bowl** Coaling Good: Yes Corresion No % Fair: Poor: Support Structure Good Legs Foundations Legs **Foundations** Legs Foundations Signs of Trespass No Yes Describe: General Condition of the Exterior Ladders Condition Corrosion Good Yes Poor Fair % Locked Vandal Guard Yes OSHA Compliant Yes No Describe General Condition of the Exterior Handrails and Balconies Poor Fair Condition Good % Corrosion Yes No No Describe: OSHA Compliant Yes General Condition of the Manways Condition Good Poor Yes Signs of Leakage No Describe General Condition of the Tank Level Controls Poor Condition Good Operational Yes No Describe General Condition of the Exterior Hatches Condition Good Fair Poor Yes % Corresion No Yes Locked No Gasket Yes No Framed 4" Above Roof Yes No Lid has 2" Overlap Yes No Evidence of Cantamination No Describe General Condition of the Exterior Vents Condition Good Fair Poor Yes Corrogion-No % Yes Properly Screened No Yes Adequately Vented No Equipped with Security Shroud | Yes Nο General Condition of the Interior Surfaces and Components -Costing----Good: Roof Walls Floor Fair: Roof Walls Floor Poor; Walls Roof Floor Yes Corresion No % Support Structure / Columns Good Fair Poor Plumbing Good Fair Poor Sedimentation Yes No Depth 13/1 Grating on Outlet Yes No Silt Stopper on Outlet Yes Νo General Condition of the Interior Surfaces and Components Clarity Good Fair Poor Growth (Algae / Plant) Yes No Foam Yes No Yes Signs of birds / insects No Yes Describe: Other: No Additional Comments OF Inspection

Inspection Conducted By: Liquid Engineering Corporation P.O. Box 80230 Billings, MT 59108 1-800-438-2187

Post or Mail to:

Montana Department of Environmental Quality **Public Water Supply Section** P.O. Box 200901 Helena, MT 59620-0901

# Liquid Engineering Corporation Voir Contamination, Health and Safety Report

Job No. 330 14 Utility City of FAST HEIGNA Tank 250 KL S/B EAST Inspector J. Vanderschilde Team Leader T. Spirling Date 7/21/07 Form 1
Complies With: AWWA • OSHA • ANSI • NIOSH • NAVFAC • NFPAC
Contamination & Health Checklist •
Air Vents Hatches Type: # Secured Properly Ves No Properly Sealed Ves No Exterior Overflow Cathodic Covers Roof to Wall Joint Roof Integrity Wall Integrity Wall Integrity Water Clarity Floating Surface Debris Hypalon Floating Cover Tolomotry Penetrations Other Discrepancies  Type: # Screen Conditions: Good Fair Poor Type: # Secured Properly Ves No Properly Sealed Ves No Gaskets: Yes No Condition: Good Fair Poor Covers in Place: Yes No Gaskets: Yes No Properly Sealed: Yes No Welded: Yes No Welded: Yes No Coracking: Yes No Other:  Cracking: Yes No Standing Water: Yes No Other:  Cracking: Yes No Condition: Good Fair Poor Odor: When Other:  Condition: Good Fair Poor Tolomotry Penetrations Other Discrepancies
Overall Ladder     Ladder Vandal Guard     Ladder Rails & Rungs     Rung Spacing & Depth     Rail Spacing & Size     Safety Climb System     Number & Locations     Ladder Attachments  - Facility Safety Compliance Checklist  - Condition: Good Fair Poor Offset Landings Yes / No #: Height:  Vandal Guard Locked: Yes / No Condition: Good Fair Poor Missing/Damaged Rungs: Yes No Spacing: in. (min. 7")  - Width: in. (min. 2") Thickness: in. (min. ½") Rail to Rail: in. (max 16")  - Type: Cage Neiched Rail Cable Grab Other None Condition: Good Fair Poor Number & Locations Ladder Attachments  - Manways  - Manways
Type and Size Type: Round Oval Square other Size:(24" - 18"X22" min.) # Support Structure Dogged Davit Arm Polled Other Condition: Good Fair Poor Number & Locations Wall Roof Riser Pipe Other
Hatch Type and Size Round Square Rectangle Other (24" - 24"X15" min.) 38 x 38  Hatch & Lid Lip Height Hatch (4" min.) Lid (2" min.)
Deck/Walkways   Condition: Good Fair Poor Width:   Hand Rails   Condition: Good Fair Poor Height   (42" min.)   No. Rails   (min. 2)
Roof   Safety Tie-Off Points   Condition: Good   Fair   Pool   #
Other Discrepancies
Additional Information

	Concre	te Water Res	ervoir Inter	ior Condition	Survey	,
Job No. 33014		Utility C141 0-	f EAST	Helena	Tank 250 K	6 S/B EAST
Inspector 5 Vand	, IV	Dive Controller 🛨		,	Date 7/21/0	7
			an Concrete CI 201.1R-92 / 311.			
		CON	CRETE CONDITION	CODE		
A - Abrasion D - Crackir B - Erosion E - Deflecti C - Blistering F - Expans				tting S - Bugholes balling T - Chalking oppouts U - Leaching		corrosion xposed Reinforcement
	QUADRANT 1*	QUADRANT 2*	QUADRANT 3*	QUADRANT 4*	REMARK	S
			ROOF 1			
General Appearance	(Good)	Poor	Damaged			>=
Interior Goating~	Good	Cracking	Blistering	Separation	N/A	
Vents	Good	Poor	Critical			
Water Level Sensors	Good	Damaged	6-1	Garal		
Roof Slab(s)	CRADE!	79300	CHOON_	<u> </u>		
- Expansion Joints 1						
-Beam Joints 1						
Roof to Column Joints	1 Carel	Canal	Tand	/ml		
Ati Expansion Joints	Uniform Width- Y	es / No Uniform Lev	ol Vos (No. Cos	ivete letest. Ven ( No.		
Other	Omioriii valdiii- 1	es / NO DIMOITTE	rei- res / NO Gas	kets Intact- Yes / No		
Other					See Inspection V	Vorksheet for specific
areas						
			WALLS 2			
General Appearance	Good	Poor	Damaged			
Interior Coating	Good	Cracking	Blistering	Separation		
Wall to Roof Joint 2	Carred,	(good)	(9200)	(200)		
Wall Structure 2	(9000)	Cood	(2000	COOL		
Ladder Structure	Good	Poor	Damaged	Missing		
All Expansion Joints	Uniform Width- Y			ets Intact- Yes / No		
Leaking	None Observed	Possible Lea	aking Dye	Tested- Yes No		
Other					2 See Inspection V	Vorksheet for specific
areas					See Hispection 9	volustiest for specific
	0	SU	PPORT COLUM	NS ³		
General Appearance	Good	Poor	Damaged			
Coating	Good	Cracking	Blistering	Separation		
Columns 3	Local	(9000	Cost	(3009		
Column Floor Plates 3						
All Expension Joints	Uniform Width-			kets Intact- Yes / No		
Column Base Leaking	None Observed	Possible Le	eaking Dye	Tested- Yes No		
Other					See Inspection Wor	ksheet for specific columns
			FLOOR 4		God mapasium Wor	manage for appearing constitutes
General Appearance	Good	Poor	Damaged			
Ceating	Good	Cracking /	Blistering	Separation/		
Perimeter Joint 4	19000	Siderilly .	Character 1		Sasket Intact- Yes / No	-
Floor Slabs 4	Beck	End	(good)	(3000)	posket litterit. Les / IAO	
Iniet Structure	Bood	Poor	Critical			
Outlet Structure	Good	Poor	Critical			
Overflow Structure	Good	Poor	Critical			
Sump System	Good	Cracking	Spalling			
All Expansion Joints				askets Intact- Yes / No	)	
Leaking	None Observe	_		ye Tested- Yes No		
Hammer/Chain Sound		None	TAKEN			
Other						
					48	Market de la la


areas

# Liquid Engineering Corporation Concrete Water Reservoir Exterior Condition Survey

ob No. <u>33014</u> Ispector <u>T. Van De</u>		tility <u>City</u>		Heleng	Tank <u>250</u> Date <u>7/2</u>	KL S/B GAS
			can Concrete II ACI 201.1R-92 / 311.18			
		CI	NCRETE CONDITION CO	nr -	_======================================	
A - Abrasion D - Cracking B - Erosion E - Deflection C - Blistering F - Expansion		J - Curling N K - Checking N	I - Void P - Pittie I - Cold Pour Q - Spal D - Honeycomb R - Pop	ng S - Bugholes lling T - Chalking	V - Exudation W - Efflorescence X - Stains	Y - Corrosion Z - Exposed Reinforcement
Q	UADRANT 1*	QUADRANT 2*	QUADRANT 3*	QUADRANT 4*	REN	IARKS
			ROOF1			
General Appearance	Good	Poor	Damaged			
Exterior Coating	Good	Cracking	Blistering	Separation	N/A	
Vents	Good	Роог	Critical			
Water Level Gauge Board	Good	Damaged	N/A			
Roof Hatch & Gaskets	Good	Poor	Critical			
Roof Hatch Hinges	Good	Damaged	Missing			
Lock & Hasp Assembly	Good	Damaged	Missing			
Hatch Cage & Railing	Good	Damaged	Missing	N/A		
Roof Slabs 1	gencel	and	(200d	Good		
Expansion Joints 1						
Roof / Wall Joint 1	Good	Crescel	Cocce	Cool		
All Expansion Joints	Jniform Width- Ye	s / No Uniform L	evel- Yes / No Gaske	ets Intact- Yes / No		
Other						
					¹ See Inspe	ection Worksheet for specific areas
			WALLS ²			
General Appearance	Good	Poor	Damaged			
Exterior Coating	Good	Cracking/	Blistering	Separation		
Wall to Roof Joint 2		///	/_/_			
Wall Structure 2			1.1			
Ladder Structure	Good	Poor	Danlaged	Missing		
Safety Climb System	Good	Poor	Damaged	Missing	<del></del>	
Overflow Structure	Good	Poor	Damaged	Missing	14.	1 2
Clean Out Hatch	Good	Poor	Damaged	Leaking	IM	71 Ca
		- (A)- 11-36	and Van / No. Cook	-4- 4-44 3/ / 8/-	/ -	
All Expansion Joints	Jniform Width- Ye	S NO Unitom	Level- Tes / No Gaski	ets intact- Yes / No		
•	Jniform Width- Ye None Observed	Possible	Damaged Level- Yes / No Gaski Leaking	ets intact- Yes / No		
		Possible	Leaking	ets intact- Yes / No		
Leaking		Possible	Leaking			
Leaking Other	None Observed	FOO	OTINGS / FOUNDAT			
Leaking Other General Appearance	None Observed	FOG Poor	DTINGS / FOUNDAT	ION 3		
Leaking Other General Appearance Coating	None Observed	FOO	OTINGS / FOUNDAT		² See Insp	ection Worksheet for specific areas
Coating Perimeter Joint 3	None Observed	FOG Poor	DTINGS / FOUNDAT	ION 3		ection Worksheet for specific areas
Ceneral Appearance Coating Perimeter Joint 3 Floor Slab 3	None Observed	FOG Poor	DTINGS / FOUNDAT	ION 3	² See Insp	ection Worksheet for specific areas
General Appearance Coating Perimeter Joint ³ Floor Slab ³ Footing Ring ³	None Observed	FOG Poor	DTINGS / FOUNDAT	ION 3	² See Insp	ection Worksheet for specific areas
General Appearance Coating Perimeter Joint ³ Floor Slab ³ Footing Ring ³ Sump / Valve Vault ³	Good Good	FOO Poor Cracking	DTINGS / FOUNDAT Damaged Blistering	Separation	² See Insp	ection Worksheet for specific areas
General Appearance Coating Perimeter Joint ³ Floor Slab ³ Footing Ring ³ Sump / Valve Vault ³ All Expansion Joints	Good Good Uniform Width -	FOG Poor Cracking	DTINGS / FOUNDAT Damaged Blistering Livel- Yes No Gask	Separation  Separation  Ats Intact- Yes / No	² See Insp	ection Worksheet for specific areas
Leaking Other  General Appearance Coating Perimeter Joint ³ Floor Slab ³ Footing Ring ³ Sump / Valve Vault ³ All Expansion Joints Overflow Structure	Good Good Uniform Width -	FOO Poor Cracking  Yes / No Uniform Poor	DTINGS / FOUNDAT Damaged Blistering  Livel-Yes No Gask Damaged	Separation  Separation  Ats Intact- Yes / No	² See Insp	ection Worksheet for specific areas
Leaking Other  General Appearance Coating Perimeter Joint ³ Floor Slab ³ Footing Ring ³ Sump / Valve Vault ³ All Expansion Joints Overflow Structure Leaking	Good Good Uniform Width - Good None Observed	Possible  FOG Poor Cracking  Yes / No Uniform Poor Possible	DTINGS / FOUNDAT Damaged Blistering  Livel-Yes No Gask Damaged	Separation  Separation  Ats Intact- Yes / No	² See Insp	ection Worksheet for specific areas
Leaking Other  General Appearance Coating Perimeter Joint ³ Floor Slab ³ Footing Ring ³ Sump / Valve Vault ³ All Expansion Joints Overflow Structure Leaking Ground Subsidence	Good Good Uniform Width - Good None Observed None Observed	FOO Poor Cracking  Yes / No Uniform Poor	DTINGS / FOUNDAT Damaged Blistering  Livel-Yes No Gask Damaged	Separation  Separation  Ats Intact- Yes / No	² See Insp	ection Worksheet for specific areas
Leaking Other  General Appearance Coating Perimeter Joint ³ Floor Slab ³ Footing Ring ³ Sump / Valve Vault ³ All Expansion Joints Overflow Structure Leaking	Good Good Uniform Width - Good None Observed None Observed	Possible  FOG Poor Cracking  Yes / No Uniform Poor Possible	DTINGS / FOUNDAT Damaged Blistering  Livel-Yes No Gask Damaged	Separation  Separation  Ats Intact- Yes / No	² See Insp	ection Worksheet for specific areas

DISCLAIMER

#### Liquid Engineering Corporation Circular Tank Diagram / Information Worksheet



## Liquid Engineering Corporation Steel Water Reservoir Exterior Condition Worksheet

Job No.: 33014 Tank Name: 250 K6 S/B EAST Date 7/21/07

#### Section 9. General Tank Security

Is the tank surrounded by a security fence?		
	Yes	No
Are the access gates locked?	Yes	No
Is the tank equipped with a vandal guard on the primary access ladder?	Yes	No
is the vandal guard locked?	Yes	No
Are all of the access hatches equipped with electronic monitoring devices?	Yes	No
Are all of the vents equipped with security vent shrouds?	Yes	(No)
Does the exterior of the tank show signs of trespass?	Yes	(No)
Does the surrounding geography of the tank obscure it from public view?	Yes	(No)
Are the external plumbing components housed in a secure vault or out building?	The	No
Is the area surrounding the tank well lit?	Yes	(No)
Are there any additional security features associated with this tank or surrounding area?  If yes, describe in additional remarks section.	Yes	No
Additional Remarks and Measurements		
Additional Notineurs and Indesdrining		
	<del></del>	
		:

# Liquid Engineering Corporation Section 17: Immediate Needs Assessment

ob No.: 33014 Tank Name: 250 KG S/R GAST	Date 7/21/07
. Health & Safety Items  Safety Climb System Installation:	<b>,</b>
☐ Vent Screen Repairs:	
I. Testing Items  Dye Testing For Leak Evaluation: Presence of Lead Test (Interior / Exterior):	
III. Destructive Testing Items  \[ \text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\text{\tex{\tex	
IV. Repair Items  Epoxy Coating Repairs:  Temporary Leak Repairs:  Float Operated Level Indicator Repairs / Maintenance:	
☐ Hypalon Repairs:	
V. Security Related Items (Critical security upgrade information is immediately available.)  Tank Vents Are Not Equipped With A Security Vent Shroud.  Tank Hatches Are Not Equipped With A Security Hatch Locking Device.  Tank Perimeter Not Adequately Secured:	
☐ EPA - Mandated Vulnerability Assessment Not Completed:	
Additional Description of Recommended Work  Inspect Filery Byrs & Clean As Neede	ed
The above noted additional work is considered immediately necessary and recommended to be completed in conjunction with work currently being performed while the field crew is on site.	d. Some items may be completed
Authorized Utility Signature:	
signing above achievedges that recommendations have been made for additional work that may be necessary and can be completed while the LEC crew is odditional work. An additional work authorization will be prepared to authorize any additional work desired.	on site. Signing above does not authorize



### System Storage Tank General Condition Report (DEQ Supplemental)

Date 7/20/07

System. West 23	JUNG	B	wien	SID#:_				(-a)	Dacity:	200	6 (In C	oanons)
General Condition of the Exteri	or Surfaces	and Compo	nents									
- Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coating - Coat	Good:	Roof	Walls		Fair:	Roof	Walls	Bowl	Poor:	Roof	Walls	<u>Powl</u>
orrosion	Yes				No				%		-	
epport Structure	Good:	Legs	Foundation	s I	Fair:	Leas	Foundati	ons	Poor:	Legs	Foundat	ions
igns of Trespass	No X	Yes	Describe:									
Seneral Condition of the Exteri	or Ladders			,	1							
Condition	Good				Fair_				Poor			
orrosion	Yes				No				%			
ocked Vandal Guard	Yes			#	No							
SHA Compliant	Yes	No	Describe:									
Seneral Condition of the Exteri	or Handrails	and Balco	nies	1								
Condition	Good		11/		Fair				Poor			
Corrosion	Yes			4-	No				%			
SHA Compliant	Yes	No	Describe.	1								
Seneral Condition of the Manw	avs		4/									
Condition	Good	-	1//	0	Fair		-		Poor			
signs of Leakage	No	Yes	Desembe:	4-								
			/									
Seneral Condition of the Tank		ols (		/	n in				L Bass			
Condition	Good	l Ma	Danashau	11	Fair		·		Poor			
perational	Yes	No	Describe			-		-				
General Condition of the Exteri	or Hatches											
Condition	Good	×			Fair				Poor			
Corrosion	Yes				No	><			%			
ocked	Yes	~			No							
Sasket	Yes	<u> </u>			No							
ramed 4" Above Roof	Yes	×			No							
id has 2" Overlap	Yes	14			No							
Evidence of Cantamination	No X	Yés	Describe:									
General Condition of the Exteri	or Vente											
Condition	Good	~			Fair				Poor			
Corrosion	Yes				No	34			%			
Properly Screened	Yes	×			No				70			
Adequately Vented	Yes	- <del>/</del> Sc			No							
quipped with Security Shroud					No	×	•					
Seneral Condition of the Interio	Good:	and Compo Roof	nents Walls	Floor 1	Fair:	Roof	Walls	Floor	Poor:	Roof	Malalla	<u> </u>
orrocion-	Yes .	11001	AADIIS		No.	Ruui	449112	FIDUE	%	1001	Walls	Floo
	Good				Fair				Poor			
Support Structure / Columns	Good	2			Fair				Poor			_
					No			· · · · · · · · · · · · · · · · · · ·	-	1/211		
lumbing	3.0								Depth	/8	_	
Plumbing Sedimentation	Yes											
Plumbing Sedimentation Grating on Outlet	Yes Yes				No	<u> </u>						
Plumbing Sedimentation Grating on Outlet Silt Stopper on Outlet	Yes Yes Yes	<u>×</u>				<u>×</u> >	Š.			<del></del>		
Plumbing Sedimentation Grating on Outlet Silt Stopper on Outlet General Condition of the Interio	Yes Yes Yes		nents		No No	<u>×</u> ×	<u> </u>					
Plumbing Sedimentation Grating on Outlet Silt Stopper on Outlet General Condition of the Interio Clarity	Yes Yes Yes Or Surfaces	and Compo	nents		No No Fair		Š.		Poor			
Plumbing Sedimentation Grating on Outlet Silt Stopper on Outlet General Condition of the Interio Clarity Growth (Algae / Plant)	Yes Yes Yes Or Surfaces Good Yes		nents		No No Fair No	<i>y</i>	<u> </u>		Poor			
Plumbing Sedimentation Grating on Outlet Silt Stopper on Outlet General Condition of the Interio Starity Growth (Algae / Plant)	Yes Yes Yes Or Surfaces Good Yes Yes		nents		No No Fair No No		C		Poor			
lumbing dedimentation Grating on Outlet Grating on Outlet Grating on Outlet General Condition of the Interior Gravity Growth (Algae / Plant) Gram Grans of birds / insects	Yes Yes Yes Or Surfaces Good Yes Yes Yes		nents		No No Fair No No	<i>y</i>			Poor			
lumbing dedimentation Grating on Outlet Grating on Outlet Grating on Outlet General Condition of the Interior Gravity Growth (Algae / Plant) Gram Grans of birds / insects	Yes Yes Yes Or Surfaces Good Yes Yes		nents		No No Fair No No	× ×	Describe:		Poor			
Plumbing Sedimentation Stating on Outlet Silt Stopper on Outlet Seneral Condition of the Interio Starity Srowth (Algae / Plant) Soam Signs of birds / insects Other:	Yes Yes Yes Or Surfaces Good Yes Yes Yes		nents		No No Fair No No	× ×			Poor			
Plumbing Sedimentation Grating on Outlet Silt Stopper on Outlet General Condition of the Interio Starity Growth (Algae / Plant) Goam Signs of birds / insects Other: Additional Comments	Yes Yes Yes Or Surfaces Good Yes Yes Yes Yes Yes	×			Fair No No No No	× × × × × × × × × × × × × × × × × × ×	Describe:		Poor			
Support Structure / Columns Plumbing Sedimentation Grating on Outlet Silt Stopper on Outlet General Condition of the Interior Clarity Growth (Algae / Plant) Foam Signs of birds / insects Other: Additional Comments	Yes Yes Yes Or Surfaces Good Yes Yes Yes Yes Yes	×			Fair No No No No	× × × × × × × × × × × × × × × × × × ×	Describe:	n	Poor			
Plumbing Sedimentation Grating on Outlet Silt Stopper on Outlet General Condition of the Interio Clarity Growth (Algae / Plant) Foam Signs of birds / insects Other: Additional Comments	Yes Yes Yes Or Surfaces Good Yes Yes Yes Yes Yes	×			Fair No No No No	× × × × × × × × × × × × × × × × × × ×	Describe:	n/	Poor			
Plumbing Sedimentation Seating on Outlet Silt Stopper on Outlet Seneral Condition of the Interiorative Serowth (Algae / Plant) Soam Signs of birds / insects Statitional Comments	Yes Yes Yes Or Surfaces Good Yes Yes Yes Yes Yes	×			Fair No No No No	× × × × × × × × × × × × × × × × × × ×	Describe:	n	Poor			
Plumbing Sedimentation Seating on Outlet Silt Stopper on Outlet Seneral Condition of the Interiorative Scowth (Algae / Plant) Soam Signs of birds / insects Other:	Yes Yes Yes Or Surfaces Good Yes Yes Yes Yes Yes	×			Fair No No No No	× × × × × × × × × × × × × × × × × × ×	Describe:	n	Poor			

# C y IGHT TOO HE HE

Post or Mail to:

Montana Department of Environmental Quality Public Water Supply Section P.O. Box 200901

Helena, MT 59620-0901

# Liquid Engineering Corporation oir Contamination, Health and Safety

Job No. 33014 Utility City of EAST Helena Tank 250 KG S/B West Inspector's Vandershelden Team Leader T. Spurling Date 7/20/07 Form 1
Complies With: AWWA • OSHA • ANSI • NIOSH • NAVFAC • NFPAC
Contamination & Health Checklist •
Air Vents Hatches Type # Screen Conditions: Good Fair Poor Type # Secured Properly Year No Properly Sealed Year No Exterior Overflow Cathodic Covers Roof to Wall Joint Roof Integrity Wall Integrity Holes: Yes No Water Clarity Floating Surface Debris Hypeton Floating Cover Tolemotry Ponetrations Other Discrepancies  # Screen Conditions: Good Fair Poor # Secured Properly Sealed Year No Properly Sealed Year No Condition: Good Fair Poor # Screen: Year No Condition: Good Fair Poor # Screen: Year No Condition: Good Fair Poor # Screen: Year No Condition: Good Fair Poor # Screen: Year No Condition: Good Fair Poor # Other: # Screen Condition: Good Fair Poor # Screen: Year No Condition: Good Fair Poor # Other: # Screen Condition: Good Fair Poor # Other: # Screen Condition: Good Fair Poor # Other: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source: # Source
- Facility Safety Compliance Checklist -    Exterior Ladder
Type and Size Type: Round Ovel Square Other Size:(24" - 18"X22" min.) #  Support Structure Dogged Davit Am Bolted Other Condition: Good Fair Poor  Number & Locations Wall Roof Riser Pipe Other
Hatches
Hatch Type and Size Round Square Rectangle Other (24" - 24"X15" min.) 58 x 35  Hatch & Lid Lip Height Hatch (4" min.) Lid (2" min.)
Balconies & Railing
Deck/Walkways Condition: Good Fair Poor Width: Hand Rails Condition: Good Fair Poor Height (42" min.) No. Rails (min. 2) Toe Rail Condition: Good Fair Floor Height (4" min.) Welds/Attachments Condition: Good Fair Floor
Roof   Safety Tie-Off Points   Condition: Good Fail   Poor #   Antennas   Types: Transfording-Femilia to Point / Omni Directional   Receiving #
Other Discrepancies
Additional Information

#### **Liquid Engineering Corporation**

10b No. 33014		te water Kes	_		_	SO KG SIB W
inspector J. VanOc	ershelder 1	Dive Controller T	: sprding		Date	7/20/07
			an Concrete I CI 201.1R-92 / 311.1			
		CON	CRETE CONDITION C	ODE		
	g G - Contraction on H - Deformation on I - Settling		Vold P - Pitt Cold Pour Q - Spa Honeycomb R - Po	alling T - Chalking	V - Exudation W - Efflorescen X - Stains	Y - Corrosion ace Z - Exposed Reinforceπ
	QUADRANT 1*	QUADRANT 2*	QUADRANT 3*	QUADRANT 4*	ŀ	REMARKS
Conord Annegrance	Good	Poor	ROOF 1 Damaged			
General Appearance Interior Coating	Good	Cracking	Blistering	Separation	(NIA)	
Vents	Good	Poor	Critical	Ocparation	<u> </u>	
Water Level Sensors	Good	Damaged	Citical			
Roof Slab(s) 1	mel	Tree	(grad	Coal		
Expansion Joints 1	- Cour					
Support Beams 1				-		
Beam-Joints						
Roof to Column Joints	Tomb	(red	19300	Cood		
All Expansion Joints	Uniform Width- Ye	s / No Uniform Lev	rel- Yes / No Gask	ets Intact- Yes / No		
Other						
0.00					¹ See	Inspection Worksheet for specific a
			WALLS ²			
General Appearance	Good	Poor	Damaged			
Interior Coating	Good	Cracking	Blistering /	Separation		
Wall to Roof Joint 2	Coocl	Trock	Coal	Good		
Wall Structure 2	04	06	DL	DL		
Ladder Structure	Good	Poor	Damaged	Missing		
All Expansion Joints	Uniform Width- Ye	es / No Uniform Lev	el- Yes / No Gaske	ets Intact- Yes / No		
Leaking	None Observed	> Possible Lea	aking Dye	Tested- Yes No		
Other						
					² See	Inspection Worksheet for specific a
		SL	IPPORT COLUMN	NS ³		
General Appearance	Good	Poor	Damaged			
Coating	Good	Cracking	Blistering	Separation		
Columns 3	Good,	Cood,	good,	and,		
Column Floor Plates 3	Cool	(9000	wat	Cood		
All Expansion Joints	Uniform Width	es No Uniform Le		kets Intact Yes / No		
Column Base Leaking	None Observed	Possible L	eaking Dye	Tested- Yes (No)		
Other		-			30	
					See Ins	spection Worksheet for specific colu
			FLOOR 4			
General Appearance	Good	Poor	Damaged			
Coating	Good	Cracking	Blistering	Separation.		<b>a</b>
Perimeter Joint 4	Soul	CHAT 1	con,	Cold	Gasket Intact	TE5/1 NO
Floor Slabs 4	Con	_cont	(9000)	000		
Inlet Structure	Good	Poor	Critical			
Outlet Structure	Good	Poor	Critical			
Overflow Structure	George	Poor	Critical			
Sump System	Good	Cracking	Spalling			8
All Expansion Joints	Uniform Width		_	askets Intact Yes / I		
Leaking	None Observe			ye Tested- Yes (No		
Hammer/Chain Sound	ings *	None 1	AKEN			
Other					40	


# Liquid Engineering Corporation Concrete Water Reservoir Exterior Condition Survey

Job No. <u>33014</u> Inspector <u>5. Van Do</u>		Utility <u>City</u> Dive Controller	of East 1		_ Tank <u>750</u> _ Date <u>7/20</u> /	KG S/B WEST
			can Concrete			
					*	
A - Abrasion D - Cracking B - Erosion E - Deflectio C - Blistering F - Expansion		J - Curling N K - Checking N			V - Exudation W - Efflorescence X - Stains	Y - Corrosion Z - Exposed ReInforcement
	QUADRANT 1*	QUADRANT 2*	QUADRANT 3*	QUADRANT 4*	REN	MARKS
General Appearance Exterior Coating Vents Water Level Gauge Boar Roof Hatch & Gaskets Roof Hatch Hinges Lock & Hasp Assembly Hatch Cage & Railing Roof Slabs 1 Expansion Joints 1 Roof / Wall Joint 1	Good Good Good Good Good Good	Poor Cracking Poor Damaged Poor Damaged Damaged	ROOF 1 Damaged Blistering Critical (N/A) Critical Missing Missing Missing	Separation  NA  Cood	(N/A)	
All Expansion Joints Other	Uniform Width- Y	es / No Uniform L	evel- Yes / No Gas	skets Intact- Yes / No		
					¹ See Inspe	ection Worksheet for specific areas
General Appearance Exterior Coating Wall to Roof Joint ² Wall Structure ² Ladder Structure Safety Climb System Overflow Structure Clean Out Hatch All Expansion Joints Leaking	Good Good Good Good Good Uniform Width	Poor Cracking Poor Poor Poor Poor Poor Possible	Damaged Damaged Damaged Damaged Damaged Damaged Damaged Level- Yes / No Gast	Separation  Missing Missing Missing Leaking Skets Intact- Yes / No	Bur	ried
Other					² See Insp	ection Worksheet for specific areas
General Appearance Coating Perimeter Joint ³ Floor Slab ³ Footing Ring ³ Sump / Valve Vault ³ All Expansion Joints Overflow Structure Leaking Ground Subsidence Hammer/Chain Sounding	Good Good Uniform Width Good None Observe	Poor Cracking  - Yes / No Uniform Poor d Possible	Damaged Leaking	Separation  Separation  Skets Intact- Yes / No	Gasket Intact- Yes	1
Other						
1	•				3 See Inco	section Worksheet for specific areas

DISCLAIMER

Unless otherwise noted, the findings contained in this report were neither prepared nor reviewed by a licensed Professional Engineer, but are based on the experience, training and visual examination of the inspecting Dive Maintenance Technician.

#### Liquid Engineering Corporation Circular Tank Diagram / Information Worksheet



## Liquid Engineering Corporation Steel Water Reservoir Exterior Condition Worksheet

Job No.: 33014 Tank Name: 250 KG S/B WCST Date 7/20/07

#### Section 9. General Tank Security

Is the tank surrounded by a security fence?	Yes	No
Are the access gates locked?	Yes	No
Is the tank equipped with a vandal guard on the primary access ladder?	Yes	No
Is the vandal guard locked?	Yes	No
Are all of the access hatches equipped with electronic monitoring devices?	Yes	No
Are all of the vents equipped with security vent shrouds?	Yes	No
Does the exterior of the tank show signs of trespass?	Yes	(NO)
Does the surrounding geography of the tank obscure it from public view?	Yes	No
Are the external plumbing components housed in a secure vault or out building?	Yes	No
Is the area surrounding the tank well lit?	Yes	(No)
Are there any additional security features associated with this tank or surrounding area?  If yes, describe in additional remarks section.	Yes	No
Additional Remarks and Measurements		
Additional framework and measurements		
		_
		:
	<u> </u>	

# Liquid Engineering Corporation Section 17: Immediate Needs Assessment

ob No.: 33014 Tank Na	me: 250	KG	S/B	West	Date 7/20/07
Health & Safety Items Safety Climb System Installation: Vent Screen Repairs:					
I. Testing Items  Dye Testing For Leak Evaluation: Presence of Lead Test (Interior / Exter					
II. Destructive Testing Items  More Coaling Adhesion Testing (Interior / Expecific written authorization required to performance)	xterior):				
V. Repair Items  Epoxy Coating Repairs: Temporary Leak Repairs: Float Operated Level Indicator Repair Hypalon Repairs:	s / Maintenanc	e:			
### Critical Security Related Items    ### Critical Security Related Items    ### Critical Security Related Items    ### Critical Security    ### Critical Security    #### Critical Security    #### Critical Security    #### Critical Security    #### Critical Security    ##################################	Security Vent S A Security Had red:	Shroud Ich Locking (	Device		
Additional Description of Recommended  Trispect Freny 34		Clem	AS I	Værd ed	
The above noted additional work is consider in conjunction with work currently being per	red immediately formed while th	y necessary ne field crew	and recomi is on site.	mended to be o	completed. Some items may be completed
Authorized Utility Signature:  Signing above schkowledges that recommendations have been in additional work. An additional work authorization will be prepared.	hade for additional wor	k that may be nec	essery and cen b	e completed while the	LEC crew is on site. Signing above does not authorize



### System Storage Tank General Condition Report (DEQ Supplemental)

Dale 7-20-07

Seneral Condition of the Exteri	or Surfaces	apd Domi	onents_									
Coating	Good:	(Roof)	Walls	Bowl	Fair:	Roof	Walls	Bowl	Poor:	Roof	Walls	Pow
orrosion	Yes		9		No				%			
uppert Structure	Good	Legs	Foundatio	ns	Fair.	Legs	Foundat	ons	Poor:	Legs	Foundat	ions
igns of Trespass	No	Yes	Describe:						<u> </u>			
eneral Condition of the Exteri			11						T 6			
ondition	Good		11/		Fair				Poor %			
orrosion ocked Vanda! Guard	Yes Yes			-//	No				70			
SHA Compliant	Yes	No _	Describe:	1	-140							
General Condition of the Exteri	or Handrail	le and Balc	onies s									
Condition	Good	3 and baic			Fair				Poor			
Corrosion	Yes		16	11	No				%			
OSHA Compliant	Yes	No	Describe/	11	1110				1 /4			
			- Country		/							
Seneral Condition of the Manw Condition	ays Good		16	10	Fair				Poor			
Signs of Leakage	No	Yes	Describe:	11	1 611				1 1 001			
igns or ceakage	1 140	1 163	Opecitoe.						-			
General Condition of the Tank		rols	-1	/	I Main				Done			
Condition	Good Yes	No	Danaville		Hair		-		Poor			
Operational	res	1 1/10	Describe	-/	7							
General Condition of the Exteri	or Hatches											
ondition	Good	Υ.	-		Fair				Poor			
orrosion	Yes				No	$\sim$			%			
ocked	Yes	75_			No							
Sasket	Yes				No							
ramed 4" Above Roof	Yes				No							
id has 2" Overlap	Yes	<u> </u>			No							
Evidence of Cantamination	I No SZ	Yes	Describe							<del></del>		
General Condition of the Exteri	or Vents					100						
Condition	Good	>	<u> </u>		Fair				Poor	·		
Corrosion	Yes		2		No	$\sim$			%			
Properly Screened	Yes	>	<		No							
dequately Vented	Yes	×			No							
quipped with Security Shroud	Yes				No	×						
Seneral Condition of the Interio												
oating -	Good:	Roof	Walls	Floor	Fair:	Roof	Walls	Floor	Poor:	Roof	Walls	Flo
orrosion	Yes				No		<u> </u>		%			
upport Structure / Columns	Good		-		Fair				Poor			
lumbing	Good		-		Fair				Poor	1/11		
edimentation	Yes	75			No				Degth	14		
Frating on Outlet	Yes	×			No	<_	Line	2 19-	1209	11011	1 pl	15
ilt Stopper on Outlet	Yes				No >		11/1	707	7 07	.00	13	
General Condition of the Interio	v Sudares	and Comp	onente		•	PI	APET	0F -	LIV.	Speci	TON	
Clarity	Good	2110 001110	_		Fair				Poor			
Growth (Algae / Plant)	Yes		_		No				1 1 001	·····		
oam	Yes				No	-						
igns of birds / insects	Yes				No	4						
Other:	Yes				No	1	Describe:					
					1.100	/	Pagailes.					
dditional Comments												
								3/4/-7				

#### Liquid Engineering Corporation

Potable Water Reservoir Contamination, Health and Safety Report
Job No. 33014 Utility Ctr of East Helena Tank 120 5/13 Concrete  Inspector Ryan Good Team Leader Troy Spurling Date 7-20-7 Form 1
Inspector Ryan Good Team Leader TROY Spurling Date 7-20-7 Form 1
Complies With: AWWA • OSHA • ANSI • NIOSH • NAVFAC • NFPAC
Contamination & Health Checklist
Air Vents  Type:
Roof to Wall Joint Welded: Yes No Properly Sealed: Yes No Properly Sealed: Yes No Works In Place: Yes No Properly Sealed: Yes No Properly Sealed: Yes No Works In Place: Yes No Properly Sealed: Yes No Works In Place: Yes No Properly Sealed: Yes No Works In Place: Yes No Properly Sealed: Yes No Works In Place: Yes No Properly Sealed: Yes No Works In Place: Yes No Works In Place: Yes No Properly Sealed: Yes No Works In Place: Yes No Works In Place: Yes No Properly Sealed: Yes No Works In Place: Yes No Works In Place: Yes No Properly Sealed: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No Works In Place: Yes No
Water Clarity General Appearance: Odor: None Other:  Floating Surface Debris Type: Source:
Hypalen Floating Cover Condition: Good Fair Poor Holes: Yes No Tears: Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Yes No Ye
Other Discrepancies
Facility Safety Compliance Checklist
Exterior Ladder  Overall Ladder Condition: Good Fair Poor Offset Landings Yes / No # Height:
Ladder Vandal Guard Ladder Rails & Rungs Rung Spacing & Depth Rail Spacing & Size Width: in. (pin 2") Thickness: in. (min. ½") Rail to Rail: in. (max 16") Safety Climb System Number & Locations Ladder Attachments  Present: Yes / No None vandal Guard Locked: Yes / No Missing/Damaged Rungs: Yes No Missing/Damaged Rungs: Yes No Missing/Damaged Rungs: Yes No Missing/Damaged Rungs: Yes No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes / No Missing/Damaged Rungs: Yes
Manways
Type and Size Type: Round Wal Square Other Size:(24"-18"X22" min.) # Support Structure Dogged Davit Arth Boltet Other Condition: Good Fair Poor Number & Locations Wall Roof Riser Pipe Other
<u>Hatches</u>
Hatch Type and Size Round Square Rectangle Other (24" - 24"X15" min.) 72"X 48"  Hatch & Lid Lip Height Hatch (4" min.) Lid ( 2" min.)
Balconies & Railing
Deck/Walkways Condition: Gold Fair Poor Width: Hand Rails Condition: Gold Fair Poor Height (42" min.) No. Rails (min. 2) Toe Rail Condition: Good Fair Poor Height (4" min.) Welds/Attachments Condition: Good Fair Poor
Roof Safety Tie-Off Points Condition: Good Fair Point # Antennas Types: Transmitting-Point / Omni Directional Receiving #
Other Discrepancies
Additional Information

D 1101	5014		Utility City	of Gas	t Helei	na	Tank_	1 m/	5/B	NO
spector	Ryan	600d	Dive Controller	TROY	Spurl	ing		7-20	_	
				can Concr (ACI 201.1R-92		tute				
			CI	ONCRETE CONDI	TION CODE				-	
- Erosion		G - Contraction H - Deformation I - Settling		N - Cold Pour	P - Pitting Q - Spalling R - Popouts	S - Bugholes T - Chaiking U - Leaching	V - Exud W - Efflor X - Stains	escence Z	' - Corrosion - Exposed Rela	nforce
		QUADRANT 1*	QUADRANT 2*			DRANT 4*		REMA	RKS	c=(== 1)
			Book	ROOF 1						
ieneral Appe		Good	Poor	Damage					3	
<del>iterior Coati</del>	10-1	Good	Cracking	Blistering	3 5	Separation	NIA			
ents		Good	Poor	Critical						
ater Level 6		Good /	Damaged	1	1	. 0				
oof Slab(s)		Cood	Cool	Cod		<del>                                      </del>				
kpansion_lo										
<del>upport Bear</del>										
oam Joints	1									
of to Colur	nn Joints ¹	Canol	Cood	Cont	1 6	2001				
Expansion	Liolnte	Uniform Width-	Yes / No Uniform L	evel- Yes / No	Gaskets Int	tact- Yes / No				
her										
								See Inspecti	on Worksheet for s	specific
as							<u> </u>			
		2		WALLS	2					
eneral Appe	arance	Good	Poor	Damage	d					
terlor Coati	गपु	Good	Cracking	Blistering	1 8	Separation				
all to Roof	Joint ²	Cood,	Cooch	(2000	L 6	end.				
all Structur	e ²	and	Cand	Coa		accel .				
adder Struct	ture	Good	Poor	Damage	d N	Aissing				
adder Struct <del>II Expansio</del> r		Uniform Width								
		Uniform, Width	Yes / No Uniform Lo	evel- Yes / No	Gaskets Inta	ct- Yes / No				
H Expansion			Yes / No Uniform Lo	evel- Yes / No		ct- Yes / No				
<del>li Expansio</del> r eaking		Uniform, Width	Yes / No Uniform Lo	evel- Yes / No	Gaskets Inta	ct- Yes / No		² See Inspecti	on Worksheet for s	specific
l Expansion eaking ther		Uniform, Width	Yes / No Uniform Lo	evel- Yes / No eaking	Gaskets Inta Dye Tested	ct- Yes / No		² See Inspecti	on Worksheet for s	specific
l Expansion paking ther	Joints	Uniform, Width	Yes / No Uniform Lo	evel- Yes / No eaking	Gaskets Inta Dye Tested	ct- Yes / No		² See Inspecti	on Worksheet for s	specific
HExpansion paking ther pas eneral Appe	Joints	Uniform, Width	Yes / No Uniform Lo Possible L	evel- Yes / No eaking  SUPPORT COL Damage	Gaskets Inta Dye Tested	- Yes No		² See Inspecti	on Worksheet for s	specific
l Expansion paking ther pas eneral Appe	Joints	Uniform, Width	Yes / No Uniform Lo Possible L	evel- Yes / No leaking  SUPPORT COI Damage	Gaskets Inta Dye Tested	ct- Yes / No		² See Inspecti	on Worksheet for s	specific
HExpansion reaking ther	a Joints	Uniform, Width	Yes / No Uniform Lo Possible L	SUPPORT COL Damage	Gaskets Inta Dye Tested	- Yes No		² See Inspecti	on Worksheet for s	specific
eneral Appe	arance	Good Good	Yes / No Uniform Lo Possible L	SUPPORT COL Damage	Gaskets Inta Dye Tested	ect-Yes/No - Yes No		² See Inspecti	on Worksheet for s	specific
Expansion paking ther pas eneral Appe pating blumns 3 blumn Floor i Expansion	r Joints  earance r Plates 3	Good Good Good Uniform Width	Poor Cracking Society - Yes / No Uniform Lo	SUPPORT COL Damage Blistering	Gaskets Inta Dye Tested  LUMNS 3 d  Gaskets Inta	ect-Yes/No - Yes No		² See Inspecti	on Worksheet for s	specific
eneral Apperating  blumns 3  blumn Floor	r Joints  earance r Plates 3	Good Good	Poor Cracking Social Yes / No Uniform Lo	SUPPORT COL Damage Blistering	Gaskets Inta Dye Tested	ect-Yes/No - Yes No		² See Inspecti	on Worksheet for s	specific
Expansion aking heras eneral Apperating alumns 3 olumn Floor Expansion olumn Base	r Joints  earance r Plates 3	Good Good Good Uniform Width	Poor Cracking Society - Yes / No Uniform Lo	SUPPORT COL Damage Blistering	Gaskets Inta Dye Tested  LUMNS 3 d  Gaskets Inta	ect-Yes/No - Yes No				
eneral Apperating blumns 3 blumn Floor Expansion	r Joints  earance r Plates 3	Good Good Good Uniform Width	Poor Cracking Society - Yes / No Uniform Lo	BUPPORT COL Damage Blistering Level- Yes / No Leaking	Gaskets Inta Dye Tested  LUMNS 3 d  Gaskets Inta Dye Tested	ect-Yes/No - Yes No	3 5		on Worksheet for spe	
eneral Apperating  and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second and a second	r Plates 3	Good Good Good Uniform Width	Poor Cracking -Yes / No Uniform Lo	SUPPORT COI Damage Blistering Level- Yes / No Leaking	Caskets Inta Dye Tested  LUMNS 3 d  Gaskets Inta Dye Tested	ect-Yes/No - Yes No	3,			
eneral Apperation of the second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second second secon	r Plates 3	Good Good Good Uniform Width	Poor Cracking Society - Yes / No Uniform Lo	BUPPORT COL Damage Blistering Level- Yes / No Leaking	Caskets Inta Dye Tested  LUMNS 3 d  Gaskets Inta Dye Tested	ect-Yes/No - Yes No	3,			
eneral Apperation of Expansion	Plates 3	Good Good Good Uniform Width	Poor Cracking -Yes / No Uniform Lo	SUPPORT COI Damage Blistering Level- Yes / No Leaking	Gaskets Inta Dye Tested  LUMNS 3 d  Gaskets Inta Dye Tested	Geparation tact-Yes/No Geparation tact-Yes/No	3 5			
eneral Apperation of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the conting of the continuous of the continuous of the continuous of the continuous of the continuous of the continuous of the continuous of the continuous of the continuous of the continuous of the continuous of the continuous of the continuous of the continuous of the continuous of the continuous of the continuous of the continuous of the continuous of the continuous of the continuous of the continuous of the continuous of the continuous of the continuous of the continuous of the continuous of the continuous of the continuous of the continuous of the continuous of the continuous of the conti	Plates 3	Good Good Good Uniform Width	Poor Possible Poor Possible Poor Poor Possible Poor	BUPPORT COL Damage Blistering Level- Yes / No Leaking	Gaskets Inta Dye Tested  LUMNS 3 d  Gaskets Inta Dye Tested	Separation Separation Separation Separation	3 ₅	See Inspection		
eneral Apperation of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the pating of the patin	Plates 3	Good Good Good Uniform Width	Poor Possible Poor Possible Poor Poor Possible Poor	SUPPORT COL Damage Blistering Level- Yes / No Leaking	Gaskets Inta Dye Tested  LUMNS 3 d  Gaskets Inta Dye Tested	Separation Separation Separation Separation		See Inspection		
eneral Apperation description of Expansion o	r Plates 3 Tubints Leaking Carance	Good Good Good Good Good Good Good Good	Poor Possible Poor Cracking Possible Poor Cracking	Blistering  FLOOR Damage Blistering  FLOOR Damage Blistering	Gaskets Inta Dye Tested  LUMNS 3 d  Gaskets Inta Dye Tested	Separation Separation Separation Separation		See Inspection		
eneral Apperation description of States and Apperating and Apperation and Apperation and Apperating and Apperating arimeter Joi our Slabs 4 let Structure	Parance  r Plates 3 Toolnts Leaking parance	Good Good Good Good Good Good Good Good	Poor Cracking Possible Poor Cracking Poor Cracking Poor Cracking Poor Cracking	BUPPORT COL Damage Blistering Level- Yes / No Leaking FLOOR Damage Blistering Critical	Gaskets Inta Dye Tested  LUMNS 3 d  Gaskets Inta Dye Tested	Separation Separation Separation Separation		See Inspection		
eneral Apperature Base Stating  Expansion Stating  Expansion Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansion Base Stating  Expansio	r Plates 3 T Joints Leaking	Good Good Good Good Good Good Good Good	Poor Cracking Possible Poor Cracking Poor Cracking Poor Cracking Poor Cracking Poor Cracking	BUPPORT COL Damage Blistering Level- Yes / No Leaking  FLOOR Damage Blistering  Critical Critical	Gaskets Inta Dye Tested  LUMNS 3 d  Gaskets Inta Dye Tested	Separation  Separation  Separation  Separation		See Inspection		
eneral Apperation of Expansion	Plates 3 Toints Leaking parance	Good Good Good Good Good Good Good Good	Poor Cracking Possible Poor Cracking Poor Cracking Poor Cracking Poor Cracking Poor Poor Poor	SUPPORT COL Damage Blistering Level- Yes / No Leaking  FLOOR Damage Blistering Critical Critical Critical	Gaskets Inta Dye Tested  LUMNS 3 d  Gaskets Inta Dye Tested	Separation  Separation  Separation  Separation		See Inspection		
eneral Apperation of Expansion	r Plates 3 Toolnts  Leaking Carance  earance  int 4  earance	Good Good Good Good Good Good Good Good	Poor Cracking Possible Poor Cracking Poor Cracking Poor Cracking Poor Cracking Poor Cracking Poor Cracking	BUPPORT COL Damage Blistering Blistering Level- Yes / No Leaking FLOOR Damage Blistering Critical Critical Critical Spalling	Gaskets Inta Dye Tested  LUMNS 3 d  Gaskets Inta Dye Tested	Separation Separation Separation Separation	Gasket-Int	See Inspection		
eneral Apperation of Expansion	r Plates 3 Toolnts  Leaking Carance  earance  int 4  earance	Good Good Good Good Good Good Good Good	Poor Cracking Possible Poor Cracking Poor Cracking Poor Cracking Poor Cracking Poor Cracking Poor Poor Cracking Poor Poor Cracking Poor Poor Cracking Door Poor Poor Cracking Door Poor Poor Poor Cracking Door Poor Poor Cracking Door Poor Poor Cracking Door Poor Cracking Door Poor Cracking Door Poor Cracking Door Cracking	FLOOR Damage Blistering  FLOOR Damage Blistering  Critical Critical Critical Spalling Level- Yes / No	Gaskets Inta Dye Tested  LUMNS 3 d Gaskets Inta Dye Tested	Separation Separation Separation Separation Separation	Gasket-Int	See Inspection		
eneral Apperation of Expansion	r Plates 3 r Joints Leaking coarance lint 4	Good Good Good Good Good Good Good Good	Poor Cracking Possible Poor Cracking Poor Cracking Poor Cracking Poor Cracking Poor Poor Poor Poor Poor Poor Poor Poo	FLOOR Damage Blistering  FLOOR Damage Blistering  Critical Critical Critical Spalling Level-Yes / No	Gaskets Inta Dye Tested  LUMNS 3 d  Gaskets Inta Dye Tested	Separation Separation Separation Separation	Gasket-Int	See Inspection		
eneral Apperation of the Structure of Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the Structure of the St	r Plates 3 r Joints Leaking coarance lint 4	Good Good Good Good Good Good Good Good	Poor Cracking Possible Poor Cracking Poor Cracking Poor Cracking Poor Cracking Poor Poor Poor Poor Poor Poor Poor Poo	FLOOR Damage Blistering  FLOOR Damage Blistering  Critical Critical Critical Spalling Level- Yes / No	Gaskets Inta Dye Tested  LUMNS 3 d Gaskets Inta Dye Tested	Separation Separation Separation Separation Separation	Gasket-Int	See Inspection		

# Liquid Engineering Corporation Concrete Water Reservoir Exterior Condition Survey

No. 330/4		Utility City o	4 GOST Hel	ena	Tank / M	4 5/B
pector Ryan	600d	Dive Controller _	TROY SPUR	ling	Date 7- 2	6-7
			an Concrete			
			NCRETE CONDITION	CODE		
Abrasion D - Cracking Erosion E - Deflection F - Expansion	n H - Deformation	J - Curling M K - Checking N	- Vold P - Pi - Cold Pour Q - S		V - Exudation W - Efflorescence X - Stains	Y - Corrosion Z - Exposed Reinforce
	QUADRANT 1*	QUADRANT 2*	QUADRANT 3*	QUADRANT 4*	RE	MARKS
	Ford	Dece	ROOF ¹			
ieneral Appearance exterior Coating	Good	Poor Cracking	Damaged	Constitut	hi/A	
ents	Good	Poor	Blistering	Separation	N/A	
ents <del>fater Level Gauge Bo</del> a			Critical N/A			
ra <del>ter Caver Sauge-Doa</del> toof Hatch & Gaskets	Good	Damaged Poor	N/A Critical			
	Good					
oof Hatch Hinges		Damaged	Missing			
ock & Hasp Assembly latch Cage & Railing	Good	Damaged	Missing	NUA .		
coof Slabs 1	9779-	Damaged	Missing	and a		
Xpension Joints 1	July	car	<u> </u>	any		
coof / Wall Joint 1	//	1 7	Tanial	Town!		
Il Expansion Joint	Uniform Width- Y	/as / No Unifo 1	evel- Yes / No Gas	hote letest Van (At		
	Unitum Water- 1	es / NO Uniform Le	over- tes / NO Gas	skets Intact- Yes / No	,	
other					See Inen	ection Worksheet for specific
			WALLS 2	<del></del>	- Oob strap	epochie
Seneral Appearance	Good	Poor	Damaged			
exterior Coating	(Good)	/ Cracking	/ Blistering	Separation		
Vall to Roof Joint 2	Cooch	Card.	ment	Carl		
Vall Structure 2	Grand	mod	wood	1900		
adder Structure	Good	Poor	Damaged	Missing		
afety Climb System	Good	Poor	Damaged	Missing		
verflow-Structure	Good	Poor	Damaged	Missing		
ilean-Out Hatch	Good	Poor	Damaged	Leaking		
II Expansion Joints	Uniform-Width- \			skets Intact- Yes N	2)	
eaking	None Observed	Possible I				
Other						
					² See Insp	ection Worksheet for specific i
		FOO	TINGS / FOUNDA	ATION 3		
Seneral Appearance	Good	Poor	Damaged			
Coating	Good	Cracking	Blistering	Separation		
erimeter Joint 3			1 /		Gasket Intact- Yes	/ No
loor Slab 3				/	•	
ooting Ring 3			//			
iump / Valve Vault 3				1	•	
VI Expansion Joints	Uniform Width	- Yes / No Uniform I	Level Yes / No Sa	kets Intact- Yes / No	0 -	. //
	Good	Poor	Damage		12	1 and
Overflow Structure	None Observe	d Possible			1)000	ried
Overflow Structure eaking	INDIR ODSELVE			•	11/	- (
eaking Ground Subsidence	None Observe	d Possible	3 Vis	ible ³	1	
eaking	None Observe	d Possible	3 Vis	ble 3		
eaking Ground Subsidence	None Observe	d Possible	3 Vis	ble 3		

DISCLAIMER

Unless otherwise noted, the findings contained in this report were neither prepared nor reviewed by a licensed Professional Engineer, but are based on the experience, training and visual examination of the inspecting Dive Maintenance Technician.

### Liquid Engineering Corporation Circular Tank Diagram / Information Worksheet

Job# 330/4	Tank Name: 1246	S/B CONCRETE	Date: 7-20-7
WALLS Q-4	Q-1	Q-2	Q-3
Roof line			
Floor line	Testing	and Discrepancy	
DOOF		Locations	FLOOR
ROOF			7 230.11
0.4	Q-1	0.4	Q-1
0-3	0.2	0.3	C-2
1/4 1/4" 1/4"	/4"\ (-	VATOXP	$\begin{pmatrix} \times & \times & \times \\ \times & \times & \times \\ \times & \times & \times \\ \end{pmatrix}$
14 14	Yy" PI	umbing & Structure Locat	
Sediment Depth Measur Average Sediment Depth= The sum of all	rements	Plumbing and Structure Codes  O=Outlet X=inlet Z=Manway V=Vent D=Drain S=Sump L=Ladder H=Hatch P=Overflow F=Float level Indicator T=Telemetry	Ope Structure
divided by the number of measurements to Average Sediment Depth:	eken. Cubic Yardage:		od succine
Type of Sediment: FRONS	11/1+ Sand		Steel Concrete Other

# Liquid Engineering Corporation Steel Water Reservoir Exterior Condition Worksheet

Job No.: 33014 Tank Name: Imb Concrete S

#### Section 9. General Tank Security

		Yes	No
Are the access gates locked?		(Yes)	No
s the tank equipped with a vandal guard on the primary access ladder?	K//B4-	Yes	No
s the vandal guard locked?	1//4	Yes	No
Are all of the access hatches equipped with electronic monitoring devices?	70/11		No
Are all of the vents equipped with security vent shrouds?		Yes	No
Does the exterior of the tank show signs of trespass?			No
Does the surrounding geography of the tank obscure it from public view?		<del>                                     </del>	NO
Are the external plumbing components housed in a secure vault or out building?		Yes	_
s the area surrounding the tank well lit?		Yes	No
Are there any additional security features associated with this tank or surrounding area?  If yes, describe in additional remarks section.		Yes	7No
f yes, describe in additional remarks section.		Yes	No
dditional Remarks and Measurements			

# Liquid Engineering Corporation Section 17: Immediate Needs Assessment

ob No.: 330/4 Tank Name: 1 MG 3/B	Date
. Health & Safety Items	
Safety Climb System Installation:	
Vent Screen Repairs:	
I. Testing Items	
Dye Testing For Leak Evaluation:	
Presence of Lead Test (Interior / Exterior);	
III. Destructive Testing Items	
☐ % Of Lead Test (Interior / Exterior)(Coating samples are removed for laboratory analysis):	
Coating Adhesion Testing (Interior / Exterior):	
Specific written authorization required to perform destructive testing. Destructive tests include touch-up of co-	ating system.
IV. Repair Items	
Epoxy Coating Repairs:	
Temporary Leak Repairs:	
☐ Float Operated Level Indicator Repairs / Maintenance:	
Hypalon Repairs:	
V. Security Related Items (Critical security upgrade information is immediately available.)	
Tank Vents Are Not Equipped With A Security Vent Shroud.	
Frank Hatches Are Not Equipped With A Security Hatch Locking Device.	
Tank Perimeter Not Adequately Secured:	
EPA - Mandated Vulnerability Assessment Not Completed:	
InspectEvery 3yrs + Chew As Neede	4
InspectEvery 3475 & Clean As Neede.	4
Inspect Every 3 yrs + Cleun As Neede	4
InspectEvery 34RS + Cleun HS Neede	4
InspectEvery 3475 & Clean As Neede.	4
InspectEvery 3yrs + Cleun Hs Neede	4
InspectEvery 3475 + Cleun Hs Neede.	
InspectEvery 3475 & Cleun As Neede.	
InspectEvery 31/25 & Cleun As Neede.	
InspectEvery 3yrs + Cleun As Neede	
InspectEvery 3475 & Cleun As Neede	
InspectEvery 3475 & Cleun As Neede	
Inspect Every 3 yrs & Crewn As Neede	
Inspect Every 31/25 & Cleun As Neede	
InspectEury 3yrs & Cheun Hs Neede	
ImpectEvery 3yrs + Crean As Neede	
InspectEvery 3yrs & Cleun As Neede	
The above noted additional work is considered immediately necessary and recommended to be con in conjunction with work currently being performed while the field crew is on site.	
The above noted additional work is considered immediately necessary and recommended to be con	
The above noted additional work is considered immediately necessary and recommended to be con	

# APPENDIX L – CITY OF EAST HELENA'S WATER RATE ORDINANCE

#### 7-4-5: WASTEWATER SERVICE RATES:

Customers shall be charged monthly, in accordance with a sewer service rate schedule adopted from time to time by the city council using as a basis the following customer classifications:

- A. Residential: Residential customers shall be charged using a flat rate water usage structure of two hundred (200) gallons, which is an average of East Helena residential, metered water consumption during winter months.
- B. Commercial: Commercial customers shall be charged by being assigned individually, an equivalent residential customer billing factor that is based on the commercial customer's average daily metered water usage during winter months (December, January, and February). This billing factor shall be multiplied by the flat rate residential wastewater service charge in accordance with the sewer service rate schedule adopted from time to time by the city council.

New commercial customers shall be charged by the city using an estimated winter months water usage, until complete metered water usage figures are available for that customer, at which time the service charge will be adjusted (if necessary) using the equivalent residential customer billing factor. Retroactive to initial billing, any overpayment amount shall be refunded to the customer by the city and any underpayment amount shall be paid to the city by the customer, within thirty (30) days of the date of the monthly statement containing the billing adjustment. (Ord. 219, 8-15-2000)

#### 7-4-6: RATE SCHEDULE:

The sewer service rate schedule shall be as follows:

# SEWER SERVICE RATE SCHEDULE (MONTHLY)

Customer Class	"Equivalent Residential Customer" Billing Factor ¹	Rate Structure	Monthly Charge ²
Residential	1.0	Flat rate	\$66.40
Commercial	Q/200	Flat rate	\$66.40 x billing factor

Where: Q is the average daily metered water usage (in gallons) for the commercial customer over the consecutive months of December, January, and February; and 200 is the average daily metered water usage (in gallons) for a single residence.

#### Notes:

- 1. Billing factors for commercial customers shall be calculated to the nearest  $^{1}/_{10}$  of a whole number, with the minimum allowable billing factor being 1.0.
- 2. The rate increase specified herein shall be effective beginning with the July 1, 2013, wastewater

monthly statement, unless sooner changed, canceled, or extended.

(Ord. 251, 5-28-2013)

#### 7-4-7: SURCHARGE RATE STRUCTURE AND SCHEDULE:

The city of East Helena or its engineer will determine the average total suspended solids (SS) and five (5) day biochemical oxygen demand (BOD) daily loadings for the average residential customer or in lieu of such a determination will consider the average residential strength wastes to be two hundred fifty milligrams per liter (250 mg/l) BOD and three hundred milligrams per liter (300 mg/l) SS. The city of East Helena will assess a surcharge rate for all commercial customers discharging wastes with BOD and SS strengths greater than the average residential customer. The surcharge will be sufficient to cover the costs of treating such customer's above normal strength wastes. Such customers will pay an additional service charge equal to six percent (6%) of the monthly operation and maintenance cost for each fifty milligrams per liter (50 mg/l) over two hundred fifty milligrams per liter (250 mg/l) of BOD and three percent (3%) of the monthly operation and maintenance cost for each fifty milligrams per liter (50 mg/l) over three hundred milligrams per liter (300 mg/l) SS. (Ord. 219, 8-15-2000)

#### 8-3-3: WATER RATES:

- A. Water user charges shall be assessed by the city according to the rates hereinafter specified.

  Charges will be based on metered water consumption and where applicable fixed rate surcharges.
- B. Water user charges shall include a base rate charge per calendar month, according to the nominal size of water meter installed. Water service line size may be different than water meter size, and service line size or type of water service will not be the basis for the base rate charge.
- C. The base rate is charged irrespective of the amount of water use recorded on the meter, unless the service has been shut off by the city.

Base rate charges may be discounted fifty percent (50%) at the discretion of the city during periods of unoccupied or unused status of the structure or property served, including seasonal nonuse, seasonal vacancies, and unoccupied rental, "for sale" or "in estate" property. Eligibility for such discounts requires that the following four (4) conditions be met:

- 1. The account for the water user must be current and paid in full; and
- Written notice fully describing the upcoming unoccupied status must be received by the city prior to consideration for the discount. The date for return to occupied, active water use status must also be specified in the notice; and
- 3. The structure must be unoccupied and the water service unused on the first and last day of any month considered for discounted base rate charges; and

- 4. No water use can be measured on the water meter during any month considered for discounted base rate charges. If water use is recorded during the month, full base rate charges apply.
- D. Water user charges shall also include a varied rate charge, based on the metered amount of water used as recorded by the water meter.
- E. To reduce the risk of freezing the city's mains or service lines connected to shallow mains, the city may issue written permission to individual water users to maintain slight flows through their service line. For users in possession of such written permission, during the winter of 1999-2000, the city will base the monthly varied rate charges during such periods on the historic water usage by the user during the month immediately prior to the implementation of freeze deterrent flows. During subsequent winters, the city will base the monthly varied rate charges during such periods on the average of the past consecutive years' historic water usage by the user for the prior month, not to exceed a three (3) year average.
- F. Base rate and varied rate charges shall be as follows, according to nominal water meter size:

WATER RATE SCHEDULE (MONTHLY)

Nominal Meter Size (Inches)	Base Rate	Varied Rate (Gallons Used)
⁵ / ₈ x ³ / ₄	\$ 30 .00	\$1 .10/1,000
³ / ₄	30 .00	1 .10/1,000
1	53 .40	1 .10/1,000
1 ¹ / ₂	120 .00	1 .10/1,000
2	213 .30	1 .10/1,000
3	480 .00	1 .10/1,000
4	853 .20	1 .10/1,000
6	1,920 .00	1 .10/1,000

Additional monthly	surcharge	per	unmetered
irrigation hydrant			

\$20.00/month (for months of May through October only)

G. No base rate or varied rate water use charges shall apply to fire hydrants nor water used from such hydrants for emergency firefighting or uses otherwise authorized by the city. No water use charges shall apply to dedicated private fire protection lines used for fire suppression sprinklers or other fire protection flows, provided such lines have detector type check valves inside the structure. No water use charges shall apply to water used from such fire protection lines for emergency fire suppression or uses otherwise authorized by the city. (Ord. 216, 5-18-1999)

#### **APPENDIX M – COST ESTIMATES**

East Helena Water Master Plan - 2018							
Water Well Source - ~200 ft deep - One Well East							
22-Mar-18							
COST ESTIMATE							
					5	SALVAGE VALUE	
ITEM	QUAN.	UNIT	UNIT PRICE	TOTAL PRICE	_	in 20 Years	Estimated life of Asset
Mobilization, Bonding & Ins.	50	LS	\$ 43,767.50		\$	i -	
Drill & Install Mininum 16 Inch Dia Steel Cased Well	100	LF LF	\$ 150.00 \$ 120.00		9	-	
Drill & Install Mininum 12 Inch Dia Steel Cased Well Drill & Install Mininum 10 Inch Dia Stainless Steel Well Screen	45	LF	\$ 300.00		9	-	
Blank Screen Leader w/ Packer	5	LF	\$ 150.00		9	-	
Grout Well	150	LF	\$ 30.00		9	-	
Well Logging, Sampling & Filing	1	LS	\$ 1,500.00		9		
Water Sampling	1	LS	\$ 2,000.00		9	-	
Well Development	16	HR	\$ 300.00		\$	-	
Well Pump Testing	24	HR	\$ 300.00		\$	-	
Well Recovery Measurements	12	HR	\$ 300.00		\$	-	
Well Pump & Motor - 75 HP, 8 Inch	1	EA	\$ 65,000.00	\$ 65,000.00	\$		
Pump Installation	1	LS	\$ 30,000.00	\$ 30,000.00			
6" Column Piping	150	LF	\$ 35.00				
1" Dia PVC Sounding Tube	150	LF	\$ 7.00		\$	-	
Pump Control, Chlorine & Mechanical Building - 10' x 20'	200	SF	\$ 250.00		\$	30,000.00	50
Site Work	1	LS	\$ 10,000.00		\$		
Sodium Hypochlorite Chlorination System	1	LS	\$ 20,000.00		\$	-	20
Electrical, Telemetry, & Controls	1	LS	\$ 20,000.00		\$	-	20
Mechanical Equipment - Flowmeter, Valves	1	LS	\$ 50,000.00		\$	25,000.00	40
10-Inch PVC Pipe	4,800	LF	\$ 70.00		\$	201,600.00	50
10-Inch Gate Valve	4	EA	\$ 3,500.00		\$	8,400.00	50
Gravel Removal and Replacement	3600	SY	\$ 15.00		\$	-	
Exploratory Excavation	2	HRS	\$ 350.00		\$		
Utility Crossings	30	EA	\$ 500.00		\$		
Grade, Seed, Fertilize, Mulch	3	AC	\$ 4,000.00		\$	-	
Generator	1	LS	\$ 75,000.00		_		
Hydrogeologic Study and Modeling	1	LS	\$ 20,000.00		\$		
Water Rights Electrical Service	1 1	LS LS	\$ 20,000.00 \$ 20,000.00	\$ 20,000.00 \$ 20,000.00	9		
Sub Total Construction - 2018	1	LS	\$ 20,000.00	\$ 20,000.00 \$ 919,118.00	*	-	
Number of Years until Construction				\$ 919,116.00	_		
Inflation rate of				3%	_		
Sub Total Construction Cost - 2020				\$975,092.00	9	265,000.00	
ous four constitution cost 1929				ψ570,032.00		200,000.00	
Admin @ 5%				\$ 48,755.00			
Contingency @ 15%				\$ 146,264.00			
Engineering @ 18%				\$ 175,517.00			
, ,							
Total Project Cost				\$1,345,628.00			`
,							
ANNUAL OPERATING AND MAINTENANCE COST							
ITEM	QUAN.	UNIT	UNIT PRICE	TOTAL PRICE			
Labor inc. yearly line flushing	12	hours	\$ 25.00	\$ 300.00			
Total Annual Cost			1	\$ 300.00			
			1				
Present Worth Analysis			1	TOT **			
DESCRIPTION Table Desirat Cont				TOTAL			
Total Project Cost				\$1,345,628			
Annual O&M				\$300			
Salvage Value in 20 years (estimate)				(\$265,000)			
Interest Rate Number of payments				3.20% 20			
number of payments		TOTAL	RESENT WORTH	\$1,208,869.00			
		TOTALP	LESENI WORTH	\$1,200,009.00			
		l	1				l

East Helena Water Master Plan - 2018								
Abandon Wylie Well #3 add Disinfection to Wylie Well #2								
7-May-18								
COST ESTIMATE								
							ALVAGE	
							LUE in 20	Estimated life
ITEM	QUAN.	UNIT	UNIT PRICE	TOTAL PRICE			Years	of Asset
Mobilization, Bonding, and Ins.	1	LS	\$ 13,460.00	\$ 13,460.00		\$	-	
Wylie Well #3 Remove Casing, Fill, and Seal	1	LS	\$ 10,000.00	\$ 10,000.00		\$	-	
Remove and Dispose of All Portions of the Existing Gas Chlorination System	1	LS	\$ 5,000.00	\$ 5,000.00		\$	-	
Remove and Dispose of All Above Grade Piping Associated with Wylie Well #3.	1	LS	\$ 10,000.00	\$ 10,000.00		\$	-	
Demo Existing Wylie Well #3 Building	1	LS	\$ 15,000.00	\$ 15,000.00		\$	-	
Burried 8" DIP	85	LF	\$ 90.00	\$ 7,650.00		\$	-	
Burried 10" DIP	85	LF	\$ 100.00	\$ 8,500.00		\$	-	
Piping & Mechanical Equipment In Chlorination Building (Includes Magnetic Flowmeter, Valves, Hot Water Heater, and Shower)	1	LS	\$ 30,000.00	\$ 30,000.00		\$	15,000.00	40
Sodium Hypochlorite Chlorination System	1	EA	\$ 20,000.00	\$ 20,000.00		\$	-	20
Building Construction (10' x 20')	200	SF	\$ 250.00	\$ 50,000.00		\$	30,000.00	50
Sitework	1	LS	\$ 10,000.00	\$ 10,000.00		\$	-	
Burried 8" Gate Valve	1	EA	\$ 3,000.00	\$ 3,000.00		\$	1,800.00	50
Burried 10" Gate Valve	1	EA	\$ 3,500.00	\$ 3,500.00		\$	2,100.00	50
Soil Removal and Replacement	285	SY	\$ 30.00	\$ 8,550.00		\$	2,100.00	30
Purchase and Install Control Panel	1	EA.	\$ 15,000.00	\$ 15,000.00		\$	-	20
Electrical	1	EA	\$ 30,000.00	\$ 30,000.00		\$	-	20
HVAC	1	EA	\$ 10,000.00	\$ 10,000.00		\$	_	20
Building Drainage	1	EA	\$ 5,000.00	\$ 5,000.00		\$	-	
Painting Painting	1	EA	\$ 8,000.00	\$ 8,000.00		\$	-	
Fencing Security	1	LS	\$ 10,000.00	\$ 10,000.00		\$	-	
Grade, Seed, Fertilize	1	AC	\$ 5,000.00	\$ 5,000.00		\$	-	
	1	LS	\$ 5,000.00	\$ 5,000.00		-\$	-	
Floodplain Permitting	- 1	LS	\$ 5,000.00	\$ 5,000.00		_		
						_		
						_	40.000.00	
Sub Total Construction - 2018				\$ 282,660.00		\$	48,900.00	
Number of Years until Construction				2		-		
Inflation rate of 3%				3%				
Sub Total Construction Cost - 2020				\$ 299,874.00				
Admin @ 5%				\$ 14,994.00				
Contigency @ 15%				\$ 44,981.00		<u> </u>		
Engineering @ 18%				\$ 53,977.00	ļ			
			I					
Total Project Cost			1	\$ 413,826.00				
						<u> </u>		
ANNUAL OPERATING AND MAINTENANCE COST								
		l	l					
Total Annual Cost (Net Change for City)				\$ -				
PRESENT WORTH ANALYSIS								
DESCRIPTION				TOTAL				
Total Project Cost				\$ 413,826.00				
Annual O&M				\$ -				
Salvage Value in 20 years (estimate)				\$ (48,900.00)				
Interest Rate				3.20%				
Number of Payments				20				
		TOTAL PR	ESENT WORTH	\$ 387,782.00				

East Helena Water Master Plan - 2018							
Water Well Source - ~200 ft deep - One Well West			1				
24-Mar-18							
COST ESTIMATE							
					S	ALVAGE VALUE	
ITEM	QUAN.	UNIT	UNIT PRICE	TOTAL PRICE	_	in 20 Years	Estimated life of Asset
Mobilization, Bonding & Ins.	1	LS	\$ 35,867.50		\$		
Drill & Install Mininum 16 Inch Dia Steel Well Casing	50	LF	\$ 150.00		\$ \$ \$	-	
Drill & Install Mininum 12 Inch Dia Steel Well Casing	100	LF	\$ 120.00		\$	-	
Drill & Install Mininum 10 Inch Dia Stainless Steel Well Screen	45	LF	\$ 300.00		\$	-	
Blank Screen Leader w/ Packer Grout Well	5 150	LF LF	\$ 150.00 \$ 30.00		\$ \$ \$	-	
	150	LS	\$ 30.00 \$ 1,500.00		2		
Well Logging, Sampling & Filing Water Sampling	1	LS	\$ 2,000.00		2		
Well Development	16	HR	\$ 300.00		\$ \$ \$		
Well Pump Testing	24	HR	\$ 300.00		9		
Well Recovery Measurements	12	HR	\$ 300.00		\$	-	
Well Pump & Motor - 75 HP, 8 Inch	1	EA	\$ 65,000.00		\$	-	
Pump Installation	1	LS	\$ 30,000.00				
6" Column Piping	150	LF	\$ 35.00				
1" Dia PVC Sounding Tube	150	LF	\$ 7.00		\$	-	
Pump Control, Mechanical Building - 10' x 20'	200	SF	\$ 250.00		\$	30,000.00	50
Site Work	1	LS	\$ 10,000.00		\$		
Electrical, Telemetry, & Controls	1	LS	\$ 20,000.00		\$	-	
Mechanical Equipment - Flowmeter, Valves	1	LS	\$ 50,000.00		\$	25,000.00	40
10-Inch PVC Pipe (Building to Existing Water Main)	3,100	LF	\$ 70.00	\$ 217,000.00	\$	130,200.00	50
10-Inch Gate Valve	2	EA	\$ 3,500.00		\$	4,200.00	50
Gravel Removal and Replacement	3600	SY	\$ 15.00		\$	-	
Exploratory Excavation	2	HRS	\$ 350.00		\$	-	
Utility Crossings	10	EA	\$ 500.00		\$	-	
Grade, Seed, Fertilize, Mulch	2.5	AC	\$ 4,000.00		\$	-	
Generator	1	LS	\$ 75,000.00				
Hydrogeologic Study and Modeling	1	LS	\$ 20,000.00		\$	-	
Water Rights	1	LS	\$ 20,000.00		\$	-	
Electrical Service	1	LS	\$ 20,000.00		\$	-	
Sub Total Construction - 2018				\$ 753,218.00	_		
Number of Years until Construction				200/	_		
Inflation rate of Sub Total Construction Cost - 2020				3% \$799,089.00	\$	189,400.00	
Sub Total Construction Cost - 2020				\$199,009.00	φ	109,400.00	
Admin @ 5%				\$ 39,954.00			
Contingency @ 15%				\$ 119,863.00			
Engineering @ 18%				\$ 143,836.00			
				,			
Total Project Cost				\$1,102,742.00			
ANNUAL OPERATING AND MAINTENANCE COST							
						·	
ITEM	QUAN.	UNIT	UNIT PRICE	TOTAL PRICE			
Labor inc. yearly line flushing	12	hours	\$ 25.00	\$ 300.00			
Total Annual Cost			1	\$ 300.00			
			1				
Proceed Words Analysis							
Present Worth Analysis			1	TOTAL	-		
DESCRIPTION Total Project Cost			-	TOTAL \$1,102,742	-		
Total Project Cost							
Annual O&M Salvage Value in 20 years (estimate)				\$300 (\$189,400)			
Interest Rate	_	<del>                                     </del>	+	3.20%			
Number of payments			+	20			
ramos o paymono		TOTAL F	RESENT WORTH	\$1,006,248.00			
				, .,, <b>.</b> 10.00			
	•						

East Helena Water Master Plan - 2018									
Caisson Protection and Level Monitoring Improvements									
3-May-18									
COST ESTIMATE									
								/AGE VALUE	Estimated life of
ITEM	QUAN.	UNIT		IIT PRICE	_	OTAL PRICE		20 Years	Asset
Mobilization, Bonding, and Ins.	1	LS	_	21,115.00	\$	21,115.00	\$	-	
Remove and Dispose of Existing Slab, Submersible Pump, Air Vent, Hatch, etc.	2	EA			\$	20,000.00	\$	-	
Site Work	2	EA	\$	5,000.00	\$	10,000.00	\$	-	
Hatches	2	EA	\$	1	\$	15,000.00	\$	-	
Building Construction (16' x 16')	512	SF	\$	200.00	\$	102,400.00	\$	61,440.00	50
Purchase Vertical Turbine Pump, 500 gpm, 6 inch	2	EA	\$	30,000.00	\$	60,000.00	\$	-	20
Pumps Install	2	EA	\$	10,000.00	\$	20,000.00	\$	-	
Piping & Mechanical Equipment (Includes Magnetic Flowmeter and Valves)	2	LS	\$	18,000.00	\$	36,000.00	\$	18,000.00	40
Connect to Existing 6 inch Piping	2	EA	\$	5,000.00	\$	10,000.00	\$	-	
HVAC	2	EA	\$	6,000.00	\$	12,000.00	\$	-	
Building Drainage	2	EA	\$	5,000.00	\$	10,000.00	\$		
Painting	2	EA	\$	7,500.00	\$	15,000.00	\$	-	
Purchase and Install Pump Control Panel	2	EA	\$	10,000.00	\$	20,000.00	\$	-	
Electrical Demolition	2	EA	\$	3,000.00	\$	6,000.00	\$	-	
General Building Wiring and Power Feeds	2	EA	\$	25,000.00	\$	50,000.00	\$	-	
Level Control System and Wiring to RTU	2	EA	\$	15,450.00	\$	30,900.00	\$	-	
Grade, Seed, Fertilize	1	AC	\$	5,000.00	\$	5,000.00	\$	-	
Sub Total Construction - 2018					\$	443,415.00	\$	79,440.00	
Number of Years until Construction						2			
Inflation rate of 3%						3%			
Sub Total Construction Cost - 2020					\$	470,419.00			
						·			
Admin @ 5%					\$	23,521.00			
Contigency @ 15%					\$	70,563.00			
Engineering @ 18%					\$	84,675.00			
g g					_	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,			
Total Project Cost		Į.			\$	649,178.00			
,					i -	,			
ANNUAL OPERATING AND MAINTENANCE COST									
Total Annual Cost (Net Change for City)		ı	1		\$	-			
3					i .				
PRESENT WORTH ANALYSIS									
DESCRIPTION			1			TOTAL	1		
Total Project Cost			1		\$	649,178.00	1		
Annual O&M			1		\$	-	1		
Salvage Value in 20 years (estimate)			1		\$	(79,440.00)	†		
Interest Rate			1		Ť	3.20%	1		
Number of Payments			1			20	1		
Trained or Caymond		TOTAL PR	RESEN	IT WORTH	s	606,868.00	+		
		. JIALII	LOCI	HORAII	Ψ	500,000.00	1		

East Helena Water Master Plan - 2018										
Caisson Access Hatch Improvements and Pumping Management										
3-May-18										
COST ESTIMATE										
ITEM		QUAN.	UNIT	LINIE	IT DDIOE	т.	TAL PRICE		E VALUE Years	Estimated life of Asset
		QUAN.	LS		IT PRICE					Asset
Mobilization, Bonding, and Ins. Site Work				\$	7,045.00 2,500.00	\$	7,045.00	\$	-	
		2	EA EA			\$	5,000.00	\$	-	
Hatches 500 500 500 500 500 500 500 500 500 50		4			7	\$	,	\$	-	
Purchase Submersible Turbine Pump, 500 gpm, 6 inch		2	EA			\$	40,000.00	\$	-	20
Pumps Install		2	EA		1	\$	15,000.00	\$	-	
Purchase and Install Pump Control Panel		2	EA		- 1	\$	20,000.00	\$	-	20
Level Control System and Wiring to RTU		2	EA	\$ .	15,450.00	\$	30,900.00	\$	-	20
Sub Total Construction - 2018						\$	147,945.00	\$	-	
Number of Years until Construction							2			
Inflation rate of 3%							3%			
Sub Total Construction Cost - 2020						\$	156,955.00			
Admin @ 5%						\$	7,848.00			
Contigency @ 15%						\$	23,543.00			
Engineering @ 18%						\$	28,252.00			
Total Project Cost	1				1	\$	216,598.00			
ANNUAL OPERATING AND MAINTENANCE COST										
Total Annual Cost (Net Change for City)				,	,	\$	- ,			
PRESENT WORTH ANALYSIS										
DESCRIPTION							TOTAL			
Total Project Cost						\$	216,598.00			
Annual O&M						\$	-			
Salvage Value in 20 years (estimate)						\$	-			
Interest Rate							3.20%			
Number of Payments							20			
			TOTAL PR	ESENT	T WORTH	\$	216,598.00			

East Helena Water Master Plan - 2018							
Pre-Stressed Concrete Tank							
24-Mar-18							
COST ESTIMATE							
					3	SALVAGE VALUE	
ITEM	QUAN.	UNIT	UNIT PRICE	TOTAL PRICE		in 20 Years	Estimated life of Asset
Mobilization, Bonding & Ins.	1	LS	\$ 110,035.00		5		
Excavation	33000	CY	\$ 9.00		3		
Tank Foundation Construction prep - 6" crushed 3/4" minus	1200	CY		\$ 36,000.00			
Construct New 1 million gal. AWW A D11- Type III Prestressed Concrete Water Tank	1000000	GAL		\$ 1,250,000.00	5		70
Backfill	22000	CY		\$ 242,000.00			
Excess Spoils Disposal	11,000	CY		\$ 77,000.00	3		
Tank Inlet/Outlet/Overflow Piping to tank footprint	1	LS	\$ 40,000.00		3		50
Electrical & Telemetry	1	LS	\$ 20,000.00				
Ultrasonic Level Sensor	1	EA		\$ 6,000.00	5		
Access Road and Site work	1	LS	\$ 30,000.00		3		
Chainlink Fence - 6' Tall	425	LF	\$ 40.00		3		20
12-Inch Overflow and Drain	300	LF		\$ 25,500.00	_5		50
12-Inch Buried Butterfly Valve	3	EA	\$ 5,000.00		5		50
12-inch buried C900 DR18 PVC transmission main	300	FT	\$ 80.00		3		50
6-Inch Inlet piping	300	FT	\$ 65.00		_ 5		50
6-inch Buried Gate Valve	2	EA	\$ 2,000.00		5		50
Exploratory Excavation	2	HR	\$ 350.00		3		
Grade, Seed, Fertilize, Mulch	3	AC	\$ 4,000.00		_ 5		
Tank Demolition	1	LS	\$ 75,000.00		3		
Testing, Chlorination and Water Disposal	1	LS	\$ 10,000.00	\$ 10,000.00		-	
Sub Total Construction - 2018				\$ 2,310,735.00	_		
Number of Years until Construction				2	_		
Inflation rate of 3%				3%			
Sub Total Construction Cost - 2020				\$2,451,459.00		969,657.14	
11:00				A 100 F70 00			
Admin @ 5%				\$ 122,573.00			
Contingency @ 15%				\$ 367,719.00			
Engineering @ 18%				\$ 441,263.00			
Total Business Const				60 000 044 00			
Total Project Cost			1	\$3,383,014.00			ı
ANNUAL OPERATING AND MAINTENANCE COST							
ANNUAL OPERATING AND MAINTENANCE COST							
ITEM	QUAN.	UNIT	UNIT PRICE	TOTAL PRICE	-		
TTEW	QUAN.	UNIT	UNITERICE	TOTAL PRICE			
Total Annual Cost				s -	- 1		l .
Total Allitual Cost	1		I	<b>.</b>	1		I
Present Worth Analysis					-		
DESCRIPTION				TOTAL	-+		
Total Project Cost				\$3,383,014	-		
Annual O&M				\$0			
Salvage Value in 20 years (estimate)				(\$969,657)	-		
Interest Rate			1	3.20%			
Number of payments				20	-+		
Trained of paymond		TOTAL P	RESENT WORTH	\$2,866,569.00	-+		
	1	TOTALI		72,000,000.00			1

East Helena Water Master Plan - 2018						
Glass-Fused-to-Steel						
24-Mar-18						
21110110						
COST ESTIMATE						
					SALVAGE	
					VALUE in 20	
ITEM	QUAN.	UNIT	UNIT PRICE	TOTAL PRICE	Years	Estimated life of Asset
Mobilization, Bonding & Ins.	1	LS	\$ 141,035.00	\$ 141,035.00	\$ -	
Excavation	33,000	CY	\$ 9.00		\$ -	
Tank Foundation Construction prep - 6" crushed 3/4" minus	1,200	CY	\$ 30.00		\$ -	
Construct New 1 million gal. Glass Fused to Steel Tank	1,000,000	GAL	\$ 0.95		\$633,333.33	60
Backfill	22,000	CY		\$ 242,000.00	\$ -	
Retaining Walls	450	FT	\$ 1,500.00	\$ 675,000.00	\$ -	
Excess Spoils Disposal	11,000	CY	\$ 7.00		\$ -	
Tank Inlet/Outlet/Overflow Piping to tank footprint	1	LS	\$ 40,000.00		\$ 24,000.00	50
Electrical & Telemetry	1	LS	\$ 20,000.00		\$ -	
Ultrasonic Level Sensor	1	EA	\$ 6,000.00		\$ -	
Access Road and Site work	1	LS	\$ 50,000.00		\$ -	+
Chainlink Fence - 6' Tall	425	LF	\$ 40.00		\$ -	
12-Inch Overflow and Drain	300	LF	\$ 85.00		\$ 15,300.00	50
12-Inch Overlow and Dialil 12-Inch Buried Butterfly Valve	300	EA	\$ 5,000.00		\$ 15,300.00	
12-inch buried butterny valve  12-inch buried C900 DR18 PVC transmission main	300	FT	\$ 3,000.00		\$ 14,400.00	
6-Inch Inlet piping	300	FT	\$ 65.00		\$ 11,700.00	
6-inch Buried Gate Valve	2	EA	\$ 2,000.00		\$ 2,400.00	
Exploratory Excavation	2	HR	\$ 2,000.00	\$ 4,000.00	\$ 2,400.00	50
Grade, Seed, Fertilize, Mulch	3	AC		\$ 12,000.00	\$ -	
Tank Demolition and removal	1	LS LS	\$ 300,000.00	\$ 300,000.00	\$ - \$ -	
Testing, Chlorination and Water Disposal  Sub Total Construction -2018	1	LS	\$ 10,000.00	\$ 10,000.00	\$ -	
				\$2,961,735.00		
Number of Years until Construction				2		
Inflation rate of 3%				3%	0740 400 00	
Sub Total Construction Cost - 2020				\$3,142,105.00	\$710,133.33	•
A Lucia @ 507				A 457 405 00		
Admin @ 5%				\$ 157,105.00		
Contingency @ 15%				\$ 471,316.00		
Engineering @ 18%				\$ 565,579.00		
Total Brook of Octob			l .	\$4.000.40F.00		
Total Project Cost				\$4,336,105.00		1
ANNULAL OPERATING AND MAINTENANCE COOT						
ANNUAL OPERATING AND MAINTENANCE COST						
ITCA	144110	LINUT	LINIT DDICE	TOTAL DDIOS		
ITEM	QUAN.	UNIT	UNIT PRICE	TOTAL PRICE		
Resealing and Painting 60,000 Every 20 years	1	LS	\$ 3,000.00	\$ 3,000.00		
Note: O&M for this item anticipates a 20 year life form most equipment						
T-/-1410/			1	0.000.00	l	1
Total Annual Cost			1	\$ 3,000.00		
Bosses (March Assets)						
Present Worth Analysis				TOT!!		
DESCRIPTION				TOTAL		
Total Project Cost				\$4,336,105		
Annual O&M				\$3,000		
Salvage Value in 20 years (estimate)				(\$710,133)		
Interest Rate				3.20%		
Number of payments				20		
		TOTAL	PRESENT WORTH	\$4,001,702.00		

East Helena Water Master Plan - 2018								
Main Street Watermain Replacement								
24-Mar-18								
21110110								
COST ESTIMATE								
							SALVAGE VALUE	
ITEM	QUAN.	UNIT	UNI	T PRICE	-	TOTAL PRICE	in 20 Years	Estimated life of Asset
Mobilization, Bonding & Ins.	1	LS	\$	6,990.00		6,990.00	\$ -	
8" PVC Watermain	50	LF	\$	70.00	\$	3,500.00	\$ 2,100.00	50
Flowable Fill	50	CY	\$	150.00	\$	7,500.00		
10" HDPE Direction Drill	250	LF	\$	225.00		56,250.00	\$ 33,750.00	50
8" Gate Valves	2	LS	\$	3,500.00	\$	7,000.00	\$ 4,200.00	50
Blow Off Assembly	2	EA	\$	1,500.00	\$	3,000.00	\$ 1,800.00	50
Traffic Control	1	LS	\$	10,000.00	\$	10,000.00	\$ -	
Pavement Removal and Replacement	120	SY	\$	200.00		24,000.00	\$ -	
Watermain Connections	2	EA	\$	7,500.00		15,000.00	\$ -	
Water Service Reconnections	3	EA	\$	4,500.00	\$	13,500.00	\$ 8,100.00	50
Sub Total Construction -2018				,	\$	146,740.00	, , , , , , , , , , , , , , , , , , , ,	
Number of Years until Construction						2		
Inflation rate						3.0%		
Sub Total Construction Cost - 2020						\$155,676.00	\$ 49,950.00	
						,,		
Admin @ 5%					\$	7.784.00		
Contingency @ 15%					\$	23,351.00		
Engineering @ 18%					\$	28,022.00		
						·		
Total Project Cost	,					\$214,833.00		
,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,						, ,		
ANNUAL OPERATING AND MAINTENANCE COST								
ITEM	QUAN.	UNIT	UNI	T PRICE	-	TOTAL PRICE		
Labor inc. yearly line flushing	12	hours	\$	30.00		360.00		
Valve exercising twice a year	10	hours	\$	30.00		300.00		
Total Annual Cost	,				\$	660.00		
					ľ			
Present Worth Analysis								
DESCRIPTION			1			TOTAL		
Total Project Cost			1			\$214,833		
Annual O&M						\$660		
Salvage Value in 20 years (estimate)						(\$49,950)		
Interest Rate			1			3,20%		
Number of payments						20		
· · · · · · · · · · · · · · · · · · ·		TOTAL P	RESEN	T WORTH		\$197,869.00		
		1		5		[		

East Helena Water Master Plan - 2018							
6-Inch Chemet Loop							
22-Mar-18							
EL Mai 10							
COST ESTIMATE							
0001 2011111112						SALVAGE VALUE	
ITEM	QUAN.	UNIT	UNIT PRICE	TOTAL PRICE		in 20 Years	Estimated life of Asset
Mobilization, Bonding & Ins.	1	LS	\$ 19,170.00		-	\$ -	Edimated ind of 7 loost
6" PVC Watermain	300	LF	\$ 70.00			\$ 12,600.00	50
8" HDPE Direction Drill	165	LF	\$ 200.00			\$ 19,800.00	50
16" Bore and Jack	480	LF	\$ 480.00			\$ 138,240.00	50
6" Gate Valves	3	LS	\$ 3,500.00			\$ 6,300.00	50
Fire Hydrant Assemble w/ Hydrant Valve	1	EA	\$ 6,500.00			\$ -	20
Blow Off Assembly	1	EA	\$ 1,500.00			\$ 900.00	50
Traffic Control	1	LS	\$ 15,000.00			\$ -	
Pavement Removal and Replacement	400	SY	\$ 115.00			\$ -	
Watermain Connections	2	EA	\$ 7,500.00			\$ -	
Water Service Reconnections	1	EA	\$ 4,500.00			\$ 2,700.00	50
Sub Total Construction - 2018		LA	Ψ 4,000.00	\$ 402,570.00		Ψ 2,700.00	30
Number of Years until Construction				2	-		
Inflation rate				3.0%	-		
Sub Total Construction Cost - 2020				\$427,087.00		\$ 180,540.00	
Sub Total Construction Cost - 2020				\$427,087.00		\$ 100,340.00	
Admin @ 5%				\$ 21,354.00			
Contingency @ 15%				\$ 64,063.00			
Engineering @ 18%				\$ 76,876.00			
Engineering @ 1676				\$ 70,070.00			
Total Project Cost		l	l .	\$589,380.00	- 1		
Total Froject cost		1	I	φ303,300.00	- 1		
ANNUAL OPERATING AND MAINTENANCE COST							
ANTICAL OF ENATING AND MAINTENANGE GOOT							
ITEM	QUAN.	UNIT	UNIT PRICE	TOTAL PRICE			
Labor inc. yearly line flushing	12	hours	\$ 30.00				
Valve exercising twice a year	10	hours	\$ 30.00				
valve exercising twice a year	10	Hours	ψ 30.00	\$ 300.00			
Total Annual Cost		l	l .	\$ 660.00	- 1		
Total Allitual Cost		ı	I	\$ 000.00	1		1
Present Worth Analysis							
DESCRIPTION				TOTAL			
Total Project Cost				\$589.380			
Annual O&M				\$660			
Salvage Value in 20 years (estimate)				(\$180,540)	-		
Interest Rate				3.20%			
Number of payments				3.20%			
riviniber of payments		TOTAL D	RESENT WORTH	\$502,863.00			
		TOTAL P	LOCKI WORTH	\$3U2,003.UU			

East Helena Water Master Plan - 2018								
1st Street North Loop						+		
22-Mar-18						-		
22-Mai-10						+		
COST ESTIMATE								
0001 20111111112							SALVAGE VALUE	
ITEM	QUAN.	UNIT	UN	IT PRICE	TOTAL PRICE		in 20 Years	Estimated life of Asset
Mobilization, Bonding & Ins.	1	LS	\$	4,713.00		<del>-</del>	\$ -	2011110100 1110 01710001
6" PVC Watermain	300	LF	\$	70.00			\$ 12,600.00	50
6" Gate Valves	1	LS	\$	3.500.00			\$ 2,100.00	50
Fire Hydrant Assemble w/ Hydrant Valve	1	EA	\$	6,500.00			\$ -	
Traffic Control	1	LS	\$	8,000.00			\$ -	
Pavement Removal and Replacement	350	SY	\$	115.00			\$ -	
Watermain Connections	2	EA	\$	7,500.00			\$ -	
Sub Total Construction - 2018					\$ 98,963.00			
Number of Years until Construction						2		
Inflation rate					3.0	6		
Sub Total Construction Cost - 2020					\$104,990.00		\$ 14,700.00	
Admin @ 5%					\$ 5,250.00	)		
Contingency @ 15%					\$ 15,749.00	)		
Engineering @ 18%					\$ 18,898.00	)		
					A			
Total Project Cost			1		\$144,887.00	'		
ANNUAL OPERATING AND MAINTENANCE COST								
ITEM	QUAN.	UNIT	UN	IT PRICE	TOTAL PRICE			
Labor inc. yearly line flushing	12	hours	\$	30.00		)		
Valve exercising twice a year	10	hours	\$	30.00	\$ 300.00	)		
ů ,								
Total Annual Cost					\$ 660.00	)	•	
					,			
Present Worth Analysis								
DESCRIPTION					TOTAL			
Total Project Cost					\$144,887			
Annual O&M					\$660			
Salvage Value in 20 years (estimate)			1		(\$14,700)	1		
Interest Rate					3.20%	1		
Number of payments					20			
		TOTAL P	RESEN	IT WORTH	\$146,698.00			

East Helena Water Master Plan - 2018							
Radial Well Access							
22-Mar-18							
COST ESTIMATE							
						SALVAGE VALUE	
ITEM	QUAN.	UNIT	UNIT PRICE		TOTAL PRICE	in 20 Years	Estimated life of Asset
Mobilization, Bonding & Ins.	1	LS	\$ 3,500.00		3,500.00	\$ -	
Install Pedestrian Bridge	1	LS	\$ 70,000.00	\$	70,000.00	\$ 14,000.00	25
Sub Total Construction - 2018				\$	73,500.00		
Number of Years until Construction					2		
Inflation rate of 3%					3%		
Sub Total Construction Cost - 2020					\$77,976.00	\$ 14,000.00	0
Admin @ 5%				\$	3,899.00		
Contingency @ 10%				\$	11,696.00		
Engineering @ 18%				\$	14,036.00		
Total Project Cost					\$107,607.00		
ANNUAL OPERATING AND MAINTENANCE COST							
ITEM	QUAN.	UNIT	UNIT PRICE	-	TOTAL PRICE		
No operation and maintenance cost assumed							
•							
Total Annual Cost				\$	-		
Present Worth Analysis							
Description					TOTAL		
Total Project Cost					\$107,607		
Annual O&M					\$0		
Salvage Value in 20 years (estimate)					(\$14,000)		
Interest Rate					3.20%		
Number of payments					20		
		TOTAL F	RESENT WORTH	1	\$100,151.00		
		1			Ţ,io0		

5				ı			
East Helena Water Master Plan - 2018							
Telemetry System Upgrades							
25-Mar-18							
COST ESTIMATE							
						SALVAGE VALUE	
ITEM	QUAN.	UNIT	UNIT PRICE	TOTAL PRICE	_	in 20 Years	Estimated life of Asset
Mobilization, Bonding & Ins.	1	LS	\$ 16,000.00			\$ -	
RTU Units	6	EA	\$ 40,000.00			\$ -	
Main SCADA Controls	1	EA	\$ 80,000.00				
Sub Total Construction - 2018				\$ 336,000.00			
Number of Years until Construction				2			
Inflation rate of 3%				3%			
Sub Total Construction Cost - 2020				\$356,462.00		\$ -	
Admin @ 5%				\$ 17,823.00			
Contingency @ 10%				\$ 35,646.00			
Engineering @ 18%				\$ 64,163.00			
Total Project Cost				\$474,094.00			
,							
ANNUAL OPERATING AND MAINTENANCE COST							
ITEM	QUAN.	UNIT	UNIT PRICE	TOTAL PRICE			
				\$ -			
Total Annual Cost		1		s -	1	•	
		1		l *	1		
Present Worth Analysis							
DESCRIPTION				TOTAL			
Total Project Cost				\$474.094			
Annual O&M				\$0			
Salvage Value in 20 years (estimate)				\$0	<u> </u>		
Interest Rate				3.20%	<del>                                     </del>		
Number of payments				20			
Number of payments		TOTAL	RESENT WORTH		_		
		IOIALF	LOCKI WOKIN	φ <del>41 4</del> ,034.00			
			1	1		1	

#### **APPENDIX N – PUBLIC PARTICIPATION**

Page

1 of 1

02/15/2018 15:10:15

Order Number PO Number 20416053 public meeting

Customer : 6

60000224 CITY OF EAST HELENA

Contact Address1 Address2

: City Clerk 1 : P.O. Box 1170

City St Zip Phone

Fax

EAST HELENA MT 59635

ile

:

Printed By : Lynn Hencley Entered By : Lynn Hencley

Keywords : Notes : Zones : Ad Number : 10946927

Ad Key

Salesperson : 04 - Lynn Hencley - 04
Publication : Independent Record
Section : Class Section

Sub Section : Legal

Category : 9999 Legals

Dates Run : 02/18/2018-02/25/2018

**Days** : 2

Size : 2 x 3.01, 28 lines

 Words
 :
 252

 Ad Rate
 :
 Folio

 Ad Price
 :
 66.00

 Amount Paid
 :
 0.00

 Amount Due
 :
 66.00

#### CITY OF EAST HELENA NOTICE OF PUBLIC MEETING

DATE: February 14, 2018

The City of East Helena will be holding a public meeting to discuss the Water System Master Plan efforts currently underway in East Helena as well as potential funding alternatives for future improvements. We invite the public to participate and comment during the development of the plan and value your participation in this process. Any interested person may appear and be heard. The meeting will be held at East Helena City Hall on February 27 at 6:00 p.m.

Attending will be Robert Peccia & Associates and the City Representatives. If you have any questions or comments, please contact East Helena City Hall at 227-5321. For more information, please visit the City's Water Master Plan web page: easthelenamt.us/wmp

The City of East Helena is committed to providing access to persons with disabilities for its meetings, in compliance with Title II of the Americans with Disabilities Act and the Montana Human Rights Act. The City will not exclude persons with disabilities from participation at its meetings, or otherwise deny them the City's services, programs, or activities. Persons with disabilities requiring accommodations to participate in the City's meetings, services, programs, or activities should contact the City Clerk, Gena Berry, as soon as possible to allow sufficient time to arrange for the requested accommodation, at any of the following: (406) 227-5321 or

TTY Relay Service 1-800-253-4091 or 711

306 East Main Street, P.O. Box 1170, East Helena, MT 59635

February 18, 25, 2018

MNAXLP

### AFFIDAVIT OF PUBLICATION STATE OF MONTANA,

County of Lewis & Clark

Billie Jo Williams

Being duly sworn, deposes and says;

That she is the principal clerk of the Independent Record, a newspaper of general circulation published daily in the City of Helena, in the County of Lewis & Clark, State of Montana, and has charge of the advertisement therof:

That the Notice of Public Meeting

a true copy of which is hearto annexed, was published in said newspaper on the following dates: viz.:

February 18, 25, 2018

making in all _2_ publication(s)

Subscribed and sworn to me this _27_ day of _February_ 2018

Notary Public for the State of Montana

Printed Name: Colleen D. Simkins Residing at Helena, Montana My commission expires March 10, 2021

(Notary Seal)

RECEIVED

MAR 0 1 2018

CITY OF EAST HELENA, MI



COLLEEN D. SIMKINS NOTARY PUBLIC for the State of Montana Residing at Helena, Montana My Commission Expires March 10, 2021



Tuesday, February 27, 2018

# City of East Helena, Montana MASTER WATER PLAN

Go to: East Helena Main Website

#### 2018 Water Master Plan

The City of East Helena is in the process of updating our public water supply Master Plan (2018 Water Master Plan), last updated and approved in 1998.

The 2018 Water Master Plan will describe how the City meets current water demands, ensures high quality drinking water, enhances system reliability, outlines future planning needs and requirements, and assists with obtaining funding sources to complete planned upgrades and additions.

The 2018 Water Master Plan will serve as a tool to assist the City of East Helena with making decisions for short-term and long-term type projects to continue to provide quality public water supply services and protect the health of our customers.

For more information, please call City Clerk Gena Berry at 406-227-5321. Public comments should be written and emailed to the

#### **Public Meeting Schedule:**

The City of East Helena 2018 Water Master Plan first public meeting will be held on Tuesday, February 27, 2018 at 6 P.M. in Room 110, City Council Chambers, at City Hall, 306 E Main Street.

#### February 27, 2018, Public Meeting Notice (PDF)

The first meeting will include a presentation on the purpose of the Master Plan, review of the existing water system, and potential water system infrastructure improvements (proposed projects), cost estimates and possible sources of funding for the highest priority projects.

Public meetings will be held for the purpose of obtaining public comments regarding the current water system and the water system upgrades recommended in the 2018

# CITY OF EAST HELENA, MONTANA WATER SYSTEM MASTER PLAN FEBRUARY 27, 2018 PUBLIC MEETING SIGN-IN SHEET

NAME	ADDRESS	PHONE NUMBER
JAMES SINELL	City of Kost Helm	468-2921
Live Yode	610 É. R. 995. St East Holana	439-6091
DON DAHL	307 King 5- E. H.	227-6876
BRAD KOENIG	RPA	447-5000
Trush Bodlovic	RPA	447-5000
Luke Laliberty	KLJ engineering	475-2546
Tim Opie	112 N Mon facea	461-15-14
		4
	•	
	*	
	~	



# City of East Helena Water System Master Plan

## **Overview and Discussion on Preliminary Findings**

Public Meeting – February 27, 2018

Robert Peccia and Associates

## In General the Master Plan includes:

- Review the existing water system and its operating parameters.
- Identify areas where system improvements should be made. Develop alternatives to provide the community with reliable water service and improve operations through the planning period.
- Complete a list of recommended improvements for the water system and a funding strategy for implementation.



# **East Helena Water System Components**

- Wylie Drive Wells and Transmission Main
  - Wylie Well #1, 600 gpm (1965)
  - Wylie Well #2, 600 gpm (1965)
  - Wylie Well #3, 450 gpm (1987) Chlorination Point for Wylie Wells
- Highway 282, 1-Million Gallon Reservoir
- McClellan Radial Wells
  - Radial Well #1, 500 gpm (1987)
  - Radial Well #2, 500 gpm (1987)






# **East Helena Water System Components** (Cont'd)

- McClellan Tanks
  - Reservoir #1, 250,000 Gallons (1928)
  - Reservoir #2, 300,000 Gallons (1948)
- Wylie and McClellan Transmission Mains
- Distribution System
- Telemetry & Control System





## **CURRENT and FUTURE OPERATING CRITERIA**

CRITERIA	VALUE	
Existing Population (2017)	2,194	
Annual Growth Rate	1.45%	
Future Population (2037)	2,926	
Current Average Daily Demand	423,835 gpd (294 gpm)	
Average Day Demand per Capita	193 gal	
Current Max Daily Demand	1,059,588 (736 gpm)	
Future Average Daily Demand	564,718 gpd	
Future Max Daily Flow	1,411,795 gpm	



# Concerns - East Helena Water System

- Wylie Well #3 Proximity to Selenium Plume and Gravel Pit.
- McClellan Tank Leakage, Inoperable Valves, Aging Concrete.
- Critical Water Main Creek Crossing Lost at Main Street.
- Accessibility to Maintain and Service Radial Wells.
- Available Fire Flow near American Chemet.
- Dead End Main at West Groschell and 1st Street.
- Aging Telemetry Controls.



# Alternatives: Wylie Well #3 Proximity to Selenium Plume

- Replace Wylie Well #3 and Pump West Re-Using Existing Chlorination Point.
- Replace Wylie Well #3 and Pump East.
   Chlorination Point at New Well.




# Alternatives: Wylie Well #3 Proximity to Selenium Plume



# Alternatives: McClellan Tanks and

**Piping** 



# Alternatives: McClellan Tanks and Piping

 Construct New 750,000-Gallon or 1-Million Gallon Tank and Replace Piping with Optimized Design.



# Summary of All Recommended Improvements

- Replace Wylie Well #3 at WWTP Property and Install New Chlorination System.
- Construct New McClellan Tank and Piping.
- Re-establish Water Main Crossing at Main Street.
- City to Work on Access Agreement and Add Walking Bridge at Radial Wells.
- Water Main Loop and Replacement from 1st Street below Highway 12 to Manlove near American Chemet.
- Water Main Loop on 1st Street from West Groschell to Gail to alleviate dead end.
- Replace Telemetry.



# TOTAL PROJECT COST - ALL RECOMMENDED ALTERNATIVES

Preliminary Estimate is \$4.4 Million.

### **Grant and Loan Funding Opportunities**

- TSEP Grants of \$500,000 to \$750,000 (biannual) 7 Criteria
  - Must Exceed TSEP "Target Rate" (2.3% of MHI = \$88.60 /mo for Water+Sewer)
    - **Current Residential Avg. Rate = \$100.25 (113% of Target Rate)**
  - Maximum of \$500,000 (unless > 125% of Target Rate)
  - "Dollar-for-Dollar" Match required can include other grants
- RRGL Grants to \$125,000 (biannual) "conservation of water resources"
  - Maximum of \$125,000
  - No Match required
- CDBG Grants to \$450,000 (annual)
  - Requires > 51% LMI Benefit (Income Survey or "Targeting")

### **Grant and Loan Funding Opportunities**

- USDA Rural Development Grant/Loan Packages
  - Grant Share is Variable
- MDEQ State Revolving Fund (SRF) Loans
  - (2) SRF Programs Water Pollution Control and Drinking Water
  - 2.50% Interest, 20 or 30 year Loans

- Most Grants Require "Financial Need".... also Health/Safety Issues
- Grant Applications are Ranked COMPETITIVELY, and Not All Funded

### **Next Steps and Project Schedule**

- Project Newsletter Forthcoming.
- Project Web Site (Current) Link From City's Web Page.
- Develop a Detailed Funding Strategy for Implementation.
- Second Public Meeting (on PER, Grant Applications, and EA).
- Grant Applications Due May and June.

#### City of East Helena

## Public Meeting to Obtain Comments on the Water Master Plan – 2018 and Funding Applications for the Water System Improvements

Tuesday February 27, 2018, 6:00 p.m.
East Helena City Hall
306 Main Street, East Helena, Montana

Meeting Minutes and Summary of Public Comments

#### In Attendance

James Schell, Mayor
Don Dahl, City Council Member
Tim Opie
Kirk Yoder, Resident
Luke LaLiberty, KLJ Engineering
Brad Koenig, P.E., Robert Peccia & Associates, Helena
Trisha Bodlovic, Robert Peccia & Associates, Helena

#### Introduction

At 6:00 p.m., Mayor James Schell called the meeting to order and introduced Brad Koenig of Robert Peccia & Associates. Brad proceeded with a presentation (copy attached), discussing the components of the East Helena Water System and the current and future operating criteria. Brad summarized the water system concerns as shown in the presentation including Wylie Well #3, the McClellan tanks, the critical water main creek crossing lost at Main Street, the accessibility to maintain and service the radial wells, the available fire flow near American Chemet, the dead-end main at West Groschell and 1st Street, and the aging telemetry. Brad then explained the alternatives to address each of the above listed concerns including replacement of Wylie Well #3, construction of a new tank to replace the McClellan tanks, re-establish the water main connection at Main Street, addition of a walking bridge at the radial wells, addition of new water main to loop the distribution system from 1st Street below Highway 12 to Manlove near American Chemet, addition of water main on 1st Street to alleviate the dead-end, and replacement of the telemetry system. The preliminary project cost of \$4.4 million was presented and potential funding possibilities were explained. Brad ended the presentation with information on the next steps on the project which included sending out a project newsletter to all water system users, development of the project website, a detailed funding strategy for implementation will be developed, a second public meeting to be held on the Master Plan as well as the submission deadlines of the project funding applications.

#### **Public Comments**

Resident Kirk Yoder voiced his concerns about the need to do all these projects at once and having to raise user rates. He believes the tank leakage is excessive and should be dealt with, however, the remaining projects should be done over the 20-year planning period.

Mayor Schell gave a history of the public water rates and his concerns with a few of the recommended improvements. He believes the Main Street stream crossing and the Wylie Well #3 is the greatest concern for the Town. Mayor Schell also explained some potential other funding sources including the Natural Resource Damage (NRD) Program and the Montana Environmental Trust Group (METG). He believes the METG may be able to help fund the new well.

The meeting was adjourned at 7:05.

1 of 1 03/21/2018 16:57:57 Page

Order Number

20418777

PO Number Customer 60000224 CITY OF EAST HELENA

Contact City Clerk Address1 P.O. Box 1170

Address2

City St Zip **Phone** 

EAST HELENA MT 59635

**Fax** 

Printed By Lynn Hencley **Entered By** Lynn Hencley

Keywords **Notes** Zones

**Ad Number** 10951147

Ad Key

Salesperson 04 - Lynn Hencley - 04 **Publication** Independent Record Section Class Section

**Sub Section** Legal

Category 9999 Legals

**Dates Run** 03/25/2018-04/01/2018

Days

Size 2 x 3.01, 28 lines

Words 257 Ad Rate Folio Ad Price 66.00 **Amount Paid** 0.00 Amount Due 66.00

#### CITY OF EAST HELENA NOTICE OF PUBLIC MEETING

**DATE:** March 21, 2018

The City of East Helena will be holding a public meeting to discuss the Water System Master Plan, the Draft Environmental Assessment, recommended alternatives of the Master Plan, and upcoming submittal of grant applications for these recommendations. We invite the public to participate and comment during the development of the plan and value your participation in this process. Any interested person may appear and be heard. The meeting will be held at East Helena City Hall on Thursday, April 5 at

Attending will be Robert Peccia & Associates and City Representatives. If you have any questions or comments, please contact East Helena City Hall at 227-5321. For more information, please visit the City's Water Master Plan web page:

easthelenamt.us/wmp

The City of East Helena is committed to providing access to persons with disabilities for its meetings, in compliance with Title II of the Americans with Disabilities Act and the Montana Human Rights Act. The City will not exclude persons with disabilities from participation at its meetings, or otherwise deny them the City's services, programs, or activities. Persons with disabilities requiring accommodations to participate in the City's meetings. services, programs, or activities should contact the City Clerk, Gena Berry, as soon as possible to allow sufficient time to arrange for the requested accommodation, at any of the following: (406) 227-5321 or

TTY Relay Service 1-800-253-4091 or 711

306 East Main Street, P.O. Box 1170, East Helena, MT 59635

March 25, April 1, 2018

MNAXLP

#### AFFIDAVIT OF PUBLICATION STATE OF MONTANA.

County of Lewis & Clark

Billie Jo Williams

Being duly sworn, deposes and says;

That she is the principal clerk of the Independent Record, a newspaper of general circulation published daily in the City of Helena, in the County of Lewis & Clark, State of Montana, and has charge of the advertisement therof:

That the Notice of Public Meeting

a true copy of which is hearto annexed, was published in said newspaper on the following dates: viz.:

March 25 & April 1, 2018

making in all _2_ publication(s)

Subscribed and sworn to me this _4_ day of _April_

Notary Public for the State of Montana

Printed Name: Colleen D. Simkins Residing at Helena, Montana

My commission expires March 10, 2021

(Notary Seal)



COLLEEN D. SIMKINS NOTARY PUBLIC for the State of Montana Residing at Helena, Montana My Commission Expires March 10, 2021

**PECEIVED** 

APR 0 6 2018

CITY OF EAST HELENA, MT

# City of East Helena Water System Improvements Project

March 2018

# Public Meeting Scheduled—Thursday April 5, 2018

### Water Improvements Project

The City of East Helena will hold a second public meeting on Thursday April 5, 2018, at 6:00 pm at East Helena City Hall. This meeting is being held to obtain public comments regarding the Water System Master Plan and recommended future improvements. A presentation on the project will discuss the Water System Master Plan recommendations, any environmental review associated with the project, costs for the water system improvements, and esti-

mated user rates.

The City intends to apply for funding in May and June of 2018 for the project and would like comments from citizens about the Master Plan recommendations proposed applications for TSEP and DNRC/ RRGL grants and an SRF loan. Comments may be given orally at the meeting or submit written comments by April 10, 2018 to Robert Peccia & Associates (P.O. Box 5653 Helena, MT 59604).



McClellan Storage Tanks

For additional information please contact Mayor James Schell or the Project Engineer Brad Koenig, P.E. with Robert Peccia & Associates at 406-447-5000.

#### **Project Information**

A recommended alternative of the Master Plan includes the development of a new production well to replace the City's current Wylie Well #3. This well is currently located in the East Valley Controlled Groundwater Area and is threatened by a nearby selenium plume. Additional alternatives include the construction of a new storage tank to replace the aging and

leaking McClellan tanks as well as distribution system improvements to eliminate dead-ends that can lead to low pressure, inadequate fire flows, and stagnant water which can cause water quality issues for the system. Replacement of the existing telemetry system with a new Supervisory Control and Data Acquisition (SCADA) system is also recommended.

### Previous Public Meeting Held February 27, 2018

The first public meeting held February 27, 2018, presented by the project engineer, discussed the need for the project, improvement alternatives and pos-

sible funding sources. Those in attendance included Mayor, James Schell, East Helena residents, and others interested in the project.

Please visit our website for up-to-date information at: www.easthelenamt.us/wmp/



Wednesday, April 18, 2018

# City of East Helena, Montana MASTER WATER PLAN

Go to: East Helena Main Website

#### 2018 Water Master Plan

The City of East Helena is in the process of updating our public water supply Master Plan (2018 Water Master Plan), last updated and approved in 1998.

The 2018 Water Master Plan describes how the City meets current water demands, ensures high quality drinking water, enhances system reliability, outlines future planning needs and requirements, and assists with obtaining funding sources to complete planned upgrades and additions.

The 2018 Water Master Plan serves as a tool to assist the City of East Helena with making decisions for short-term and long-term type projects to continue to provide quality public water supply services and protect the health of our customers.

#### **Current System Overview**

The City of East Helena's water holding, transmission, and distribution system serves residents and businesses within the city limits which is approximately 1.74 square miles (appx 1115 acres) with a 2010 population of 1984.

The City's public water supply system includes:

- Three water storage tanks in two locations totalling 1.55 million gallons of available storage capacity
- Three pump houses servicing three wells west of the city and one pump house servicing two radial wells to the south east

#### Draft 2018 Water Master Plan:

The Draft 2018 Water Master Plan is now available: Draft 2018 Water Master Plan (PDF)

A paper copy of the Draft 2018 Water Master Plan is available at City Hall for public review during normal business hours.

The City welcomes public comments and questions. For more information, please call City Clerk Gena Berry at 406-227-5321.

Please consider completing a letter of support for upgrades to our water system to be included in our grant funding applications:

TSEP/DNRC Grant Support Letter (PDF)
Mail or return the letter to City Hall in person.

#### Public Meetings:

Notices for the public meetings were published on this website and in the local newspaper. A notice was mailed to all residential and business utility bill recipients for the 2nd public meeting.

2018 Water Master Plan Public Meeting Notices: February 27, 2018, Public Meeting Notice (PDF) April 5, 2018, Public Meeting Newsletter (PDF) April 5, 2018, Public Meeting Notice (PDF)

#### CITY OF EAST HELENA, MONTANA WATER SYSTEM MASTER PLAN APRIL 5, 2018 PUBLIC MEETING SIGN-IN SHEET

NAME	ADDRESS	PHONE NUMBER
Andy Anderson	510 clinton	406-439-40
SALLY NYLAND	203 PRICKLEY PEAR	227-6038
Muston	106 E. (1995	unlistes
DON DAHL	327 Kun	227-6876
DON ANDORSON	202 N. PRICKY POAR	202-0005
Mile Miguere	316 F. Clinton	461.6650
Kit Johnson	706 E. Clark ST	465 8960
Tom Jones Trada	3150 York RS	4229223
Kevin Ore	2665 Toney Dr	455-3768
Judy Leland	116 E Clark	227-6284
JAMES SCHELL	720 F GROSCHEU/ CITY	465-2921
Scott St. Clair	111 E. G-Roseholl	410-1125
Luke Serati	116 W. Grose hell	459 - 9816
Insha Bodlovic	RPA	447-5000
BRAD KUENIG	RPA	447-5000



# **City of East Helena**

**Water System Master Plan** 

## **Overview and Discussion on Preliminary Findings**

Public Meeting - April 5, 2018

Robert Peccia and Associates

## In General the Master Plan includes:

- Review the existing water system and its operating parameters.
- ▶ Identify areas where system improvements should be made. Develop alternatives to provide the community with reliable water service and improve operations through the planning period.
- Complete a list of recommended improvements for the water system and a funding strategy for implementation.



# **East Helena Water System Components**

### Wylie Drive Wells and Transmission Main

- Wylie Well #1, 600 gpm (1965)
- Wylie Well #2, 600 gpm (1965)
- Wylie Well #3, 450 gpm (1987) Chlorination Point for Wylie Wells

### McClellan Radial Wells

- Radial Well #1, 500 gpm (1987)
- Radial Well #2, 500 gpm (1987)






# East Helena Water System Components (Cont'd)


- McClellan Tanks
  - Reservoir #1, 250,000 Gallons (1928)
  - Reservoir #2, 300,000 Gallons (1948)
- Highway 282, 1-Million-Gallon Reservoir
- Distribution System
- Wylie and McClellan Transmission Main
- > Telemetry & Control System





# East Helena Planning Area





# **Current and Future Operating Criteria**

CRITERIA	VALUE	
Existing Population (2017)	2,194	
Annual Growth Rate	1.45%	
Planning Population (2037)	2,926	
Current Average Day Demand	423,835 gpd (294 gpm)	
Average Day Demand per Capita	193 gal	
Current Max Day Demand	1,059,588 (736 gpm)	
2037 Average Day Demand	564,718 gpd	
2037 Max Day Flow	1,411,795 gpd (980 gpm)	



## Concerns - East Helena Water System

- Potential Contamination of Wylie Well #3.
- > Aging McClellan Creek Tanks.
- Water Main That Crosses PPC Lost in 2012.
  Important Crossing.
  - > Only other Stream Crossings at Pacific and Riggs.
- Dead-End Main, Could Cause Stagnation (1st Street & W. Groschell).
- One area of Low Fire Flows (End of Manlove).
- Accessibility to Radial Wells.
- Aging Telemetry Controls.



## **Need for New Water Source**

- > Selenium Plume Approximately 1,250' from Well.
- Helena Sand and Gravel Pit Could Influence Groundwater Adjacent to Well.
- Water Rights Reserved for East Helena in Closed Basin.
- McClellan Radial Well #2 Had Low Water Levels in 2017. (Uncertainty)



# **Water Supply Alternatives:**

- > Alternative 1
  - No Action
- > Alternative 2
  - New Production Well at Northeast Corner of City Owned Property
- > Alternative 3
  - New Production Well at Northwest Corner of City Owned Property



# Preferred Water Supply Alternative





# **Need for New Water Storage**

- Water Loss.
  - Leaking Approximately 44,000 Gallons per Day (16 MG per Year).
  - Current System Water Loss 19%.
  - Estimated Water Loss Without McClellan Tanks is 9%.
- Deteriorating Concrete at Joints Could Become Health Issue.
- Un-Operable Isolation Valves.
- Deteriorating Connecting Piping.




# **Water Storage Alternatives:**

- Alternative 1
  - No Action
- Alternative 2
  - Replace McClellan Storage Tanks With a 1-Million-Gallon Pre-Stressed Concrete Storage Tank
- Alternative 3
  - Replace McClellan Storage Tanks With a 1-Million-Gallon Glass-Fused-To-Steel Bolted Tank



# Preferred Water Storage Alternative





# Need For Water Distribution System Improvements

## Main Street Creek Crossing

- Allows Water To Flow From Wylie Source to East Side of PPC (and viceversa).
- Dead-End Main.

#### Manlove Water Main

- Dead-End Main.
- Providing Lower Fire Flows.

#### West Groschell and 1st Street Main

- Decreased Available Fire Flow.
- Dead-End Main.




# **Distribution System Alternatives:**


- > Alternative 1
  - No Action
- > Alternative 2
  - Main Street Stream Crossing
- Alternative 3
  - Loop Distribution System at Manlove
- Alternative 4
  - Eliminate Dead-End at 1st Street and West Groschell
     Street




# Preferred Water Distribution System Alternative 2



# Preferred Water Distribution System Alternative 3



# Preferred Water Distribution System Alternative 4



# Need For Other Water System Improvements

#### > Radial Well Access

- No Creek Crossing.
- Existing 2-Track Becomes Impassible in Spring and Winter.
- Wells Not Inspected on Regular Basis.
- Could be Inaccessible in Emergency Event.

### > Telemetry System

- Scada System Not Communicating Properly with Radial Wells.
- Aging Equipment.
- Potential For Operators Not to be Notified of Alarm Conditions.



# Other Water System Alternatives:

# **McClellan Water Source Access**


- > Alternative 1
  - No Action
- Alternative 2
  - New Pedestrian Bridge

# **Telemetry System**

- > Alternative 1
  - No Action
- Alternative 2
  - Upgrade SCADA System



# Preferred McClellan Water Source Access Alternative





# Summary of All Recommended Improvements

- Replace Wylie Well #3 on City Property and Install New Chlorination System.
- Construct New McClellan Tank and Piping.
- > Re-establish Water Main Crossing at Main Street.
- City to Work on Access Agreement and Add Walking Bridge at Radial Wells.
- Water Main Loop and Replacement from 1st Street below Highway 12 to Manlove.
- Water Main Loop on 1st Street from West Groschell to Gail to alleviate dead-end.
- Replace Telemetry.



# TOTAL PROJECT COST - ALL RECOMMENDED ALTERNATIVES

Alternative	Total Project Cost
One New Well on East Side of City Property	\$1,345,627
1,000,000-Gallon Pre-Stressed Concrete Storage Tank	\$3,383,010
Main Street Stream Crossing	<b>\$2</b> 14, <b>8</b> 30
Loop Main At Manlove	\$589,380
1 st Street Loop	\$144,890
McClellan Source Access	\$107,610
Telemetry System	\$474,090
Total Project Cost or All Recommend Alternatives	\$6,259,437

## **Grant and Loan Funding Opportunities**

- TSEP Grants of \$500,000 to \$750,000 (biannual) 7 Criteria
  - Must Exceed TSEP "Target Rate" (2.3% of MHI = \$88.60 /mo for Water+Sewer).
    - **Current Residential Avg. Rate = \$100.25 (113% of Target Rate)**
  - Maximum of \$500,000 (unless > 125% of Target Rate).
  - "Dollar-for-Dollar" Match required can include other grants.
- RRGL Grants to \$125,000 (biannual) "conservation of water resources"
  - Maximum of \$125,000.
  - No Match required.
- DOJ, Natural Resource Damages Program (Potential Portion of Settlement)
  - Groundwater Damages is One Criteria.

## **Grant and Loan Funding Opportunities**

- USDA Rural Development Grant/Loan Packages
  - Grant Share is Variable.
- MDEQ State Revolving Fund (SRF) Loans
  - (2) SRF Programs Water Pollution Control and Drinking Water.
  - 2.50% Interest, 20 or 30 year Loans.

- Most Grants Require "Financial Need".... also Health/Safety Issues
- Grant Applications are Ranked COMPETITIVELY, and Not All Funded

## Grant and Loan Funding Strategy - BE OPPORTUNISTIC

- Apply for TSEP Grants of \$500,000
  - May be a tough year given the project scope and political circumstances.
- Apply for DNRC RRGL Grant to \$125,000
  - The project that meets this program's criteria best is the replacement of the McClellan Tanks (Reduce Leakage).
- DOJ, Natural Resource Damage (NRD) Program City Amount Unknown - Total Settlement \$6M
  - Groundwater Damages fit criteria for East Helena Water System.
  - Continue to provide NRD with information.

# Next Steps and Project Schedule

- City to Adopt Water Master Plan.
- City to Adopt and Approve Grant Applications (DRNC and TSEP). These to be submitted in May and June.
- Natural Resource Damage (NRD) Program will hold a Public Meeting most likely in June. A Restoration Plan which includes how the settlement will be allocated to follow.
- Project Web Site (Current) Link From City's Web Page.

#### City of East Helena

# Public Meeting to Obtain Comments on the Water Master Plan – 2018 and Funding Applications for the Water System Improvements

# Thursday April 5, 2018, 6:00 p.m. East Helena City Hall 306 Main Street, East Helena, Montana

Meeting Minutes and Summary of Public Comments

#### In Attendance

James Schell, Mayor
Scott St. Claire, Public Works Director
Kit Johnson, City Council President
Don Dahl, City Council Member
Mike Misowic, City Council Member
Judy Leland, City Council Member
Kevin Ore, Public Works Department
Andy Anderson, Resident
Sally Nyland, Resident
Resident at 106 E. Riggs (signature illegible)
Don Anderson, Resident
Resident at 3150 York Road (signature illegible)
Luke Serati, Resident
Brad Koenig, P.E., Robert Peccia & Associates, Helena
Trisha Bodlovic, Robert Peccia & Associates, Helena

#### Introduction

At 6:05 p.m., Mayor James Schell called the meeting to order and opened with a discussion on the Master Plan. He introduced the Public Works Director, Scott St. Claire, and Kevin Ore with the Public Works Department as well as the 4 council members attending: Kit Johnson, Don Dahl, Mike Misowic, and Judy Leland. Mayor Schell then introduced Brad Koenig of Robert Peccia & Associates. Brad Koenig proceeded with a presentation (copy attached), discussing the components of the East Helena Water System and discussed the current and future operating criteria. Brad summarized the water system concerns as shown in the presentation including Wylie Well #3, the McClellan tanks, the critical water main creek crossing lost at Main Street, the accessibility to maintain and service radial wells, the available fire flow near American Chemet, the dead-end main at West Groschell and 1st Street, and the aging telemetry. Brad then explained the alternatives discussed in the Master Plan to address each of the above listed concerns and the preferred alternatives selected in the Master Plan including the replacement of Wylie Well #3, construction of a new tank to replace the McClellan tanks, re-establish the water main connection at Main Street, addition of a walking bridge at the radial wells, addition of new water main to loop the distribution system from 1st Street below Highway 12 to Manlove near American Chemet, addition of water main on 1st Street to alleviate the dead-end, and replacement of the telemetry system. The preliminary project cost which includes administration, contingency, and engineering was presented. A project funding strategy was explained and discussed. Brad ended the

presentation with information on the next steps and the project schedule which includes the City adopting the Water Master Plan and approve submission of the grant applications, the NRD Program will be holding a public meeting in June regarding how the settlement funds will be allocated, and directed the public on the project website that has been developed.

#### **Public Comments**

Mayor Schell commented that the Montana Environmental Trust Group (METG) may be willing to pay for part or all of the costs to move Wylie Well #3. Brad then explained that the new well would stay in the Helena Valley Aquifer and in response to a question about moving the well south of Highway 12, Brad commented that the groundwater availability south of the City is less certain.

In response to a question whether the potential new High School would be able to connect to the new distribution line on Valley Drive, Brad explained that the new well would include a disinfection system and the new water main would have sufficient contact time required in order for the potential new school to connect.

In response to a question on how deep the new well may be, Brad explained Wylie Well #3 was approximately 200 feet deep and the Master Plan estimates the new well to be drilled to the same depth.

In response to a question on how many wells the City owns, Brad explained the City owns 3 groundwater wells, known and the Wylie Wells, and 2 horizontal wells, known as the radial wells.

When asked whether or not the new tank could be constructed at the new well, Brad explained how the water system currently works with regards to pressure and the new tank would need to be constructed at the same elevation as the Highway 282 tank in order to maintain that pressure. Therefore, a new tank could not be constructed at the new well location.

When asked about the water line near American Chemet, Brad explained that the fire protection for the building is low and the Manlove area currently isolated with only one line. Looping the distribution system at this location would not only increase the fire flows but it would also give the Manlove area an additional line in case the existing water line was ever disrupted.

Brad was asked to explain the concept of a pre-stressed tank.

Mayor Schell explained the City's 4 enterprise funds including the General Fund, the Water Fund, the Sewer Fund, and the Garbage Fund. He then explained the General Fund is financed using property taxes, while the other funds are financed using user rates. Currently, the City is exceeding their target rates assessed by the Montana Department of Commerce.

When asked whether or not rates will need to be raised, Mayor Schell explained that some of these projects will be paid for through other means and the City will be asking for funds from the Natural Resource Damage program and the METG group in order to keep user rates as low as possible.

#### The meeting was adjourned at 7:25.

MEETING AGENDA CITY OF EAST HELENA CITY HALL – 306 EAST MAIN – ROOM 110 COUNCIL MEETING: 7:00 PM DATE: TUESDAY, APRIL 17, 2018

MEETING CALLED TO ORDER: Mayor Schell

PLEDGE OF ALLEGENCE: Councilmember Johnson

#### **PUBLIC COMMENTS:**

Note: This time is set aside for public comment on non-agenda items. Public comment will be taken on agenda items prior to a motion. All public comments will be limited to a reasonable duration. Please state your name and address in an audible tone of voice for the record, prior to your comments.

#### PRESENTATION:

1. Point of Sale and Tobacco – Lewis & Clark County Public Health Action: Approve/Deny/Table

#### **PROCLAMATIONS**

1. Proclamation to Observe May, 2018 as Mental Health Month – Mayor Schell Action: Approve/Deny/Table

**APPROVAL OF MINUTES:** April 3, 2018

#### **CITY COURT REPORT:**

City Judge

#### MONTANA ENVIRONMENTAL TRUST GROUP/EPA UPDATE:

Written report dated May 16, 2017 Action: None – Information only

#### **DEPARTMENTAL REPORTS:**

Administration – Clerk/Treasurer Gena Berry Police Department – Acting Police Chief Bill Harrington Public Works - Public Works Director Scott St. Clair Volunteer Fire Department - Fire Chief Troy Maness

#### **COMMITTEE REPORTS:**

- 1. Gazebo/Main Street Park Brick Committee Mayor Schell
- 2. Street Safety Committee Public Works Director St. Clair

#### **UNFINISHED BUSINESS:**

1. ROW Committee Ordinance Update/Schedule – Mayor Schell

Action: Approve/Deny/Table

2. Jaycee Hall City Owned Building Legal Disposition/Sale Process – Mayor Schell

Action: Approve/Deny/Table

3. City of East Helena Casino Hours – Mayor Schell

Action: Information Only

#### **NEW BUSINESS:**

 South Montana Avenue Petition Review – Mayor Schell Action: Information Only

2. Resolution 503 to Approve 2018 Water Master Plan & Accept The Master Plan Recommendations – Mayor Schell Action: Approve/Deny/Table

 Resolution of the Acceptability of Environmental Assessment to Allow Proceeding With Proposed Action (504) – Mayor Schell

Action: Approve/Deny/Table

4. Resolution 505 to Authorize Water System Funding Applications – Mayor Schell

Action: Approve/Deny/Table

5. MMIA Employee Benefits Program FY19(2018/2019) – Mayor Schell

Action: Approve/Deny/Table

Request For East Helena School District Use of Kennedy Park Fee Waiver June 4, 2018 for Second Grade Park Day
 – Mayor Schell

Action: Approve/Deny/Table

7. Request to Proceed With Elections & Ward Regulations Ordinance Updates - Mayor Schell & City Attorney

Elverum

Action: Approve/Deny/Table

#### **MAYOR'S REPORTS:**

Mayor Schell

#### **COUNCIL MEMBERS' REPORTS:**

Don Dahl

Kit Johnson

Judy Leland

Mike Misowic

#### **LEGAL REPORTS:**

City Attorney Elverum

**PAYMENT OF BILLS:** Mayor Schell - Action: Approve/Deny/Table

#### **SPECIAL MEETINGS & ANNOUNCEMENTS:**

- 1. Planning Board Public Hearing Subdivision Regulation Update, Tuesday, April 24, 2018, 6PM, City Hall Rm 110
- 2. East Helena Fun Run, Kennedy Park, Saturday, May 19, 2018,

#### **MEETING SCHEDULE:**

1. Scheduled East Helena Council Meeting, Tuesday, May 1, 2018, 7PM, City Hall Rm 110

**ADJOURNMENT:** Mayor Schell

#### ADA NOTICE

The City of East Helena is committed to providing access to persons with disabilities for its meetings, in compliance with Title II of the Americans with Disabilities Act and the Montana Human Rights Act. The City will not exclude persons with disabilities from participation at its meetings, or otherwise deny them the City's services, programs, or activities. Persons with disabilities requiring accommodations to participate in the City's meetings, services, programs, or activities should contact the City Clerk, Gena Berry, as soon as possible to allow sufficient time to arrange for the requested accommodation, at any of the following:

(406) 227-5321

TTY Relay Service 1-800-253-4091 or 711

cityclerk@easthelenamt.us

306 East Main Street, P.O. Box 1170, East Helena, MT 59635

#### MEETING MINUTES CITY OF EAST HELENA REGULAR COUNCIL MEETING: 7PM TUESDAY, April 17, 2018

COUNCIL MEMBERS PRESENT: Kit Johnson, Don Dahl, and Mike Misowic; Judy Leland

**EXCUSED/ABSENT:** Fire Chief Troy Maness

<u>PRESENT FROM CITY:</u> Mayor James Schell, Clerk Treasurer Gena Berry, Acting Chief of Police William Harrington, City Attorney Peter Elverum, and Public Works Director Scott St. Clair

<u>OTHERS PRESENT:</u> Cheryl Verbanac, Myrna Verbanac, Blaine Verbanac, Dave Jensen, Sally Nyland, Sarah Hallauer, Tova Reddick-Starkel, Melanie Reynolds, Karen Lane, Sarah Shapiro, Linda Amo and Jess Hegstrom

<u>PUBLIC MEETING CALLED TO ORDER / PLEDGE OF ALLEGIANCE:</u> Mayor Schell called the public meeting to order at 7:00 pm. The Pledge of Allegiance was led by Councilmember Johnson

<u>PUBLIC COMMENTS:</u> Linda Amo asked questions about the proposed new water well at the treatment plant site; the proposed new high school and associated taxes. David Jensen asked about clarifying the nuisance vegetation ordinance regarding common weeds and if the City will be spraying this year.

**PRESENTATION:** Melanie Reynolds, Karen Lane and Sarah Shapiro of the Lewis and Clark County Health Department gave a presentation about point of sale tobacco. A short question and answer session followed.

#### **PROCLAMATIONS:**

Proclamation to Observe May 2018 as Mental Health Month. Mayor Schell read the proclamation. Tova Reddick-Starkel made a public comment thanking the Mayor, Council and public for their continued support. Jess Hegstrom thanked the Mayor and Council for always being a front runner about making these types of proclamations. Councilmember Johnson made a motion to approve the proclamation. Councilmember Dahl seconded. Motion carried unanimously.

<u>APPROVAL OF MINUTES:</u> The minutes of the April 3, 2018 Regular Council Meeting were reviewed for approval as presented. <u>Action:</u> A motion was made by Councilmember Misowic to approve the minutes as presented. The motion was seconded by Councilmember Leland. Motion carried unanimously.

#### **CITY COURT REPORT:**

February and March 2018 revenue reports were presented last meeting.

#### MONTANA ENVIRONMENTAL TRUST GROUP/EPA UPDATE:

Last written report was dated May 16, 2017. Mayor Schell spoke about the April 11, 2018 meeting METG held regarding the Corrective Measure Study Report. Information only.

#### **DEPARTMENTAL REPORTS:**

City Clerk Treasurer: Clerk Treasurer Berry reported that it was her last meeting but had nothing more to report.

**<u>Police Department:</u>** Acting Chief Harrington spoke about the following:

- 911 Public Safety Open House this Saturday at the Dispatch Center 11am-3pm
- Research continues on the calls for service to casinos
- Chief worked a 20 hour shift one day last week on an acute criminal matter

#### **Public Works Department:** Public Works Director St. Clair spoke about:

- Sensus meter training
- Water main leak on Riggs and Harrison being repaired tomorrow
- Street sweeping to take place Friday and Saturday
- Kevin Ore and Julia Shannon have been continuing to work on UB billing and meter reading issues
- Considering not having the yard waste disposal site this year and have residents haul to Tri-Co instead. David Jensen suggested finding out the disposal rules and educating the residents

- Montana Ave/Valley Drive is a substandard road and will need to be redone especially if a high school comes. The cost is estimated to be \$2.8 million.
- Wylie well #3 could become contaminated at some point in the future. The City is asking METG to help by paying for a new well to be drilled using settlement money from the Asarco bankruptcy. Mayor Schell stated that he will not promote raising residents rates to pay for a well primarily because of a plume that may or may not reach the well. He will work with Montana Environmental Trust group to pay for it to the best of his ability. Linda Amo commented that it is uncertain that they will pay and how much they would pay. Linda asked about plume study data. Mayor Schell and Public Works Director St. Clair advised her to speak with Bob Anderson who conducted the creek hydro studies. Public Works Director explained the pools of money given to the Trust Group and the Natural Resource Damage Department of Justice program and how the City is vying for the funds from each group and the proposed projects and the competition for the funds. PWD St. Clair asked for letters of support. Sally Nyland asked about a petition instead. Attorney Elverum suggested public support at the June 13th meeting regarding the funds.
- Weeds are a work in progress as the Parks Employee is in the process of earning weed spraying certificates.
   Attorney Elverum spoke to the new ordinance. David Jensen would like to have the ordinance address common weeds
- Mayor Schell spoke to Linda Amo's public comment questions regarding the proposed high school explaining that the City Council has no control over the school district. Mayor Schell suggested Linda meet with the superintendent and or the school board members. David Jensen asked if any numbers have been provided regarding cost to the City. Attorney Elverum suggested a public records request to the school for that information.

<u>Volunteer Fire Department:</u> Fire Chief Maness was absent. Mayor Schell stated that Chief Maness will have an agenda request at the May 1st, 2018 meeting regarding the annual banquet and a report on the fire station remodel.

#### **COMMITTEE REPORTS:**

- <u>Gazebo/Main Street Park Brick Committee-</u> Mayor Schell invited the public to the next meeting Friday, April 27, 2018 at 3pm room 110 City Hall.
- <u>Street Safety Committee Meeting-</u> Public Works Director St. Clair is working on obtaining quotes on the traffic studies needed.

#### **UNFINISHED BUSINESS:**

- ROW Committee Ordinance Update/Schedule Mayor Schell included the public notice in the packet for the
  Method of Parking Ordinance public hearing. Attorney Elverum asked for the public to submit their comments at or
  before the hearing not at the second reading. Sally Nyland asked if that ordinance addresses abandoned vehicles or
  not. <u>Action:</u> Councilmember Misowic made a motion to table. Councilmember Dahl seconded. Motion carried
  unanimously.
- 2. <u>Jaycee Hall City Owned Building Legal Disposition/Sale Process</u> Mayor Schell included the public notice in the packet for the next steps of the process. The banner has been received and will be placed within the next week. No public comment. <u>Action:</u> Councilmember Johnson made a motion to table. Councilmember Leland seconded. Motion carried unanimously.
- 3. <u>City of East Helena Casino Hours</u> Acting Chief Harrington updated the Council on where he is at in his research of calls for service regarding the casinos. No public comment. **Action:** Information Only

#### **NEW BUSINESS:**

- **1.** South Montana Avenue Petition Review Mayor Schell stated that the City is waiting to hear from the METG in the form of a new petition. Linda Amo asked what the zoning is in Dartman Field. Action: Information Only
- 2. Resolution 503 to Approve 2018 Water Master Plan & Accept The Master Plan Recommendations Mayor Schell read Resolution 503. No public comment. Action: Councilmember Dahl made a motion to approve Resolution 503. Councilmember Leland seconded. Motion carried unanimously.
- 3. Resolution of the Acceptability of Environmental Assessment to Allow Proceeding With Proposed Action

  (504) Mayor Schell read Resolution 504. No public comment. Action: Councilmember Johnson made a motion to pass Resolution 504. Councilmember Dahl seconded. Motion passed unanimously.
- **4.** Resolution 505 to Authorize Water System Funding Applications Mayor Schell read Resolution 505. No public comment. Action: Councilmember Misowic made a motion to pass Resolution 505. Councilmember Leland seconded. Motion carried unanimously.
- 5. MMIA Employee Benefits Program FY19(2018/2019) Mayor Schell gave an update on the increased rate of 3.7% for health insurance. Mayor Schell asked for approval to continue to pay 100% of the Madison Plan for full time employees and offer the Bridger Plan with the employee paying the difference. Mayor Schell also asked the Council to allow employees to pay for and utilize orthodontic coverage for themselves and dependents as allowed by

the plan. No public comment. <u>Action:</u> Councilmember Dahl made a motion to approve. Councilmember Johnson seconded. Motion carried unanimously.

- 6. Request For East Helena School District Use of Kennedy Park Fee Waiver June 4, 2018 for Second Grade

  Park Day Mayor Schell explained that historically the park has been reserved and used for free for this purpose and this year it is being brought to Council for approval. Public Works Director St. Clair asked why the fee should be waived. Action: Councilmember Dahl made a motion to allow the free use of JFK park June 4th, 2018.

  Councilmember Johnson seconded. Motion carried unanimously.
- 7. Request to Proceed With Elections & Ward Regulations Ordinance Updates City Attorney Elverum explained the purpose of the updates to the Elections Ordinance to align city code with state law. No public comment. Action: Councilmember Johnson made a motion to proceed with the public notice and public hearing. Councilmember Misowic seconded. Motion carried unanimously.

#### **MAYOR'S REPORT:**

Mayor Schell

**Council Meeting Packet Handouts** 

April 17, 2018

- Lake Helena Watershed Group Newsletter April 9, 2018 (email)
- Announcement for MLCT/MMIA/MLGC 2018 Municipal Summits around Montana, including June 4th 9am to 4pm Summit in Helena at the Civic Center.
- Announcement for 38th Annual Montana Municipal Institute conference and Elected Officials Workshop (May 6-10 2018) in Billings. Council meeting packet handouts included:

On the desks were the following:

- Group of residents around 217 W Groschell submitted written complaints about community decay. Chief Harrington addressed some of these concerns.
- Copies of letters of support written by Representative Mary Ann Dunwell.
- Resolution sample from the Town of Lima allowing elected officials to participated in the City's group health plan on a self-pay basis. Councilmember Dahl expressed his interest to include permanent part time employees in this.

Mayor Schell spoke of the following:

- Big sky Gas contract proposal is under review
- Attended MLCT board meeting
- Attended a Mayor's Conference in Polson
- DES radios for the Fire Department have been ordered
- Cyber security work to begin in May
- DES radio change order for the Police Department has been submitted
- Water and Sewer Ordinances and policies need to be aligned
- DEQ is removing East Helena from the lists of non-attainment standards that no longer apply
- Interviews for Police Chief, Pool Manager, Summer Recreation Leader and Supervisor are happening soon

#### **COUNCIL MEMBERS' REPORTS:**

Don Dahl attended the Water Master Plan public hearing, METG Corrective Measure Study meeting, land redevelopment meeting and the school meeting.

Kit Johnson attended the METG meeting and gave a reminder for the Planning Board meeting.

Judy Leland attended the Water Master Plan public hearing

Mike Misowic attended the land re-development meeting and the Water Master Plan public hearing

Mayor and Council thanked Clerk Treasurer Berry for all of her work.

#### **LEGAL REPORT:**

Attorney Elverum attended the METG meeting, the land re-development meeting and a meeting regarding DUI blood drawing held in conjunction with the City of Helena and Lewis and Clark County. Reviewing the draft parking tickets. Busy with criminal items.

**PAYMENT OF BILLS:** Approval of claims 290598-290628 totaling \$39,817.14. Councilmember Johnson made a motion to approve the claims. Councilmember Dahl seconded. Motion carried unanimously.

#### **SPECIAL ANNOUNCEMENTS:**

- 1. Planning Board Public Hearing Subdivision Regulation Update, Tuesday, April 24, 2018, 6PM, City Hall Rm 110
- 2. East Helena Fun Run, Kennedy Park, Saturday, May 19, 2018,

MEETING SCHEDULE:  1. Scheduled East Helena Council Meeting, May 1, 2018, 7PM, City Hall Rm 110			
<b>ADJOURNMENT:</b> Mayor Schell adjourned the meeting at 9:37pm.			
ATTEST:			
Clerk	<u> </u>	Mayor	

## **APPENDIX O – RESOLUTIONS**

# RESOLUTION TO APPROVE 2018 WATER MASTER PLAN AND ACCEPT THE MASTER PLAN RECOMMENDATIONS FOR THE CITY OF EAST HELENA, MONTANA

#### Resolution No. 503

WHEREAS, the City of East Helena, Montana, commissioned Robert Peccia & Associates to prepare the 2018 Water Master Plan, utilizing the format outlined in the Uniform Preliminary Engineering Report for Montana Public Facilities Projects, October 2017, Eleventh Edition;

WHEREAS, the findings of that Master Plan have been presented to the City, and the City of East Helena has held at least one advertised public meeting as required to receive public comments about the Master Plan — including the project area, water problems and needs, alternatives, the engineer's recommendations for improvements, environmental considerations, the project budget, and the anticipated schedule;

WHEREAS, the City of East Helena has legal jurisdiction and authority to construct, finance, operate and maintain improvements to the water system.

BE IT RESOLVED that the City of East Helena hereby approves the 2018 Water Master Plan, and accepts the engineer's recommendation for improvements to the water system.

Signed:

Name:

James Schell

Title:

Mayor

Date:

Attested.

OF EAST HE CORPORATE TO SEAL

# RESOLUTION OF THE ACCEPTABILITY OF ENVIRONMENTAL ASSESSMENT TO ALLOW PROCEEDING WITH PROPOSED ACTION

#### Resolution No. 504

WHEREAS, the City of East Helena, Montana commissioned Robert Peccia & Associates to prepare a 2018 Water Master Plan, an Environmental Checklist, and an Environmental Assessment (EA), the availability of which has been formally advertised for public review and comment;

WHEREAS, the City of East Helena has considered all substantive comments received in response to the draft EA at the formally- advertise comment period and public meeting required, resulting in a decision by the City that an Environmental Impact Statement (EIS) is not necessary for the proposed action. The proposed action contemplated is the execution by the City of a grant contract with the Montana Department of Commerce for Treasure State Endowment Program (TSEP) funds, if so awarded, and implementation of the recommended alternatives identified in the 2018 Water Master Plan;

BE IT RESOLVED that James Schell, Mayor, is authorized to accept the engineer's recommendation that an EIS is not necessary for the proposed project, and to execute a TSEP grant agreement, if offered.

Signed:

Name:

James Schell

Title:

Mayor

Date:

Attested:

SEAL ANONTANA

# RESOLUTION TO AUTHORIZE WATER SYSTEM FUNDING APPLICATIONS FOR THE CITY OF EAST HELENA, MONTANA

#### Resolution No. 505

WHEREAS, the City of East Helena, Montana is applying to the Montana Department of Commerce for a Treasure State Endowment Program (TSEP) grant, the Montana Department of Natural Resources and Conservation for a Renewable Resource Grant and Loan (RRGL) grant, and to the Montana Drinking Water Control State Revolving Fund (SRF) loan program to obtain financial assistance for Water System Improvements;

WHEREAS, the City of East Helena has legal jurisdiction and authority to construct, finance, operate and maintain improvements to water system;

WHEREAS, the City of East Helena agrees to comply with all State laws and regulations, and the requirements described in the TSEP, RRGL, and SRF application guidelines for 2018, and the TSEP Project Administration Manual;

BE IT RESOLVED that the City of East Helena commits to provide the amount of matching funds and indebtedness as proposed in the funding application(s); and

THAT James Schell, Mayor, is authorized to sign and submit these applications to the TSEP, RRGL, and SRF Program along with the \$250 RRGL application fee on behalf of the City, to act on behalf of the City with respect to these applications, and to provide such additional information as may be required by these funding agencies.

Signed:

Name:

James Schell

Title:

Mayor

Date:

UL 17,2018

Attacted: